



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/09/2017
Received: 02/02/2017
Sampled By:
Work Order: 7033012

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Hibbard

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7033012-01	Sample Name: Hibbard OPS kitchen Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-02	Sample Name: Hibbard Lower Men's right Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-03	Sample Name: Hibbard upper fountain left Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-04	Sample Name: Hibbard upper kitchen Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-05	Sample Name: Hibbard lower womens right Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-06	Sample Name: Hibbard lower fountain left Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-07	Sample Name: Hibbard staff room Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-08	Sample Name: Mailbox sink Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-09	Sample Name: upper women's rr left Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06
7033012-10	Sample Name: upper mens rr left Sampled: 2/2/17 6:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/08/17 18:06



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/09/2017
Received: 02/02/2017
Sampled By:
Work Order: 7033012

C **Tigard-Tualatin SD**
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Hibbard

Lab Number

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director