

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017  
Received: 01/10/2017  
Sampled By:  
Work Order: 7010002

**C**  
**L**  
**I**  
**E**  
**N**  
**T**


**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Twality

**Lab Number**

| Lab Number        | Code  | Method    | Result               | Units | MRL | EPA MCL* | Analysis Date/ Time        |
|-------------------|---|-----------|----------------------|-------|-----|----------|----------------------------|
| <b>7010002-01</b> | <b>Sample Name:</b> R-17 F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 49.4                 | ppb   | 4.0 | 20 ppb   | 02/27/17 17:08 <b>MCLE</b> |
| <b>7010002-02</b> | <b>Sample Name:</b> R-18 F1<br><b>Sampled:</b> 1/10/17 5:00 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 12.1                 | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-03</b> | <b>Sample Name:</b> R-16 F1<br><b>Sampled:</b> 1/10/17 5:00 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 2.2                  | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-04</b> | <b>Sample Name:</b> R-15 F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 26.1                 | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08 <b>MCLE</b> |
| <b>7010002-05</b> | <b>Sample Name:</b> R-1 F 1<br><b>Sampled:</b> 1/10/17 5:00 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | ND                   | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-06</b> | <b>Sample Name:</b> R-35-F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 12.2                 | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-07</b> | <b>Sample Name:</b> R-38-F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 8.0                  | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-08</b> | <b>Sample Name:</b> R-25-F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 4.0                  | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-09</b> | <b>Sample Name:</b> R-24-F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 9.1                  | ppb   | 2.0 | 20 ppb   | 02/27/17 17:08             |
| <b>7010002-10</b> | <b>Sample Name:</b> R-19-F<br><b>Sampled:</b> 1/10/17 5:00  |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 16.3                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017  
Received: 01/10/2017  
Sampled By:  
Work Order: 7010002


**C  
L  
I  
E  
N  
T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Twality

**Lab Number**

|                   | Code  | Method    | Result               | Units | MRL | EPA MCL* | Analysis Date/ Time        |
|-------------------|---|-----------|----------------------|-------|-----|----------|----------------------------|
| <b>7010002-11</b> | <b>Sample Name:</b> R-26 F<br><b>Sampled:</b> 1/10/17 5:20      |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 3.1                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-12</b> | <b>Sample Name:</b> R-27 F<br><b>Sampled:</b> 1/10/17 5:20      |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | ND                   | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-13</b> | <b>Sample Name:</b> R-33 F<br><b>Sampled:</b> 1/10/17 5:20      |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 7.9                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-14</b> | <b>Sample Name:</b> R 34 F<br><b>Sampled:</b> 1/10/17 5:20      |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 12.4                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-15</b> | <b>Sample Name:</b> Library<br><b>Sampled:</b> 1/10/17 5:20     |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | <b>35.9</b>          | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38 <b>MCLE</b> |
| <b>7010002-16</b> | <b>Sample Name:</b> R-4 F<br><b>Sampled:</b> 1/10/17 5:20       |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | <b>72.6</b>          | ppb   | 4.0 | 20 ppb   | 02/28/17 16:38 <b>MCLE</b> |
| <b>7010002-17</b> | <b>Sample Name:</b> R-5 F<br><b>Sampled:</b> 1/10/17 5:20       |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 3.0                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-18</b> | <b>Sample Name:</b> lecture R F<br><b>Sampled:</b> 1/10/17 5:20 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 6.9                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-19</b> | <b>Sample Name:</b> R 31 F<br><b>Sampled:</b> 1/10/17 5:20      |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 11.4                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-20</b> | <b>Sample Name:</b> R 32 F<br><b>Sampled:</b> 1/10/17 5:20      |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030  | EPA 200.9 | 6.7                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

## ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017  
Received: 01/10/2017  
Sampled By:  
Work Order: 7010002

**C**  
**L**  
**I**  
**E**  
**N**  
**T**

**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Twality

### Lab Number

| Lab Number        | Code   | Method    | Result               | Units | MRL | EPA MCL* | Analysis Date/ Time        |
|-------------------|--|-----------|----------------------|-------|-----|----------|----------------------------|
| <b>7010002-21</b> | <b>Sample Name:</b> R L27 F<br><b>Sampled:</b> 1/10/17 5:40    |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 93.8                 | ppb   | 8.0 | 20 ppb   | 02/28/17 16:38 <b>MCLE</b> |
| <b>7010002-22</b> | <b>Sample Name:</b> R L4 F<br><b>Sampled:</b> 1/10/17 5:40     |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 6.6                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-23</b> | <b>Sample Name:</b> R L3 F<br><b>Sampled:</b> 1/10/17 5:40     |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 5.0                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-24</b> | <b>Sample Name:</b> R L19 F<br><b>Sampled:</b> 1/10/17 5:40    |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 11.8                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-25</b> | <b>Sample Name:</b> R 30 F<br><b>Sampled:</b> 1/10/17 5:40     |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 35.5                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38 <b>MCLE</b> |
| <b>7010002-26</b> | <b>Sample Name:</b> R L 23 F 1<br><b>Sampled:</b> 1/10/17 5:40 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 12.1                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-27</b> | <b>Sample Name:</b> R L 22 F 1<br><b>Sampled:</b> 1/10/17 5:40 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | ND                   | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-28</b> | <b>Sample Name:</b> R L 24 F<br><b>Sampled:</b> 1/10/17 5:40   |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 10.4                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |
| <b>7010002-29</b> | <b>Sample Name:</b> R L 26 F 1<br><b>Sampled:</b> 1/10/17 5:40 |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 24.3                 | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38 <b>MCLE</b> |
| <b>7010002-30</b> | <b>Sample Name:</b> R L 29 F<br><b>Sampled:</b> 1/10/17 5:40   |           | <b>Matrix:</b> Water |       |     |          |                            |
| +Lead             | 1030   | EPA 200.9 | 5.5                  | ppb   | 2.0 | 20 ppb   | 02/28/17 16:38             |



Professional Laboratory Services

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/01/2017

Received: 01/10/2017

Sampled By:

Work Order: 7010002

**C**  
**L**  
**I**  
**E**  
**N**  
**T**  
**Tigard-Tualatin SD**  
Attn: Phil Wentz  
6960 SW Sandburg St.  
Tigard OR, 97223  
Phone: (503) 431-4017

**Project:**  
Project # : N/A  
Sample Type :

Sampling Location: Tuality

---

## Lab Number

---

**MCL** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director