Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/25/2017
Received: 11/16/2016
Sampled By: P Wentz
Work Order: 6322023

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Fowler

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322023-01	**Sample Name:** Kitchen food prep **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	12.2	ppb	2.0	20 ppb	01/24/17 16:59
6322023-02	**Sample Name:** Gym west fountain **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/24/17 16:59
6322023-03	**Sample Name:** Rm 38 left sink **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**89.0**	ppb	8.0	20 ppb	01/24/17 16:59 **MCLE**
6322023-04	**Sample Name:** Boys by rm 21 **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	10.3	ppb	2.0	20 ppb	01/24/17 16:59
6322023-05	**Sample Name:** Boys by rm 11 **Sampled:** 11/16/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	10.2	ppb	2.0	20 ppb	01/24/17 16:59
6322023-06	**Sample Name:** Kitchen food prep flush **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
6322023-07	**Sample Name:** Gym w fount. flush **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/24/17 16:59
6322023-08	**Sample Name:** Rm 38 left sink flush **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.0	ppb	2.0	20 ppb	01/24/17 16:59
6322023-09	**Sample Name:** Boys by rm 21 flush **Sampled:** 11/16/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	01/24/17 16:59
6322023-10	**Sample Name:** Boys by rm 11 flush **Sampled:** 11/16/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.8	ppb	2.0	20 ppb	01/24/17 16:59

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/25/2017
Received: 11/16/2016
Sampled By: P Wentz
Work Order: 6322023

CLIENT

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Fowler

Lab Number

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: Carrie Leidl for AGG
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.