

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

Reported: 05/17/2017
Received: 05/01/2017
Sampled By:
Work Order: 7121003


C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7121003-01	Sample Name: Library Work Rm F Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	05/10/17 16:53
7121003-02	Sample Name: Rm 30 F Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	05/10/17 16:53
7121003-03	Sample Name: Rm 30 BB Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	5.2	ppb	2.0	20 ppb	05/10/17 16:53
7121003-04	Sample Name: Rm 15 F Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	05/10/17 16:53
7121003-05	Sample Name: Rm 15 B Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	05/10/17 16:53
7121003-06	Sample Name: Rm L26 - L F Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	8.0	ppb	2.0	20 ppb	05/10/17 16:53
7121003-07	Sample Name: Rm L26 L BB Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	05/10/17 16:53
7121003-08	Sample Name: Rm L26 R F Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	14.6	ppb	2.0	20 ppb	05/10/17 16:53
7121003-09	Sample Name: Rm L26 R B Sampled: 4/29/17 9:15		Matrix: Water				
+Lead	1030	EPA 200.9	9.2	ppb	2.0	20 ppb	05/10/17 16:53
7121003-10	Sample Name: Rm L27 F Sampled: 4/29/17 9:30		Matrix: Water				
+Lead	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	05/10/17 16:53



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 05/17/2017

Received: 05/01/2017

Sampled By:

Work Order: 7121003

C
L
I
E
N
T
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7121003-11	Sample Name: Rm L 27 BB Sampled: 4/29/17 9:30		Matrix: Water				
+Lead	1030	EPA 200.9	8.4	ppb	2.0	20 ppb	05/10/17 16:53
7121003-12	Sample Name: Rm L 28 R 1st F Sampled: 4/29/17 9:30		Matrix: Water				
+Lead	1030	EPA 200.9	236	ppb	20.0	20 ppb	05/10/17 16:53 MCLE
7121003-13	Sample Name: Rm L 28 R2nd F Sampled: 4/29/17 9:30		Matrix: Water				
+Lead	1030	EPA 200.9	417	ppb	40.0	20 ppb	05/10/17 16:53 MCLE
7121003-14	Sample Name: Rm L28 R 3rd F Sampled: 4/29/17 9:30		Matrix: Water				
+Lead	1030	EPA 200.9	127	ppb	8.0	20 ppb	05/15/17 16:32 MCLE
7121003-15	Sample Name: Rm L 28 Back Wall Sampled: 4/29/17 9:35		Matrix: Water				
+Lead	1030	EPA 200.9	19.6	ppb	2.0	20 ppb	05/15/17 16:32

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.