APEX
ENVIRONMENTAL CONSULTING

April 20, 2021

Mr. Jesse Cavazos
Tigard Tualatin School District
6960 SW Sandburg
Tigard, Oregon 97223

LEAD IN WATER TESTING AT TWALITY MIDDLE SCHOOL IN TIGARD OREGON

Dear Mr. Cavazos:

At your request Apex Environmental collected samples for lead in water analysis at Twality Middle School located at 14650 SW 97th Avenue in Tigard, Oregon. Samples were collected from possible drinking water and water used for food preparation in locations identified by the school district and located in newly remodeled areas. In accordance with EPA 3Ts Drinking Water School Tool Kit Guidelines and Oregon Health Authority Reducing Lead in Drinking School Drinking Water Guidelines of 2017.

The water in the system was flushed by School District personnel and allowed to remain in the system for a minimum of 18 hours prior to testing. Apex collected one first draw sample and a follow-up sample after the water flushed for a period of 30 seconds. Each of the samples were sent to Alexin Laboratories in Tigard, Oregon for Analysis. Alexin is accredited by the Oregon Environmental Laboratory for the analysis of drinking water under the U.S. EPA Safe Drinking Water Act as Laboratory #OR100013. Follow-up flushed samples were only analyzed if the results of the initial draw sample showed greater than 15 parts per billion lead content. All of the initial water samples collected at Twality MS were below this threshold and therefore no follow up samples were analyzed as directed by the district. Corrective action would not be required based upon this criteria.

Attached are the lab results and chain of custody for samples collected at Twality MS. If you have any questions or need anything further, please feel free to call me.

Sincerely,

Tulla R. Stocker

Tulla R. Stocker
Principal

PO Box 1445
p 503.682.9737
Wilsonville, OR 97070
www.apexenviro.com
f 503.682.0525

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077020-01	**Sample Name:** TWMS - 01A A220 Teachers Lounge Sink **Sampled:** 3/18/21 3:07						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/31/21 16:16
1077020-03	**Sample Name:** TWMS - 02A A220 Teachers Lounge Bubbler **Sampled:** 3/18/21 3:09						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/31/21 16:16
1077020-05	**Sample Name:** TWMS - 03A A222 Classroom Slap Sink **Sampled:** 3/18/21 3:09						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/31/21 16:16
1077020-07	**Sample Name:** TWMS - 04A A222 Classroom Sink **Sampled:** 3/18/21 3:09						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/31/21 16:16
1077020-09	**Sample Name:** TWMS - 05A A214 Girls RR (R-L) **Sampled:** 3/18/21 3:11						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-11	**Sample Name:** TWMS - 06A Girls RR 214 (R-L) **Sampled:** 3/18/21 3:12						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-13	**Sample Name:** TWMS - 07A Girls RR 214 (R-L) **Sampled:** 3/18/21 3:12						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-15	**Sample Name:** TWMS - 08A Girls RR 214 (R-L) **Sampled:** 3/18/21 3:14						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-17	**Sample Name:** TWMS - 09A Boy RR 218 (R-L) **Sampled:** 3/18/21 3:16						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-19	**Sample Name:** TWMS - 10A Boy RR 218 (R-L) **Sampled:** 3/18/21 3:16						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077020-21	**Sample Name:** TWMS - 11A Boy RR 218 (R-L) **Sampled:** 3/18/21 3:16						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-23	**Sample Name:** TWMS - 12A Boy RR 218 (R-L) **Sampled:** 3/18/21 3:16						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-25	**Sample Name:** TWMS - 13A RR 216 All User **Sampled:** 3/18/21 3:19						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-27	**Sample Name:** TWMS - 14A Water Fountain Near 212(R) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-29	**Sample Name:** TWMS - 15A Water Fountain Near 212(L) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-31	**Sample Name:** TWMS - 16A Science A202 (Teacher) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077020-33	**Sample Name:** TWMS - 17A Science A202 (R-L) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077020-35	**Sample Name:** TWMS - 18A Science A202 (R-L) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	04/02/21 15:45
1077020-37	**Sample Name:** TWMS - 19A Science A202 (R-L) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077020-39	**Sample Name:** TWMS - 20A Science A202 (R-L) **Sampled:** 3/18/21 3:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077020-41	**Sample Name:** TWMS - 21A A222 Science (R-L) **Sampled:** 3/18/21 3:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-43	**Sample Name:** TWMS - 22A A222 Science (R-L) **Sampled:** 3/18/21 3:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077020-45	**Sample Name:** TWMS - 23A A201 Science Prep **Sampled:** 3/18/21 3:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-47	**Sample Name:** TWMS - 24A A200 Science Techer **Sampled:** 3/18/21 3:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-49	**Sample Name:** TWMS - 25A A200 Science (R-L) **Sampled:** 3/18/21 3:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-51	**Sample Name:** TWMS - 26A A200 Science (R-L) **Sampled:** 3/18/21 3:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077020-53	**Sample Name:** TWMS - 27A A200 Science (R-L) **Sampled:** 3/18/21 3:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077020-55	**Sample Name:** TWMS - 28A A200 Science (R-L) **Sampled:** 3/18/21 3:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	04/02/21 15:45
1077020-57	**Sample Name:** TWMS - 29A A200 Science (R-L) **Sampled:** 3/18/21 3:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077020-59	**Sample Name:** TWMS - 30A A200 Science (R-L) **Sampled:** 3/18/21 3:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077020-61	**Sample Name:** TWMS - 31A A225 Makers Room Slap **Sampled:** 3/18/21 3:37						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-63	**Sample Name:** TWMS - 32A A225 Makers Room Sink **Sampled:** 3/18/21 3:39						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-65	**Sample Name:** TWMS - 33A A227 Makers Space Slap **Sampled:** 3/18/21 3:39						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077020-67	**Sample Name:** TWMS - 34A A227 Makers Space Sink **Sampled:** 3/18/21 3:39						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-69	**Sample Name:** TWMS - 35A B228 Classroom Sink **Sampled:** 3/18/21 3:39						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-71	**Sample Name:** TWMS - 36A B230 All User RRoom Sink **Sampled:** 3/18/21 3:43						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-73	**Sample Name:** TWMS - 37A B241 Kitchen Sink **Sampled:** 3/18/21 3:43						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-75	**Sample Name:** TWMS - 38A B247 All Use RR **Sampled:** 3/18/21 3:43						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-77	**Sample Name:** TWMS - 39A B214 Girls RR (R-L) **Sampled:** 3/18/21 3:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077020-79	**Sample Name:** TWMS - 40A B214 Girls RR (R-L) **Sampled:** 3/18/21 3:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077027-01	**Sample Name:** TWMS-41A B214 Girls RR **Sampled:** 3/18/21 3:45						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077027-03	**Sample Name:** TWMS-42A B214 Girls RR **Sampled:** 3/18/21 3:45						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077027-05	**Sample Name:** TWMS-43A Boys RR 217 (R-L) **Sampled:** 3/18/21 3:47						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077027-07	**Sample Name:** TWMS-44A Boys RR 217 (R-L) **Sampled:** 3/18/21 3:47						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-09	**Sample Name:** TWMS-45A Boys RR 217 (R-L) **Sampled:** 3/18/21 3:47						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077027-11	**Sample Name:** TWMS-46A Boys RR 217 (R-L) **Sampled:** 3/18/21 3:48						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-13	**Sample Name:** TWMS-47A Drinking Bubbler Near B217 **Sampled:** 3/18/21 3:48						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-15	**Sample Name:** TWMS-48A Drinking Bubbler Near B217 **Sampled:** 3/18/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-17	**Sample Name:** TWMS-49A RR 216 SH use RR sink **Sampled:** 3/18/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-19	**Sample Name:** TWMS-50A Classroom 211 Sink (R-L) **Sampled:** 3/18/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077027-21	**Sample Name:** TWMS-51A Classroom 211 Sink (R-L) **Sampled:** 3/18/21 3:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-23	**Sample Name:** TWMS-52A Classroom 211 Sink (R-L) **Sampled:** 3/18/21 3:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-25	**Sample Name:** TWMS-53A Classroom 211 Sink (R-L) **Sampled:** 3/18/21 3:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-27	**Sample Name:** TWMS-54A Classroom 211 Sink (R-L) **Sampled:** 3/18/21 3:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-29	**Sample Name:** TWMS-55A Classroom 211 Sink (R-L) **Sampled:** 3/18/21 3:56						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-31	**Sample Name:** TWMS-56A Classroom 210 (R-L) Sink **Sampled:** 3/18/21 3:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-33	**Sample Name:** TWMS-57A Classroom 210 (R-L) Sink **Sampled:** 3/18/21 3:58						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-35	**Sample Name:** TWMS-58A Classroom 209 (R-L) Sink **Sampled:** 3/18/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-37	**Sample Name:** TWMS-59A Classroom 209 (R-L) Sink **Sampled:** 3/18/21 4:02						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-39	**Sample Name:** TWMS-60A all use RR B246 Sink **Sampled:** 3/18/21 4:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077027-41	**Sample Name:** TWMS-61A Health Room Sink B245 **Sampled:** 3/18/21 4:04						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-43	**Sample Name:** TWMS-62A Cafeteria Sink (4)(R-L) **Sampled:** 3/18/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-45	**Sample Name:** TWMS-63A Cafeteria Sink (4)(R-L) **Sampled:** 3/18/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-47	**Sample Name:** TWMS-64A Cafeteria Sink (4)(R-L) **Sampled:** 3/18/21 4:07						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-49	**Sample Name:** TWMS-65A Cafeteria Sink (4)(R-L) **Sampled:** 3/18/21 4:07						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	8	ppb	1	15 ppb	04/02/21 15:45
1077027-51	**Sample Name:** TWMS-66A Commons DR Fountain Bubbler (R-L) **Sampled:** 3/16/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-53	**Sample Name:** TWMS-67A Commons DR Fountain Bubbler (R-L) **Sampled:** 3/16/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-55	**Sample Name:** TWMS-68A Commons DR Fountain Bubbler (R-L) **Sampled:** 3/16/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-57	**Sample Name:** TWMS-69A Commons DR Fountain Bubbler (R-L) **Sampled:** 3/16/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-59	**Sample Name:** TWMS-70A Class 207 Bank (R-L) Bubbler **Sampled:** 3/16/21 4:13						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077027-61	**Sample Name:** TWMS-71A Class D207 - Band Sink **Sampled:** 3/18/21 4:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-63	**Sample Name:** TWMS-72A Class D204 - Orchestra Bubbler **Sampled:** 3/18/21 4:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-65	**Sample Name:** TWMS-73A Class D204 - Orchestra Sink **Sampled:** 3/18/21 4:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077027-67	**Sample Name:** TWMS-74A Class D202 Bubbler **Sampled:** 3/18/21 4:17						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1077027-69	**Sample Name:** TWMS-75A Class D202 Sink **Sampled:** 3/18/21 4:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-71	**Sample Name:** TWMS-76A Kitchen corner sink **Sampled:** 3/18/21 4:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/02/21 15:45
1077027-73	**Sample Name:** TWMS-77A Kitchen scraps sink **Sampled:** 3/18/21 4:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	04/02/21 15:45
1077027-75	**Sample Name:** TWMS-78A Kitchen Dish across from scrap **Sampled:** 3/18/21 4:24						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/02/21 15:45
1077027-77	**Sample Name:** TWMS-79A Kitchen Dish across from scrap **Sampled:** 3/18/21 4:24						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	04/02/21 15:45
1077027-79	**Sample Name:** TWMS-80A Kitchen RR Sink **Sampled:** 3/18/21 4:26						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078002-01	**Sample Name:** TWMS-81A Kitchen eye/handwash sink **Sampled:** 3/18/21 4:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/02/21 15:45
1078002-03	**Sample Name:** TWMS-82A Kitchen Sink with hose **Sampled:** 3/18/21 4:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-05	**Sample Name:** TWMS-83A Kitchen small sink near desk **Sampled:** 3/18/21 4:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-07	**Sample Name:** TWMS-84A Kitchen handwash @ serve **Sampled:** 3/18/21 4:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-09	**Sample Name:** TWMS-85A E210 all use RR **Sampled:** 3/18/21 4:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-11	**Sample Name:** TWMS-86A Girls RR E204 Sink (R-L) **Sampled:** 3/18/21 4:37						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-13	**Sample Name:** TWMS-87A Girls RR E204 Sink (R-L) **Sampled:** 3/18/21 4:37						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-15	**Sample Name:** TWMS-88A Girls RR E204 Sink (R-L) **Sampled:** 3/18/21 4:37						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-17	**Sample Name:** TWMS-89A Girls RR E204 Sink (R-L) **Sampled:** 3/18/21 4:39						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-19	**Sample Name:** TWMS-90A Boys RR E211 (R-L) Sink **Sampled:** 3/18/21 4:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078002-21	**Sample Name:** TWMS-91A Boys RR E211 (R-L) Sink **Sampled:** 3/18/21 4:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-23	**Sample Name:** TWMS-92A Boys RR E211 (R-L) Sink **Sampled:** 3/18/21 4:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	04/05/21 15:26
1078002-25	**Sample Name:** TWMS-93A Boys RR E211 (R-L) Sink **Sampled:** 3/18/21 4:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	04/05/21 15:26
1078002-27	**Sample Name:** TWMS-94A all user E205 Sink **Sampled:** 3/18/21 4:44						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-29	**Sample Name:** TWMS-97A Entry to AuxGym (R) Bubbler **Sampled:** 3/18/21 4:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-31	**Sample Name:** TWMS-98A Entry to AuxGym (R) Bubbler **Sampled:** 3/18/21 4:56						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-33	**Sample Name:** TWMS-99A Girls RR E105 (R-L) **Sampled:** 3/18/21 4:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	04/05/21 15:26
1078002-35	**Sample Name:** TWMS-100A Girls RR E105 (R-L) **Sampled:** 3/18/21 4:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	04/05/21 15:26
1078002-37	**Sample Name:** TWMS-101A Girls RR E105 (R-L) **Sampled:** 3/18/21 5:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	5	ppb	1	15 ppb	04/05/21 15:26
1078002-39	**Sample Name:** TWMS-102A Girls RR E105 (R-L) **Sampled:** 3/18/21 5:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078002-41	**Sample Name:** TWMS-103A Girls RR E105 (R-L) **Sampled:** 3/18/21 5:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	04/05/21 15:26
1078002-43	**Sample Name:** TWMS-104A Girls RR E105 (R-L) **Sampled:** 3/18/21 5:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-45	**Sample Name:** TWMS-105A Girls RR E105 (R-L) **Sampled:** 3/18/21 5:04						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-47	**Sample Name:** TWMS-106A Girls RR E105 (L) **Sampled:** 3/18/21 5:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-49	**Sample Name:** TWMS-107A Boys RR E106 (R-L) **Sampled:** 3/18/21 5:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-51	**Sample Name:** TWMS-108A Boys RR E106 (R-L) **Sampled:** 3/18/21 5:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-53	**Sample Name:** TWMS-109A Boys RR E106 (R-L) **Sampled:** 3/18/21 5:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-55	**Sample Name:** TWMS-110A Boys RR E106 (R-L) **Sampled:** 3/18/21 5:06						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-57	**Sample Name:** TWMS-111A All use RR E107 **Sampled:** 3/18/21 5:09						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-59	**Sample Name:** TWMS-112A B113 Girls RR Sink (R-L) **Sampled:** 3/18/21 5:12						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078002-61	**Sample Name:** TWMS-113A B113 Girls RR Sink (R-L) **Sampled:** 3/18/21 5:12						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078002-63	**Sample Name:** TWMS-114A B113 Girls RR Sink (R-L) **Sampled:** 3/18/21 5:12						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-65	**Sample Name:** TWMS-115A B113 Girls RR Sink (R-L) **Sampled:** 3/18/21 5:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-67	**Sample Name:** TWMS-116A Boys B116 Sink (R-L) **Sampled:** 3/18/21 5:17						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-69	**Sample Name:** TWMS-117A Boys B116 Sink (R-L) **Sampled:** 3/18/21 5:17						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-71	**Sample Name:** TWMS-118A Boys B116 Sink (R-L) **Sampled:** 3/18/21 5:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078002-73	**Sample Name:** TWMS-119A Boys B116 Sink (R-L) **Sampled:** 3/18/21 5:19						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078002-75	**Sample Name:** TWMS-120A B115 Single Use RR Sink **Sampled:** 3/18/21 5:19						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-01	**Sample Name:** TWMS-121A B11 Lactation room **Sampled:** 3/18/21 5:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-03	**Sample Name:** TWMS-122A Bubblers near B114 (R) **Sampled:** 3/18/21 5:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078004-05	**Sample Name:** TWMS-123A Bubblers near B114 (L) **Sampled:** 3/18/21 5:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-07	**Sample Name:** TWMS-124A Classroom B111 (R-L) **Sampled:** 3/18/21 5:24						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-09	**Sample Name:** TWMS-125A Classroom B111 (R-L) **Sampled:** 3/18/21 5:24						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-11	**Sample Name:** TWMS-126A Classroom B111 (R-L) **Sampled:** 3/18/21 5:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-13	**Sample Name:** TWMS-127A Classroom B111 (R-L) **Sampled:** 3/18/21 5:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078004-15	**Sample Name:** TWMS-128A Classroom B111 (R-L) **Sampled:** 3/18/21 5:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	04/05/21 15:26
1078004-17	**Sample Name:** TWMS-129A Classroom B111 (R-L) **Sampled:** 3/18/21 5:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078004-19	**Sample Name:** TWMS-130A Class B110 (R-L) **Sampled:** 3/18/21 5:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-21	**Sample Name:** TWMS-131A Classroom B110 Sink (L) **Sampled:** 3/18/21 5:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	04/05/21 15:26
1078004-23	**Sample Name:** TWMS-132A Classroom B109 Sink (R) **Sampled:** 3/18/21 5:31						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078004-25	**Sample Name:** TWMS-133A Classroom B109 Sink (L) **Sampled:** 3/18/21 5:31						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-27	**Sample Name:** TWMS-134A Girls RR A114 (R-L) **Sampled:** 3/18/21 5:33						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-29	**Sample Name:** TWMS-135A Girls RR A114 (R-L) **Sampled:** 3/18/21 5:33						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-31	**Sample Name:** TWMS-136A Girls RR A114 (R-L) **Sampled:** 3/18/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-33	**Sample Name:** TWMS-137A Girls RR A114 (R-L) **Sampled:** 3/18/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-35	**Sample Name:** TWMS-138A Boys RR A118 **Sampled:** 3/18/21 5:39						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-37	**Sample Name:** TWMS-139A Boys RR A118 **Sampled:** 3/18/21 5:39						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-39	**Sample Name:** TWMS-140A Boys RR A118 **Sampled:** 3/18/21 5:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-41	**Sample Name:** TWMS-141A Boy RR 118 (R-L) **Sampled:** 3/18/21 5:41						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-43	**Sample Name:** TWMS-142A A117 all user **Sampled:** 3/18/21 5:41						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078004-45	**Sample Name:** TWMS-143A Bubblers near A117 R **Sampled:** 3/18/21 5:41						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-47	**Sample Name:** TWMS-144A Bubblers near A117 L **Sampled:** 3/18/21 5:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-49	**Sample Name:** TWMS-145A Classroom A102 **Sampled:** 3/18/21 5:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-51	**Sample Name:** TWMS-146A Classroom 102 (R-L) **Sampled:** 3/18/21 5:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-53	**Sample Name:** TWMS-147A Classroom 102 (R-L) **Sampled:** 3/18/21 5:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-55	**Sample Name:** TWMS-148A Classroom 102 (R-L) **Sampled:** 3/18/21 5:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	1	15 ppb	04/05/21 15:26
1078004-57	**Sample Name:** TWMS-149A Classroom 102 (R-L) **Sampled:** 3/18/21 5:52						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-59	**Sample Name:** TWMS-150A Classroom 102 (R-L) **Sampled:** 3/18/21 5:53						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-61	**Sample Name:** TWMS-151A Classroom A102 **Sampled:** 3/18/21 5:54						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26
1078004-63	**Sample Name:** TWMS-152A Science Prep A101 **Sampled:** 3/18/21 5:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/08/2021
Received: 03/18/2021
Sampled By:
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Twality MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1078004-65	**Sample Name:** TWMS-153A Classroom A100 Teachers **Sampled:** 3/18/21 5:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078004-67	**Sample Name:** TWMS-154A Classroom A100 Teachers **Sampled:** 3/18/21 5:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-69	**Sample Name:** TWMS-155A Classroom A100 Teachers **Sampled:** 3/18/21 5:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078004-71	**Sample Name:** TWMS-156A Classroom A100 (R-L) **Sampled:** 3/18/21 5:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	1	15 ppb	04/05/21 15:26
1078004-73	**Sample Name:** TWMS-157A Classroom A100 (R-L) **Sampled:** 3/18/21 5:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078004-75	**Sample Name:** TWMS-158A Classroom A100 (R-L) **Sampled:** 3/18/21 5:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	1	15 ppb	04/05/21 15:26
1078004-77	**Sample Name:** TWMS-159A Classroom A100 (R-L) **Sampled:** 3/18/21 6:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	1	15 ppb	04/05/21 15:26

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.