



Lead Testing Results Table

Horace Greeley High School, Chappaqua School District					
Sample Collection Date	Sample ID	Floor	Location	Lead Level (ppb)	Actions Taken
9/30/2020	1-Kitchen-KF-P-1	1	Food prep sink - Kitchen sink 1	6.89	Not Applicable
9/30/2020	1-Kitchen-KF-P-2	1	Stove top filler tap - Kitchen 2	14.8	Not Applicable
9/30/2020	1-Kitchen-IM-P-1	1	Ice machine - Kitchen	ND	Not Applicable
9/30/2020	1-Studio1-CF-P-1	1	Studio 1 - Art room - Sink 1 (Right)	ND	Not Applicable
9/30/2020	1-Studio1-CF-P-2	1	Studio 1 - Art room - Sink 2 (Left)	ND	Not Applicable
9/30/2020	1-Studio2-CF-P-3	1	Studio 2 - Art room - Sink 1	2.75	Not Applicable
9/30/2020	1-Studio3-CF-P-4	1	Studio 3 - Art room - Sink 1	8.59	Not Applicable
9/30/2020	1-Staff Lounge-CF-P-5	1	Staff lounge - Sink 1 (coffee) - Room F2	ND	Not Applicable
9/30/2020	1-Staff Lounge-CF-P-6	1	Staff lounge - E6 - Sink (coffee)	7.99	Not Applicable
9/30/2020	1-Commons Room-CF-P-7	1	Academic commons room - Sink	ND	Not Applicable
9/30/2020	1-Nurse-NS-P-1	1	Nurse office - Sink	1.36	Not Applicable
9/30/2020	1-Nurse-NS-P-2	1	Nurse bathroom - Sink	3.41	Not Applicable
9/30/2020	1-Trainer-CF-P-8	1	Trainer room - Sink	23.8	Changed the faucet and speedy connections to the sink. Confirmation sampling performed. See below.
9/30/2020	1-Trainer-IM-P-2	1	Trainer room - Ice machine	ND	Not Applicable
9/30/2020	1-Girls Locker Rm-BF-P-1	1	Girl's locker room bathroom - Sink 1 (Right)	2.53	Not Applicable



Lead Testing Results Table

Horace Greeley High School, Chappaqua School District					
Sample Collection Date	Sample ID	Floor	Location	Lead Level (ppb)	Actions Taken
9/30/2020	1-Girls Locker Rm-BF-P-2	1	Girl's locker room bathroom - Sink 2 (Left)	ND	Not Applicable
Resample					
11/6/2020	1-Trainer-CF-P-8	1	Gym building, Trainer room - Sink	2.98	Not Applicable