



Park Hill School District

Building Successful Futures • Each Student • Every Day

ADDENDUM No. 2

Park Hill School District

2024 Roofing Projects

January 11, 2024

You are instructed to read and note the following described changes, corrections, clarifications, omissions, deletions, additions, approvals and statements pertinent to the Construction Documents.

Addendum No. 1 is a part of the Contract Bid and Construction Documents and shall govern the performance of the Work.

I. General Information

- A. Confirming that the date for all roofing work to be 100% complete is August 2, 2024.

II. Scope of Work Additions and Changes

A. Park Hill High School

1. On Roof H, remove all wall counterflashing including where there are two pieces of metal counterflashing.
 - a) New counterflashing shall extend down over the bar termination at the top edge of the new base flashing at least four inches.

ACKNOWLEDGEMENT: Each Bidder shall acknowledge receipt of Addendum No. 2 on the Bid Forms.

END OF ADDENDUM NO. 2