

ADDENDUM #2

MEASURE BB BOND: BID BUNDLE #5
HIGH SCHOOL REFRESH #2:

WILSON HIGH SCHOOL
16455 Wedgeworth Drive
Hacienda Heights, CA 91745

LOS ALTOS HIGH SCHOOL
15325 E. Los Robles Avenue
Hacienda Heights, CA 91745

STIMSON LEARNING CENTER
1655 S. Stimson Avenue
Hacienda Heights, CA 91745

**HACIENDA LA PUENTE
UNIFIED SCHOOL DISTRICT**

PURCHASING DEPARTMENT
15959 E. Gale Avenue
City of Industry, CA 91745
(626) 933-3930



CONSTRUCTION MANAGER:

CUMMING-GROUP
120 Vantis, Suite 510
Aliso Viejo, CA 92656
(949) 732-8386



PN: 2023-24.08

Date: January 12, 2024

ADDENDUM #2

THE FOLLOWING CORRECTIONS, MODIFICATIONS, OR ADDITIONS SHALL BE INCLUDED IN THE DRAWINGS, SPECIFICATIONS, AND OTHER CONTRACT DOCUMENTS AND SHALL BE TAKEN INTO CONSIDERATION BY CONTRACTORS IN SUBMITTING BIDS ON THE NAMED PROJECT (S). THE BIDDERS SHALL BE RESPONSIBLE FOR TRANSMITTING THIS INFORMATION TO ALL AFFECTED SUBCONTRACTORS AND SUPPLIERS PRIOR TO CLOSING OF BIDS. ACKNOWLEDGEMENT OF RECEIPT OF THIS ADDENDUM IS REQUIRED IN SPACES PROVIDED ON THE BID FORM. FAILURE TO ACKNOWLEDGE WILL SUBJECT BIDDER TO DISQUALIFICATION.

PROJECT MANUAL

1. Section 024119.16 “Selective Demolition.” Page 1, 1.02, A, 1, a: delete and replace with: “a. Technology items mounted or unmounted - the District will disconnect and remove technology for each school at the start of each phase. Once construction is complete at the end of each phase, the District will move technology back into each classroom and re-install. Contractor shall coordinate schedule with District and CM.”

DRAWINGS

1. Los Altos High School, Sheet T-2:
 - a. The attached Sheet T-2 for Los Altos High School (ADDENDUM NO. 2, EXHIBIT 1), dated 1/12/24 should replace the originally issued Sheet T-2.
 - b. Note T Clarification: Note T is related to integrated diffusers in ceiling systems. Linear diffusers are to remain in place and be painted.
 - c. Note U Clarification: Where there are wall mounted heat pump units and similarly wall mounted diffusers from ducts, remove and replace grilles with new 626 finish metal grilles to fit opening.
2. Wilson High School, Sheet T-2:
 - a. The attached Sheet T-2 for Wilson High School (ADDENDUM NO. 2, EXHIBIT 2) dated 1/12/24 should replace the originally issued Sheet T-2.
 - b. Note T Clarification: Note T is related to integrated diffusers in ceiling systems. Linear diffusers are to remain in place and be painted.
 - c. Note U Clarification: Where there are wall mounted heat pump units and similarly wall mounted diffusers from ducts, remove and replace grilles with new 626 finish metal grilles to fit opening.
3. Stimson Learning Center, Sheet G-1:
 - a. The attached Sheet G-1 for Stimson Learning Center (ADDENDUM NO. 2, EXHIBIT 3) dated 1/12/24 should replace the originally issued Sheet G-1.
 - b. Note T Clarification: Note T is related to integrated diffusers in ceiling systems. Linear diffusers are to remain in place and be painted.

ADDENDUM #2

- c. Note U Clarification: Where there are wall mounted heat pump units and similarly wall mounted diffusers from ducts, remove and replace grilles with new 626 finish metal grilles to fit opening.

ATTACHMENTS

1. EXHIBIT 1 – Los Altos High School, Sheet T-2 (ADDENDUM NO. 2), dated 1/12/24.
2. EXHIBIT 2 – Wilson High School, Sheet T-2 (ADDENDUM NO. 2), dated 1/12/24.
3. EXHIBIT 3 – Stimson Learning Center, Sheet G-1 (ADDENDUM NO. 2), dated 1/12/24.

END OF ADDENDUM #2

ABBREVIATIONS

&	AND	(E)	EXISTING	K	KIP (1000 LB)	R	RISER
∠	ANGLE	EA	EACH	KIT.	KITCHEN	RAD.	RADIUS
@	AT	EJ	EXPANSION JOINT	KO	KNOCKOUT	R.D.	ROOF DRAIN
⊖	CENTERLINE	ELEC.	ELECTRICAL	KVA	KILOVOLT AMPERE	REDWOOD	REDWOOD
⊕	DIAMETER OR ROUND	ELEV.	ELEVATION	LAB.	LABORATORY	REF.	REFERENCE
#	NUMBER	EMER.	EMERGENCY	LAM.	LAMINATED	REFR.	REFRIGERATOR
AB	ANCHOR BOLT	ENCL.	ENCLOSURE	LAV.	LAVATORY	REG.	REGISTER
AC	ASPHALTIC CONCRETE	ENG	ENGINEER	LB.	POUND	REINF.	REINFORCING
ACP	ACOUSTICAL PANEL	ENGY	ENERGY	LOG	LANDING	REQD.	REQUIRED
ACT	ACOUSTICAL TILE	ENTR	ENTRANCE	LL	LIVE LOAD	RESIL.	RESILIENT
ACOUS	ACOUSTICAL	EP	EPOXY ENAMEL	LL	LIVE LOAD	RET	RETURN
AD	AREA DRAIN	EQ	EQUAL	LT	LIGHT	REV.	REVERSE
ADH	ADHESIVE	EQUIP.	EQUIPMENT	LTF	LINOLEUM TILE FLOORING	RFG	ROOFING
ADJ	ADJACENT	EST.	ESTIMATE	LTO	LIGHTING	RM	ROOM
AFF	ABOVE FINISH FLOOR	E.W.C.	ELECTRIC WATER COOLER	LVL	LEVEL	R.O.	ROUGH OPENING
AFP	ACCORDIAN FOLDING PARTITION	EW	ELECTRIC WATER HEATER	LVR	LOUVER	R.T.F.	RUBBER TILE FLOORING
AGGR	AGGREGATE	EXH	EXHAUST	MAINT	MAINTENANCE	S.B.	SPLASH BLOCK
ALT	ALTERNATE	EXIST.	EXISTING	MAN	MANUAL	S.C.	SOLID CORE
ALUM	ALUMINUM	EXP.	EXPANSION	MAS	MASONRY	SCHED.	SCHEDULE
AMP	AMPERE	EXPSD.	EXPOSED	MATL.	MATERIAL	SCN	SOLID CORE NATURAL FINISH
ANCD	ANNOUNCED	EXT.	EXTERIOR	MAX.	MAXIMUM	SCP	SOLID CORE PAINT FINISH
APPROX	APPROXIMATELY	F	FACTORY FINISH	MCC.	MOTOR CONTROL CENTER	SCLP	SOLID CORE PLUM FINISH
ARCH	ARCHITECT	F.A.	FIRE ALARM	MECH.	MECHANICAL	S.D.	STORM DRAIN
ASB	ASBESTOS	FC	FOOTCANDLE	MED	MEDIUM	SECT.	SECTION
ASSY	ASSEMBLY	F.D.	FLOOR DRAIN	MEZZ	MEZZANINE	SF	SQUARE FOOT
BAT	BATTERY	FDC	FIRE DEPARTMENT CONNECTION	MFR.	MANUFACTURER	SHT.	SHEET
BBB	BULLETIN BOARD	FDN	FOUNDATION	MH	MANHOLE	SIM.	SIMILAR
BO	BOARD	F.E.	FIRE EXTINGUISHER	MIN.	MINIMUM	SLR	SEALER
BLDG	BUILDING	F.E.C.	FIRE EXTINGUISHER CABINET	MIR	MIRROR	SPEC	SPECIFICATIONS
BKGS	BLOCKING	F.F.	FINISH FLOOR	MISC.	MISCELLANEOUS	SPLY	SUPPLY
BLO	BLOWER	F.G.	FINISHED GRADE	MKR	MARKER	SQ	SQUARE
BLR	BOILER	F.H.	FIRE HYDRANT	MTL	METAL	S.S.K.	SSERVICE SINK
BLW	BELOW	FIN.	FINISH	MTD.	MOUNTED	SST.	STAINLESS STEEL
BM	BEAM	F.L.	FLOW LINE	MUL.	MULLION	ST	STREET
BO	BOTTOM OF	FLASH.	FLASHING	MVBL	MOVABLE	STAG	STAGGERED
BRKR	BREAKER	FLR.	FLOOR	(N)	NEW	STC	SOUND TRANSMISSION CLASS
BTU	BRITISH THERMAL UNIT	FLUR.	FLUORESCENT	(N)	NEW	STD.	STANDARD
BUR	BUILT UP ROOFING	F.O.	FACE OF	NAT.	NATURAL	STL	STEEL
CAB	CABINET	F.O.C.	FACE OF CONCRETE	NEG	NEGATIVE	STN	STAIN FINISH
CARP	CARPET	F.O.F.	FACE OF FINISH	N.I.C.	NOT IN CONTRACT	STOR	STORAGE
CAT	CATALOG	F.O.M.	FACE OF MASONRY	NO.	NUMBER	STRUCT.	STRUCTURAL
CB	CATCH BASIN	F.O.S.	FACE OF STUD	NOM	NOMINAL	SURF.	SURFACE
CEM	CEMENT	FPF	FOLDING PANEL PARTITION	N.T.S.	NOT TO SCALE	SUSP	SUSPENDED
CF	CURB FACE	FPW	FOLDING PANEL WOOD DOOR	OV	OVERALL	SV	SHEET VINYL
CFM	CUBIC FEET PER MINUTE	F.R.	FIRE RETARDANT	O.A.	ON CENTER	SWBD	SWITCHBOARD
CHBD	CHALKBOARD	F.R.A.	FIRE RATED ASSEMBLY	O.C.	OUTSIDE DIAMETER	SWGR	SWITCHGEAR
CHEM	CHEMICAL	F.R.P.	FIBERGLASS REINFORCED PANEL	O.D.	OUTSIDE DIAMETER	SWR	SEWER
CHWR	CHILLED WATER RETURN	F.S.	FLOOR SINK	O.F.	OVERFLOW DRAIN	SYM	SYMBOL
CHWS	CHILLED WATER SUPPLY	FT.	FOOT OR FEET	OPCI	OWNER FURNISHED-CONTRACTOR INSTALLED	SYS	SYSTEM
CI	CAST IRON	FTG.	FOOTING	OFF	OFFICE	T	TREAD
CIR	CIRCLE	FXTR	FIXTURE	OFDI	OWNER FURNISHED-OWNER INSTALLED	T. & B.	TOP AND BOTTOM
CJ	CONTROL JOINT	G.	GAS	OPNG.	OPENING	T. & G.	TONGUE AND GROOVE
CL	CENTERLINE	GA	GAGE	OPP.	OPPOSITE	T.C.	TOP OF CURB
CLG	CEILING	GALV.	GALVANIZED	OVHD	OVERHEAD	T.O.	TRENCH DRAIN
CLO	CLOSET	GB	GRAB BAR	TECH	TECHNICAL	TEL.	TELEPHONE
CLRM	CLASSROOM	GL	GALVANIZED IRON	PART.	PARTITION	TEMP.	TEMPERATURE
CLT	CERAMIC TILE	G.L.	GLASS	PB	PULL BOX	T.G.	TOP OF GRATE
CMU	CONCRETE MASONRY UNIT	GLU.LAM.	GLUE LAMINATED	PSD	PARTICLEBOARD	THK	THICK
CND	CONDUIT	GND.	GROUND	PC	PORTLAND CEMENT	THRES.	THRESHOLD
CO	CLEANOUT	GPM	GALLONS PER MINUTE	PD	PLANTER DRAIN	THRU	THROUGH
COL	COLUMN	GR.	GRADE	PERF	PERFORATED	T.BD	TACKBOARD
COMM	COMMUNICATION	GYP.	GYPSUM	PERP	PERPENDICULAR	T.O.	TOP OF
COMP	COMPOSITION	H.B.	HOSE BIBB	PE	PAINT EGGSHELL	T.O.P.	TOP OF PARAPET
CONC	CONCRETE	HON	HOLLOW CORE NATURAL FINISH	PF	PAINT FLAT	TOT	TOTAL
CONF	CONFERENCE	HCP	HOLLOW CORE PAINT FINISH	PG	PAINT GLOSS	T.P.	TOP OF PAVING
CONN	CONNECTION	HDBD	HARBORBOARD	PH	PAINT HARDWARE	TRNSF.	TRANSFORMER
CONT	CONTINUOUS	HDR	HEADER	PV	POST INDICATOR VALVE	TW	TOP OF WALL
CONTR	CONTRACTOR	HDW.	HARDWARE	PL	PROPERTY LINE	TYP.	TYPICAL
COORD	COORDINATE	HDW.	HARDWARE	PL	PLATE	UNGD	UNDERGROUND
CORR	CORRIDOR	HGT.	HEIGHT	PLAS	PLASTER	UNFIN	UNFINISHED
COV	COVER	H.M.	HOLLOW METAL	PLAT.	PLATFORM	U.N.O.	UNLESS NOTED OTHERWISE
CP	CONTROL PANEL	HORIZ	HORIZONTAL	PLBG	PLUMBING	U.O.S.	UNDERSIDE OF STRUCTURE
CR	CONDENSATE RETURN	HP	HORSEPOWER	PLF	POUNDS PER LINEAR FOOT	URINAL	URINAL
CSWK	CASEWORK	HR.	HOUR	PLYVD.	PLYWOOD	UTIL	UTILITY
CT	CERAMIC TILE	HTG.	HEATING	PAN.	PANEL	V	VOLT
CTSK	COUNTERSINK	HTWR	HOT WATER RETURN	POS	POSITIVE	VAC	VACUUM
CTV	CABLE TELEVISION	HTWS	HOT WATER SUPPLY	PR	PAIR	VAV	VARIABLE AIR VOLUME
CW	COLD WATER	HVAC	HEATING, VENTILATING, AIR CONDITIONING	PREFAB	PREFABRICATED	V.C.T.	VINYL COMPOSITION TILE
DBL	DOUBLE	HVY	HEAVY	PREFIN	PREFINISHED	VERT.	VERTICAL
DEMO	DEMOLITION	HW	HOT WATER	PRELIM	PRELIMINARY	VEST.	VESTIBULE
DEPT	DEPARTMENT	ID.	INSIDE DIAMETER	PROJ	PROJECT	VFCV	VINYL FABRIC WALL COVERING
DET	DETAIL	IE	INVERT ELEVATION	PSG	POUNDS PER SQUARE FOOT	W	WATT
DF	DRINKING FOUNTAIN	INSUL	INSULATION	PSI	POUNDS PER SQUARE INCH	WT	WITH
DG	DECOMPOSED GRANITE	INT.	INTERIOR	PVC	POLYVINYL CHLORIDE	W.C.	WATER CLOSET
DIA	DIAMETER	INV.	INVERT	Q.T.	QUARRY TILE	WD	WOOD
DIM	DIMENSION	IW	IRRIGATION WATER	QTY	QUANTITY	WDO.	WINDOW
DISP	DISPENSER	JAN.	JANITOR	WL	WAREHOUSE	WSE	WAREHOUSE
DIST.	DISTANCE	JCT.	JUNCTION	WLD	WELDED	WLP	WORKING POINT
DIV.	DIVISION	JOINT	JOINT	WR	WATERPROOFING	WR	WATER RESISTANT
D.L.	DEAD LOAD			WBCST	WAINSCOT	WT	WEIGHT
DN.	DOWN			W.F.	WELDED WIRE FABRIC	XPRM	TRANSFORMER
DS.	DOWN SPOUT						
DWG.	DRAWING						

GENERAL NOTES

- CONTRACTOR SHALL IDENTIFY, PHOTOGRAPH AND DOCUMENT ALL EXISTING ITEMS NOTED TO REMAIN AND SHALL VERIFY OPERABILITY. RECORD AND REPORT ANY DAMAGED SURFACES, EQUIPMENT, CABINETS, DOORS, LIGHTS OR ANY OTHER ITEMS TO BE RE-USED. CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR FINAL OPERABILITY AND FINISH OF ALL NEW OR RE-USED PRODUCTS OR MATERIALS IN THE FINAL INSTALLATION THAT IS NOT RECORDED AND IDENTIFIED AT THE BEGINNING OF THE JOB AND REPORTED TO THE CONSTRUCTION MANAGER IN WRITING.
- ALL EXISTING AND NEW SURFACES AT INTERIOR THAT ARE NORMALLY PAINTED, INCLUDING TRIM, DOOR AND WINDOW FRAMES NOT PRE-FINISHED SHALL BE PAINTED AS A PART OF THIS CONTRACT UNLESS SPECIFICALLY NOTED PREP, PRIME AND PAINT ALL (E) PLYWOOD/WOOD PANELS ON WALLS.
- WORK SHALL INCLUDE ALL NECESSARY DEMOLITION OF INCIDENTAL ITEMS WHICH ARE NOT PART OF THE NEW INSTALLATION. REMOVE ALL ABANDONED CONDUIT AND PIPE THAT IS NOT BEING REUSED IN THE NEW WORK.
- PROTECT ALL (E) FIRE ALARM, PA, INTRUSION EQUIPMENT, LIGHTING AND LIGHTING CONTROLS, CEILING, HVAC EQUIPMENT AND ALL RELATED CONDUITS IN PLACE. AFTER DEMOLITION OR CONSTRUCTION, CONTRACTOR SHALL TEST FIRE ALARM SYSTEM AND SATISFACTORILY RESTORE TO WORKING CONDITION TO MEET NFPA 72 REQUIREMENTS.
- DETAILS AND NOTES ARE TYPICAL FOR ALL RELATED CONDITIONS IN EACH ROOM WHETHER OR NOT SPECIFICALLY REFERENCED.
- THE CONTRACTOR SHALL REPAIR OR REPLACE ANY EXISTING CONSTRUCTION DAMAGED DURING THE WORK OF THIS CONTRACT
- PATCH, REPAIR, PRIME & PAINT AREAS WHERE REMOVAL OF MATERIAL, CABINETS, ACCESSORIES, FIXTURES OR EQUIPMENT RESULTS IN UNFINISHED SURFACE, INCLUDING WALLS, FLOORS AND CEILING. REPAIR & FINISH SHALL MATCH (E) ADJACENT CONDITION.
- THE CONTRACTOR SHALL ASSUME THE REPLACEMENT OF 10% OF THE ACOUSTIC TILE IN EACH ROOM. REMOVE PROVIDE AND INSTALL NEW TILE PRIOR TO THE PAINTING OF CEILINGS AND OR WALLS.

DEMOLITION NOTES

- REMOVE, ROLL AND PROTECT FLAGS FROM DAMAGE STORE FOR REINSTALLATION ACCORDING TO THE U.S. FLAG CODE TITLE 4, CHAPTER 1.
- REMOVE AND SALVAGE ALL (E) TECHNOLOGY EQUIPMENT. LOW VOLTAGE DEVICES (THERMOSTAT), CLOCK AND ASSOCIATED MOUNTING HARDWARE, INCLUDING BUT NOT LIMITED TO FASTENERS, AND EXPANSION SHIELDS, LEAVING WALLS SMOOTH FLUSH AND UNINTERRUPTED ON THE SURFACE. RETAIN-STORE EQUIPMENT AND MOUNTING HARDWARE, GIVE DISTRICT FIRST RIGHT OF SALVAGE. DISPOSE OF ELEMENTS THAT THE DISTRICT REJECTS IN A LAWFUL MANNER.
- REMOVE AND SALVAGE EXISTING CURTAINS AND TRACK. ARRANGE FOR CURTAINS TO BE CLEANED STORE NEATLY AWAY FROM WORK ACTIVITIES UNTIL REINSTALLATION. CLEAN BLINDS AND OTHER WINDOW TREATMENTS, SIMILAR AND TYPICAL
- REMOVE, CLEAN AND SALVAGE FOR REINSTALLATION, COVER PLATES FROM SWITCH PLATES, OUTLETS, AND OTHER ELECTRICAL AND DATA BOXES IN WALLS AND FLOORS. TEST CONNECTIVITY IN POWER CIRCUITS, DATA AND OTHER LOW VOLTAGE SYSTEMS AND/OR CABEL FROM ABANDONED PLUGS. REMOVE WIRE AND OR CABLE FROM ABANDONED PLUGS AND/OR DROPS BACK TO PANEL BOX OR IDF.
- WHERE DATA (ABANDONED LOW VOLTAGE INCLUSIVE) AND/OR POWER HAS BEEN REMOVED, REMOVE ALL ASSOCIATED SURFACE MOUNTED BOXES, WIREMOLD, CEILING MOUNTING HARDWARE, ACCESSORIES, AND FASTENERS COMPLETELY. REMOVE OBSOLETE TELEPHONE RELATED INFRASTRUCTURE.
- REMOVE AND SALVAGE WALL MOUNTED WHITE BOARDS AND BULLETIN BOARDS. RETAIN BOARDS AND MOUNTING HARDWARE FOR REINSTALLATION.
- REMOVE ALL LIGHT FIXTURE BASES, FASTENERS, BRACKETS, DEVICES, (ASSOCIATED OR NOT ASSOCIATED WITH INSTALLED ELEMENTS) FROM THE FINISHED PLYWOOD PANELING, MASONRY AND PLASTER WALLS AND CEILING. REMOVE EXCESS MOLDING, BLOCKING BOARDS, HOOKS, STICKERS, CLIPS, TAPE, AND ANY HARDWARE. PRIOR TO PAINTING.
- CLEAN & REPAIR, FLOOR SLABS AFTER ABATEMENT AND FLOORING REMOVAL. PROVIDE AND INSTALL LEVELING COMPOUND TO FLOORS AS REQUIRED PRIOR TO INSTALLING FLOORING.
- PROTECT SECURITY SYSTEM WIRING. YOU MAY DISCONNECT, UN-INSTALL WIRES. SALVAGE WIRE AND CONTACTS AS NECESSARY. RETAIN PARTS AND NOTE LOCATION FOR EXACT REINSTALLATION AFTER PAINTING. ANY DAMAGE SHALL RESULT IN REPAIR AT CONTRACTOR'S COST. RECOMMEND PRE-TESTING ALL SYSTEMS BEFORE DEMOLITION OR SALVAGE.
- REMOVE (E) GREEN BOARD CHALKBOARDS (MAY BE UNDER-BEHIND WHITE BOARDS) COMPLETELY. CONSULT HAZ-MAT REMOVAL SPECIFICATIONS FOR THE HANDLING OF ASBESTOS CONTAINING MATERIALS.
- REMOVE (E) FLOOR TILES. CONSULT HAZ-MAT REMOVAL SPECIFICATIONS FOR THE HANDLING OF ASBESTOS CONTAINING MATERIALS. SAND-BLAST (E) SLAB CONCRETE TO REMOVE ALL TYPES OF ADHESIVES REGARDLESS C ASBESTOS CONTENT.
- PROTECT BRONZE FLOOR BOXES DURING DEMOLITION ACTIVITIES. CLEAN AND POLISH FLOOR PLATE COVERS BEFORE RETURNING TO DISTRICT.
- REMOVE TAPE, TACKS, HOOKS, AND ANY OTHER HARDWARE FROM (E) CEILING TILES, WALLS AND GLAZING TYP.
- REMOVE (E) SUPPLY AND RETURN AIR GRILLES AT WALL MOUNTED HEAT PUMP UNITS, REPLACE WITH NEW.
- REMOVE ALL INTERIOR SIGNAGE. INCLUDE MOUNTING MECHANISMS, SCREWS, SHIELDS, AND ADHESIVE. REPLACE ANY DAMAGED SIGNAGE.
- REMOVE AND SALVAGE FOR RE-INSTALLATION: SOAP, PAPER TOWEL, AND HAND SANITIZER DISPENSERS.
- NOT USED
- REMOVE AND SALVAGE LEARNING AIDS SUCH AS MAPS, MOUNTING BRACKETS, ARTWORK, AND POSTERS. RE-INSTALL AS INSTRUCTED.
- REMOVE, SALVAGE AND STORE FIRE EXTINGUISHER WITH MOUNTING HARDWARE FOR RE-INSTALLATION.
- REMOVE CARPET, FLOORING, AND ADHESIVE COMPLETE, LEAVE FLOOR CLEAN READY FOR NEW WORK. MEDIA BLAST TO REMOVE ADHESIVE, DO NOT USE DETERGENT.
- REMOVE RUBBER WALL BASE AND ADHESIVE COMPLETELY.
- PROTECT FIRE ALARM DEVICES AND SYSTEMS DEVICES TYPICAL, INCLUDING BUT NOT LIMITED TO: MOTION SENSORS, SMOKE DETECTORS, STROBES. MASK BEFORE PAINTING, MEDIA BLASTING, OR USE OF CHEMICALS THAT COULD SET OFF, ACTIVATE OR DAMAGE THE SYSTEMS.
- CONTRACTOR IS RESPONSIBLE FOR ALL WORK ASSOCIATED WITH THE WORK SCOPE WHETHER SPECIFICALLY NOTED AND/OR ASSOCIATED BY NECESSITY OF THE SPECIFIC IDENTIFIED WORK SCOPE. THESE NOTES ARE CONSIDERED TYPICAL.
- REMOVE (E) BASE CABINETS COMPLETELY, INCLUDING FASTENERS AND ANCHORS. SEE CONST. NOTES FOR FLOOR PREP. AND REPAIR.

CONSTRUCTION NOTES

- REINSTALL SALVAGED TECHNOLOGY INDICATED BY DISTRICT.
- REINSTALL CURTAIN TRACK AND CLEANED CURTAINS. REMOVE WRINKLES AND CREASES CAUSED BY STORAGE. PATCH AND REPAIR FABRIC DAMAGE. REPLACE DAMAGED HANGERS, HOOKS, LOOPS AND REPAIR GROMETS AS NECESSARY TO RESTORE TO OPERATIONAL, AND RE-INSTALL.
- REINSTALL LIGHTING BASES, ELECTRICAL AND DATA PLATE COVERS. CONFIRM LABELED CIRCUITS WITH INSTALL LOCATIONS. PROVIDE AND INSTALL LABELS ON MISSING OR ILLEGIBLE LABELS.
- PATCH AND FILL HOLES, DIVOTS, DENTS AND DEPRESSIONS IN WALL SURFACES FROM PRIOR DAMAGE, REMOVE FASTENER AND WIRES. PREP, PRIOR TO APPLICATION OF PRIMER AND PAINT. SEE SPEC.
- PROTECT DEVICES, BOXES, LIGHTING, AND WIRE MOLD FROM PAINT. PREPARE SURFACES AND APPLY PAINT PER SPECIFICATIONS ACCORDING TO MATERIAL SPECIFICATIONS.
- PREP AND PAINT WALLS IN COLOR 1 INDICATED USING THE PROCESS SPECIFIED. SEE SPEC.
- PREP AND PAINT WALLS IN COLOR 2 INDICATED USING THE PROCESS SPECIFIED. SEE SPEC.
- PREP AND PAINT DOORS IN COLOR 3 INDICATED USING THE PROCESS SPECIFIED. REMOVE ALL HARDWARE INCLUDING BUT NOT LIMITED TO HANDLES, KNOBS, ROSES, ESCUTCHEONS, CLOSERS, COVER PLATES, KICK PLATES, SWEEPS, LATCH PLATES, PANIC DEVICES AND SIGNAGE PRIOR TO PREP WORK. REINSTALL ALL AFTER PAINTING.
- PREP AND PAINT FRAMES IN COLORS 3 INDICATED USING THE PROCESS SPECIFIED.
- PREP, PRIME, AND PAINT WINDOWS INCLUDING TRIMS, FRAMES, SASHES, CASEMENTS, AND ALL PARTS OF WINDOWS EXCLUDING GLAZING. REMOVE ANY NEW PAINT FROM GLAZING AND OTHER UNINTENDED SURFACES.
- PREP AND PAINT CEILING IN COLOR INDICATED USING THE PROCESS SPECIFIED.
- PRIOR TO REINSTALLATION, CLEAN WHITEBOARDS ACCORDING TO THE MANUFACTURERS RECOMMENDATIONS ON WRITING SURFACE AND PEN RAILS. REINSTALL THE DRY ERASE-WHITE BOARDS IN THE APPROXIMATE LOCATIONS FROM WHERE THEY WERE REMOVED. ADDRESS THE BULLETIN BOARDS SIMILARLY, BUT PREP, PRIME AND PAINT THE VINYL SURFACE WITH COLOR SELECTED BY DISTRICT.
- IN AREAS THAT ARE FINISHED WITH STAINED AND VARNISHED PLYWOOD WALL PANELS, SAND, PREP, PRIME AND PAINT. SEE SPEC
- THOROUGHLY CLEAN ALL PLASTIC WIRE MOLD COVERS WITH MILD DETERGENT AND WARM WATER. USE CARE NOT TO DAMAGE. LET DRY COMPLETELY BEFORE REINSTALLATION. PROTECT FROM PAINT. REPLACE DAMAGED SECTIONS OF WIRE MOLD WITH NEW. MATCH SIZE, COLOR, PROFILE AND CONFIGURATION WITH EXISTING. REPLACE DAMAGED ELECTRICAL PLATES FOR PLUGS, OUTLETS, SWITCHES, COVER PLATES AND COMMUNICATIONS PORTS. WHERE ELEMENTS, PARTS, TRANSITIONS AND PIECES ARE MISSING IN (E) WIREMOLD REPLACE WITH NEW PARTS. VERIFY CIRCUITS AND LABEL INTERIOR OF COVER PLATE.
- REMOVE BLASTING MEDIA AND DUST FROM ALL SURFACES IN EACH ROOM PRIOR TO THE START OF PAINTING.
- PROVIDE AND INSTALL LUXURY VINYL TILE PLANKS LONG-WISE BETWEEN NON-WINDOW WALLS. CAREFULLY FIT FLOORING AROUND WALL AND (E) FLOOR AND WALL ELEMENTS.
- PROVIDE AND INSTALL TOPSET BASE AT ALL WALLS AND AT TOE KICKS OF ALL CASEWORK. MATCH HEIGHT WITH ORIGINAL, REPLACE WITH SAME. CONTRACTOR SHALL CONFIRM HEIGHT AT CASEWORK. DO NOT HAND CUT TALL TOPSET DOWN TO SIZE.
- RE-ATTACH SECURITY SYSTEM WIRING AND CONTACT IN NEAT, STRAIGHT LINES. TEST AND PREPARE A REPORT INDICATING FULL OPERATION. MAKE REPAIRS TO SYSTEM UNTIL IT IS FULLY OPERATIONAL. TECHNOLOGY ITEMS WITH WHIPS SHALL BE SIMILARLY AND TYPICALLY ADDRESSED.
- CLEAN WINDOW THOROUGHLY. REMOVE DECALS, TAPE, SOIL, FOREIGN MATERIALS FROM GLAZING COMPLETE. MAINTAIN TINTING AND OBSCURING FILMS.
- PREP, PRIME AND PAINT ALL PREVIOUSLY PAINTED SURFACES, INCLUDING BUT NOT LIMITED: WALLS, WINDOW FRAMES, SASHES, AND MULLIONS, ELECTRICAL AND COMMUNICATIONS PANELS, JUNCTION BOXES AND PULL BOXES, FIXTURES, GRILLES AND CEILING PANELS.
- REPLACE WALL MOUNTED HEAT-PUMP GRILLS WITH NEW 626 (SILVER COLORED BRUSHED METAL FINISH) METAL GRILLES. CM AND DISTRICT TO APPROVE NSTALLATION OF NEW.
- CLEAN ALL EXPOSED BRICK PER SPECIFICATION TO REMOVE DIRT AND EFFLORESCENCE.
- RE-INSTALL FIRE EXTINGUISHER.
- PREP, PRIME, AND PAINT PLASTIC AND METAL WIREMOLD TO MATCH WALLS.
- CLEAN AND REINSTALL ELECTRICAL WALL PLATE. VERIFY AND COORDINATE CIRCUIT LABELING. REPLACE AND OR CORRECT AS NECESSARY.
- WHERE COLUMNS AND WALL HEAD FRAMES ARE EXPOSED, REPAINT WITH GLOSS BLACK PAINT.
- INCLUDE WALK OFF MATS AT EACH DOOR FROM EXTERIOR ON PATH OF TRAVEL.
- IN ALL ROOMS WITH SPIRIT PAINTING, MURALS, GRAPHICS, PROTECT THE GRAPHICS. USE REMOVABLE TAPE THAT WI NOT DAMAGE ARTWORK. FULLY COVER ALL PORTIONS OF THE GRAPHICS, INCLUDING BUT NOT LIMITED TO LOGS, SLOGANS, STRIPES, WRITING, AND SCRIPT. PROTECT IN PLACE.
- PROTECT ELEMENT IN PLACE
- 2x4 AND 2x2 LAY-IN ACOUSTIC TILE CEILING: REMOVE & REPLACE INDIVIDUAL DAMAGED TILES FROM GRID. GRID: PAINT CEILING GRID WITH GLOSS BRIGHT WHITE PAINT TO MATCH TILES. PROTECT SURROUNDING FINISHES AND DEVICES FROM OERSPRAY INCLUDING BUT NOT LIMITED TO WALLS, LIGHTING, WINDOWS, LOW VOLTAGE, FIRE ALARM, AND SECURITY DEVICES. COLOR AS SELECTED FROM SUBMITTALS BY CM.
- PROVIDE AND INSTALL CARPET TILE TO FLOOR AND RISERS. PROVIDE AND INSTALL CONTRASTING STRIP AT THE TOP OF EACH LEVEL CHANGE, FULL LENGTH OF RISER AND AT TOP AND BOTTOM OF ACCESS STAIRS EACH SIDE.


SHEET INDEX

GENERAL		(NO. OF DRAWINGS -)
T-1	COVER SHEET	
T-2	SHEET INDEX	
* DRAWINGS		
(NO. OF DRAWINGS -)		
A1-1	SITE PLAN	
A2-1	BUILDINGS J	
A2-2	BUILDINGS M	
A2-3	BUILDINGS F, G AND H	
A2-4	BUILDINGS C, D AND E	
A2-5	BUILDINGS A AND B	
A2-6	BUILDINGS A	
A2-7	BUILDINGS S	

PROJECT DIRECTORY

OWNER
 HACIENDA LA PUENTE UNIFIED SCHOOL DISTRICT
 1599 E. GALE AVENUE
 CITY OF INDUSTRY, CA 91745
 PHONE: (626) 933-1000

REFERENCE SYMBOLS



LOS ALTOS HIGH SCHOOL REFRESH

HACIENDA LA PUENTE UNIFIED SCHOOL DISTRICT
 15325 E. LOS ROBLES AVENUE
 HACIENDA HEIGHTS, CALIFORNIA 91744

owner

project number : 2023-24.08

Rev:	date:	description:
▲	1/12/24	ADDENDUM NO. 2

drawing title:
SHEET INDEX

drawing no.:
T-2

EXHIBIT 1

ABBREVIATIONS

&	AND	(E)	EXISTING	K	KIP (1000 LB)	R	RISER
∠	ANGLE	EA	EACH	KIT.	KITCHEN	RA.	RADIUS
@	AT	E.J.	EXPANSION JOINT	KO	KNOCKOUT	R.D.	ROOF DRAIN
⊕	CENTERLINE	ELEC.	ELECTRICAL	KVA	KILOVOLT AMPERE	RWD.	REWOOD
⊙	DIAMETER OR ROUND	ELEV.	ELEVATION	REF.	REFERENCE	REF.	REFRIGERATOR
#	NUMBER	EMER.	EMERGENCY	LAB.	LABORATORY	REG.	REGISTER
AB	ANCHOR BOLT	ENCL.	ENCLOSURE	LAM.	LAMINATED	REIN.	REINFORCING
AC	ASPHALTIC CONCRETE	ENG	ENGINEER	LAV.	LAVATORY	REQD.	REQUIRED
ACP	ACOUSTICAL PANEL	ENR	ENERGY	LOG	LANDING	RESIL.	RESILIENT
ACT	ACOUSTICAL TILE	EP	EPOXY ENAMEL	LL	LIVE LOAD	RET	RETURN
ACOUS	ACOUSTICAL	EQ.	EQUAL	LT	LIGHT	REV.	REVERSE
AD	AREA DRAIN	EQUP.	EQUIPMENT	LTF	LITHOLEUM TILE FLOORING	RFG	ROOFING
ADH	ADHESIVE	EST.	ESTIMATE	LTO	LIGHTING	RM.	ROOM
ADJ	ADJACENT	E.W.C.	ELECTRIC WATER COOLER	LVL	LEVEL	R.O.	ROUGH OPENING
AFF	ABOVE FINISH FLOOR	EW	ELECTRIC WATER HEATER	LVR	LOUVER	R.T.F.	RUBBER TILE FLOORING
AFP	ACCORDIAN FOLDING PARTITION	EKH	EXHAUST				
AGGR	AGGREGATE	EXIST.	EXISTING	MAINT	MAINTENANCE	S.B.	SPLASH BLOCK
ALT	ALTERNATE	EXP.	EXPANSION	MAN	MANUAL	S.C.	SOLID CORE
ALUM	ALUMINUM	EXPSD.	EXPOSED	MAS	MASONRY	SCHED.	SCHEDULE
AMP	AMPERE	EXT.	EXTERIOR	MATL.	MATERIAL	SCN	SOLID CORE NATURAL FINISH
ANOD	ANODIZED			MAX.	MAXIMUM	SCP	SOLID CORE PAINT FINISH
APPROX	APPROXIMATELY	F	FACTORY FINISH	MCC	MOTOR CONTROL CENTER	SCPL	SOLID CORE PLUM FINISH
ARCH	ARCHITECT	F.A.	FIRE ALARM	MECH.	MECHANICAL	S.D.	STORM DRAIN
ASB	ASBESTOS	FC	FOOTCANDLE	MED	MEDIUM	SECT.	SECTION
ASSY	ASSEMBLY	F.D.	FLOOR DRAIN	MEZZ	MEZZANINE	SF	SQUARE FOOT
		FDC	FIRE DEPARTMENT CONNECTION	MFR.	MANUFACTURER	SHT.	SHEET
BAT	BATTERY	FDN	FOUNDATION	MH	MANHOLE	SIM.	SIMILAR
BBB	BULLETIN BOARD	F.E.	FIRE EXTINGUISHER	MN.	MINIMUM	SLR	SEALER
BO	BOARD	F.E.C.	FIRE EXTINGUISHER CABINET	MIR	MIRROR	SPEC.	SPECIFICATIONS
BLDG	BUILDING	F.F.	FINISH FLOOR	MISC.	MISCELLANEOUS	SPLY	SUPPLY
BLDG	BUILDING	F.G.	FINISHED GRADE	MKR	MARKER	SQ	SQUARE
BLG	BLOWER	F.H.	FIRE HYDRANT	MTL.	METAL	S.S.K.	SEWER SINK
BLR	BOILER	FIN.	FINISH	MTD.	MOUNTED	SST.	STAINLESS STEEL
BLW	BELOW	F.L.	FLOW LINE	MUL.	MULLION	ST	STREET
BM	BEAM	FLASH.	FLASHING	MVB.	M/VALE	STAG	STAGGERED
BO	BOTTOM OF	FLR.	FLOOR			STC	SOUND TRANSMISSION CLASS
BRKR	BREAKER	FLUOR.	FLUORESCENT	(N)	NEW	STD.	STANDARD
BTU	BRITISH THERMAL UNIT	F.O.	FACE OF	NAT.	NATURAL	STL.	STEEL
BUR	BUILT UP ROOFING	F.O.C.	FACE OF CONCRETE	NEG	NEGATIVE	STN	STAIN FINISH
		F.O.F.	FACE OF FINISH	N.I.C.	NOT IN CONTRACT	STR	STOR
CAB	CABINET	F.O.M.	FACE OF MASONRY	NO.	NUMBER	STRUCT.	STRUCTURAL
CARP	CARPET	F.O.S.	FACE OF STUD	NOM.	NOMINAL	SURF	SURFACE
CAT	CATALOG	FPF	FOLDING PANEL PARTITION	N.T.S.	NOT TO SCALE	SUSP	SUSPENDED
CB	CATCH BASIN	FPW	FOLDING PANEL WOOD DOOR			SV	SHEET VINYL
CEM	CEMENT	F.R.	FIRE RETARDANT	O.A.	OVERALL	SWBD	SWITCHBOARD
CF	CURB FACE	F.R.A.	FIRE RATED ASSEMBLY	O.C.	ON CENTER	SWGR	SWITCHGEAR
CFM	CUBIC FEET PER MINUTE	F.R.P.	FIBERGLASS REINFORCED PANEL	O.D.	OUTSIDE DIAMETER	SWR	SEWER
CHBD	CHALKBOARD	F.S.	FLOOR SINK	O.F.	OVERFLOW DRAIN	SY	SYMBOL
CHEM	CHEMICAL	FT.	FOOT OR FEET	OPCI	OWNER FURNISHED-CONTRACTOR	SYS	SYSTEM
CHWR	CHILLED WATER RETURN	FTG.	FOOTING				
CHWS	CHILLED WATER SUPPLY	FURR.	FURRING	IFF	INSTALLED	T.	TREAD
CI	CAST IRON	FXTR	FIXTURE	OFD	OWNER FURNISHED-OWNER	T. & B	TOP AND BOTTOM
CIR	CIRCLE			INSTALLED		T. & G	TONGUE AND GROOVE
CJ	CONTROL JOINT	G.	GAS	OPNG.	OPENING	T.C	TOP OF CURB
CL	CENTERLINE	G.A.	GAGE	OPP.	OPPOSITE	TD	TRENCH DRAIN
CLG	CEILING	GALV.	GALVANIZED	OVHD	OVERHEAD	TECH	TECHNICAL
CLO	CLOSET	GB	GRAB BAR			TEL.	TELEPHONE
CLRM	CLASSROOM	G.I.	GALVANIZED IRON	PART.	PARTITION	TEMP.	TEMPERATURE
CLT	CERAMIC TILE	GL	GLASS	PB	PULL BOX	T.G.	TOP OF GRATE
CMU	CONCRETE MASONRY UNIT	GLULAM.	GLUE LAMINATED	PBD	PARTICLEBOARD	THK	THICK
CND	CONDUIT	GND.	GROUND	PC	PORTLAND CEMENT	THRES.	THRESHOLD
CO	CLEANOUT	GPM	GALLONS PER MINUTE	PD	PLANTER DRAIN	THRU	THROUGH
COL	COLUMN	GR.	GRADE	PERF	PERFORATED	T.BD	TACKBOARD
COMM	COMMUNICATION	GYP.	GYPSPUM	PERP	PERPENDICULAR	T.O.	TOP OF
COMP	COMPOSITION			PE	PAINT EGGSHELL	T.O.P.	TOP OF PARAPET
CONC	CONCRETE	H.B.	HOSE BIBB	PF	PAINT FLAT	TOT	TOTAL
CONF	CONFERENCE	HCN	HOLLOW CORE NATURAL FINISH	PG	PAINT GLOSS	T.P.	TOP OF PAVING
CONN	CONNECTION	HCP.	HOLLOW CORE PAINT FINISH	P.H.	PANIC HARDWARE	TRNSF.	TRANSFORMER
CONT	CONTINUOUS	HDBD.	HARDBOARD	PV	POST INDICATOR VALVE	TW	TOP OF WALL
CONTR	CONTRACTOR	HDR.	HEADER	P.L.	PROPERTY LINE	TYP.	TYPICAL
COORD	COORDINATE	HDW.	HARDWARE	PL.	PLATE		
CORR	CORRIDOR	HDWD.	HARDWOOD	P.LAM.	PLASTIC LAMINATE	UGND	UNDERGROUND
COV	COVER	HGT.	HEIGHT	PLAS.	PLASTER	UNFIN.	UNFINISHED
CP	CONTROL PANEL	H.M.	HOLLOW METAL	PLAT.	PLATFORM	U.N.O.	UNLESS NOTED OTHERWISE
CR	CONDENSATE RETURN	HORIZ	HORIZONTAL	PLBG	PLUMBING	U.O.S.	UNDERSIDE OF STRUCTURE
CSWK	CASEWORK	HP	HORSEPOWER	PLF	POUNDS PER LINEAR FOOT	URL	URNAL
CT	CERAMIC TILE	HR.	HOUR	PL.VVD.	PLYWOOD	UTL	UTILITY
CTSK	COUNTERSINK	HTG.	HEATING	PAL.	PANEL	V	VOLT
CTV	CABLE TELEVISION	HTWR	HOT WATER RETURN	POS	POSITIVE	VAC	VACUUM
CW	COLD WATER	HTWS	HOT WATER SUPPLY	PR	PAIR	VAV	VARIABLE AIR VOLUME
		HVAC	HEATING, VENTILATING, AIR CONDITIONING	PREFAB	PREFABRICATED	W.C.	WATER CLOSET
DBL	DOUBLE	HV	HEAVY	PREFIN	PREFINISHED	V.C.T.	VINYL COMPOSITION TILE
DEMO	DEMOLITION	HW	HOT WATER	PRELIM	PRELIMINARY	VERT.	VERTICAL
DEPT	DEPARTMENT			PROJ	PROJECT	VEST.	VESTIBULE
DET	DETAIL			PSF	POUNDS PER SQUARE FOOT	VFCV	VINYL FABRIC WALL COVERING
DF	DRINKING FOUNTAIN	ID.	INSIDE DIAMETER	PSG	PAINT SEMI-GLOSS	W	WATT
DG	DECOMPOSED GRANITE	IE	INVERT ELEVATION	PSI	POUNDS PER SQUARE INCH	W	WITH
DI	DIAMETER	INSUL	INSULATION	PVC	POLYVINYL CHLORIDE	W	WATER
DIM	DIMENSION	INT.	INTERIOR			W.D.	WOOD
DISP.	DISPENSER	INV.	INVERT	Q.T.	QUARRY TILE	WDW.	WINDOW
DIST.	DISTANCE	IWR	IRRIGATION WATER	QTY	QUANTITY	WSE	WAREHOUSE
DIV.	DIVISION	JAN.	JANITOR			WL	WIND LOAD
D.L.	DEAD LOAD	JCT.	JUNCTION			WLD	WELDED
DN.	DOWN	JOINT	JOINT			WP	WORKING POINT
DS.	DOWN SPOUT					WPG	WATERPROOFING
DWG.	DRAWING					WR	WATER RESISTANT
						W.SCT.	WAINSCOT
						WT	WEIGHT
						W.W.F.	WELDED WIRE FABRIC
						XPR	TRANSFORMER

GENERAL NOTES

- CONTRACTOR SHALL IDENTIFY, PHOTOGRAPH AND DOCUMENT ALL EXISTING ITEMS NOTED TO REMAIN AND SHALL VERIFY OPERABILITY, RECORD AND REPORT ANY DAMAGED SURFACES, EQUIPMENT, CABINETS, DOORS, LIGHTS OR ANY OTHER ITEMS TO BE RE-USED. CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR FINAL OPERABILITY AND FINISH OF ALL NEW OR RE-USED PRODUCTS OR MATERIALS IN THE FINAL INSTALLATION THAT IS NOT RECORDED AND IDENTIFIED AT THE BEGINNING OF THE JOB AND REPORTED TO THE CONSTRUCTION MANAGER IN WRITING.
- ALL EXISTING AND NEW SURFACES AT INTERIOR THAT ARE NORMALLY PAINTED, INCLUDING TRIM, DOOR AND WINDOW FRAMES NOT PRE-FINISHED SHALL BE PAINTED AS A PART OF THIS CONTRACT UNLESS SPECIFICALLY NOTED PREP, PRIME AND PAINT ALL (E) PLYWOOD/WOOD PANELS ON WALLS.
- WORK SHALL INCLUDE ALL NECESSARY DEMOLITION OF INCIDENTAL ITEMS WHICH ARE NOT PART OF THE NEW INSTALLATION. REMOVE ALL ABANDONED CONDUIT AND PIPE THAT IS NOT BEING REUSED IN THE NEW WORK.
- PROTECT ALL (E) FIRE ALARM, PA, INTRUSION EQUIPMENT, LIGHTING AND LIGHTING CONTROLS, CEILING, HVAC EQUIPMENT AND ALL RELATED CONDUITS IN PLACE. AFTER DEMOLITION OR CONSTRUCTION, CONTRACTOR SHALL TEST FIRE ALARM SYSTEM AND SATISFACTORILY RESTORE TO WORKING CONDITION TO MEET NFPA 72 REQUIREMENTS.
- DETAILS AND NOTES ARE TYPICAL FOR ALL RELATED CONDITIONS IN EACH ROOM WHETHER OR NOT SPECIFICALLY REFERENCED.
- THE CONTRACTOR SHALL REPAIR OR REPLACE ANY EXISTING CONSTRUCTION DAMAGED DURING THE WORK OF THIS CONTRACT
- PATCH, REPAIR, PRIME & PAINT AREAS WHERE REMOVAL OF MATERIAL, CABINETRY, ACCESSORIES, FIXTURES OR EQUIPMENT RESULTS IN UNFINISHED SURFACE, INCLUDING WALLS, FLOORS AND CEILING. REPAIR & FINISH SHALL MATCH (E) ADJACENT CONDITION.
- THE CONTRACTOR SHALL ASSUME THE REPLACEMENT OF 10% OF THE ACOUSTIC TILE IN EACH ROOM. REMOVE PROVIDE AND INSTALL NEW TILE PRIOR TO THE PAINTING OF CEILINGS AND OR WALLS.

DEMOLITION NOTES

- REMOVE, ROLL AND PROTECT FLAGS FROM DAMAGE STORE FOR REINSTALLATION ACCORDING TO THE U.S. FLAG CODE TITLE 4, CHAPTER 1.
- REMOVE AND SALVAGE ALL (E) TECHNOLOGY EQUIPMENT. LOW VOLTAGE DEVICES (THERMOSTAT), CLOCK AND ASSOCIATED MOUNTING HARDWARE, INCLUDING BUT NOT LIMITED TO FASTENERS, AND EXPANSION SHIELDS, LEAVING WALLS SMOOTH FLUSH AND UNINTERRUPTED ON THE SURFACE. RETAIN-STORE EQUIPMENT AND MOUNTING HARDWARE, GIVE DISTRICT FIRST RIGHT OF SALVAGE. DISPOSE OF ELEMENTS THAT THE DISTRICT REJECTS IN A LAWFUL MANNER.
- REMOVE AND SALVAGE EXISTING CURTAINS AND TRACK. ARRANGE FOR CURTAINS TO BE CLEANED STORE NEATLY AWAY FROM WORK ACTIVITIES UNTIL REINSTALLATION. CLEAN BLINDS AND OTHER WINDOW TREATMENTS, SIMILAR AND TYPICAL
- REMOVE, CLEAN AND SALVAGE FOR REINSTALLATION, COVER PLATES FROM SWITCH PLATES, OUTLETS, AND OTHER ELECTRICAL AND DATA BOXES IN WALLS AND FLOORS. TEST CONNECTIVITY IN POWER CIRCUITS, DATA AND OTHER LOW VOLTAGE SYSTEMS AND/OR CABEL FROM ABANDONED PLUGS. REMOVE WIRE AND OR CABLE FROM ABANDONED PLUGS AND/OR DROPS BACK TO PANEL BOX OR IDF.
- WHERE DATA (ABANDONED LOW VOLTAGE INCLUSIVE) AND/OR POWER HAS BEEN REMOVED, REMOVE ALL ASSOCIATED SURFACE MOUNTED BOXES, WIREMOLD, CEILING MOUNTING HARDWARE, ACCESSORIES, AND FASTENERS COMPLETELY. REMOVE OBSOLETE TELEPHONE RELATED INFRASTRUCTURE.
- REMOVE AND SALVAGE WALL MOUNTED WHITE BOARDS AND BULLETIN BOARDS. RETAIN BOARDS AND MOUNTING HARDWARE FOR REINSTALLATION.
- REMOVE ALL LIGHT FIXTURE BASES, FASTENERS, BRACKETS, DEVICES, (ASSOCIATED OR NOT ASSOCIATED WITH INSTALLED ELEMENTS) FROM THE FINISHED PLYWOOD PANELING, MASONRY AND PLASTER WALLS AND CEILING. REMOVE EXCESS MOLDING, BLOCKING BOARDS, HOOKS, STICKERS, CLIPS, TAPE, AND ANY HARDWARE. PRIOR TO PAINTING.
- CLEAN & REPAIR, FLOOR SLABS AFTER ABATEMENT AND FLOORING REMOVAL. PROVIDE AND INSTALL LEVELING COMPOUND TO FLOORS AS REQUIRED PRIOR TO INSTALLING FLOORING.
- PROTECT SECURITY SYSTEM WIRING. YOU MAY DISCONNECT, UN-INSTALL WIRES. SALVAGE WIRE AND CONTACTS AS NECESSARY. RETAIN PARTS AND NOTE LOCATION FOR EXACT REINSTALLATION AFTER PAINTING. ANY DAMAGE SHALL RESULT IN REPAIR AT CONTRACTOR'S COST. RECOMMEND PRE-TESTING ALL SYSTEMS BEFORE DEMOLITION OR SALVAGE.
- REMOVE (E) GREEN BOARD CHALKBOARDS (MAY BE UNDER-BEHIND WHITE BOARDS) COMPLETELY. CONSULT HAZ-MAT REMOVAL SPECIFICATIONS FOR THE HANDLING OF ASBESTOS CONTAINING MATERIALS.
- REMOVE (E) FLOOR TILES. CONSULT HAZ-MAT REMOVAL SPECIFICATIONS FOR THE HANDLING OF ASBESTOS CONTAINING MATERIALS. "SAND-BLAST" (E) SLAB CONCRETE TO REMOVE ALL TYPES OF ADHESIVES REGARDLESS OF ASBESTOS CONTENT.
- PROTECT BRONZE FLOOR BOXES DURING DEMOLITION ACTIVITIES. CLEAN AND POLISH FLOOR PLATE COVERS BEFORE RETURNING TO DISTRICT.
- REMOVE TAPE, TACKS, HOOKS, AND ANY OTHER HARDWARE FROM (E) CEILING TILES, WALLS AND GLAZING TYP.
- REMOVE (E) SUPPLY AND RETURN AIR GRILLES AT WALL MOUNTED HEAT PUMP UNITS, REPLACE WITH NEW.
- REMOVE ALL INTERIOR SIGNAGE. INCLUDE MOUNTING MECHANISMS, SCREWS, SHIELDS, AND ADHESIVE. REPLACE ANY DAMAGED SIGNAGE.
- REMOVE AND SALVAGE FOR RE-INSTALLATION: SOAP, PAPER TOWEL, AND HAND SANITIZER DISPENSERS.
- NOT USED
- REMOVE AND SALVAGE LEARNING AIDS SUCH AS MAPS, MOUNTING BRACKETS, ARTWORK, AND POSTERS. RE-INSTALL AS INSTRUCTED.
- REMOVE, SALVAGE AND STORE FIRE EXTINGUISHER WITH MOUNTING HARDWARE FOR RE-INSTALLATION.
- REMOVE CARPET, FLOORING, AND ADHESIVE COMPLETE, LEAVE FLOOR CLEAN READY FOR NEW WORK. MEDIA BLAST TO REMOVE ADHESIVE, DO NOT USE DETERGENT.
- REMOVE RUBBER WALL BASE AND ADHESIVE COMPLETELY.
- PROTECT FIRE ALARM DEVICES AND SYSTEMS DEVICES TYPICAL, INCLUDING BUT NOT LIMITED TO: MOTION SENSORS, SMOKE DETECTORS, STROBES. MASK BEFORE PAINTING, MEDIA BLASTING, OR USE OF CHEMICALS THAT COULD SET OFF, ACTIVATE OR DAMAGE THE SYSTEMS.
- CONTRACTOR IS RESPONSIBLE FOR ALL WORK ASSOCIATED WITH THE WORK SCOPE WHETHER SPECIFICALLY NOTED AND/OR ASSOCIATED BY NECESSITY OF THE SPECIFIC IDENTIFIED WORK SCOPE. THESE NOTES ARE CONSIDERED TYPICAL.
- REMOVE (E) BASE CABINETS COMPLETELY, INCLUDING FASTENERS AND ANCHORS. SEE CONST. NOTES FOR FLOOR PREP. AND REPAIR.

CONSTRUCTION NOTES

- REINSTALL SALVAGED TECHNOLOGY INDICATED BY DISTRICT.
- REINSTALL CURTAIN TRACK AND CLEANED CURTAINS. REMOVE WRINKLES AND CREASES CAUSED BY STORAGE. PATCH AND REPAIR FABRIC DAMAGE. REPLACE DAMAGED HANGERS, HOOKS, LOOPS AND REPAIR GROMETS AS NECESSARY TO RESTORE TO OPERATIONAL, AND RE-INSTALL.
- REINSTALL LIGHTING BASES, ELECTRICAL AND DATA PLATE COVERS. CONFIRM LABELED CIRCUITS WITH INSTALL LOCATIONS. PROVIDE AND INSTALL LABELS ON MISSING OR ILLEGIBLE LABELS.
- PATCH AND FILL HOLES, DIVOTS, DENTS AND DEPRESSIONS IN WALL SURFACES FROM PRIOR DAMAGE, REMOVE FASTENER AND WIRES. PREP, PRIOR TO APPLICATION OF PRIMER AND PAINT. SEE SPEC.
- PROTECT DEVICES, BOXES, LIGHTING, AND WIRE MOLD FROM PAINT. PREPARE SURFACES AND APPLY PAINT PER SPECIFICATIONS ACCORDING TO MATERIAL SPECIFICATIONS.
- PREP AND PAINT WALLS IN COLOR 1 INDICATED USING THE PROCESS SPECIFIED. SEE SPEC.
- PREP AND PAINT WALLS IN COLOR 2 INDICATED USING THE PROCESS SPECIFIED. SEE SPEC.
- PREP AND PAINT DOORS IN COLOR 3 INDICATED USING THE PROCESS SPECIFIED. REMOVE ALL HARDWARE INCLUDING BUT NOT LIMITED TO HANDLES, KNOBS, ROSES, ESCUTCHEONS, CLOSERS, COVER PLATES, KICK PLATES, SWEEPS, LATCH PLATES, PANIC DEVICES AND SIGNAGE PRIOR TO PREP WORK. REINSTALL ALL AFTER PAINTING.
- PREP AND PAINT FRAMES IN COLORS 3 INDICATED USING THE PROCESS SPECIFIED.
- PREP, PRIME, AND PAINT WINDOWS INCLUDING TRIMS, FRAMES, SASHES, CASEMENTS, AND ALL PARTS OF WINDOWS EXCLUDING GLAZING. REMOVE ANY NEW PAINT FROM GLAZING AND OTHER UNINTENDED SURFACES.
- PREP AND PAINT CEILING IN COLOR INDICATED USING THE PROCESS SPECIFIED.
- PRIOR TO REINSTALLATION, CLEAN WHITEBOARDS ACCORDING TO THE MANUFACTURERS RECOMMENDATIONS ON WRITING SURFACE AND PEN RAILS. REINSTALL THE DRY ERASE-WHITE BOARDS IN THE APPROXIMATE LOCATIONS FROM WHERE THEY WERE REMOVED. ADDRESS THE BULLETIN BOARDS SIMILARLY, BUT PREP, PRIME AND PAINT THE VINYL SURFACE WITH COLOR SELECTED BY DISTRICT.
- IN AREAS THAT ARE FINISHED WITH STAINED AND VARNISHED PLYWOOD WALL PANELS, SAND, PREP, PRIME AND PAINT. SEE SPEC.
- THOROUGHLY CLEAN ALL PLASTIC WIRE MOLD COVERS WITH MILD DETERGENT AND WARM WATER. USE CARE NOT TO DAMAGE. LET DRY COMPLETELY BEFORE REINSTALLATION. PROTECT FROM PAINT. REPLACE DAMAGED SECTIONS OF WIRE MOLD WITH NEW. MATCH SIZE, COLOR, PROFILE AND CONFIGURATION WITH EXISTING. REPLACE DAMAGED ELECTRICAL PLATES FOR PLUGS, OUTLETS, SWITCHES, COVER PLATES AND COMMUNICATIONS PORTS. WHERE ELEMENTS, PARTS, TRANSITIONS AND PIECES ARE MISSING IN (E) WIREMOLD REPLACE WITH NEW PARTS. VERIFY CIRCUITS AND LABEL INTERIOR OF COVER PLATE.
- REMOVE BLASTING MEDIA AND DUST FROM ALL SURFACES IN EACH ROOM PRIOR TO THE START OF PAINTING.
- PROVIDE AND INSTALL LUXURY VINYL TILE PLANKS LONG-WISE BETWEEN NON-WINDOW WALLS. CAREFULLY FIT FLOORING AROUND WALL AND (E) FLOOR AND WALL ELEMENTS.
- PROVIDE AND INSTALL TOPSET BASE AT ALL WALLS AND AT TOE KICKS OF ALL CASEWORK. MATCH HEIGHT WITH ORIGINAL, REPLACE WITH SAME. CONTRACTOR SHALL CONFIRM HEIGHT AT CASEWORK. DO NOT HAND CUT TALL TOPSET DOWN TO SIZE.
- RE-ATTACH SECURITY SYSTEM WIRING AND CONTACT IN NEAT, STRAIGHT LINES. TEST AND PREPARE A REPORT INDICATING FULL OPERATION. MAKE REPAIRS TO SYSTEM UNTIL IT IS FULLY OPERATIONAL. TECHNOLOGY ITEMS WITH WHIPS SHALL BE SIMILARLY AND TYPICALLY ADDRESSED.
- CLEAN WINDOW THOROUGHLY. REMOVE DECALS, TAPE, SOIL, FOREIGN MATERIALS FROM GLAZING COMPLETE. MAINTAIN TINTING AND OBSCURING FILMS.
- PREP, PRIME AND PAINT ALL PREVIOUSLY PAINTED SURFACES, INCLUDING BUT NOT LIMITED: WALLS, WINDOW FRAMES, SASHES, AND MULLIONS, ELECTRICAL AND COMMUNICATIONS PANELS, JUNCTION BOXES AND PULL BOXES, FIXTURES, GRILLES AND CEILING PANELS.
- REPLACE WALL MOUNTED HEAT-PUMP GRILLS WITH NEW 626 (SILVER COLORED BRUSHED METAL FINISH) METAL GRILLES. CM AND DISTRICT TO APPROVE NSTALLATION OF NEW.
- CLEAN ALL EXPOSED BRICK PER SPECIFICATION TO REMOVE DIRT AND EFFLORESCENCE.
- RE-INSTALL FIRE EXTINGUISHER.
- PREP, PRIME, AND PAINT PLASTIC AND METAL WIREMOLD TO MATCH WALLS.
- CLEAN AND REINSTALL ELECTRICAL WALL PLATE. VERIFY AND COORDINATE CIRCUIT LABELING. REPLACE AND OR CORRECT AS NECESSARY.
- WHERE COLUMNS AND WALL HEAD FRAMES ARE EXPOSED, REPAINT WITH GLOSS BLACK PAINT.
- INCLUDE WALK OFF MATS AT EACH DOOR FROM EXTERIOR ON PATH OF TRAVEL.
- IN ALL ROOMS WITH "SPIRIT PAINTING", "MURALS", "GRAPHICS", PROTECT THE GRAPHICS. USE REMOVABLE TAPE THAT WILL NOT DAMAGE ARTWORK. FULLY COVER ALL PORTIONS OF THE GRAPHICS, INCLUDING BUT NOT LIMITED TO LOGS, SLOGANS, STRIPES, WRITING, AND SCRIPT. PROTECT IN PLACE.
- PROTECT ELEMENT IN PLACE
- 2X4 AND 2X2 LAY-IN ACOUSTIC TILE CEILING: REMOVE & REPLACE INDIVIDUAL DAMAGED TILES FROM GRID. GRID: PAINT CEILING GRID WITH GLOSS BRIGHT WHITE PAINT TO MATCH TILES. PROTECT SURROUNDING FINISHES AND DEVICES FROM OVERSPRAY INCLUDING BUT NOT LIMITED TO WALLS, LIGHTING, WINDOWS, LOW VOLTAGE, FIRE ALARM, AND SECURITY DEVICES. COLOR AS SELECTED FROM SUBMITTALS BY CM.
- PROVIDE AND INSTALL CARPET TILE TO FLOOR AND RISERS. PROVIDE AND INSTALL CONTRASTING STRIP AT THE TOP OF EACH LEVEL CHANGE, FULL LENGTH OF RISER AND AT TOP AND BOTTOM OF ACCESS STAIRS EACH SIDE.

SHEET INDEX

T-1	COVER SHEET
T-2	SHEET INDEX
AS-1	OVERALL CAMPUS SITE PLAN
A-1	BUILDING F,H,P,T
A-2	BUILDING A
A-3	BUILDING B
A-4	BUILDING D
A-5	BUILDING G
A-6	BUILDING C
A-7	BUILDING E,S, POOL EQUIP.

PROJECT DIRECTORY

OWNER
HACIENDA LA PUENTE UNIFIED SCHOOL DISTRICT
1999 E. GALE AVENUE
CITY OF INDUSTRY, CA 91745
PHONE: (626) 933-1000

CONSTRUCTION NOTES

- REINSTALL SALVAGED TECHNOLOGY INDICATED BY DISTRICT.
- REINSTALL CURTAIN TRACK AND CLEANED CURTAINS. REMOVE WRINKLES AND CREASES CAUSED BY STORAGE. PATCH AND REPAIR FABRIC DAMAGE. REPLACE DAMAGED HANGERS, HOOKS, LOOPS AND REPAIR GROMETS AS NECESSARY TO RESTORE TO OPERATIONAL, AND RE-INSTALL.
- REINSTALL LIGHTING BASES, ELECTRICAL AND DATA PLATE COVERS. CONFIRM LABELED CIRCUITS WITH INSTALL LOCATIONS. PROVIDE AND INSTALL LABELS ON MISSING OR ILLEGIBLE LABELS.
- PATCH AND FILL HOLES, DIVOTS, DENTS AND DEPRESSIONS IN WALL SURFACES FROM PRIOR DAMAGE, REMOVE FASTENER AND WIRES. PREP, PRIOR TO APPLICATION OF PRIMER AND PAINT. SEE SPEC.
- PROTECT DEVICES, BOXES, LIGHTING, AND WIRE MOLD FROM PAINT. PREPARE SURFACES AND APPLY PAINT PER SPECIFICATIONS ACCORDING TO MATERIAL SPECIFICATIONS.
- PREP AND PAINT WALLS IN COLOR 1 INDICATED USING THE PROCESS SPECIFIED. SEE SPEC.
- PREP AND PAINT WALLS IN COLOR 2 INDICATED USING THE PROCESS SPECIFIED. SEE SPEC.
- PREP AND PAINT DOORS IN COLOR 3 INDICATED USING THE PROCESS SPECIFIED. REMOVE ALL HARDWARE INCLUDING BUT NOT LIMITED TO HANDLES, KNOBS, ROSES, ESCUTCHEONS, CLOSERS, COVER PLATES, KICK PLATES, SWEEPS, LATCH PLATES, PANIC DEVICES AND SIGNAGE PRIOR TO PREP WORK. REINSTALL ALL AFTER PAINTING.
- PREP AND PAINT FRAMES IN COLORS 3 INDICATED USING THE PROCESS SPECIFIED.
- PREP, PRIME, AND PAINT WINDOWS INCLUDING TRIMS, FRAMES, SASHES, CASEMENTS, AND ALL PARTS OF WINDOWS EXCLUDING GLAZING. REMOVE ANY NEW PAINT FROM GLAZING AND OTHER UNINTENDED SURFACES.
- PREP AND PAINT CEILING IN COLOR INDICATED USING THE PROCESS SPECIFIED.
- PRIOR TO REINSTALLATION, CLEAN WHITEBOARDS ACCORDING TO THE MANUFACTURERS RECOMMENDATIONS ON WRITING SURFACE AND PEN RAILS. REINSTALL THE DRY ERASE-WHITE BOARDS IN THE APPROXIMATE LOCATIONS FROM WHERE THEY WERE REMOVED. ADDRESS THE BULLETIN BOARDS SIMILARLY, BUT PREP, PRIME AND PAINT THE VINYL SURFACE WITH COLOR SELECTED BY DISTRICT.
- IN AREAS THAT ARE FINISHED WITH STAINED AND VARNISHED PLYWOOD WALL PANELS, SAND, PREP, PRIME AND PAINT. SEE SPEC.
- THOROUGHLY CLEAN ALL PLASTIC WIRE MOLD COVERS WITH MILD DETERGENT AND WARM WATER. USE CARE NOT TO DAMAGE. LET DRY COMPLETELY BEFORE REINSTALLATION. PROTECT FROM PAINT. REPLACE DAMAGED SECTIONS OF WIRE MOLD WITH NEW. MATCH SIZE, COLOR, PROFILE AND CONFIGURATION WITH EXISTING. REPLACE DAMAGED ELECTRICAL PLATES FOR PLUGS, OUTLETS, SWITCHES, COVER PLATES AND COMMUNICATIONS PORTS. WHERE ELEMENTS, PARTS, TRANSITIONS AND PIECES ARE MISSING IN (E) WIREMOLD REPLACE WITH NEW PARTS. VERIFY CIRCUITS AND LABEL INTERIOR OF COVER PLATE.
- REMOVE BLASTING MEDIA AND DUST FROM ALL SURFACES IN EACH ROOM PRIOR TO THE START OF PAINTING.
- PROVIDE AND INSTALL LUXURY VINYL TILE PLANKS LONG-WISE BETWEEN NON-WINDOW WALLS. CAREFULLY FIT FLOORING AROUND WALL AND (E) FLOOR AND WALL ELEMENTS.
- PROVIDE AND INSTALL TOPSET BASE AT ALL WALLS AND AT TOE KICKS OF ALL CASEWORK. MATCH HEIGHT WITH ORIGINAL, REPLACE WITH SAME. CONTRACTOR SHALL CONFIRM HEIGHT AT CASEWORK. DO NOT HAND CUT TALL TOPSET DOWN TO SIZE.
- RE-ATTACH SECURITY SYSTEM WIRING AND CONTACT IN NEAT, STRAIGHT LINES. TEST AND PREPARE A REPORT INDICATING FULL OPERATION. MAKE REPAIRS TO SYSTEM UNTIL IT IS FULLY OPERATIONAL. TECHNOLOGY ITEMS WITH WHIPS SHALL BE SIMILARLY AND TYPICALLY ADDRESSED.
- CLEAN WINDOW THOROUGHLY. REMOVE DECALS, TAPE, SOIL, FOREIGN MATERIALS FROM GLAZING COMPLETE. MAINTAIN TINTING AND OBSCURING FILMS.
- PREP, PRIME AND PAINT ALL PREVIOUSLY PAINTED SURFACES, INCLUDING BUT NOT LIMITED: WALLS, WINDOW FRAMES, SASHES, AND MULLIONS, ELECTRICAL AND COMMUNICATIONS PANELS, JUNCTION BOXES AND PULL BOXES, FIXTURES, GRILLES AND CEILING PANELS.
- REPLACE WALL MOUNTED HEAT-PUMP GRILLS WITH NEW 626 (SILVER COLORED BRUSHED METAL FINISH) METAL GRILLES. CM AND DISTRICT TO APPROVE NSTALLATION OF NEW.
- CLEAN ALL EXPOSED BRICK PER SPECIFICATION TO REMOVE DIRT AND EFFLORESCENCE.
- RE-INSTALL FIRE EXTINGUISHER.
- PREP, PRIME, AND PAINT PLASTIC AND METAL WIREMOLD TO MATCH WALLS.
- CLEAN AND REINSTALL ELECTRICAL WALL PLATE. VERIFY AND COORDINATE CIRCUIT LABELING. REPLACE AND OR CORRECT AS NECESSARY.
- WHERE COLUMNS AND WALL HEAD FRAMES ARE EXPOSED, REPAINT WITH GLOSS BLACK PAINT.
- INCLUDE WALK OFF MATS AT EACH DOOR FROM EXTERIOR ON PATH OF TRAVEL.
- IN ALL ROOMS WITH "SPIRIT PAINTING", "MURALS", "GRAPHICS", PROTECT THE GRAPHICS. USE REMOVABLE TAPE THAT WILL NOT DAMAGE ARTWORK. FULLY COVER ALL PORTIONS OF THE GRAPHICS, INCLUDING BUT NOT LIMITED TO LOGS, SLOGANS, STRIPES, WRITING, AND SCRIPT. PROTECT IN PLACE.
- PROTECT ELEMENT IN PLACE
- 2X4 AND 2X2 LAY-IN ACOUSTIC TILE CEILING: REMOVE & REPLACE INDIVIDUAL DAMAGED TILES FROM GRID. GRID: PAINT CEILING GRID WITH GLOSS BRIGHT WHITE PAINT TO MATCH TILES. PROTECT SURROUNDING FINISHES AND DEVICES FROM OVERSPRAY INCLUDING BUT NOT LIMITED TO WALLS, LIGHTING, WINDOWS, LOW VOLTAGE, FIRE ALARM, AND SECURITY DEVICES. COLOR AS SELECTED FROM SUBMITTALS BY CM.
- PROVIDE AND INSTALL CARPET TILE TO FLOOR AND RISERS. PROVIDE AND INSTALL CONTRASTING STRIP AT THE TOP OF EACH LEVEL CHANGE, FULL LENGTH OF RISER AND AT TOP AND BOTTOM OF ACCESS STAIRS EACH SIDE.

GLEN A. WILSON HIGH SCHOOL

