



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779  
T: 631.580.3191 • F: 631.580.3195 • W: [envirohealth.org](http://envirohealth.org)

January 15, 2024

Mr. Ray Renda  
Edgemont UFSD  
300 White Oak Lane  
Scarsdale, NY 10583

Re: **Lead in Drinking Water Sampling & Analysis 2023-2025**

Dear Mr. Renda,

On January 12, 2024, Envirosience Consultants performed limited water sampling events at the Edgemont Union Free School District. Samples were collected at the Edgemont Jr./Sr. High School for newly installed bottle fillers / water fountains.

First draw samples were collected in wide-mouth 250 milliliter containers during the early morning, prior to any water sources being used. The samples were transported to New York Environmental Laboratory and analyzed for lead concentration. The current limit for lead in drinking water is 5 parts per billion (ppb). There were no exceedances.

The following locations were sampled and passed:

- Building A: Hall by Room A17 Right - BF / WF (FS 1001)
- Building E: Vestibule by Bathrooms - BF / WF (FS 1007)

Please see the attached lab reports for results. These locations have satisfied the requirement for the 2023 -2025 Lead in Drinking Water sampling period.

Should you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Shannon Gallagher". The signature is written in a cursive, flowing style.

Shannon Gallagher  
Environmental Inspector

**Laboratory Report**  
NYE Report #: 2400203-28153

January 15, 2024

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Edgemont UFSD; Edgemont Jr./sr. High School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on January 12, 2024. New York Environmental analyzed the samples on January 15, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director

Date Collected:	12 Jan 2024
Date Received:	12 Jan 2024
Date Analyzed:	15 Jan 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240112J002	1	Bldg A: Hall by Rm A17 - Right (WF)	0.001	<0.001	mg/L	
240112J003	2	Bldg A: Hall by Rm A17 - Right (BF)	0.001	<0.001	mg/L	
240112J004	3	Bldg LGI: Vestibule by BRs - Right (WF)	0.001	<0.001	mg/L	
240112J005	4	Bldg LGI: Vestibule by BRs - Right (BF)	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation