



October 13, 2023

Gary Bowers
NB-Sullivan BOCES
15 Sullivan Ave Ste 1W
Liberty, NY 12754

Project Location: SC BOCES Main Campus
Project Number: SC BOCES Main Campus
Laboratory Work Order Number: 23I3952

Enclosed are results of analyses for samples received by the laboratory on September 29, 2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Rose M. Cusack".

Project Manager



NB-Sullivan BOCES
15 Sullivan Ave Ste 1W
Liberty, NY 12754
ATTN: Gary Bowers

REPORT DATE: 10/13/2023

PURCHASE ORDER NUMBER:

PROJECT NUMBER: SC BOCES Main Campus

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 2313952

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: SC BOCES Main Campus

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
M1	2313952-01	Drinking Water		EPA 200.8 Rev 5.4	
M2	2313952-02	Drinking Water		EPA 200.8 Rev 5.4	
M8	2313952-03	Drinking Water		EPA 200.8 Rev 5.4	
M9	2313952-04	Drinking Water		EPA 200.8 Rev 5.4	
M10	2313952-05	Drinking Water		EPA 200.8 Rev 5.4	
M11	2313952-06	Drinking Water		EPA 200.8 Rev 5.4	
M12	2313952-07	Drinking Water		EPA 200.8 Rev 5.4	
M13	2313952-08	Drinking Water		EPA 200.8 Rev 5.4	
M14	2313952-09	Drinking Water		EPA 200.8 Rev 5.4	
M15	2313952-10	Drinking Water		EPA 200.8 Rev 5.4	
M16	2313952-11	Drinking Water		EPA 200.8 Rev 5.4	
M17	2313952-12	Drinking Water		EPA 200.8 Rev 5.4	
M47	2313952-13	Drinking Water		EPA 200.8 Rev 5.4	
M48	2313952-14	Drinking Water		EPA 200.8 Rev 5.4	
M49	2313952-15	Drinking Water		EPA 200.8 Rev 5.4	
M50	2313952-16	Drinking Water		EPA 200.8 Rev 5.4	
M51	2313952-17	Drinking Water		EPA 200.8 Rev 5.4	
M52	2313952-18	Drinking Water		EPA 200.8 Rev 5.4	
M55	2313952-19	Drinking Water		EPA 200.8 Rev 5.4	
M56	2313952-20	Drinking Water		EPA 200.8 Rev 5.4	
M59	2313952-21	Drinking Water		EPA 200.8 Rev 5.4	
M60	2313952-22	Drinking Water		EPA 200.8 Rev 5.4	
M61	2313952-23	Drinking Water		EPA 200.8 Rev 5.4	
M62	2313952-24	Drinking Water		EPA 200.8 Rev 5.4	
M63	2313952-25	Drinking Water		EPA 200.8 Rev 5.4	
M64	2313952-26	Drinking Water		EPA 200.8 Rev 5.4	
M65	2313952-27	Drinking Water		EPA 200.8 Rev 5.4	
M66	2313952-28	Drinking Water		EPA 200.8 Rev 5.4	
M67	2313952-29	Drinking Water		EPA 200.8 Rev 5.4	
M68	2313952-30	Drinking Water		EPA 200.8 Rev 5.4	
M69	2313952-31	Drinking Water		EPA 200.8 Rev 5.4	
M70	2313952-32	Drinking Water		EPA 200.8 Rev 5.4	
M71	2313952-33	Drinking Water		EPA 200.8 Rev 5.4	
M72	2313952-34	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.
I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M1

Sampled: 9/29/2023 06:05

Sample ID: 2313952-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:25	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M2

Sampled: 9/29/2023 06:07

Sample ID: 2313952-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:35	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M8

Sampled: 9/29/2023 06:12

Sample ID: 2313952-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:38	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M9

Sampled: 9/29/2023 06:13

Sample ID: 2313952-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:40	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M10

Sampled: 9/29/2023 06:15

Sample ID: 2313952-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:42	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M11

Sampled: 9/29/2023 06:17

Sample ID: 2313952-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:45	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: MI2

Sampled: 9/29/2023 06:19

Sample ID: 2313952-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:52	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M13

Sampled: 9/29/2023 06:21

Sample ID: 2313952-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
									Prepared	Analyzed	
Lead	ND	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:55	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M14

Sampled: 9/29/2023 06:23

Sample ID: 2313952-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
									Prepared	Analyzed	
Lead	ND	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:57	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M15

Sampled: 9/29/2023 06:25

Sample ID: 2313952-10

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 18:59	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M16

Sampled: 9/29/2023 06:27

Sample ID: 2313952-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:02	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M17

Sampled: 9/29/2023 06:28

Sample ID: 2313952-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
									Prepared	Analyzed	
Lead	ND	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:07	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M47

Sampled: 9/29/2023 06:35

Sample ID: 2313952-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:09	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M48

Sampled: 9/29/2023 06:36

Sample ID: 2313952-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:11	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M49

Sampled: 9/29/2023 06:37

Sample ID: 2313952-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:14	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M50

Sampled: 9/29/2023 06:40

Sample ID: 2313952-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:21	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M51

Sampled: 9/29/2023 06:41

Sample ID: 2313952-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
									Prepared	Analyzed	
Lead	ND	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:24	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M52

Sampled: 9/29/2023 06:41

Sample ID: 2313952-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:26	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M55

Sampled: 9/29/2023 06:46

Sample ID: 2313952-19

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:28	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M56

Sampled: 9/29/2023 06:47

Sample ID: 2313952-20

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:31	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M59

Sampled: 9/29/2023 06:50

Sample ID: 2313952-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:33	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M60

Sampled: 9/29/2023 06:51

Sample ID: 2313952-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:43	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M61

Sampled: 9/29/2023 06:52

Sample ID: 2313952-23

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:50	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M62

Sampled: 9/29/2023 06:55

Sample ID: 2313952-24

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:53	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M63

Sampled: 9/29/2023 06:56

Sample ID: 2313952-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:55	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M64

Sampled: 9/29/2023 06:58

Sample ID: 2313952-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 19:58	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M65

Sampled: 9/29/2023 06:59

Sample ID: 2313952-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:00	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M66

Sampled: 9/29/2023 07:04

Sample ID: 2313952-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:02	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M67

Sampled: 9/29/2023 07:05

Sample ID: 2313952-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:05	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M68

Sampled: 9/29/2023 07:06

Sample ID: 2313952-30

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:07	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M69

Sampled: 9/29/2023 07:07

Sample ID: 2313952-31

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:10	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M70

Sampled: 9/29/2023 07:12

Sample ID: 2313952-32

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:20	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M71

Sampled: 9/29/2023 07:13

Sample ID: 2313952-33

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:22	EMC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: SC BOCES Main Campus

Sample Description:

Work Order: 2313952

Date Received: 9/29/2023

Field Sample #: M72

Sampled: 9/29/2023 07:14

Sample ID: 2313952-34

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/11/23	10/12/23 20:24	EMC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level

Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.

No results have been blank subtracted unless specified in the case narrative section.

Sample Condition Upon Receipt Form (SCUR)

Project # 23I3952
Client: Sullivan Bocas

Date and Initials of person:
 Examining contents: PR
 Label: PR
 Deliver to location: PR
 pH: PR

Thermometer Used: IRG4 Date: 9/29 Time: 1107 Initials: PR

State of Origin: NY

Cooler #1 Temp: °C 19.2 (Visual) 0.2 (Correction Factor) _____ (Actual) Samples on ice, cooling process has begun

Courier: Fed Ex UPS USPS Client Commercial Pace Other _____

Shipping Method: First Overnight Priority Overnight Standard Overnight Ground
 Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Ice: Wet Blue Melted None

Packing Material: Bubble Wrap Bubble Bags None Other _____

Samples were collected by Pace employee Yes No N/A

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sampler Name and Signature on COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Preservation Information: Preservative: _____ Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: Vials, Microbiology, O&G, Metals	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Headspace in VOA Vials? (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	

Additional Login Comments:

Client notification/ Resolution
 Person Contacted: _____ Date/Time: _____
 Comments/Resolution: _____

Sample #	Date	Time	AREA	250 ml HNO3	Analysis Requested
M1	9/29/23	0605	RPEC Tin Barn Utility Sink	250ml HNO3	Lead
M2	9/29/23	0607	RPEC Tin Barn Hand Sink in Counter	250ml HNO3	Lead
M8	9/29/23	0612	RPEC A7 ALC Hand Sink	250ml HNO3	Lead
M9	9/29/23	0613	RPEC A10 Class Sink	250ml HNO3	Lead
M10	9/29/23	0615	RPEC B Wing Nurse Hand Sink	250ml HNO3	Lead
M11	9/29/23	0617	RPEC B7 Class Sink	250ml HNO3	Lead
M12	9/29/23	0619	RPEC B11 Class Sink	250ml HNO3	Lead
M13	9/29/23	0621	RPEC B12 Class Sink	250ml HNO3	Lead
M14	9/29/23	0623	RPEC B14 Class Sink	250ml HNO3	Lead
M15	9/29/23	0625	RPEC B15 Class Sink	250ml HNO3	Lead
M16	9/29/23	0627	RPEC B18 Class Sink	250ml HNO3	Lead
M17	9/29/23	0628	RPEC B20 Class Sink	250ml HNO3	Lead
M47	9/29/23	0635	RPEC D Wing Nail Drying Room Sink	250ml HNO3	Lead
M48	9/29/23	0636	RPEC Cosmo 1 Class Sink	250ml HNO3	Lead
M49	9/29/23	0637	RPEC Cosmo II Class Sink	250ml HNO3	Lead
M50	9/29/23	0640	RPEC F Bld Room 6 Class Sink	250ml HNO3	Lead
M51	9/29/23	0641	RPEC F Bld Room 4 Class Sink	250ml HNO3	Lead
M52	9/29/23	0641	RPEC F Bld Kitchen Sink	250ml HNO3	Lead
M55	9/29/23	0646	RPEC Main Lobby Bottle Fill	250ml HNO3	Lead
M56	9/29/23	0647	RPEC Main Lobby Bubbler	250ml HNO3	Lead
M59	9/29/23	0650	RPEC Spec Ed Cafeteria Bottle Fill	250ml HNO3	Lead
M60	9/29/23	0651	RPEC Spec Ed Cafeteria Bubbler	250ml HNO3	Lead
M61	9/29/23	0652	RPEC C Wing Bottle Fill	250ml HNO3	Lead
M62	9/29/23	0655	RPEC D Wing Bottle Fill	250ml HNO3	Lead
M63	9/29/23	0656	RPEC D Wing Bubbler	250ml HNO3	Lead
M64	9/29/23	0658	RPEC F Bld Bottle Fill	250ml HNO3	Lead
M65	9/29/23	0659	RPEC F Bld Bubbler	250ml HNO3	Lead
M66	9/29/23	0704	RPEC G Bld Bubbler Right	250ml HNO3	Lead
M67	9/29/23	0705	RPEC G Bld Bubbler Center	250ml HNO3	Lead
M68	9/29/23	0706	RPEC G Bld Bottle Fill	250ml HNO3	Lead
M69	9/29/23	0707	RPEC G Bld Bubbler Left	250ml HNO3	Lead
M70	9/29/23	0712	RPEC H Bld Bottle Fill	250ml HNO3	Lead
M71	9/29/23	0713	RPEC H Bld Bubbler	250ml HNO3	Lead
M72	9/29/23	0714	RPEC H Bld Early Childhood Sink	250ml HNO3	Lead



23I3952