



Troy Schools District

RFP #2324-12

BP#1A – Elementary School Playgrounds Phase #1 –

Addendum #2

January 18, 2024

Content Included in this Addendum:

Cover Page (1 Page)

Barton Malow Write Up (1 Page)

Pre-Bid Walk Sign-In Sheet (1 Page)

Troy Elementary Playground Schedule (5 Pages)

TOTAL PAGES: 8 Pages



January 18, 2024

Troy School District – RFP #2324-12
BP #1A – Elementary School Playgrounds Phase #1

Addendum #1 Bidder Clarifications

A. General Clarifications

- Attached preliminary schedule – please provide feedback with your bid regarding durations in the schedule and comments.

B. Clarifications and Additions to Work Scopes

- Earthwork
 - There is no paving required within the earthwork scope of work.
- Landscaping
 - There is no fencing required within the landscape scope of work.
 - Spec section 32 9200 turfs and grasses is the responsibility of this contractor.
 - Provide non-straw erosion blankets on all new seeding around playground area.
 - Restoration around jogging track does not require erosion blankets.

C. RFI Responses

Q: To confirm the RFI posted, topsoil and seeding of restoration are under the sitework category not the landscaping category?

A: Topsoil and seeding of restoration are under the landscape scope of work.

Q: Does that include the topsoil and seeding around the jogging track that was initially the asphalt bid category's responsibility? Also, there is nothing on irrigation. Confirming there is no irrigation.

A: Yes, that includes the topsoil and seeding around the jogging track. Correct, there is no irrigation.

Q: Is there irrigation on any of the schools?

A: There is no irrigation at any of the schools.

