



Technical Report

prepared for:

Parkway School
c/o Greenwich Public Schools, 290 Greenwich Ave
Greenwich, CT 06830
Attention: Elisa Gonzalez

Report Date: 01/17/2024
Client Project ID: PWS ID CT0570212-Distribution
York Project (SDG) No.: N4A0282

CT Cert. No. PH-0800



New York Cert. No. 11706

56 Church Hill Road #2



Newtown, CT 06470

www.YORKLAB.com

(203) 270-9973

FAX (203) 270-3348

ClientServices@yorklab.com

Report Date: 01/17/2024
Client Project ID: PWS ID CT0570212-Distribution
York Project (SDG) No.: N4A0282

Parkway School
c/o Greenwich Public Schools, 290 Greenwich Ave
Greenwich, CT 06830
Attention: Elisa Gonzalez

Purpose and Results

This report contains the analytical data for the sample(s) identified on the attached chain-of-custody received in our laboratory on January 10, 2024 and listed below. The project was identified as your project: **PWS ID CT0570212-Distribution**.

The analyses were conducted utilizing appropriate EPA, Standard Methods, and ASTM methods as detailed in the data summary tables.

All samples were received in proper condition meeting the customary acceptance requirements for environmental samples except those indicated under the Sample and Analysis Qualifiers section of this report.

All analyses met the method and laboratory standard operating procedure requirements except as indicated by any data flags, the meaning of which are explained in the Sample and Data Qualifiers Relating to This Work Order section of this report and case narrative if applicable.

Please contact Client Services at 203-270-9973 with any questions regarding this report.

<u>York Sample ID</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Collected</u>	<u>Date Received</u>
N4A0282-01	PS017 - Teachers Lounge Sink	Drinking Water	01/10/2024	01/10/2024



Sample Information

<u>Client Sample ID:</u> PS017 - Teachers Lounge Sink		<u>York Sample ID:</u> N4A0282-01		
<u>York Project (SDG) No.</u>	<u>Client Project ID</u>	<u>Matrix</u>	<u>Collection Date/Time</u>	<u>Date Received</u>
N4A0282	PWS ID CT0570212-Distribution	Drinking Water	January 10, 2024 12:40 pm	01/10/2024
Field Analyses:		Log-in/Sample Notes:		

Results

Parameter	Result	Units	Qualifier	MCL	Reference Method	Date/Time Prepared	Date/Time Analyzed	Analyst
Alkalinity, total	90	mg/L		-	SM 21-23 2320B (-97)	01/11/2024 14:33	01/11/2024 14:33	MR
						Certifications: CTDOH-PH-0800,NELAC-NY11706		



Definitions and Other Information

B Analyte is found in the associated analysis batch blank. For volatiles, methylene chloride and acetone are common lab contaminants.

***** Analyte is not certified or the state of the samples origination does not offer certification for the Analyte.

MCL The Maximum Contaminant Level (MCL) is the maximum concentration of a chemical that is allowed in public drinking water systems. The MCL is established by the U.S. Environmental Protection Agency (EPA). Some states have MCLs that are equal to or less than the Federally established MCL. The listed MCL value reflects the MCL established by the State where the sample was taken.

General Notes for N4A0282

1. The RLs and MDLs (Reporting Limit and Method Detection Limit respectively) reported are adjusted for any dilution necessary due to the levels of target and/or non-target analytes and matrix interference. The RL(REPORTING LIMIT) is based upon the lowest standard utilized for the calibration where applicable.
2. Samples are retained for a period of thirty days after submittal of report, unless other arrangements are made.
3. York's liability for the above data is limited to the dollar value paid to York for the referenced project.
4. This report shall not be reproduced without the written approval of York Analytical Laboratories, Inc.
5. All analyses conducted met method or Laboratory SOP requirements. See the Sample and Data Qualifiers Section for further information.
6. It is noted that no analyses reported herein were subcontracted to another laboratory, unless noted in the report.
7. This report reflects results that relate only to the samples submitted on the attached chain-of-custody form(s) received by York.

Approved By:

Charles Morrow
Technical Director

Date: January 17, 2024

