

Stober Elementary School - Sampled 6/30/16				Resampled* 5/1/18	
SampleNumber	Description	Lead Result	Units	Lead Result	Units
43200-128-S1	Food Services - Food Prep Sink	4.1	ppb	5.8	ppb
43200-128-S2	Food Services - Hose Connection Spigot	11.5	ppb		
43200-128-S3	Food Services - Hand Washing Sink	1.2	ppb		
43200-128-S4	Food Services - Sanitize/Rinse Sink	11.0	ppb		
43200-128-S5	Food Services - Wash Sink	7.3	ppb		
43200-124H-DFL	Hallway Drinking Fountain Near Art Room/Left	0.2	ppb	0.2	ppb
43200-124H-DFR	Hallway Drinking Fountain Near Art Room/Right	0.2	ppb	0.1	ppb
43200-ART-S	Sink in Art Room	2.1	ppb		
43200-139H-DFL	Hallway Drinking Fountain outside of Gym/Left	1.1	ppb	1.1	ppb
43200-139H-DFR	Hallway Drinking Fountain outside of Gym/Right	1.3	ppb	1.0	ppb
43200-116-S	Sink in Teacher's Lounge	0.7	ppb	0.7	ppb
43200-113H-DFL	Hallway Drinking Fountain Near Kindergarten Classroom 111/Left	0.5	ppb	0.5	ppb
43200-113H-DFR	Hallway Drinking Fountain Near Kindergarten Classroom 111/Right	0.5	ppb	0.4	ppb
43200-111-S	Sink in Kindergarten Classroom 111	2.9	ppb		
43200-111-SWB	Sink with Bubbler in Kindergarten Classroom 111	1.0	ppb	4.3	ppb
43200-108-S	Sink in Clinic room 108	0.7	ppb	1.0	ppb
43200-27-S	Sink in Classroom 27	2.4	ppb		
43200-27-SWB	Sink with Bubbler in Classroom 27	0.7	ppb	2.0	ppb
43200-25-S	Sink in Classroom 25	14.3	ppb		
43200-25-SWB	Sink with Bubbler in Classroom 25	3.8	ppb	2.2	ppb
43200-28-S	Sink in Library Workroom	16.9**	ppb		
43200-23-S	Sink in Classroom 23	1.3	ppb		
43200-23-SWB	Sink with Bubbler in Classroom 23	0.8	ppb	1.6	ppb
43200-21-S	Sink in Classroom 21	2.2	ppb	1.3	ppb
43200-21-SWB	Sink with Bubbler in Classroom 21	0.8	ppb	0.3	ppb
43200-20-S	Sink in classroom 20	1.9	ppb		
43200-20-SWB	Sink with Bubbler in Classroom 20	1.3	ppb	2.8	ppb
43200-220H-DFL	Hallway Drinking Fountain near Classroom 22/Left	0.4	ppb	0.2	ppb
43200-220H-DFR	Hallway Drinking Fountain near Classroom 22/Right	0.3	ppb		
43200-22-S	Sink in Classroom 22	2.5	ppb		
43200-22-SWB	Sink with Bubbler in Classroom 22	1.2	ppb	2.2	ppb
43200-203H-DFL	Hallway Drinking Fountain near Classroom 25/Left	1.4	ppb	0.8	ppb
43200-203H-DFR	Hallway Drinking Fountain near Classroom 25/Right	2.2	ppb	1.1	ppb
43200-34-S	Sink in classroom 34	0.5	ppb		
43200-34-SWB	Sink with Bubbler in Classroom 34	0.3	ppb	0.1	ppb
43200-33-S	Sink in Classroom 33	5.0	ppb		
43200-33-SWB	Sink with Bubbler in Classroom 33	0.2	ppb	0.2	ppb
43200-32-S	Sink in Classroom 32	1.1	ppb		
43200-32-SWB	Sink with Bubbler in Classroom 32	0.5	ppb	0.9	ppb
43200-24-S	Sink in Classroom 24	8.3	ppb		
43200-24-SWB	Sink with Bubbler in Classroom 24	1.6	ppb	2.9	ppb
43200-26-S	Sink in Classroom 26	3.2	ppb		
43200-26-SWB	Sink with Bubbler in Classroom 26	1.1	ppb	3.6	ppb
43200-REC-115-DF	Drinking Fountain in Temporary Classroom REC-115	4.2	ppb	0.9	ppb

* Resampling results were from samples collected on 5/1/18 as part of an ongoing five-year rotation of lead testing.

** This fixture is signed "Do Not Drink, Hand Washing Only"