Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 06/01/2017
Received: 05/31/2017
Sampled By: Jared Plahn
Work Order: 7151007

CLIENT
St. Helen's School District
Attn: Jared Plahn
474 N 16th St
St. Helens OR, 97051
Phone: (503) 397-4677

Project:
Project # : N/A
Sample Type :
PO # : 172021

Sampling Location:
Sample Matrix: Water

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
7151007-01	**Sample Name:** Col. City Kitchen **Sampled:** 5/31/17 6:26						**Matrix:** Water
†*Lead*	1030	EPA 200.9	11	ppb	2	20 ppb	06/01/17 10:03

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.