ANALYSIS REPORT

Analysis by: ORELAP ID#: OR100013

Alexin Analytical LABORATORIES, INC. Professional Laboratory Services

CLIENT

St. Helens School District
Attn: Jared P.
301 St Helens St.
St. Helens, Oregon 97051

Date Reported: 10/31/08
Date Sampled: 10/16/08
Date Received: 10/17/08
Job Number: **08291/01-14**
Page: 1 of 1

P.O. #: MA0928
Project: Annual Test
Sampled By: JP
Sample Type: Drinking Water

phone: 503-397-4677

Lab Number	Client ID	Total Lead	Total Copper
		mg/L;ppm	mg/L;ppm
08291/01	Deer Island	**0.027***	**0.41**
08291/02	Columbia City Gym	**ND**	**0.48**
08291/03	Columbia City Lower	**ND**	**0.61**
08291/04	Mid School Boys Locker Room	**ND**	**ND**
08291/05	Mid School Office	**0.015**	**ND**
08291/06	District Office	**ND**	**0.20**
08291/07	Lewis & Clark Lower	**ND**	**0.13**
08291/08	Lewis & Clark Gym	**ND**	**0.26**
08291/09	McBride Gym	**ND**	**0.21**
08291/10	McBride B-Pod	**ND**	**0.24**
08291/11	High School West Hall	**ND**	**0.37**
08291/12	High School West "B"	**ND**	**0.18**
08291/13	Bachelor Flat Kitchen	**0.006**	**0.08**
08291/14	#18 SAC Annex	**ND**	**0.22**
	Method:	EPA 200.9	SM3111B
	Laboratory Reporting Limit:	0.002	0.05
	EPA Action Limit:	0.015	1.3
	Date Analyzed:	10/21-30/08	10/28/08

ND = None Detected

All procedures utilized for this report conform to NELAC standards.

This report reflects the results for these samples only.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

* Exceeds EPA limit for this sample analysis.

Approved by:

Scott Dickman
Inorganic Technical Director