ANALYSIS REPORT

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
Analysis by: ORELAP ID #: OR100013

CLIENT

St. Helen's School Dist. #502
301 St. Helen's St.
St. Helen's, OR 97051

phone: 503-397-4677
fax: 503-397-7280

Date Reported: 3/16/04
Date Sampled: 3/9/04
Date Received: 3/11/04
Job Number: **04071/42-53**
Page: 1 of 1

Sample Type: Drinking water
Sampling Location: St. Helen's School Dist.

Lab Number	Sample ID	Results Lead mg / L; ppm	Results Copper mg / L; ppm
04071/42	Mid school fountain outside office	**ND**	**0.45**
04071/43	Mid school fountain Boys Locker Rm.	**0.002**	**0.03**
04071/44	Col. City fountain outside gym door	**ND**	**0.38**
04071/45	Col. City fountain lower level	**0.001**	**1.97**
04071/46	Deer Island fountain	**0.001**	**0.05**
04071/47	High school fountain West hall "A"	**ND**	**0.20**
04071/48	High school fountain West "B"	**0.002**	**0.64**
04071/49	McBride fountain Gym	**ND**	**0.70**
04071/50	McBride fountain B-Pod	**ND**	**0.70**
04071/51	Lewis & Clark fountain Gym	**ND**	**0.82**
04071/52	Lewis & Clark fountain Lower Level	**ND**	**0.22**
04071/53	Yankton fountain Primary	**0.007**	**ND**
	Laboratory Reporting Limit:	0.001	0.01
	Method:	200.9	3111B

ND = None Detected

The action level for lead is set at 0.015 mg/L and 1.3 mg/L for copper.

All procedures utilized for this report conform to NELAC standards.

Approved By:

Scott Dickman
Inorganic Technical Director