

2024 Columbia City Elementary Radon Testing Results - Initial Short Term

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result	Variance	Analysis Date	%Moist.
7408104	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Cafeteria	2024-1	1	2.4	0.4	2024-01-16	4.3
7408105	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Cafeteria	2024-1	1	2.4	0.5	2024-01-16	4.3
7408106	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Gym	2024-1	1	2.2	0.5	2024-01-16	4.3
7408107	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Gym	2024-1	1	2.3	0.5	2024-01-16	4.4
7408108	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Gym	2024-1	1	2.5	0.5	2024-01-16	4.3
7408109	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Gym	2024-1	1	2.4	0.5	2024-01-16	4.3
7408110	2024-01-08	6:00 am	2024-01-11	6:00 am	69	COLUMBIA CITY ELEM.	MAIN	Spike	2024-1	1	33.2	2.7	2024-01-16	12.1
7408111	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Reception	2024-1	1	1	0.4	2024-01-16	3.6
7408112	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Staff Lounge	2024-1	1	0.8	0.4	2024-01-16	5.1
7408113	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Staff Lounge	2024-1	1	< 0.3	0.4	2024-01-16	4.3
7408114	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Office 1	2024-1	1	1.1	0.4	2024-01-16	4.3
7408115	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Office 2	2024-1	1	0.6	0.4	2024-01-16	4.4
7408116	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Office 3	2024-1	1	0.6	0.4	2024-01-16	4.3
7408117	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Basement 1	2024-1	0	3.2	0.5	2024-01-16	3.6
7408118	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Basement 1	2024-1	0	3.8	0.6	2024-01-16	3.6
7408119	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Office 4	2024-1	1	8.3	0.7	2024-01-16	4.3
7408120	2024-01-08	6:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Office 5	2024-1	1	5.9	0.7	2024-01-16	3.6
7408121	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 29	2024-1	1	8.2	0.8	2024-01-16	4.4
7408122	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 27	2024-1	1	3.7	0.5	2024-01-16	4.3
7408123	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 26	2024-1	1	3.8	0.6	2024-01-16	4.3
7408124	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 26	2024-1	1	< 0.3	0.5	2024-01-16	2.8
7408125	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 14	2024-1	1	1	0.4	2024-01-16	5.1
7408126	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 14	2024-1	1	0.5	0.4	2024-01-16	4.3
7408127	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 12	2024-1	1	1	0.4	2024-01-16	5.1
7408128	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room10	2024-1	1	< 0.3	0.5	2024-01-16	5.1
7408129	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 11	2024-1	1	0.8	0.4	2024-01-16	5.1
7408130	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 13	2024-1	1	2.9	0.5	2024-01-16	3.6
7408131	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	MAIN	Room 15	2024-1	1	2.2	0.5	2024-01-16	4.3
7408132	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	PORTABLE	Portable 1	2024-1	1	< 0.3	0.4	2024-01-16	4.4
7408133	2024-01-08	7:00 am	2024-01-11	7:00 am	69	COLUMBIA CITY ELEM.	PORTABLE	Portable 2	2024-1	1	< 0.3	0.4	2024-01-16	4.4