
Radon Inspection Report

Test Location:

St Helens High School

Test For:**Inspected By:**

12839 NE Airport Way
Portland, OR 97230
503-421-4813

Bldg. Type: Educational

Type: Post-Mitigation

Test Result: Pass

Overall Average:

0.4 pCi/l

EPA Average:

0.4 pCi/l

Test Device Details:

Serial Number: 241778005
Model Number: 1028XP
Last Calibration: 05/06/2019
Next Calibration: 05/06/2020
Cal-Factors: 2.83
Motion Error: Yes

Test Site Condition:

Structure Type: High School
Mitigation Sys: Installed and Active

Test Summary:


| | | | | |
|---|---|--|--------------------------|------------------------------------|
| <u>CRM Location:</u> Center counter | <u>Start:</u> 10/20/2019 11:30 AM | <u>Stop:</u> 10/25/2019 11:30 AM | <u>Interval:</u> 1 hr | <u>Duration:</u> 120 hr |
| *First 4 hrs of data excluded Radon Concentration: | <u>Min:</u> 0.0 | <u>Max:</u> 2.5 | <u>Average:</u> 0.4 | <u>Measurement Units:</u> pCi/l |

Comments:

Lic/Cert Signature

Inspection Report Date: 10/25/2019

Radon Inspection Chart



Test Result: Pass

Test Location: ,

Inspection Report Date: 10/25/2019

Test Table

* Data from first 4 hours excluded from EPA calculations

| <u>Date/Time</u> | <u>Radon(pCi/l)</u> | <u>Flags</u> |
|-------------------|---------------------|--------------|
| 10/20/19 12:30 PM | 0.7 | - |
| 10/20/19 01:30 PM | 0.4 | - |
| 10/20/19 02:30 PM | 0.0 | - |
| 10/20/19 03:30 PM | 1.8 | - |
| 10/20/19 04:30 PM | 0.4 | - |
| 10/20/19 05:30 PM | 0.7 | - |
| 10/20/19 06:30 PM | 0.0 | - |
| 10/20/19 07:30 PM | 0.4 | - |
| 10/20/19 08:30 PM | 0.0 | - |
| 10/20/19 09:30 PM | 0.0 | - |
| 10/20/19 10:30 PM | 0.0 | - |
| 10/20/19 11:30 PM | 0.7 | - |
| 10/21/19 12:30 AM | 0.4 | - |
| 10/21/19 01:30 AM | 0.7 | - |
| 10/21/19 02:30 AM | 0.7 | - |
| 10/21/19 03:30 AM | 0.7 | - |
| 10/21/19 04:30 AM | 0.0 | - |
| 10/21/19 05:30 AM | 0.0 | - |
| 10/21/19 06:30 AM | 0.4 | - |
| 10/21/19 07:30 AM | 0.4 | - |
| 10/21/19 08:30 AM | 0.4 | - |
| 10/21/19 09:30 AM | 0.0 | - |
| 10/21/19 10:30 AM | 0.4 | - |
| 10/21/19 11:30 AM | 0.7 | - |
| 10/21/19 12:30 PM | 0.0 | - |
| 10/21/19 01:30 PM | 0.0 | - |
| 10/21/19 02:30 PM | 0.4 | - |
| 10/21/19 03:30 PM | 0.4 | - |
| 10/21/19 04:30 PM | 0.0 | - |
| 10/21/19 05:30 PM | 0.7 | - |
| 10/21/19 06:30 PM | 0.0 | - |
| 10/21/19 07:30 PM | 0.0 | - |
| 10/21/19 08:30 PM | 0.4 | - |
| 10/21/19 09:30 PM | 0.4 | - |
| 10/21/19 10:30 PM | 0.0 | M |
| 10/21/19 11:30 PM | 0.0 | - |
| 10/22/19 12:30 AM | 0.4 | - |
| 10/22/19 01:30 AM | 0.7 | - |
| 10/22/19 02:30 AM | 0.0 | - |
| 10/22/19 03:30 AM | 0.0 | - |
| 10/22/19 04:30 AM | 0.4 | - |
| 10/22/19 05:30 AM | 0.0 | - |
| 10/22/19 06:30 AM | 0.0 | - |
| 10/22/19 07:30 AM | 0.0 | - |

Test Result: Pass

Test Location: ,

Inspection Report Date: 10/25/2019

Test Table

* Data from first 4 hours excluded from EPA calculations

| Date/Time | Radon(pCi/l) | Flags |
|-------------------|--------------|-------|
| 10/22/19 08:30 AM | 0.4 | - |
| 10/22/19 09:30 AM | 0.0 | M |
| 10/22/19 10:30 AM | 0.0 | - |
| 10/22/19 11:30 AM | 0.7 | - |
| 10/22/19 12:30 PM | 0.4 | - |
| 10/22/19 01:30 PM | 0.0 | - |
| 10/22/19 02:30 PM | 0.4 | - |
| 10/22/19 03:30 PM | 0.0 | - |
| 10/22/19 04:30 PM | 0.0 | - |
| 10/22/19 05:30 PM | 0.7 | - |
| 10/22/19 06:30 PM | 0.7 | - |
| 10/22/19 07:30 PM | 0.7 | - |
| 10/22/19 08:30 PM | 0.7 | - |
| 10/22/19 09:30 PM | 0.4 | - |
| 10/22/19 10:30 PM | 0.0 | - |
| 10/22/19 11:30 PM | 0.4 | - |
| 10/23/19 12:30 AM | 0.7 | - |
| 10/23/19 01:30 AM | 0.7 | - |
| 10/23/19 02:30 AM | 0.0 | - |
| 10/23/19 03:30 AM | 0.4 | - |
| 10/23/19 04:30 AM | 0.0 | - |
| 10/23/19 05:30 AM | 0.4 | - |
| 10/23/19 06:30 AM | 0.0 | - |
| 10/23/19 07:30 AM | 2.5 | - |
| 10/23/19 08:30 AM | 1.4 | M |
| 10/23/19 09:30 AM | 2.5 | - |
| 10/23/19 10:30 AM | 1.1 | - |
| 10/23/19 11:30 AM | 0.7 | - |
| 10/23/19 12:30 PM | 0.0 | - |
| 10/23/19 01:30 PM | 0.0 | - |
| 10/23/19 02:30 PM | 0.0 | - |
| 10/23/19 03:30 PM | 0.4 | - |
| 10/23/19 04:30 PM | 0.0 | - |
| 10/23/19 05:30 PM | 0.0 | - |
| 10/23/19 06:30 PM | 0.0 | - |
| 10/23/19 07:30 PM | 0.0 | - |
| 10/23/19 08:30 PM | 0.0 | - |
| 10/23/19 09:30 PM | 0.4 | - |
| 10/23/19 10:30 PM | 0.7 | - |
| 10/23/19 11:30 PM | 0.0 | - |
| 10/24/19 12:30 AM | 0.4 | - |
| 10/24/19 01:30 AM | 0.7 | - |
| 10/24/19 02:30 AM | 1.1 | - |
| 10/24/19 03:30 AM | 0.7 | - |

Test Result: Pass

Test Location: ,

Inspection Report Date: 10/25/2019

Test Table

* Data from first 4 hours excluded from EPA calculations

| Date/Time | Radon(pCi/l) | Flags |
|-------------------|--------------|-------|
| 10/24/19 04:30 AM | 0.4 | - |
| 10/24/19 05:30 AM | 1.1 | - |
| 10/24/19 06:30 AM | 0.7 | - |
| 10/24/19 07:30 AM | 0.4 | - |
| 10/24/19 08:30 AM | 0.0 | M |
| 10/24/19 09:30 AM | 1.1 | - |
| 10/24/19 10:30 AM | 1.8 | M |
| 10/24/19 11:30 AM | 0.7 | - |
| 10/24/19 12:30 PM | 0.4 | - |
| 10/24/19 01:30 PM | 0.0 | - |
| 10/24/19 02:30 PM | 0.7 | M |
| 10/24/19 03:30 PM | 0.7 | - |
| 10/24/19 04:30 PM | 0.4 | - |
| 10/24/19 05:30 PM | 0.7 | - |
| 10/24/19 06:30 PM | 0.0 | - |
| 10/24/19 07:30 PM | 0.0 | - |
| 10/24/19 08:30 PM | 0.4 | - |
| 10/24/19 09:30 PM | 0.7 | - |
| 10/24/19 10:30 PM | 0.0 | - |
| 10/24/19 11:30 PM | 0.4 | - |
| 10/25/19 12:30 AM | 0.0 | - |
| 10/25/19 01:30 AM | 1.1 | - |
| 10/25/19 02:30 AM | 0.7 | - |
| 10/25/19 03:30 AM | 1.1 | - |
| 10/25/19 04:30 AM | 0.0 | - |
| 10/25/19 05:30 AM | 0.7 | - |
| 10/25/19 06:30 AM | 0.7 | - |
| 10/25/19 07:30 AM | 1.8 | - |
| 10/25/19 08:30 AM | 0.0 | - |
| 10/25/19 09:30 AM | 0.7 | - |
| 10/25/19 10:30 AM | 0.4 | - |
| 10/25/19 11:30 AM | 0.7 | - |

Test Result: Pass

Test Location: ,

Inspection Report Date: 10/25/2019