

2019 Plymouth High School Radon Testing Results - Initial Short Term

Kit Number	Start Date	Start Time	End Date	End Time	Temp	Building	Room	Project ID	Floor	Result	Variance	Analysis Date	%Moist.
9306453	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Reception	2019-11	1	< 0.3	0.3	2019-11-22	5.3
9306454	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Office	2019-11	1	< 0.3	0.3	2019-11-22	6
9306455	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Staff Lounge	2019-11	1	< 0.3	0.3	2019-11-22	5.2
9306456	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Multi-Purpose	2019-11	1	< 0.3	0.3	2019-11-22	5.9
9306457	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Multi-Purpose	2019-11	1	0.5	0.3	2019-11-22	5.9
9306458	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Media Center	2019-11	1	< 0.3	0.3	2019-11-22	5.9
9306459	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Media Center	2019-11	1	< 0.3	0.3	2019-11-22	3.6
9306460	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 100	2019-11	1	< 0.3	0.3	2019-11-22	5.9
9306461	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	SPIKE	2019-11	1	18.3	1.1	2019-11-22	6.6
9306462	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 101	2019-11	1	0.5	0.3	2019-11-22	5.1
9306463	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 103	2019-11	1	0.8	0.3	2019-11-22	6.7
9306464	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 102	2019-11	1	< 0.3	0.3	2019-11-22	6.7
9306465	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 102	2019-11	1	< 0.3	0.3	2019-11-22	6.5
9306466	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 104	2019-11	1	0.5	0.3	2019-11-22	6.7
9306467	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 105	2019-11	1	< 0.3	0.3	2019-11-22	5.1
9306468	2019-11-18	10:00 am	2019-11-21	12:00 pm	69	PLYMOUTH HS	Room 105	2019-11	1	0.7	0.3	2019-11-22	5.2