MIDLAND PUBLIC SHOOLS

600 E. Carpenter Street Midland, MI 48640



TRANSPORTATION BUILDING - AHU/RTU REPLACEMENT

DATE: 01/22/2024

ISSUANCE: BIDS/PERMITS

MECHANICAL:

MO.OTB MECHANICAL GENERAL INFORMATION

M1.1TB MECHANICAL PLANS — TRANSPORTATION BUILDING
M1.2TB MECHANICAL ROOF PLANS — TRANSPORTATION BUILDING

ELECTRICAL:

EO.OTB ELECTRICAL GENERAL INFORMATION


E1.1TB ELECTRICAL PLANS — TRANSPORTATION BUILDING
E1.2TB ELECTRICAL ROOF PLANS — TRANSPORTATION BUILDING

MEP ENGINEERS:



4000 W. Eleven Mile Road Berkley, MI 48072 Phone 248.399.1900 Fax 248.399.1901 www.sesnet.com © 2023 SES, INC. SES Project # 23 0939 01

LOCATION: MIDLAND PUBLIC SCHOOLS TRANSPORTATION BUILDING 410 E. Hines Road Midland, MI 48640



MAP IMAGE

ABBREV.	DESCRIPTION
AAV	AUTOMATIC AIR VENT / AIR ADMITTANCE VALVE
AD	ACCESS DOOR
AE	AIR EXTRACTOR
AFF	ABOVE FINISHED FLOOR
APD	AIR PRESSURE DROP
ASR	AUTOMATIC SPRINKLER RISER
BFP	BACKFLOW PREVENTER
BHP	BRAKE HORSEPOWER
BOD	BOTTOM OF DUCT
BTU	BRITISH THERMAL UNIT
BTUH	BRITISH THERMAL UNITS PER HOUR
BWV	BACKWATER VALVE
CAP	CAPACITY
CAV	CONSTANT AIR VOLUME
CFH	CUBIC FEET PER HOUR
CFM	CUBIC FEET PER MINUTE
CIRC	CIRCULATING
CLG	COOLING
CO	CLEAN OUT
CONT	CONTINUATION OR CONTINUED
CONV	CONVECTOR
CUH	CABINET UNIT HEATER
CV	CONTROL VALVE
DB DEG	DRY BULB TEMPERATURE DEGREES
DDC	DIRECT DIGITAL CONTROL
DN	DOWN
DTC	DRAIN TILE CONNECTION
DWH	DOMESTIC WATER HEATER
(E)	EXISTING
EA/EXH	EXHAUST AIR
EAT	ENTERING AIR TEMPERATURE
EDB	ENTERING DRY BULB TEMPERATURE
EF	EXHAUST FAN
EJ	EXPANSION JOINT
EL	ELEVATION
ELECT	ELECTRICAL
EMS	ENERGY MANAGEMENT SYSTEM
ESP	EXTERNAL STATIC PRESSURE
EWB	ENTERING WET BULB TEMPERATURE
EWC	ELECTRIC WATER COOLER
• F	DEGREES FAHRENHEIT
FA	FACE AREA (COIL) / FREE AREA (LOUVER)
FC	FLEXIBLE CONNECTION
FD	FLOOR DRAIN
FDC	FIRE DEPARTMENT CONNECTION
FH	FIRE HYDRANT
FHC	FIRE HOSE CABINET
FHR	FIRE HOSE RACK
FHV	FIRE HOSE VALVE
FLA	FULL LOAD AMPS
FLR	FLOOR
FPM	FEET PER MINUTE
FFD	FUNNEL FLOOR DRAIN
FFE	FINISHED FLOOR ELEVATION
FS	FLOOR SINK
FT	FEET
FURN	FURNISHED
FV	FACE VELOCITY
FVC	FIRE VALVE CABINET
GAL	GALLON
GPH	GALLONS PER HOUR
GPM	GALLONS PER MINUTE
НВ	HOSE BIBB
НО	HUB OUTLET
	1105 001221

HR HTG HYD HZ ID IE IN INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA MECH	HOUR HEATING HYDRANT HERTZ INSIDE DIAMETER INVERT ELEVATION INCHES INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL MANUFACTURER
HYD HZ ID IE IN INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	HYDRANT HERTZ INSIDE DIAMETER INVERT ELEVATION INCHES INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
HZ ID IE IN INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INSIDE DIAMETER INVERT ELEVATION INCHES INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
ID IE IN INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INSIDE DIAMETER INVERT ELEVATION INCHES INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
IE IN INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INVERT ELEVATION INCHES INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY
IN INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INCHES INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
INST INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INSTALLED INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY
INV ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INVERT INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
ISP IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INTERNAL STATIC PRESSURE INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
IW KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	INDIRECT WASTE KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
KW LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	KILOWATT LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
LAT LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	LEAVING AIR TEMPERATURE LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY
LAV LBS/HR LDB LRA LWB MAV MAX MBH MCA	LAVATORY POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
LBS/HR LDB LRA LWB MAV MAX MBH MCA	POUNDS PER HOUR LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
LDB LRA LWB MAV MAX MBH MCA	LEAVING DRY BULB TEMPERATURE LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
LRA LWB MAV MAX MBH MCA	LOCKED ROTOR AMPS LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
LWB MAV MAX MBH MCA	LEAVING WET BULB TEMPERATURE MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
MAX MBH MCA	MANUAL AIR VENT MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
MAX MBH MCA	MAXIMUM 1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
MBH MCA	1000 BRITISH THERMAL UNITS PER HOUR MINIMUM CIRCUIT AMPACITY MECHANICAL
MCA	MINIMUM CIRCUIT AMPACITY MECHANICAL
	MECHANICAL
MECH	
MED	MANUFACTURER
MFR MH	MANHOLE
MIN	MINIMUM
MISC	MISCELLANEOUS
MOD	MOTOR OPERATED DAMPER (AUTOMATIC)
MOP	MAXIMUM OVER—CURRENT PROTECTION
N.C.	NOISE CRITERIA
NIC	NOT IN CONTRACT
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
NOM	NOMINAL
OA	OUTSIDE AIR
OBD	OPPOSED BLADE DAMPER
ос	ON CENTER / CENTER TO CENTER
OD	OUTSIDE DIAMETER
OED	OPEN ENDED DUCT
ORS	OVERFLOW ROOF SUMP
PD	PRESSURE DROP (FEET OF WATER)
PRV	PRESSURE REDUCING VALVE
PSIA	POUNDS PER SQUARE INCH — ABSOLUTE
PSIG	POUNDS PER SQUARE INCH - GAUGE
PT	PRESSURE / TEMPERATURE PORT
RA	RETURN AIR
RH	RELATIVE HUMIDITY
REQD	REQUIRED
REL.A	RELIEF AIR
RPM	REVOLUTIONS PER MINUTE
RPZ	REDUCED PRESSURE ZONE
RS	ROOF SUMP
SA	SUPPLY AIR
SH	SHOWER STATIC DRESSLIPE
SP act / Sc	SOLIABE FOOT/SOLIABE FEET
qFt / SF	SQUARE FOOT/SQUARE FEET
SS	SERVICE SINK
TD	TEMPERATURE CONTROL TRANSFER AIR DUCT
TD T & P	TRANSFER AIR DUCT TEMPERATURE AND PRESSURE
T & P	TEMPERATURE AND PRESSURE TOTAL STATIC PRESSURE
TYP	TYPICAL
UG	UNDERGROUND
UH	UNIT HEATER
UL	UNDERWRITERS LABORATORY

MECHANICAL ABBREVIATIONS		
ABBREV.	DESCRIPTION	
UR	URINAL	
VD	VOLUME DAMPER (MANUALLY ADJUSTABLE)	
VTR	VENT THRU ROOF	
W	WASTE	
W &∨	WASTE AND VENT	
WB	WET BULB TEMPERATURE	
WC	WATER CLOSET	
WG	WATER GAUGE	
WH	WALL HYDRANT	

MECHANICAL PIPING SYMBOLS				
ABBREV.	DESCRIPTION			
 0	PIPE ELBOW UP			
———э	PIPE ELBOW DOWN			
	PIPE TEE DOWN			
	DIRECTION OF FLOW			
	UNION			
	STRAINER			
	CONCENTRIC REDUCER			
	ECCENTRIC REDUCER			
	EXPANSION JOINT			
	FLEXIBLE CONNECTION			
\rightarrow	PIPE ANCHOR			
	PIPE GUIDE			
	PIPE CAP OR PLUG			
	ISOLATION VALVE			
	CIRCULATING PUMP			
— ¤——	GLOBE VALVE			
——————————————————————————————————————	BALL VALVE			
/	BUTTERFLY VALVE			
-	BACKWATER VALVE			
፮ ──	ANGLE VALVE			
*\-	CHECK VALVE (SWING)			
→ S	CHECK VALVE (SPRING)			
——I√I——	PLUG VALVE			
—₩——	NEEDLE VALVE			
 	OUTSIDE SCREW AND YOKE VALVE (OS&Y)			
<u> </u>	PRESSURE REGULATING VALVE			
<u> </u>	SOLENOID VALVE			
\$	CONTROL VALVE (2-WAY / 3-WAY)			
\bigcirc	CENTRIFUGAL FAN			
f o	AUTOMATIC GAS SHUT-OFF VALVE			
∞—	TRAP (PLAN VIEW)			
O 🖶	FLOOR DRAIN / FUNNEL FLOOR DRAIN (PLAN VIEW)			
	FLOOR DRAIN / FUNNEL FLOOR DRAIN (ELEVATION)			
	ROOF SUMP			
—— CO	CLEAN OUT (IN FLOOR)			
<u>/\</u> C0	CLEAN OUT (IN LINE)			
wco	CLEAN OUT (WALL)			
BFP	BACKFLOW PREVENTER			
1 M → M	WATER METER ASSEMBLY			
+	HOSE BIBB, WALL HYDRANT			
	DIRECTION OF PIPE PITCH			
<u> </u>	SPRINKLER HEAD (UPRIGHT)			
	SPRINKLER HEAD (SIDEWALL)			
—FS	FLOW SWITCH			
ď,	SIAMESE CONNECTION (YARD)			
$\vec{\ }$	SIAMESE CONNECTION (WALL MOUNTED)			
Η	FIRE HYDRANT			
→ >̈́>	FLOW MEASURING DEVICE			
À	BALANCING VALVE			
₫	COMBINATION FLOW MEASURING AND BALANCING DEVICE			

М	MECHANICAL SYMBOLS			
ABBREV.	ABBREV. DESCRIPTION			
5 5	RECTANGULAR TAKE-OFF (SINGLE LINE)			
	RECTANGULAR TAKE-OFF (DOUBLE LINE)			
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	ROUND TAKE-OFF (SINGLE LINE)			
	ROUND TAKE-OFF (DOUBLE LINE)			
	SPIN-IN FITTING (WITH VOLUME DAMPER)			
	ELBOW (WITH TURNING VANES)			
	RADIUS RECTANGULAR ELBOW			
	RADIUS ROUND ELBOW			
	RECTANGULAR ELBOW UP			
E T O	ROUND ELBOW UP			
	RECTANGULAR ELBOW DOWN			
	ROUND ELBOW DOWN			
	CONCENTRIC TRANSITION (DOUBLE LINE)			
S	CONCENTRIC TRANSITION (SINGLE LINE)			
	ECCENTRIC TRANSITION (DOUBLE LINE)			
<u> </u>	ECCENTRIC TRANSITION (SINGLE LINE)			
R	INCLINED RISE IN DIRECTION OF AIR FLOW (DOUBLE LINE)			
<u> </u>	INCLINED RISE IN DIRECTION OF AIR FLOW (SINGLE LINE)			
₽ D	INCLINED DROP IN DIRECTION OF AIR FLOW (DOUBLE LINE)			
<u> </u>	INCLINED DROP IN DIRECTION OF AIR FLOW (SINGLE LINE)			
	FLEXIBLE CONNECTION			
	FLEXIBLE DUCT CONNECTION TO SUPPLY DIFFUSER			
F	SUPPLY DIFFUSER			
	LINEAR SLOT DIFFUSER			
>	RETURN OR EXHAUST GRILLE			
‡	TRANSFER GRILLE			
	CROSS SECTION OF SUPPLY AIR DUCT			
	CROSS SECTION OF EXHAUST OR RETURN AIR DUCT			
	EXISTING FIRE DAMPER (HORIZONTAL) NEW			
	EXISTING			
	FIRE DAMPER (VERTICAL) NEW			
	EXISTING SMOKE DAMPER			
	NEW EXISTING			
	COMBINATION FIRE/SMOKE DAMPER NEW (VERTICAL)			
18	EXISTING COMBINATION FIRE/SMOKE DAMPER (HORIZONTAL)			
	VOLUME DAMPER (MANUALLY ADJUSTABLE)			
M	MOTORIZED DAMPER			
SD	SMOKE DETECTOR			
(CO2)	CO2 SENSOR			
1	THERMOSTAT OR TEMPERATURE SENSOR			
H	HUMIDISTAT OR HUMIDITY SENSOR			
♪	RETURN OR EXHAUST / SUPPLY AIR FLOW			

	PIPING LEGEND
ABBREV.	DESCRIPTION
——СА——	COMPRESSED AIR PIPING
——CD——	CONDENSATE DRAIN PIPING
——DT——	DRAIN TILE
——F——	FIRE PROTECTION PIPING
FOR	FUEL OIL RETURN PIPING
—_F0S—	FUEL OIL SUPPLY PIPING
——	NATURAL GAS PIPING
——BCW——	BOOSTED-DOMESTIC COLD WATER PIPING
——BHW——	BOOSTED-DOMESTIC HOT WATER PIPING
CW	DOMESTIC COLD WATER PIPING
—NPCW—	NON POTABLE COLD WATER PIPING
TW	TEMPERED WATER PIPING
——HW——	DOMESTIC HOT WATER PIPING
—HW(XXX)—	DOMESTIC HOT WATER PIPING CIRCULATED AT XXX TEMPERATURE
HWR	DOMESTIC HOT WATER RETURN PIPING
SAN	SANITARY WASTE PIPING
PSAN	PUMPED SANITARY PIPING
V	VENT PIPING
ST	STORM SEWER PIPING
——PST——	PUMPED STORM PIPING
RC	RAIN CONDUCTOR PIPING
——ORC——	OVERFLOW RAIN CONDUCTOR PIPING
CHWR	CHILLED WATER RETURN PIPING
—CHWS—	CHILLED WATER SUPPLY PIPING
CWR	CONDENSER WATER RETURN PIPING
CWS	CONDENSER WATER SUPPLY PIPING
——HHWR——	HEATING HOT WATER RETURN PIPING
——HHWS——	HEATING HOT WATER SUPPLY PIPING
——HPLR——	HEAT PUMP LOOP RETURN PIPING
——HPLS——	HEAT PUMP LOOP SUPPLY PIPING
RL	REFRIGERANT LIQUID PIPING
RS	REFRIGERANT SUCTION PIPING
——HGB——	HOT GAS BY-PASS PIPING
GXHR	GEO HEAT EXCHANGE RETURN
—GXHS—	GEO HEAT EXCHANGE SUPPLY
——STM——	STEAM PIPING
——HPS——	HIGH PRESSURE STEAM PIPING
——LPS——	LOW PRESSURE STEAM PIPING
CR	STEAM CONDENSATE RETURN PIPING
——PCR——	PUMPED STEAM CONDENSATE RETURN PIPING
LPC	LOW PRESSURE CONDENSATE PIPING
——HPC——	HIGH PRESSURE CONDENSATE PIPING
MA	MEDICAL AIR PIPING
N	NITROGEN GAS PIPING
1 1	

APPLICABLE CODES AND REGULATIONS		
YEAR	CODE	
2015	MICHIGAN BUILDING CODE	
2015	MICHIGAN REHABILITATION CODE FOR EXISTING BUILDINGS	
2015	MICHIGAN MECHANICAL CODE	
2015	MICHIGAN UNIFORM ENERGY CODE	
2015	INTERNATIONAL FUEL GAS CODE	
2009	ICC/ANSI ACCESSIBLE AND USABLE BUILDING & FACILITIES	
_	AMERICANS WITH DISABILITIES ACT ACCESSIBILITIES GUIDELINE (ADA—AG)	

OXYGEN GAS PIPING

DRAWING INDEX		
SHT NO	DESCRIPTION	
мо.отв	MECHANICAL GENERAL INFORMATION	
M1.1TB	MECHANICAL PLANS — TRANSPORTATION BUILDING	
M1.2TB	MECHANICAL ROOF PLANS — TRANSPORTATION BUILDING	

I	DRAWING NOTATION	
SYMBOL DESCRIPTION		
1	NEW WORK KEY NOTE NO. 1	
1	DEMOLITION KEY NOTE NO. 1	
<u>EF-1</u>	EQUIPMENT TAG	
S-1 10x10 100-2	AIR TERMINAL TAG: S = SUPPLY R = RETURN IE: DIFFUSER TYPE = S-1 NECK SIZE = 10x10 CFM = 100 (TYPICAL FOR 2)	
	EXISTING DEVICES OR EQUIPMENT	
	NEW OR MODIFIED DEVICES OR EQUIPMENT	
4///	EXISTING SYSTEM COMPONENT TO BE REMOVED	
→	POINT OF NEW CONNECTION	
	SECTION NO. 4 M5.2 SHEET M5.2 ON WHICH SECTION DRAWN	
6 M5.2	SECTION SCALE: 1/4" = 1' - 0" SHEET M5.2 ON WHICH SECTION IS CUT (ENLARGED PARTIAL PLAN SIMILAR)	

SES®
Strategic Energy Solutions® 4000 W. Eleven Mile Road Berkley, MI 480 Phone 248.399.1900 Fax 248.399.1900
www.sesnet.com
© 2023 SES, INC. SES Project #23 0939 01

MIDLAND PUBLIC SCHOOLS 600 East Carpenter Street Midland, MI 48640
PROJECT: MIDLAND PUBLIC SCHOOLS TRANSPORTATION
BUILDING - AHU/RTU REPLACEMENT 410 East Hines Road Midland, MI 48640

SSUED FOR: BIDS/PERMITS	01/22/24	

Seal:

SSUED	DATE

SHEET TITLE:

MECHANICAL GENERAL INFORMATION

SHEET NUMBER:

DESIGNER: ENGINEER:

M0.0TB




MECHANICAL DEMOLITION NOTES

- 1. THESE DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL EXTENT OF WORK TO BE PERFORMED. THE EXACT EXTENT OF DEMOLITION SHALL BE AS REQUIRED BY THE NEW WORK.
- 2. PRIOR TO COMMENCEMENT OF WORK, CONTRACTOR SHALL VISIT THE SITE AND BECOME FAMILIAR WITH EXISTING SITE CONDITIONS, SYSTEMS, AND UTILITIES. NOTIFY ARCHITECT OF ANY INTERFERENCES OR DISCREPANCIES.
- 3. VERIFY DEPTH, SIZE, LOCATIONS AND CONDITION OF EXISTING UTILITIES IN THE FIELD, INCLUDING POINTS OF CONNECTION PRIOR TO STARTING ANY WORK.
- 4. ANY INTERRUPTIONS OF EXISTING SERVICES AND/OR EQUIPMENT SHALL BE PERFORMED AT A TIME APPROVED IN ADVANCE BY THE OWNER'S REPRESENTATIVE SO AS NOT TO INTERFERE WITH THE PRESENT BUILDING'S OPERATION.
- 5. ALL ITEMS ON DEMOLITION PLAN SHALL BE CONSIDERED EXISTING UNLESS OTHERWISE NOTED. ALL WORK INDICATED ON PLANS HAS BEEN LOCATED PER EXISTING DRAWINGS AND/OR FIELD OBSERVATION AND REQUIRES FIELD
- 6. ALL ITEMS INDICATED WITH CROSS—HATCHING SHALL BE REMOVED COMPLETE, WITH ALL RELATED ITEMS INCLUDING HANGERS, SUPPORTS, INSULATION, CONTROLS, ETC. CAP ALL OPEN ENDED PIPES AND DUCTS.
- 7. ALL EXISTING WORK TO REMAIN SHALL BE PROTECTED FROM DAMAGE. WHERE DUCT OR PIPE INSULATION HAS BEEN DAMAGED DURING DEMOLITION, THE CONTRACTOR SHALL REPAIR INSULATION AS REQUIRED TO MATCH EXISTING.
- 8. THE OWNER SHALL HAVE FIRST RIGHT OF REFUSAL ON ALL EQUIPMENT BEING REMOVED. ALL ITEMS REMOVED SHALL BE LEGALLY DISPOSED OF. GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EXISTING RELOCATED AND OWNER PROVIDED EQUIPMENT.

DEMOLITION KEYED NOTES

- 2. REMOVE RTU AND DUCTWORK AS INDICATED. REMOVE GAS PIPING AND

- REMOVE EXISTING INDOOR AHU, DUCTWORK AS INDICATED, CONDENSING UNIT ON ROOF, AND HEATING HOT WATER PIPING BACK TO MAIN.
- PREPARE FOR CONNECTION TO NEW RTU.





HVAC GENERAL NOTES

- THE WORK. PROVIDE HVAC SYSTEMS COMPLETE PER SPECIFICATION, SMACNA STANDARDS, AND PER APPLICABLE CODES INCLUDING ALL NECESSARY OFFSETS, FITTINGS, SPECIAL RADIUS OR MITERED ELBOWS WHICH ARE REQUIRED DUE TO SPACE CONSTRAINTS OR STRUCTURAL CONDITIONS OR OTHER CONDITIONS.
- 2. CONTRACTOR SHALL COORDINATE THEIR WORK WITH THE WORK OF ALL OTHER TRADES. ALL DUCTWORK IS TO BE ROUTED AS HIGH A POSSIBLE. PROVIDE ACCESS AROUND ALL NEW EQUIPMENT PER MANUFACTURER'S RECOMMENDATIONS. VERIFY ALL CLEARANCES PRIOR TO THE FABRICATION OF ANY WORK.
- 3. DUCTWORK/PIPING SHALL BE ROUTED AS HIGH AS POSSIBLE AND SHALL NOT BE LOCATED OVER ELECTRICAL EQUIPMENT/PANELS. PROVIDE REQUIRED CLEARANCE IN FRONT OF ELECTRICAL EQUIPMENT. DUCTWORK/PIPING SHALL NOT INTERFERE WITH ELECTRICAL EQUIPMENT CLEARANCE. 4. DUCTWORK/PIPING SHALL NOT BE INSTALLED IN A LOCATION THAT RESTRICTS
- THE ACCESS TO MECHANICAL DEVICES REQUIRING ACCESS.
- 5. THE CONTRACTOR SHALL PROVIDE ALL MISCELLANEOUS SUPPORTING STEEL, ETC. FOR THE PROPER INSTALLATION OF ALL MECHANICAL SYSTEMS.
- 6. COORDINATE FLOOR, WALL, ROOF PENETRATIONS, LOUVER SIZES, PAD LOCATIONS ETC. WITH ARCHITECTURAL TRADES. SEAL ALL PIPING AND DUCT PENETRATIONS.
- 7. BRANCH DUCTWORK TO GRILLES, REGISTERS AND DIFFUSERS SHALL BE THE SAME SIZE AS THE GRILLE, REGISTER OR DIFFUSER NECK SIZE WHERE NO DUCT SIZE IS INDICATED ON PLAN.
- 8. MAXIMUM LENGTH OF FLEXIBLE DUCT SHALL BE 5'-0".

- 1. THESE DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL EXTENT OF 9. PROVIDE CODE REQUIRED CLEARANCE/ACCESS DOORS FOR DAMPERS, VALVES, AND CLEANOUTS LOCATED IN WALLS OR ABOVE HARD CEILINGS. COORDINATE LOCATIONS WITH ARCHITECT. REFER TO ARCHITECTURAL PLANS FOR CEILING
 - 10. CONNECTION TO EQUIPMENT SHALL BE VERIFIED WITH MANUFACTURER'S CERTIFIED DRAWINGS. TRANSITIONS TO ALL EQUIPMENT SHALL BE VERIFIED AND PROVIDED FOR EQUIPMENT FURNISHED.

KEYED NOTES

- 1. PROVIDE METAL INSULATED PANEL TO BLANK OFF EXISTING OA INTAKE LOUVER.
- 2. 1" GAS UP TO RTU. PROVIDE DIRT LEG, UNION AND SHUT-OFF VALVE AT UNIT CONNECTION. COORDINATE EXACT LOCATION WITH UNIT PROVIDED. PROVIDE ROOF FLASHING CONE AND COUNTER FLASHING AT ROOF PENETRATION.
- REMOVE AND REPLACE FTR OR CONVECTOR CONTROLS WITH DDC CONTROLS. INCLUDE NEW CONTROL VALVE, TEMPERATURE SENSOR AND ZONE CONTROLLER. FIELD VERIFY WHICH SENSOR SERVES EACH PIECE OF EQUIPMENT.
- 4. REMOVE AND REPLACE CUH CONTROLS AND TEMPERATURE SENSOR WITH DDC CONTROLS. INCLUDE NEW CONTROLLER, CONTROL VALVE, DAMPER ACTUATORS, TEMPERATURE SENSORS, ETC. AS REQUIRED FOR COMPLETE DDC CONTROL OF THE UNIT.



Strategic Energy Solutions® 4000 W. Eleven Mile Road Berkley, MI 48072

Phone 248.399.1900 Fax 248.399.1901 www.sesnet.com


> © 2023 SES, INC. SES Project #23 0939 01

Midland, MI 48640

MIDLAND PUBLIC SCHOOLS 600 East Carpenter Street

MIDLAND PUBLIC SCHOOLS TRANSPORTATION BUILDING - AHU/RTU REPLACEMENT

410 East Hines Road Midland, MI 48640



Seal:

SUED FOR: BIDS/PERMITS	01/22/24

DATE ISSUED

DESIGNER: ENGINEER:

SHEET TITLE:

MECHANICAL PLANS -TRANSPORTATION BUILDING

SHEET NUMBER:






MECHANICAL DEMOLITION NOTES

- 1. THESE DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL EXTENT OF WORK TO BE PERFORMED. THE EXACT EXTENT OF DEMOLITION SHALL BE AS REQUIRED BY THE NEW WORK.
- BECOME FAMILIAR WITH EXISTING SITE CONDITIONS, SYSTEMS, AND UTILITIES. NOTIFY ARCHITECT OF ANY INTERFERENCES OR DISCREPANCIES.
- 3. VERIFY DEPTH, SIZE, LOCATIONS AND CONDITION OF EXISTING UTILITIES IN THE FIELD, INCLUDING POINTS OF CONNECTION PRIOR TO STARTING ANY WORK.
- 4. ANY INTERRUPTIONS OF EXISTING SERVICES AND/OR EQUIPMENT SHALL BE PERFORMED AT A TIME APPROVED IN ADVANCE BY THE OWNER'S REPRESENTATIVE SO AS NOT TO INTERFERE WITH THE PRESENT BUILDING'S
- 5. ALL ITEMS ON DEMOLITION PLAN SHALL BE CONSIDERED EXISTING UNLESS OTHERWISE NOTED. ALL WORK INDICATED ON PLANS HAS BEEN LOCATED PER EXISTING DRAWINGS AND/OR FIELD OBSERVATION AND REQUIRES FIELD VERIFICATION.
- 6. ALL ITEMS INDICATED WITH CROSS-HATCHING SHALL BE REMOVED COMPLETE, WITH ALL RELATED ITEMS INCLUDING HANGERS, SUPPORTS, INSULATION, CONTROLS, ETC. CAP ALL OPEN ENDED PIPES AND DUCTS.
- 7. ALL EXISTING WORK TO REMAIN SHALL BE PROTECTED FROM DAMAGE, WHERE DUCT OR PIPE INSULATION HAS BEEN DAMAGED DURING DEMOLITION, THE CONTRACTOR SHALL REPAIR INSULATION AS REQUIRED TO MATCH EXISTING.
- 8. THE OWNER SHALL HAVE FIRST RIGHT OF REFUSAL ON ALL EQUIPMENT BEING REMOVED. ALL ITEMS REMOVED SHALL BE LEGALLY DISPOSED OF. GENERAL CONTRACTOR SHALL BE RESPONSIBLE FOR ALL EXISTING RELOCATED AND OWNER PROVIDED EQUIPMENT.

DEMOLITION KEYED NOTES

- 1. REMOVE CONDENSING UNIT, LINE SET AND ROOF CURB. PATCH ROOF TO
- 2. PRIOR TO COMMENCEMENT OF WORK, CONTRACTOR SHALL VISIT THE SITE AND 2. REMOVE EXISTING RTU. PROVIDE INSULATED CAP ON EXISTING ROOF CURB. REMOVE GAS PIPING TO THRU ROOF AND PATCH ROOF TO MATCH EXISTING.







HVAC GENERAL NOTES

- 1. THESE DRAWINGS ARE DIAGRAMMATIC AND INDICATE THE GENERAL EXTENT OF 14. PROVIDE CODE REQUIRED CLEARANCE/ACCESS DOORS FOR DAMPERS, VALVES, THE WORK. PROVIDE HVAC SYSTEMS COMPLETE PER SPECIFICATION, SMACNA STANDARDS, AND PER APPLICABLE CODES INCLUDING ALL NECESSARY OFFSETS, FITTINGS, SPECIAL RADIUS OR MITERED ELBOWS WHICH ARE REQUIRED DUE TO SPACE CONSTRAINTS OR STRUCTURAL CONDITIONS OR OTHER CONDITIONS.
- 2. CONTRACTOR SHALL COORDINATE THEIR WORK WITH THE WORK OF ALL OTHER TRADES. ALL DUCTWORK IS TO BE ROUTED AS HIGH A POSSIBLE. PROVIDE ACCESS AROUND ALL NEW EQUIPMENT PER MANUFACTURER'S RECOMMENDATIONS. VERIFY ALL CLEARANCES PRIOR TO THE FABRICATION OF
- BE LOCATED OVER ELECTRICAL EQUIPMENT/PANELS. PROVIDE REQUIRED CLEARANCE IN FRONT OF ELECTRICAL EQUIPMENT. DUCTWORK/PIPING SHALL NOT INTERFERE WITH ELECTRICAL EQUIPMENT CLEARANCE.
- 4. DUCTWORK/PIPING SHALL NOT BE INSTALLED IN A LOCATION THAT RESTRICTS THE ACCESS TO MECHANICAL DEVICES REQUIRING ACCESS.
- 5. THE CONTRACTOR SHALL PROVIDE ALL MISCELLANEOUS SUPPORTING STEEL,

ETC. FOR THE PROPER INSTALLATION OF ALL MECHANICAL SYSTEMS.

- 6. COORDINATE FLOOR, WALL, ROOF PENETRATIONS, LOUVER SIZES, PAD LOCATIONS ETC. WITH ARCHITECTURAL TRADES. SEAL ALL PIPING AND DUCT PENETRATIONS.
- 7. THE CONTRACTOR SHALL REFER TO ARCHITECTURAL REFLECTED CEILING PLANS FOR EXACT LOCATION OF GRILLES, REGISTERS, AND DIFFUSERS.
- 8. COORDINATE AND PROVIDE ACCESS DOORS IN HARD CEILING AREAS FOR ACCESS TO BALANCING DAMPERS, ETC. REFER TO ARCHITECTURAL DRAWINGS FOR CEILING TYPES.
- 9. BRANCH DUCTWORK TO GRILLES, REGISTERS AND DIFFUSERS SHALL BE THE SAME SIZE AS THE GRILLE, REGISTER OR DIFFUSER NECK SIZE WHERE NO DUCT SIZE IS INDICATED ON PLAN.
- 10. MAXIMUM LENGTH OF FLEXIBLE DUCT SHALL BE 5'-0".
- 11. FOR EQUIPMENT VALVING, COMPONENT, AND PIPING ARRANGEMENT, REFER TO PIPING DIAGRAMS AND DETAILS.
- 12. PAINT ALL VISIBLE INTERIOR SURFACES OF EXHAUST/RETURN GRILLES, REGISTERS AND VISIBLE ASSOCIATED DUCTWORK FLAT BLACK.

ALL MATERIAL IN THE CEILING SPACE IS TO BE PLENUM RATED.

13. THE CEILING SPACE IS USED AS A RETURN AIR PLENUM. NO PLASTIC MATERIALS INCLUDING PVC PIPING, CONDUIT, WIRING, ETC. SHALL BE USED.

- AND CLEANOUTS LOCATED IN WALLS OR ABOVE HARD CEILINGS. COORDINATE LOCATIONS WITH ARCHITECT. REFER TO ARCHITECTURAL PLANS FOR CEILING
- 15. DUCTWORK TO AND FROM VAV BOXES/TERMINAL UNITS SHALL BE EQUAL TO THE BOX CONNECTIONS SIZES UNLESS INDICATED OTHERWISE.
- 16. CONNECTION TO EQUIPMENT SHALL BE VERIFIED WITH MANUFACTURER'S CERTIFIED DRAWINGS. TRANSITIONS TO ALL EQUIPMENT SHALL BE VERIFIED AND PROVIDED FOR EQUIPMENT FURNISHED.
- 3. DUCTWORK/PIPING SHALL BE ROUTED AS HIGH AS POSSIBLE AND SHALL NOT 17. ALL BRANCH PIPING TO TERMINAL UNITS TO BE 3/4" UNLESS OTHERWISE
 - 18. ROOF MOUNTED EQUIPMENT REQUIRING SERVICE SHALL BE LOCATED A MINIMUM OF 10 FEET FROM ROOF EDGES. WHERE EQUIPMENT CAN'T BE LOCATED AWAY FROM ROOF EDGE AND GUARD RAILS ARE NOT PROVIDED. PROVIDE PERMANENT FALL ARREST ANCHORAGE CONNECTION DEVICE THAT COMPLIES WITH ANSI/ASSE Z 359.1.

KEYED NOTES

- 1. EXTEND PLUMBING VENT TO 2' ABOVE OUTDOOR AIR INTAKE ON RTU. 2. RTU ON NEW ROOF CURB FLASHED INTO EXISTING ROOF. PROVIDE OPENING
- THRU EXISTING PRE-CAST CONCRETE DOUBLE T ROOF STRUCTURE. PROVIDE MISC. STEEL AS REQUIRED TO FRAME AND REINFORCE OPENING.
- 3. INSULATED CAP ON EXISTING ROOF CURB.

												PAG	CKAG	ED COM	MERCIA	L RC	OFT	OP UNIT	SCHE	DULE -	(DX	- GA	S)									
				SU	IPPLY FAN	١					DX (COOLING (COIL					NATURAL GA	AS HEATING SE	CTION			POWER			ELECT	RICAL		DISCO	NNECT		
UNIT ID	TOTAL SUPPLY (CFM)	DESIGN OA (CFM)	ESP (IN WG)	FAN TYPE	DRIVE TYPE	ВНР	HP	TOTAL CAPACITY (MBH)	SENSIBLE CAPACITY (MBH)	EDB (°F)	EWB LD	B LWB (°F)	APD (IN WG)	MIN. EFFICIENCY (EER/IEER)	REFRIGERANT TYPE	INPUT (MBH)	OUTPUT (MBH)	GAS PRESS. MIN.— MAX. (IN WG)	STAGES OR MODULATION TURNDOWN	BURNER TYPE	EAT (°F)	LAT (°F)	EXHAUST OR BAROMETRIC RELIEF	FILTER TYPE	MOCP	MCA FL	_A VOLTS	S PHASE	FURN. BY	INST. BY	MANUFACTURER/ MODEL NO.	REMARKS
RTU-1	1,950	450	0.5	SWSI	DIRECT	0.85	4.0	62.1	48.9	80.0	67.0 5 ⁻	7 56.9	0.33	12.8/17.1	R-410A	64	51.2	5-14	5:1 MODULATION	STAINLESS	50	80	BAROMETRIC RELIEF	MERV 8 MERV 14	40	28.7 25	5.7 208	3	MAN.	MAN.	DAIKIN/ DPS005A	

1. DRY BULB ECONOMIZER. 2. PROVIDE WITH 24" ROOF CURB.

NOTES:

Strategic Energy Solutions 4000 W. Eleven Mile Road Berkley, MI 48072 Phone 248.399.1900 Fax 248.399.1901

> (C) 2023 SES, INC. SES Project #23 0939 01


www.sesnet.com

MIDLAND PUBLIC SCHOOLS

600 East Carpenter Street Midland, MI 48640

MIDLAND PUBLIC SCHOOLS TRANSPORTATION BUILDING - AHU/RTU REPLACEMENT

410 East Hines Road Midland, MI 48640



Seal:

ISSUED FOR:	
BIDS/PERMITS	01/22/24
	· -

DATE ISSUED

DESIGNER: ENGINEER:

SHEET TITLE:

MECHANICAL ROOF PLANS -TRANSPORTATION BUILDING

SHEET NUMBER:

				COPI	PER FEEDER SCHEDULE			
FEEDER (AMPS)	COND. SIZE	2 WIRE WITH GROUND	FEEDER (AMPS)	COND. SIZE	3 WIRE WITH GROUND	FEEDER (AMPS)	COND. SIZE	4 WIRE WITH GROUND
(15S)	12	2#12, 1#12 GND IN 3/4"C	15	12	3#12, 1#12 GND IN 3/4"C	(15N)	12	4#12, 1#12 GND IN 3/4"C
20S	12	2#12, 1#12 GND IN 3/4"C	20	12	3#12, 1#12 GND IN 3/4"C	(20N)	12	4#12, 1#12 GND IN 3/4"C
25S	10	2#10, 1#10 GND IN 3/4"C	25	10	3#10, 1#10 GND IN 3/4"C	(25N)	10	4#10, 1#10 GND IN 3/4"C
30S	10	2#10, 1#10 GND IN 3/4"C	30	10	3#10, 1#10 GND IN 3/4"C	(30N)	10	4#10, 1#10 GND IN 3/4"C
35S	8	2#8, 1#10 GND IN 3/4"C	35	8	3#8, 1#10 GND IN 3/4"C	(35N)	8	4#8, 1#10 GND IN 3/4"C
40S	8	2#8, 1#10 GND IN 3/4"C	40	8	3#8, 1#10 GND IN 3/4"C	40N	8	4#8, 1#10 GND IN 3/4"C
45S	6	2#6, 1#10 GND IN 3/4"C	45	6	3#6, 1#10 GND IN 3/4"C	45N	6	4#6, 1#10 GND IN 1"C
50S	6	2#6, 1#10 GND IN 3/4"C	50	6	3#6, 1#10 GND IN 3/4"C	(50N)	6	4#6, 1#10 GND IN 1"C
(60S)	4	2#4, 1#10 GND IN 1"C	60	4	3#4, 1#10 GND IN 1"C	(60N)	4	4#4, 1#10 GND IN 1 1/4"C
70S	4	2#4, 1#8 GND IN 1"C	70	4	3#4, 1#8 GND IN 1"C	(70N)	4	4#4, 1#8 GND IN 1 1/4"C
80S	3	2#3, 1#8 GND IN 1"C	80	3	3#3, 1#8 GND IN 1"C	(80N)	3	4#3, 1#8 GND IN 1 1/4"C
90\$	2	2#2, 1#8 GND IN 1"C	90	2	3#2, 1#8 GND IN 1 1/4"C	90N	2	4#2, 1#8 GND IN 1 1/2"C
(100S)	1	2#1, 1#8 GND IN 1 1/4"C	(100)	1	3#1, 1#8 GND IN 1 1/4"C	(100N)	1	4#1, 1#8 GND IN 1 1/2"C
•		•	(110)	2	3#2, 1#6 IN 1 1/4"C	(110N)	2	4#2, 1#6 GND IN 1 1/4"C
			125	1	3#1, 1#6 GND IN 1 1/4"C	(125N)	1	4#1, 1#6 GND IN 1 1/2"C
			(150)	1/0	3#1/0, 1#6 GND IN 1 1/2"C	(150N)	1/0	4#1/0, 1#6 GND IN 2"C
			175	2/0	3#2/0, 1#6 GND IN 1 1/2"C	(175N)	2/0	4#2/0, 1#6 GND IN 2"C
			200	3/0	3#3/0, 1#6 GND IN 2"C	(200N)	3/0	4#3/0, 1#6 GND IN 2"C
			225	4/0	3#4/0, 1#4 GND IN 2"C	(225N)	4/0	4#4/0, 1#4 GND IN 2 1/2"C
			250	250	3-250 KCMIL, 1#4 GND IN 2"C	(250N)	250	4-250 KCMIL, 1#4 GND IN 2 1/2"C
			300	350	3-350 KCMIL, 1#4 GND IN 2"C	(300N)	350	4-350 KCMIL, 1#4 GND IN 3"C
			350	500	3-500 KCMIL, 1#3 GND IN 3"C	(350N)	500	4-500 KCMIL, 1#3 GND IN 3 1/2"C
			400	600	3-600 KCMIL, 1#3 GND IN 3 1/2"C	400N	600	4-600 KCMIL, 1#3 GND IN 4"C
			450	2-4/0	(2) 3#4/0, 1#2 GND IN 2"C	450N	2-4/0	(2) 4#4/0, 1#2 GND IN 2 1/2"C
			500	2-250	(2) 3-250 KCMIL, 1#2 GND IN 2 1/2"C	(500N)	2-250	(2) 4-250 KCMIL, 1#1 GND IN 3"C
			600	2-350	(2) 3-350 KCMIL, 1#1 GND IN 2 1/2"C	(600N)	2-350	(2) 4-350 KCMIL, 1#1 GND IN 3"C
			700	2-500	(2) 3-500 KCMIL, 1#1/0 GND IN 3"C	(700N)	2-500	(2) 4-500 KCMIL, 1#1/0 GND IN 3 1/2"C
			800	2-600	(2) 3-600 KCMIL, 1#1/0 GND IN 3 1/2"C	(800N)	2-600	(2) 4-600 KCMIL, 1#1/0 GND IN 4"C
			(1000)	3-500	(3) 3-500 KCMIL, 1#2/0 GND IN 3"C	(1000N)	3-500	(3) 4-500 KCMIL, 1#2/0 GND IN 3 1/2"C
			(1200)	3-600	(3) 3-600 KCMIL, 1#3/0 GND IN 4"C	(1200N)	3-600	(3) 4-600 KCMIL, 1#3/0 GND IN 4"C
			(1600)	4-600	(4) 3-600 KCMIL, 1#4/0 GND IN 4"C	(1600N)	4-600	(4) 4-600 KCMIL, 1#4/0 GND IN 4"C
			2000	5-600	(5) 3-600 KCMIL, 1-250 KCMIL GND IN 4"C	2000	5-600	(5) 4-600 KCMIL, 1-250 KCMIL GND IN 4"C
			2500	7-500	(7) 3-500 KCMIL, 1-350 KCMIL GND IN 3 1/2"C	2500N	7-500	(7) 4-500 KCMIL, 1-350 KCMIL GND IN 3 1/2"C
			3000	8-500	(8) 3-500 KCMIL, 1-400 KCMIL GND IN 3 1/2"C	3000N	8-500	(8) 4-500 KCMIL, 1-400 KCMIL GND IN 3 1/2"C
			4000	10-600	(10) 3-600 KCMIL, 1-500 KCMIL GND IN 4"C	4000N	10-600	(10) 4-600 KCMIL, 1-500 KCMIL GND IN 4"C
			(5000)	12-600	(12) 3-600 KCMIL, 1-700 KCMIL GND IN 4"C	5000N	12-600	(12) 4-600 KCMIL, 1-700 KCMIL GND IN 4"C
			(6000)	15-600	(15) 3-600 KCMIL, 1-500 KCMIL GND IN 4"C	(6000N)	15-600	(15) 4-600 KCMIL, 1-800 KCMIL GND IN 4"C
NOTES:						-		

. AMPACITIES FOR FEEDER SIZES ARE BASED ON N.E.C. CODE 110-14. (TERMINATION PROVISIONS FOR EQUIPMENT RATED 100A OR LESS ARE RATED FOR USE WITH CONDUCTORS RATED 60°C. TERMINATION PROVISIONS FOR EQUIPMENT RATED GREATER THAN 100A ARE RATED FOR USE WITH CONDUCTORS RATED 75°C.)

2. CONTRACTOR MAY OPTIONALLY USE 1/2" CONDUIT IN LIEU OF 3/4" CONDUIT FOR #10 AND #12 CONDUCTORS.

3. CONDUIT FILL IS BASED ON 40% FILL USING SINGLE CONDUCTOR BUILDING WIRE OF INSULATION TYPES THHN, THWN-2, XHH, XHHW, AND XHHW-2 IN RMC. FOR OTHER RACEWAY TYPES REFER TO APPROPRIATE N.E.C. APPENDIX C TABLES.

4. EQUIPMENT GROUND SIZING BASED ON N.E.C. TABLE 250.122.

ı	POWER SYMBOL LIST
SYMBOL	DESCRIPTION
•	CONDUIT DOWN
0	CONDUIT UP
4	DISCONNECT SWITCH - NON FUSED
4	DISCONNECT SWITCH - FUSED
L	DISCONNECT SWITCH - COMB. MOTOR STARTER
	ELECTRICAL PANEL
•	GROUNDING ROD
=	GROUND
	GROUNDING BAR
J	JUNCTION BOX
M	METER
\(\)	MOTOR - SINGLE PHASE
\ <u>\</u>	MOTOR - THREE PHASE
\$м	MOTOR RATED SWITCH
φ	POWER RECEPTACLE - SIMPLEX TYPE
P	POWER RECEPTACLE - DUPLEX TYPE
 	POWER RECEPTACLE - DUPLEX 6" ABOVE COUNTER
Pusa	POWER RECEPTACLE - USB/DUPLEX COMBO. DEVICE
#	POWER RECEPTACLE - QUADRUPLEX TYPE
FB	POWER RECEPTACLE - RECESSED FLOOR TYPE
PT	POWER RECEPTACLE - POKE THRU TYPE
\Diamond	POWER RECEPTACLE - SPECIALTY TYPE
TC	TIME CLOCK
Т	TRANSFORMER

NOTES:

1. ALL DEVICE RATINGS/SIZES SHALL BE COORDINATED WITH PLANS AND SCHEDULES.

ELEC	CTRICAL ABBREVIATIONS
ABBREV.	DESCRIPTION
AFF	ABOVE FINISHED FLOOR
Α	AMPERE
AF	AMPERE FUSE/AMPERE FRAME
AWG	AMERICAN WIRE GAUGE
ATC	AMPERE TRIP
ATS AIC	AUTOMATIC TRANSFER SWITCH AVAILABLE INTERRUPTING CURRENT (AMPS)
C	CONDUIT OR CEILING MOUNTED
CB	CIRCUIT BREAKER
CL	CONTROL LOAD
CU	COPPER
СТ	CURRENT TRANSFORMER
DIA	DIAMETER
DISC	DISCONNECT
EMT	ELECTRICAL METALLIC TUBING
EWC	ELECTRIC WATER COOLER
EPO	EMERGENCY POWER OFF
(E)	EXISTING ELECTRICAL EQUIPMENT OR WORK
FA	FIRE ALARM
FACP FLA	FIRE ALARM CONTROL PANEL FULL LOAD AMPS
FLA F	FULL LOAD AMPS FUSE
G/GRD	GROUND
GFCI/GFI	GROUND FAULT CIRCUIT INTERRUPTER
НОА	HAND-OFF-AUTO
HP	HORSEPOWER
IG	ISOLATED GROUND
KV	KILOVOLT
KVA	KILOVOLT AMPERE
KW	KILOWATT
KWH	KILOWATT HOUR
LP MCB	LIGHTING PANEL MAIN CIRCUIT BREAKER
MDP	MAIN DISTRIBUTION PANEL
MLO	MAIN LUG ONLY
MAX	MAXIMUM
MIN	MINIMUM
NEC	NATIONAL ELECTRICAL CODE
NEMA	NATIONAL ELECTRICAL MANUFACTURERS ASSOC.
N/NEU	NEUTRAL
NF	NON-FUSIBLE
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
NIC PH. OR Ø	NOT IN CONTRACT PHASE
P	POLE
PF	POWER FACTOR
PVC	POLYVINYL CHLORIDE (PLASTIC)
(R)	RELOCATED EXISTING ELECTRICAL EQUIPMENT
(RR)	REMOVE AND REINSTALL
RMC	RIGID METALLIC CONDUIT
RP	RECEPTACLE PANEL
TBB	TELEPHONE BACKBOARD
TYP.	TYPICAL
UC	UNDER COUNTER
UL	UNDERWRITERS LABORATORIES
UPS	UNINTERRUPTIBLE POWER SUPPLY
USB V	UNIVERSAL SERIAL BUS VOLT
VA VA	VOLT AMPERE
	WATT
	<u> </u>

WIRE GUARD

WEATHERPROOF

TRANSFORMER

	DRAWING INDEX
SHT NO	DESCRIPTION
E0.0TB	ELECTRICAL GENERAL INFORMATION
E1.1TB	ELECTRICAL PLANS — TRANSPORTATION BUILDING
E1.2TB	ELECTRICAL ROOF PLANS — TRANSPORTATION BUILDING

	DRAWING NOTATION
SYMBOL	DESCRIPTION
L1	LIGHTING FIXTURE TAG
1	CONSTRUCTION KEY NOTE NUMBER 1
1	DEMOLITION KEY NOTE NUMBER 1
20	COPPER FEEDER SIZE TAG (REFER TO FEEDER SCHEDULE)
20	ALUMINUM FEEDER SIZE TAG (REFER TO FEEDER SCHEDULE)
<u>EQUIPMENT</u>	EQUIPMENT TAG
	EXISTING DEVICES OR EQUIPMENT
	NEW OR MODIFIED DEVICES OR EQUIPMENT
	NEW OR MODIFIED UNDERGROUND WIRING
\$//////	EXISTING SYSTEM COMPONENT TO BE REMOVED
•	POINT OF NEW CONNECTION

SES®
Strategic Energy Solutions®
4000 W. Eleven Mile Road Berkley, MI 48072
Phone 248.399.1900 Fax 248.399.1901
www.sesnet.com

© 2023 SES, INC. SES Project #23 0939 01

MIDLAND PUBLIC SCHOOLS 600 East Carpenter Street

Midland, MI 48640

Midland, MI 48640

MIDLAND PUBLIC SCHOOLS TRANSPORTATION BUILDING - AHU/RTU REPLACEMENT 410 East Hines Road

ISSUED FOR: BIDS/PERMITS 01/22/24

SHEET TITLE:

ENGINEER:

ISSUED

ELECTRICAL GENERAL INFORMATION

SHEET NUMBER:



$\frac{1}{\text{SCALE}:1/8"} = 1'-0"$

ELECTRICAL DEMOLITION NOTES

- 1. VISIT THE SITE PRIOR TO SUBMISSION OF BID TO EXAMINE THE EXISTING CONDITIONS AND THE EXTENT OF DEMOLITION WORK.
- 2. EXAMINE THE DRAWINGS OF OTHER TRADES, BE FAMILIAR WITH THE DEMOLITION REQUIRED BY OTHER TRADES.
- 3. PERFORM ALL INCIDENTAL ELECTRICAL DEMOLITION AND/OR RELOCATION OF DEVICES AND EQUIPMENT REQUIRED TO FACILITATE THE DEMOLITION WORK OF
- 4. COORDINATE WITH NEW WORK PLANS, ONE LINE, AND RISER DIAGRAMS FOR EXTENT OF DEMOLITION WORK.

OTHER TRADES.


- 5. COORDINATE ANY SHUTDOWN OF EXISTING SERVICES AND EQUIPMENT REMAINING IN USE WITH OWNERS' REPRESENTATIVE. WHERE EXISTING BUILDING SERVICE IS REQUIRED TO BE SHUT DOWN, INCLUDE ALL ASSOCIATED OVERTIME COST TO PERFORM THIS WORK DURING EVENING AND WEEKENDS. INCLUDE ALL COSTS FOR PROVIDING TEMPORARY POWER.
- 6. REMOVE ALL CONDUIT AND WIRE BACK TO NEAREST UPSTREAM DEVICE REMAINING IN SERVICE.
- 7. WHERE DEMOLITION WORK AFFECTS ELECTRICAL SERVICE TO DOWNSTREAM DEVICES TO REMAIN; EXTEND CONDUIT AND WIRE AS REQUIRED TO MAINTAIN ELECTRICAL SERVICE.

8. PROVIDE BLANK COVER PLATES WHERE SWITCHES AND DEVICES ARE REMOVED

- AND WALL REMAINS INTACT. MARK ALL UNUSED CIRCUIT BREAKERS AS "SPARE"
- 9. CONTRACTOR TO TAG ALL CIRCUITS AT BOTH ENDS AFFECTED BY THIS SCOPE OF WORK.
- 10. CONTRACTOR SHALL PROVIDE UPDATED, TYPED—IN DIRECTORIES FOR ALL PANELS AFFECTED BY THIS SCOPE OF WORK.
- 11. CONTRACTOR SHALL VERIFY ALL UNDERGROUND AND IN—SLAB UTILITIES LOCATIONS PRIOR TO SAW CUTTING OR PENETRATING ANY FLOOR SLABS. CONTRACTOR SHALL REPAIR ALL UTILITIES DAMAGED BY SAW CUTTING.

DEMOLITION KEYED NOTES

1. MECHANICAL EQUIPMENT TO BE REMOVED. REMOVE CIRCUITING COMPLETE BACK TO SOURCE.



POWER GENERAL NOTES

- ALL RECEPTACLES ON EXTERIOR, IN KITCHEN, IN CONCESSION, IN LABORATORY, AND WITHIN 6'-0" OF SINK OR OTHER WATER SUPPLY SHALL BE READILY ACCESSIBLE GFCI TYPE RECEPTACLE.
- 2. ALL CONDUITS SERVING 120 VOLTS OR GREATER SHALL INCLUDE A GROUND
- 3. ALL CONDUITS SHALL BE ROUTED CONCEALED UNLESS NOTED OTHERWISE.
- 4. ALL 120 VOLT CIRCUITS SHALL UTILIZE A SEPARATE NEUTRAL.

Panel Designation	: (E) F	PANI	EL B			٨	۸ai	n: M	LO				P-P V	'oltage:	208				
Panel Location														'oltage:					
Fed From			01		G	round		_		V DL)			1 -14 4	Phase					
Feeder Size		_			O.	Noun								Wire	<u> </u>				
reeder size	• EXIONN	G						9: 30 al: [] (∠ E		60 1-1-	19		'				
	1	I									1				EXISTING				
Remarks	Light Load	Recept Load	Cont Load	nonC Load	OC Prot	СКТ	Ø A	Ø Ø B C	СКТ	OC Prot	nonC Load	Cont Load	Recept Load	Light Load	Remarks				
existing load	500				20	1	X		2	20	500				EXISTING LOAD				
EXISTING LOAD				1000	20	3		Х	4	20	500				existing load				
EXISTING LOAD				1000	20	5		X	6		1200								
existing load	500				20	7			8	20	1200				existing load				
EXISTING LOAD				1000	20	9		Х	10		1200								
2/10/11/10 E0/10				1000		11		X		20					SPARE				
				3086		13		\perp	14	20	500				existing load				
RTU-1				3086	40	15		Х	16	20	500				existing load				
				3086		17		X		20	180				GFI ROOFTOP RECEPTACLE				
EXISTING LOAD	500				20	19			20						SPACE				
SPARE					20	21		Х	22						SPACE				
SPARE					20	23		X		20					SPARE				
SPARE					20	25			26	20					SPARE				
SPARE					20	27		Х	28	20					SPARE				
SPARE					20	29		X		20					SPARE				
SPARE					20	31	_		32	20					SPARE				
SPARE					20	33		x	34	20					SPARE				
SPARE					20	35		X	36	20					SPARE				
SPARE					20	37	X		38	20					SPARE				
Spare					20	39		Х	40	20					SPARE				
SPARE					20	41		X	42	20					SPARE				
		Connect	ed Load	1			Der	nand				Deman	d Load	l	1				
Load Description	ØA	ØB	ØC	Total	-			ctor			ØA	ØB	ØC	Total					
Lighting or Continous Load (Volt-Amps)	1500	0	0	1500				.25			1875	0	0	1875					
180VA Receptacle Load (Volt-Amps)	0	0	0	0		1.00		st 101	KVA)		0	0	0	0	Receptacle Demand Factor per				
		ount ove		0			<u> </u>	> 10k			0	0	0	0	Article 220.44 of the National Electrical				
Continuous Load (Volt-Amps)	0	0	0	0				.25			0	0	0	0	Code.				
Non-Continuous Load (Volt-Amps)	5286	7286	6466	19038				.00			5286	7286	6466	19038					
Total Load (kVA)	6.79	7.29	6.47	20.54	125%	of Lia			and R	ecept	7.16	7.29	6.47	20.91					
Total Ampacity (Amps)	56.5	60.7	53.8	57.0	₹	(VA) Id				-	59.6	60.7	53.8	58.0	1				
Minimum Feeder Sizing (Amps)	60.4	60.7	53.8	58.3	< I	-		•				60.7	53.8	59.3	1				



Strategic Energy Solutions®
4000 W. Eleven Mile Road Berkley, MI 48072
Phone 248.399.1900 Fax 248.399.1901

© 2023 SES, INC. SES Project #23 0939 01

www.sesnet.com

CLIENT:


MIDLAND PUBLIC SCHOOLS

600 East Carpenter Street Midland, MI 48640

PROJECT

MIDLAND PUBLIC SCHOOLS
TRANSPORTATION
BUILDING - AHU/RTU
REPLACEMENT

410 East Hines Road Midland, MI 48640



Seal:

ISSUED FOR:
BIDS/PERMITS

01/22/24

ISSUED DATE

DESIGNER: GBS
ENGINEER: SE


SHEET TITLE:

ELECTRICAL PLANS -TRANSPORTATION BUILDING

SHEET NUMBER:

E1.1TB

Drawing: S:\23 0939 01 Midland Public Schools Misc Mechanical Projects\CAD\Elec\23 0939 01_E1.1TB.dwg






TO SOURCE.

ELECTRICAL DEMOLITION NOTES

- 1. VISIT THE SITE PRIOR TO SUBMISSION OF BID TO EXAMINE THE EXISTING CONDITIONS AND THE EXTENT OF DEMOLITION WORK.
- 2. EXAMINE THE DRAWINGS OF OTHER TRADES, BE FAMILIAR WITH THE DEMOLITION REQUIRED BY OTHER TRADES.
- PERFORM ALL INCIDENTAL ELECTRICAL DEMOLITION AND/OR RELOCATION OF DEVICES AND EQUIPMENT REQUIRED TO FACILITATE THE DEMOLITION WORK OF OTHER TRADES.
 COORDINATE WITH NEW WORK PLANS, ONE LINE, AND RISER DIAGRAMS FOR EXTENT OF DEMOLITION WORK.
- 5. COORDINATE ANY SHUTDOWN OF EXISTING SERVICES AND EQUIPMENT REMAINING IN USE WITH OWNERS' REPRESENTATIVE. WHERE EXISTING BUILDING SERVICE IS REQUIRED TO BE SHUT DOWN, INCLUDE ALL ASSOCIATED OVERTIME COST TO PERFORM THIS WORK DURING EVENING AND WEEKENDS. INCLUDE ALL COSTS FOR PROVIDING TEMPORARY POWER.
- 6. REMOVE ALL CONDUIT AND WIRE BACK TO NEAREST UPSTREAM DEVICE REMAINING IN SERVICE.
- 7. WHERE DEMOLITION WORK AFFECTS ELECTRICAL SERVICE TO DOWNSTREAM DEVICES TO REMAIN; EXTEND CONDUIT AND WIRE AS REQUIRED TO MAINTAIN ELECTRICAL SERVICE.
- 8. PROVIDE BLANK COVER PLATES WHERE SWITCHES AND DEVICES ARE REMOVED AND WALL REMAINS INTACT. MARK ALL UNUSED CIRCUIT BREAKERS AS "SPARE"
- 9. CONTRACTOR TO TAG ALL CIRCUITS AT BOTH ENDS AFFECTED BY THIS SCOPE OF WORK.
- 10. CONTRACTOR SHALL PROVIDE UPDATED, TYPED—IN DIRECTORIES FOR ALL PANELS AFFECTED BY THIS SCOPE OF WORK.
- 11. CONTRACTOR SHALL VERIFY ALL UNDERGROUND AND IN—SLAB UTILITIES LOCATIONS PRIOR TO SAW CUTTING OR PENETRATING ANY FLOOR SLABS. CONTRACTOR SHALL REPAIR ALL UTILITIES DAMAGED BY SAW CUTTING.



1. MECHANICAL EQUIPMENT TO BE REMOVED. REMOVE CIRCUITING COMPLETE BACK





POWER GENERAL NOTES

- 1. ALL RECEPTACLES ON EXTERIOR, IN KITCHEN, IN CONCESSION, IN LABORATORY, AND WITHIN 6'-0" OF SINK OR OTHER WATER SUPPLY SHALL BE READILY ACCESSIBLE GFCI TYPE RECEPTACLE.
- 2. ALL CONDUITS SERVING 120 VOLTS OR GREATER SHALL INCLUDE A GROUND
- 3. ALL CONDUITS SHALL BE ROUTED CONCEALED UNLESS NOTED OTHERWISE.
- 4. ALL 120 VOLT CIRCUITS SHALL UTILIZE A SEPARATE NEUTRAL.



Strategic Energy Solutions®
4000 W. Eleven Mile Road Berkley, MI 48072
Phone 248.399.1900 Fax 248.399.1901
www.sesnet.com

© 2023 SES, INC. SES Project #23 0939 01

CLIENT:


Midland, MI 48640

MIDLAND PUBLIC SCHOOLS
600 East Carpenter Street

PROJE

MIDLAND PUBLIC SCHOOLS
TRANSPORTATION
BUILDING - AHU/RTU
REPLACEMENT

410 East Hines Road Midland, MI 48640



Seal:

ISSUED FOR:
BIDS/PERMITS
01/22/24

ISSUED DATE

DESIGNER:
ENGINEER:

SHEET TITLE:

ELECTRICAL ROOF PLANS -TRANSPORTATION BUILDING

SHEET NUMBER:

E1.2TB