

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Country Parkway								
Location	101 Classroom Sink # 1	102 Classroom Sink #1	107 Classroom Sink	108 Classroom Sink	110 Classroom Sink	Speech Office Sink	116 Classroom Sink	117 Classroom Sink
Results	18.10	25.60	18.20	19.40	25.00	19.60	16.00	29.00
Remediation								
Results								
Results								
Results								
Back in use								
Location	121 Classroom Sink	123 Classroom Sink	122 Classroom Sink	124 Classroom Sink	125 Classroom Sink	127 Classroom Sink	12 Kitchen Bathroom Sink	
Results	19.70	18.90	24.60	15.60	20.00	15.50	35.90	
Remediation								
Results								
Back in use								
Back in use								

Williamsville Central School District
New York State Public School District
Water Testing for Lead Report (5/27/2021)

School	Number of Samples Tested (1)	Number of above 15ppb	Location of Samples Tested above 15ppb												Received All Results Yes - No
			Drinking Fountains	Student Lavatories	Classroom Faucets	Classroom Fountains	Science-Tech Classroom	Student-staff Showers/ Locker rooms	Office Sinks	Staff Lavatories	Custodial Outlets	Child Nutrition Faucets	Pool Faucets	Outdoor Faucets	
Country Parkway	81	15	0	0	0	0	0	0	1	1	0	0	NA	NA	Yes
Dodge	91	4	0	2	0	0	0	0	0	0	2	0	NA	NA	Yes
Forest	93	8	0	2	5	0	0	0	1	0	0	0	NA	NA	Yes
Heim													NA	NA	
Maple East	96	7	0	0	3	0	0	1	1	0	2	0	NA	NA	Yes
Maple West	82	8	0	0	4	0	0	0	1	0	2	1	NA	NA	Yes
Casey middle															
Heim middle															
Mill middle															
Transit middle															
East high															
North high															
South high															
AIM building															
District office															
Total Samples	443	42	0	4	12	0	0	1	4	1	6	1	0	0	29

(1) New York State water testing parameters for lead require all water outlets to be tested after water has been stagnant in the water pipes and faucets for a minimum of eight hours. Flushing water through the water outlet is not permitted per the test

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Dodge								
Location	105 Bathroom Sink	144 Bathroom Sink	Basement Source	Basement Sink				
Results	18.10	18.50	42.70	43.50				
Remediation								
Results								
Back in use								
Location								
Results								
Remediation								
Results								
Back in use								

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107327. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107327

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description AIM-100
Girls Bathroom Sink
Collected: 6/12/2021 6:14:00 AM
Lab ID: 012107327-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.74	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:43

Client Sample Description AIM-101
Womens Faculty Lav Sink
Collected: 6/12/2021 6:14:00 AM
Lab ID: 012107327-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:44

Client Sample Description AIM-102
Mens Faculty Lav Sink
Collected: 6/12/2021 6:16:00 AM
Lab ID: 012107327-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:46

Client Sample Description AIM-103
Boys Lav Sink
Collected: 6/12/2021 6:16:00 AM
Lab ID: 012107327-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:47

Client Sample Description AIM-104
Storage Room Sink
Collected: 6/12/2021 6:17:00 AM
Lab ID: 012107327-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.98	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:48



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012107327
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107300. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-102
 Teachers Conference Room Sink
Collected: 6/5/2021 8:54:00 AM
Lab ID: 012107300-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:44

Client Sample Description CM-103
 Teachers Conference Room Mens Bathroom Sink
Collected: 6/5/2021 8:55:00 AM
Lab ID: 012107300-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:51

Client Sample Description CM-104
 Teachers Conference Room Womens Bathroom Sink
Collected: 6/5/2021 8:55:00 AM
Lab ID: 012107300-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.69	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:52

Client Sample Description CM-105
 Hallways Fountain Across from Room 221
Collected: 6/5/2021 8:54:00 AM
Lab ID: 012107300-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:54

Client Sample Description CM-106
 Boys Lav by Room 221 Sink #1
Collected: 6/5/2021 8:57:00 AM
Lab ID: 012107300-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.49	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-107
 Boys Lav by Room 221 Sink #2
Collected: 6/5/2021 8:57:00 AM
Lab ID: 012107300-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:56

Client Sample Description CM-108
 Boys Lav by Room 221 Sink #3
Collected: 6/5/2021 8:57:00 AM
Lab ID: 012107300-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:57

Client Sample Description CM-109
 Boys Lav by Room 221 Sink #4
Collected: 6/5/2021 9:00:00 AM
Lab ID: 012107300-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:59

Client Sample Description CM-110
 Girls Lav by Room 221 Sink #1
Collected: 6/5/2021 9:00:00 AM
Lab ID: 012107300-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:00

Client Sample Description CM-111
 Girls Lav by Room 221 Sink #2
Collected: 6/5/2021 9:00:00 AM
Lab ID: 012107300-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-112
 Girls Lav by Room 221 Sink #3
Collected: 6/5/2021 9:00:00 AM
Lab ID: 012107300-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:05

Client Sample Description CM-113
 Girls Lav by Room 221 Sink #4
Collected: 6/5/2021 9:00:00 AM
Lab ID: 012107300-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:09

Client Sample Description CM-117
 Room 201 Classroom Sink
Collected: 6/5/2021 9:01:00 AM
Lab ID: 012107300-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:10

Client Sample Description CM-118
 Hallway Fountain Across from Room 119
Collected: 6/5/2021 8:41:00 AM
Lab ID: 012107300-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:12

Client Sample Description CM-119
 Room 120 Classroom Sink
Collected: 6/5/2021 8:45:00 AM
Lab ID: 012107300-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-120
Room 121 Classroom Sink
Collected: 6/5/2021 8:45:00 AM
Lab ID: 012107300-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.16	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:14

Client Sample Description CM-121
Room 122 Classroom Sink
Collected: 6/5/2021 8:45:00 AM
Lab ID: 012107300-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:16

Client Sample Description CM-122
Boys Lav across from Attendance Sink #1
Collected: 6/5/2021 8:27:00 AM
Lab ID: 012107300-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:17

Client Sample Description CM-123
Boys Lav across from Attendance Sink #2
Collected: 6/5/2021 8:27:00 AM
Lab ID: 012107300-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.82	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:21

Client Sample Description CM-124
Boys Lav across from Attendance Sink #3
Collected: 6/5/2021 8:27:00 AM
Lab ID: 012107300-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-125 **Collected:** 6/5/2021 **Lab ID:** 012107300-0021
 Boys Lav across from Attendance Sink #4 8:27:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:27

Client Sample Description CM-126 **Collected:** 6/5/2021 **Lab ID:** 012107300-0022
 Girls Lav across from Attendance Sink #1 8:30:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:31

Client Sample Description CM-127 **Collected:** 6/5/2021 **Lab ID:** 012107300-0023
 Girls Lav across from Attendance Sink #2 8:30:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:32

Client Sample Description CM-128 **Collected:** 6/5/2021 **Lab ID:** 012107300-0024
 Girls Lav across from Attendance Sink #3 8:30:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.04	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:36

Client Sample Description CM-129 **Collected:** 6/5/2021 **Lab ID:** 012107300-0025
 Girls Lav across from Attendance Sink #4 8:30:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-130
 Room 114 Classroom Sink
Collected: 6/5/2021 8:35:00 AM
Lab ID: 012107300-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:39

Client Sample Description CM-131
 Faculty Bathroom Across from Room 113 Sink
Collected: 6/5/2021 8:33:00 AM
Lab ID: 012107300-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:40

Client Sample Description CM-132
 Room 113 Classroom Sink
Collected: 6/5/2021 8:34:00 AM
Lab ID: 012107300-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:42

Client Sample Description CM-133
 Room 112 Classroom Sink
Collected: 6/5/2021 8:34:00 AM
Lab ID: 012107300-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:43

Client Sample Description CM-134
 Clinic Sink
Collected: 6/5/2021 8:36:00 AM
Lab ID: 012107300-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-135
Clinic Bathroom Sink #1
Collected: 6/5/2021 8:36:00 AM
Lab ID: 012107300-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:45

Client Sample Description CM-136
Clinic Med Room Sink #2
Collected: 6/5/2021 8:36:00 AM
Lab ID: 012107300-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:52

Client Sample Description CM-137
Room 11 Classroom Sink
Collected: 6/5/2021 8:39:00 AM
Lab ID: 012107300-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:53

Client Sample Description CM-138
IMC Sink
Collected: 6/5/2021 8:39:00 AM
Lab ID: 012107300-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:55

Client Sample Description CM-139
Main Office Sink
Collected: 6/5/2021 8:25:00 AM
Lab ID: 012107300-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.45	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-140
Library Sink
Collected: 6/5/2021 8:24:00 AM
Lab ID: 012107300-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:57

Client Sample Description CM-141
Room 129 Classroom Sink
Collected: 6/5/2021 8:23:00 AM
Lab ID: 012107300-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.5	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 07:58

Client Sample Description CM-142
Room 130 Classroom Sink
Collected: 6/5/2021 8:22:00 AM
Lab ID: 012107300-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:00

Client Sample Description CM-143
Boys Locker Room Bathroom Sink #1
Collected: 6/5/2021 8:19:00 AM
Lab ID: 012107300-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.47	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:01

Client Sample Description CM-144
Boys Locker Room Bathroom Sink #2
Collected: 6/5/2021 8:20:00 AM
Lab ID: 012107300-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:02

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-147
 Hallway Fountain across from Room 131
Collected: 6/5/2021 8:16:00 AM
Lab ID: 012107300-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:36

Client Sample Description CM-148
 Room 132 Classroom Sink #1
Collected: 6/5/2021 8:11:00 AM
Lab ID: 012107300-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:43

Client Sample Description CM-149
 Room 132 Classroom Sink #2
Collected: 6/5/2021 8:11:00 AM
Lab ID: 012107300-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:44

Client Sample Description CM-150
 Room 132 Classroom Sink #3
Collected: 6/5/2021 8:11:00 AM
Lab ID: 012107300-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.23	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:46

Client Sample Description CM-151
 Room 132 Classroom Sink #4
Collected: 6/5/2021 8:11:00 AM
Lab ID: 012107300-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.9	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-152
Room 132 Classroom Sink #5
Collected: 6/5/2021 8:11:00 AM
Lab ID: 012107300-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.8	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:48

Client Sample Description CM-153
Room 133 Classroom Sink #1
Collected: 6/5/2021 8:07:00 AM
Lab ID: 012107300-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.35	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:49

Client Sample Description CM-154
Room 133 Classroom Sink #2
Collected: 6/5/2021 8:07:00 AM
Lab ID: 012107300-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.68	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:51

Client Sample Description CM-155
Room 133 Classroom Sink #3
Collected: 6/5/2021 8:07:00 AM
Lab ID: 012107300-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.69	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:52

Client Sample Description CM-156
Room 133 Classroom Sink #4
Collected: 6/5/2021 8:07:00 AM
Lab ID: 012107300-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.86	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-157
Stage Sink
Collected: 6/5/2021 7:50:00 AM
Lab ID: 012107300-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	96.8	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:56

Client Sample Description CM-158
Hallway Fountain Across from OT/PT
Collected: 6/5/2021 7:40:00 AM
Lab ID: 012107300-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:57

Client Sample Description CM-159
Room 138 Classroom Sink
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107300-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.93	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:01

Client Sample Description CM-161
Room 139 Classroom Sink #1
Collected: 6/5/2021 7:03:03 AM
Lab ID: 012107300-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:02

Client Sample Description CM-164
Room 140 Classroom Sink
Collected: 6/5/2021 7:29:00 AM
Lab ID: 012107300-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.94	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-165
Room 141 Classroom Sink
Collected: 6/5/2021 7:27:00 AM
Lab ID: 012107300-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:05

Client Sample Description CM-166
Room 144 Classroom Sink
Collected: 6/5/2021 7:25:00 AM
Lab ID: 012107300-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:06

Client Sample Description CM-167
Room 145 Classroom Sink
Collected: 6/5/2021 7:23:00 AM
Lab ID: 012107300-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:08

Client Sample Description CM-168
Room 147 Classroom Sink
Collected: 6/5/2021 7:22:00 AM
Lab ID: 012107300-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.89	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:14

Client Sample Description CM-169
Boys Lav by Room 147 Sink
Collected: 6/5/2021 7:20:00 AM
Lab ID: 012107300-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.20	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:16

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107300
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-170
Girls Lav by Room 147 Sink
Collected: 6/5/2021 7:21:00 AM
Lab ID: 012107300-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.17	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:17

Client Sample Description CM-171
Staff Lav by Room 152 Sink
Collected: 6/5/2021 7:19:00 AM
Lab ID: 012107300-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:45

Client Sample Description CM-172
Faculty Lounge Sink
Collected: 6/5/2021 7:13:00 AM
Lab ID: 012107300-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.9	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:47

Client Sample Description CM-173
Faculty Bathroom Sink #1
Collected: 6/5/2021 7:15:00 AM
Lab ID: 012107300-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	37.8	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:48

Client Sample Description CM-174
Faculty Bathroom Sink #2
Collected: 6/5/2021 7:15:00 AM
Lab ID: 012107300-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.38	1.00 µg/L	7/13/2021 VD	7/13/2021 KB 21:52



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012107300
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107329. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107329

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-175
 Teachers Conference Room Sink
Collected: 6/5/2021 7:00:00 AM
Lab ID: 012107329-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.0	1.00 µg/L	7/9/2021 VD	7/9/2021 11:37 VD

Client Sample Description CM-176
 Teachers Conference Room Mens Bathroom Sink
Collected: 6/5/2021 6:44:00 AM
Lab ID: 012107329-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/9/2021 VD	7/9/2021 11:38 VD

Client Sample Description CM-177
 Teachers Conference Room Womens Bathroom Sink
Collected: 6/5/2021 6:41:00 AM
Lab ID: 012107329-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	7/9/2021 VD	7/9/2021 11:46 VD

Client Sample Description CM-178
 Hallway Fountain Across from Room 221
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107329-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.35	1.00 µg/L	7/9/2021 VD	7/9/2021 11:47 VD

Client Sample Description CM-179
 Boys Lav by Room 221 # 1
Collected: 6/5/2021 6:31:00 AM
Lab ID: 012107329-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.61	1.00 µg/L	7/9/2021 VD	7/9/2021 11:49 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107329
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-180
 Storage Across from Girls Locker Room Sink #1
Collected: 6/5/2021 6:17:00 AM
Lab ID: 012107329-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.81	1.00 µg/L	7/9/2021 VD	7/9/2021 11:51 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description CM-181
 Storage Across from Girls Locker Room Sink #2
Collected: 6/5/2021 6:18:00 AM
Lab ID: 012107329-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	4.80	1.00 µg/L	7/9/2021 VD	7/9/2021 11:52 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description CM-183
 Girls Locker Room Bathroom Sink # 1
Collected: 6/5/2021 6:10:00 AM
Lab ID: 012107329-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.14	1.00 µg/L	7/9/2021 VD	7/9/2021 11:54 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description CM-184
 Girls Locker Room Bathroom Sink # 2
Collected: 6/5/2021 6:10:00 AM
Lab ID: 012107329-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.34	1.00 µg/L	7/9/2021 VD	7/9/2021 11:55 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description CM-185
 Girls Locker Room Bathroom Sink # 3
Collected: 6/5/2021 6:13:00 AM
Lab ID: 012107329-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	2.03	1.00 µg/L	7/9/2021 VD	7/9/2021 11:57 VD
-------	------	------	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107329

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-186
 Girls Locker Room Water Fountain
Collected: 6/5/2021 6:03:00 AM
Lab ID: 012107329-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/9/2021 VD	7/9/2021 12:01 VD

Client Sample Description CM-187
 Kitchen Sink #1
Collected: 6/5/2021 6:21:00 AM
Lab ID: 012107329-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.26	1.00 µg/L	7/16/2021 KB	7/16/2021 20:56 VD

Client Sample Description CM-188
 Kitchen Sink #2
Collected: 6/5/2021 6:23:00 AM
Lab ID: 012107329-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.36	1.00 µg/L	7/16/2021 KB	7/16/2021 21:00 VD

Client Sample Description CM-189
 Kitchen Sink #3
Collected: 6/5/2021 6:23:00 AM
Lab ID: 012107329-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.97	1.00 µg/L	7/16/2021 KB	7/16/2021 21:01 VD

Client Sample Description CM-190
 Kitchen Bathroom Sink
Collected: 6/5/2021 6:24:00 AM
Lab ID: 012107329-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.8	1.00 µg/L	7/16/2021 KB	7/16/2021 21:03 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107329

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-191
Boiler Room
Collected: 6/5/2021 9:06:00 AM
Lab ID: 012107329-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.31	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:04

Client Sample Description CM-192
Custodial Break Room Sink
Collected: 6/5/2021 9:05:00 AM
Lab ID: 012107329-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:05

Client Sample Description CM-193
Group Practice Room Sink
Collected: 6/5/2021 9:03:00 AM
Lab ID: 012107329-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:09

Client Sample Description CM-194
Mezzanine to Mechanicals Sink
Collected: 6/5/2021 6:35:00 AM
Lab ID: 012107329-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	65.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:10

Client Sample Description CM-195
Hallway Fountain Across from Room 157
Collected: 6/5/2021 6:35:00 AM
Lab ID: 012107329-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107329

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CM-196
 Room 157 Bathroom Sink
Collected: 6/5/2021 6:41:00 AM
Lab ID: 012107329-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.86	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:13

Client Sample Description CM-197
 Womens staff lav across from Room 156 Sink #2
Collected: 6/5/2021 7:45:00 AM
Lab ID: 012107329-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.25	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:14

Client Sample Description CM-198
 Room 134 Sink # 1
Collected: 6/5/2021 8:03:00 AM
Lab ID: 012107329-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:18

Client Sample Description CM-199
 Room 134 Sink # 2
Collected: 6/5/2021 8:03:00 AM
Lab ID: 012107329-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.43	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:20

Client Sample Description CM-200
 Room 134 Sink # 3
Collected: 6/5/2021 8:03:00 AM
Lab ID: 012107329-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:21

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107329

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		CM-201 Room 134 Sink # 4	Collected:	6/5/2021 8:03:00 AM	Lab ID:	012107329-0026	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	13.8	1.00 µg/L	7/16/2021	KB	7/16/2021 21:25	VD
Client Sample Description		CM-202 Room 119 Sink	Collected:	6/5/2021 8:43:00 AM	Lab ID:	012107329-0027	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	7/16/2021	KB	7/16/2021 21:26	VD
Client Sample Description		CM-203 Room 124 Sink	Collected:	6/5/2021 8:48:00 AM	Lab ID:	012107329-0028	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	7/16/2021	KB	7/16/2021 21:27	VD
Client Sample Description		CM-204 Room 214 Sink	Collected:	6/5/2021 8:56:00 AM	Lab ID:	012107329-0029	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	7/16/2021	KB	7/16/2021 21:29	VD

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012105003. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-100
 Hallway Fountain Across from Room 100
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012105003-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:49

Client Sample Description CP-101
 Room 100 Classroom Sink
Collected: 5/1/2021 6:15:00 AM
Lab ID: 012105003-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.74	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:53

Client Sample Description CP-103
 Library Office Sink
Collected: 5/1/2021 6:38:00 AM
Lab ID: 012105003-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:55

Client Sample Description CP-104
 Room 101 Classrom Sink #1
Collected: 5/1/2021 6:17:00 AM
Lab ID: 012105003-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:56

Client Sample Description CP-105
 Room 101 Classrom Sink #2
Collected: 5/1/2021 6:20:00 AM
Lab ID: 012105003-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-107
 Room 102 Classrom Sink #1
Collected: 5/1/2021 6:21:00 AM
Lab ID: 012105003-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	25.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:01

Client Sample Description CP-108
 Room 102 Classrom Sink #2
Collected: 5/1/2021 6:22:00 AM
Lab ID: 012105003-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.29	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:03

Client Sample Description CP-110
 Room 103 Classrom Sink
Collected: 5/1/2021 6:23:00 AM
Lab ID: 012105003-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:04

Client Sample Description CP-112
 Room 104 Classrom Sink
Collected: 5/1/2021 6:25:00 AM
Lab ID: 012105003-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.42	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:05

Client Sample Description CP-114
 Room 105 Classrom Sink
Collected: 5/1/2021 6:25:00 AM
Lab ID: 012105003-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.01	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-116
Room 106 Classrom Sink
Collected: 5/1/2021 6:26:00 AM
Lab ID: 012105003-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.2	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:08

Client Sample Description CP-118
Room 107 Classrom Sink
Collected: 5/1/2021 6:28:00 AM
Lab ID: 012105003-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.2	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:12

Client Sample Description CP-120
Room 108 Classrom Sink
Collected: 5/1/2021 6:30:00 AM
Lab ID: 012105003-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.4	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:16

Client Sample Description CP-122
Room 109 Classrom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012105003-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.99	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:17

Client Sample Description CP-124
Room 110 Classrom Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012105003-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	25.0	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-126
 Room 111 Classrom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012105003-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.82	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:20

Client Sample Description CP-128
 Room 112 Classrom Sink
Collected: 5/1/2021
Lab ID: 012105003-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.30	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:21

Client Sample Description CP-130
 Room 113 Classrom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012105003-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.2	1.00 µg/L	5/20/2021 JD	5/21/2021 JW 14:02

Client Sample Description CP-132
 Room 114 Classrom Sink
Collected: 5/1/2021 6:37:00 AM
Lab ID: 012105003-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.43	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:22

Client Sample Description CP-134
 Room 115 Classrom Sink
Collected: 5/1/2021 6:39:00 AM
Lab ID: 012105003-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.65	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-136
 Hallway Fountain Across from Room 115
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012105003-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:25

Client Sample Description CP-137
 Speech Office Sink
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012105003-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:33

Client Sample Description CP-138
 Main Office Sink
Collected: 5/1/2021 6:44:00 AM
Lab ID: 012105003-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:36

Client Sample Description CP-139
 Boys Bathroom Main Hallway
Collected: 5/1/2021 7:35:00 AM
Lab ID: 012105003-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.61	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:38

Client Sample Description CP-140
 Clinic Sink
Collected: 5/1/2021 6:44:00 AM
Lab ID: 012105003-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.83	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-141
Clinic Bathroom Sink
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012105003-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.98	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:40

Client Sample Description CP-142
Main Office Bathroom Sink
Collected: 5/1/2021 6:46:00 AM
Lab ID: 012105003-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:42

Client Sample Description CP-145
Boys Locker Room Bathroom Sink #1
Collected: 5/1/2021 7:28:00 AM
Lab ID: 012105003-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.18	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:43

Client Sample Description CP-146
Girls Locker Room Bathroom Sink #1
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012105003-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.18	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:47

Client Sample Description CP-147
Girls Locker Room Bathroom Sink #2
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012105003-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.06	1.00 µg/L	5/20/2021 JD	5/21/2021 JW 14:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-148
 Hallway Fountain by Computer Lab in 4th Grade
Collected: 5/1/2021 6:51:00 AM
Lab ID: 012105003-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:48

Client Sample Description CP-149
 Café Sink
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012105003-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.22	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:50

Client Sample Description CP-150
 Faculty Lounge Sink
Collected: 5/1/2021 6:52:00 AM
Lab ID: 012105003-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.24	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:51

Client Sample Description CP-151
 Room 116 Classrom Sink
Collected: 5/1/2021 6:52:00 AM
Lab ID: 012105003-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.0	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:55

Client Sample Description CP-153
 Room 117 Classrom Sink
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012105003-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.0	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-155
 Room 118 Classrom Sink
Collected: 5/1/2021 6:54:00 AM
Lab ID: 012105003-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:57

Client Sample Description CP-157
 Room 119 Classrom Sink
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012105003-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 02:59

Client Sample Description CP-158
 Room 120 Classrom Sink
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012105003-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.70	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:03

Client Sample Description CP-160
 Room 121 Classrom Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012105003-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.7	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:04

Client Sample Description CP-162
 Room 123 Classrom Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012105003-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:05

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-164
 Room 122 Classrom Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012105003-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	24.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:07

Client Sample Description CP-166
 Room 124 Classrom Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012105003-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.6	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 03:08

Client Sample Description CP-168
 Room 125 Classrom Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012105003-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.0	1.00 µg/L	5/20/2021 JD	5/21/2021 JW 14:06

Client Sample Description CP-170
 Room 126 Classrom Sink
Collected: 5/1/2021 7:01:00 AM
Lab ID: 012105003-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.14	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:36

Client Sample Description CP-172
 Room 127 Classrom Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012105003-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.5	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-174
 Room 128 Classrom Sink
Collected: 5/1/2021 7:01:00 AM
Lab ID: 012105003-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:44

Client Sample Description CP-176
 Room 129 Classrom Sink
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012105003-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:45

Client Sample Description CP-178
 Hallway Fountain Across from Room 129
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012105003-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:46

Client Sample Description CP-179
 Room 150 Classrom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012105003-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.99	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:47

Client Sample Description CP-180
 Hallway Fountain Across from Room 139
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012105003-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:49

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-181
 Boys Bathroom Across from Room 139 Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012105003-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.86	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:50

Client Sample Description CP-182
 Boys Bathroom Across from Room 139 Sink
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012105003-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:51

Client Sample Description CP-183
 OT/PT Classroom Sink
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012105003-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:53

Client Sample Description CP-184
 Faculty Bathroom Sink #1
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012105003-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 13:57

Client Sample Description CP-185
 Faculty Bathroom Sink #2
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012105003-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.18	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105003
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-186
Room 130 Classroom Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012105003-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.19	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:02

Client Sample Description CP-188
Room 131 Classroom Sink
Collected: 5/1/2021 7:13:00 AM
Lab ID: 012105003-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.02	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:03

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104884. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104884

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-190
 Room 132 Classroom Sink
Collected: 5/1/2021 7:14:00 AM
Lab ID: 012104884-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.63	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:00

Client Sample Description CP-192
 Room 133 Classroom Sink
Collected: 5/1/2021
Lab ID: 012104884-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.90	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:04

Client Sample Description CP-194
 Room 134 Classroom Sink
Collected: 5/1/2021 7:17:00 AM
Lab ID: 012104884-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:06

Client Sample Description CP-196
 Room 135 Classroom Sink
Collected: 5/1/2021 7:16:00 AM
Lab ID: 012104884-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:07

Client Sample Description CP-198
 Room 136 Classroom Sink
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104884-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:08

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104884
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-200
Room 136 Classroom Sink
Collected: 5/1/2021 7:32:00 AM
Lab ID: 012104884-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:12

Client Sample Description CP-201
Room 138 Classroom Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104884-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:13

Client Sample Description CP-202
Room 139 Classroom Sink
Collected: 5/1/2021 7:09:00 AM
Lab ID: 012104884-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.55	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:15

Client Sample Description CP-203
Girls Bathroom Main Hallway Sink #1
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104884-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.73	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:16

Client Sample Description CP-204
Girls Bathroom Main Hallway Sink #2
Collected: 5/1/2021
Lab ID: 012104884-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:17

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104884

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-205
 Girls Bathroom Main Hallway Sink #3
Collected: 5/1/2021
Lab ID: 012104884-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.75	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:19

Client Sample Description CP-206
 Girls Bathroom Main Hallway Sink #4
Collected: 5/1/2021
Lab ID: 012104884-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.13	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:23

Client Sample Description CP-207
 Boys Bathroom Main Hallway Sink #1
Collected: 5/1/2021
 7:22:00 AM
Lab ID: 012104884-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.40	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:24

Client Sample Description CP-208
 Boys Bathroom Main Hallway Sink #2
Collected: 5/1/2021
 7:22:00 AM
Lab ID: 012104884-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:28

Client Sample Description CP-209
 Boys Bathroom Main Hallway Sink #3
Collected: 5/1/2021
 7:22:00 AM
Lab ID: 012104884-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.85	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104884

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-210 Boys Bathroom Main Hallway Sink #4
Collected: 5/1/2021 7:23:00 AM
Lab ID: 012104884-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.23	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:30

Client Sample Description CP-211 Handicapped Bathroom by Kitchen Sink
Collected: 5/1/2021 7:25:00 AM
Lab ID: 012104884-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:32

Client Sample Description CP-212 Kitchen Bathroom Sink
Collected: 5/1/2021 7:25:00 AM
Lab ID: 012104884-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	35.9	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:33

Client Sample Description CP-213 Kitchen Sink #1
Collected: 5/1/2021
Lab ID: 012104884-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.11	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:34

Client Sample Description CP-214 Kitchen Sink #2
Collected: 5/1/2021 7:29:00 AM
Lab ID: 012104884-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104884

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description CP-215 Kitchen Sink #3 **Collected:** 5/1/2021 7:29:00 AM **Lab ID:** 012104884-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:35

Client Sample Description CP-216 Boiler Room Source **Collected:** 5/1/2021 7:33:00 AM **Lab ID:** 012104884-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:36

Client Sample Description CP-217 Custodial Bathroom Sink **Collected:** 5/1/2021 7:33:00 AM **Lab ID:** 012104884-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.03	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:37

Client Sample Description CP-218 Faculty Mail Room Sink **Collected:** 5/1/2021 6:49:00 AM **Lab ID:** 012104884-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:39

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107275. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107275
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DO-100
Lav by Central Printing
Collected: 6/5/2021 6:48:00 AM
Lab ID: 012107275-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.95	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 15:49

Client Sample Description DO-101
Central Printing Sink
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107275-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.1	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 15:54

Client Sample Description DO-102
Staff Lounge Sink
Collected: 6/5/2021 6:51:00 AM
Lab ID: 012107275-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.61	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 15:56

Client Sample Description DO-103
Womens Lav by Conference Room Sink # 1
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107275-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.75	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 15:58

Client Sample Description DO-104
Womens Lav by Conference Room Sink # 2
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107275-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.71	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107275

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DO-105
 Hall fountain Near IT Conference Room
Collected: 6/5/2021 7:00:00 AM
Lab ID: 012107275-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:06

Client Sample Description DO-106
 Lav by Conference Room C Sink
Collected: 6/5/2021 7:01:00 AM
Lab ID: 012107275-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:08

Client Sample Description DO-107
 Male Lav across from Broad Room Sink # 1
Collected: 6/5/2021 7:03:00 AM
Lab ID: 012107275-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.23	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:10

Client Sample Description DO-108
 Male Lav across from Broad Room Sink # 2
Collected: 6/5/2021 7:03:00 AM
Lab ID: 012107275-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.74	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:11

Client Sample Description DO-109
 Female Lav across from Broad Room Sink # 1
Collected: 6/5/2021 7:06:00 AM
Lab ID: 012107275-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107275
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DO-110 **Collected:** 6/5/2021 **Lab ID:** 012107275-0011
Female Lav across from Broad Room Sink # 2 7:06:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:15

Client Sample Description DO-111 **Collected:** 6/5/2021 **Lab ID:** 012107275-0012
Hallwat Fountain by HR 7:08:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:21

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104945. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-100
 Hallway Fountain by Main Office
Collected: 5/1/2021 6:30:00 AM
Lab ID: 012104945-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:54

Client Sample Description DE-101
 Room 120 Bathroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104945-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.34	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:58

Client Sample Description DE-102
 Room 103 Classroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104945-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.87	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:00

Client Sample Description DE-104
 Room 103 Bathroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104945-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.09	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:01

Client Sample Description DE-105
 Room 106 Bathroom Sink
Collected: 5/1/2021 6:39:00 AM
Lab ID: 012104945-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.05	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:05

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		DE-107 Room 106 Bathroom Sink	Collected:		5/1/2021 6:45:00 AM	Lab ID:		012104945-0006
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	14.7	1.00 µg/L		5/20/2021	VD	5/20/2021 22:06	VD
Client Sample Description		DE-108 Room 105 Bathroom Sink	Collected:		5/1/2021 6:43:00 AM	Lab ID:		012104945-0007
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/20/2021	VD	5/20/2021 22:07	VD
Client Sample Description		DE-110 Room 105 Bathroom Sink	Collected:		5/1/2021 7:00:00 AM	Lab ID:		012104945-0008
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	18.1	1.00 µg/L		5/20/2021	VD	5/20/2021 22:09	VD
Client Sample Description		DE-111 Room 108 Bathroom Sink	Collected:		5/1/2021 6:57:00 AM	Lab ID:		012104945-0009
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/20/2021	VD	5/20/2021 22:10	VD
Client Sample Description		DE-113 Room 108 Bathroom Sink	Collected:		5/1/2021 6:57:00 AM	Lab ID:		012104945-0010
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	9.64	1.00 µg/L		5/20/2021	VD	5/20/2021 22:11	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		DE-114 Room 107 Bathroom Sink	Collected:		5/1/2021 6:52:00 AM	Lab ID:		012104945-0011
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	1.77	1.00 µg/L		5/20/2021	VD	5/20/2021 22:13	VD

Client Sample Description		DE-116 Room 107 Bathroom Sink	Collected:		5/1/2021 6:52:00 AM	Lab ID:		012104945-0012
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	9.90	1.00 µg/L		5/20/2021	VD	5/20/2021 22:17	VD

Client Sample Description		DE-117 Room 110 Bathroom Sink	Collected:		5/1/2021 6:52:00 AM	Lab ID:		012104945-0013
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	2.14	1.00 µg/L		5/20/2021	VD	5/20/2021 22:21	VD

Client Sample Description		DE-119 Room 110 Bathroom Sink	Collected:		5/1/2021 6:51:00 AM	Lab ID:		012104945-0014
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	1.60	1.00 µg/L		5/20/2021	VD	5/20/2021 22:22	VD

Client Sample Description		DE-120 Room 109 Bathroom Sink	Collected:		5/1/2021 6:54:00 AM	Lab ID:		012104945-0015
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	2.67	1.00 µg/L		5/20/2021	VD	5/20/2021 22:23	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		DE-122 Room 109 Bathroom Sink	Collected:		5/1/2021 6:54:00 AM	Lab ID:		012104945-0016
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	11.6	1.00 µg/L		5/20/2021	VD	5/20/2021 22:24	VD
Client Sample Description		DE-123 Room 112 Bathroom Sink	Collected:		5/1/2021 6:55:00 AM	Lab ID:		012104945-0017
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	3.97	1.00 µg/L		5/20/2021	VD	5/20/2021 22:26	VD
Client Sample Description		DE-125 Room 112 Bathroom Sink	Collected:		5/1/2021 6:55:00 AM	Lab ID:		012104945-0018
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	9.87	1.00 µg/L		5/20/2021	VD	5/20/2021 22:27	VD
Client Sample Description		DE-126 Room 121 Bathroom Sink #1	Collected:		5/1/2021 7:02:00 AM	Lab ID:		012104945-0019
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/20/2021	VD	5/20/2021 22:28	VD
Client Sample Description		DE-127 Room 121 Bathroom Sink #2	Collected:		5/1/2021 7:02:00 AM	Lab ID:		012104945-0020
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/20/2021	VD	5/20/2021 22:30	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-128
 Room 122 Bathroom Sink
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012104945-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:40

Client Sample Description DE-130
 Room 123 Bathroom Sink
Collected: 5/1/2021 7:04:00 AM
Lab ID: 012104945-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:44

Client Sample Description DE-131
 Room 124 Bathroom Sink
Collected: 5/1/2021 7:04:00 AM
Lab ID: 012104945-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:45

Client Sample Description DE-133
 Room 125 Bathroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104945-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:47

Client Sample Description DE-135
 Room 126 Bathroom Sink
Collected: 5/1/2021 7:06:00 AM
Lab ID: 012104945-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-137
Room 127 Bathroom Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012104945-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:52

Client Sample Description DE-139
Room 128 Bathroom Sink
Collected: 5/1/2021
Lab ID: 012104945-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:53

Client Sample Description DE-141
Room 129 Bathroom Sink
Collected: 5/1/2021 7:09:00 AM
Lab ID: 012104945-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:55

Client Sample Description DE-143
Hallway Fountain Across from Room 121
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012104945-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:56

Client Sample Description DE-144
Mens Bathroom by Room 121 Sink
Collected: 5/1/2021 7:11:00 AM
Lab ID: 012104945-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-145
 Womens Bathroom by Room 121 Sink
Collected: 5/1/2021 7:11:00 AM
Lab ID: 012104945-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 22:58

Client Sample Description DE-146
 Mens Bathroom by Room 120 Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104945-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:02

Client Sample Description DE-147
 Womens Bathroom by Room 120 Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104945-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:04

Client Sample Description DE-148
 Room 120 Bathroom Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104945-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:08

Client Sample Description DE-149
 Café Sink
Collected: 5/1/2021 7:14:00 AM
Lab ID: 012104945-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-150
Café Fountain
Collected: 5/1/2021 7:14:00 AM
Lab ID: 012104945-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:10

Client Sample Description DE-151
Clinic Sink
Collected: 5/1/2021 7:16:00 AM
Lab ID: 012104945-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.2	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:12

Client Sample Description DE-152
Clinic Bathroom Sink
Collected: 5/1/2021 7:16:00 AM
Lab ID: 012104945-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:13

Client Sample Description DE-153
Mens Bathroom across from Gym Sink
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104945-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:14

Client Sample Description DE-154
Womens Bathroom across from Gym Sink
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104945-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-155 **Collected:** 5/1/2021 **Lab ID:** 012104945-0041
 Boys Locker Room Sink #1 7:15:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:23

Client Sample Description DE-156 **Collected:** 5/1/2021 **Lab ID:** 012104945-0042
 Boys Locker Room Sink #2 7:15:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.48	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:27

Client Sample Description DE-157 **Collected:** 5/1/2021 **Lab ID:** 012104945-0043
 Boys Locker Room Coaches Office Sink 7:20:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:29

Client Sample Description DE-158 **Collected:** 5/1/2021 **Lab ID:** 012104945-0044
 Boys Bathroom by Room 137 Sink #1 7:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.44	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:30

Client Sample Description DE-159 **Collected:** 5/1/2021 **Lab ID:** 012104945-0045
 Boys Bathroom by Room 137 Sink #2 7:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.35	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-160
 Boys Bathroom by Room 137 Sink #3
Collected: 5/1/2021 7:46:00 AM
Lab ID: 012104945-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:32

Client Sample Description DE-161
 Bathroom by Room 132 Sink #1
Collected: 5/1/2021 7:26:00 AM
Lab ID: 012104945-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.10	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:34

Client Sample Description DE-162
 Bathroom by Room 132 Sink #2
Collected: 5/1/2021 7:26:00 AM
Lab ID: 012104945-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.45	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:35

Client Sample Description DE-163
 Room 132 Classroom Sink
Collected: 5/1/2021 7:48:00 AM
Lab ID: 012104945-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:39

Client Sample Description DE-164
 Room 130 Classroom Sink
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012104945-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.96	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:40

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104945
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-165
Bathroom by Room 131 Sink #1
Collected: 5/1/2021 7:29:00 AM
Lab ID: 012104945-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.03	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:42

Client Sample Description DE-166
Bathroom by Room 131 Sink #2
Collected: 5/1/2021 7:30:00 AM
Lab ID: 012104945-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:45

Client Sample Description DE-169
Room 133 Classroom Sink
Collected: 5/1/2021 7:33:00 AM
Lab ID: 012104945-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:47

Definitions:

MDL - method detection limit
J - Result was below the reporting limit, but at or above the MDL
ND - indicates that the analyte was not detected at the reporting limit
RL - Reporting Limit (Analytical)
D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/25/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104885. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		DE-170 Room 135 Bathroom Sink	Collected: 5/1/2021 7:35:00 AM		Lab ID: 012104885-0001			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	3.37	1.00 µg/L		5/24/2021	VD	5/24/2021 16:41	VD
Client Sample Description		DE-171 Room 136 Bathroom Sink	Collected: 5/1/2021 7:35:00 AM		Lab ID: 012104885-0002			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	2.57	1.00 µg/L		5/24/2021	VD	5/24/2021 16:46	VD
Client Sample Description		DE-172 Room 137 Bathroom Sink	Collected: 5/1/2021 7:38:00 AM		Lab ID: 012104885-0003			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	9.98	1.00 µg/L		5/24/2021	VD	5/24/2021 16:48	VD
Client Sample Description		DE-173 Room 138 Bathroom Sink	Collected: 5/1/2021 7:37:00 AM		Lab ID: 012104885-0004			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	4.68	1.00 µg/L		5/24/2021	VD	5/24/2021 16:49	VD
Client Sample Description		DE-174 Room 117 Bathroom Sink	Collected: 5/1/2021 8:07:00 AM		Lab ID: 012104885-0005			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	3.01	1.00 µg/L		5/24/2021	VD	5/24/2021 16:51	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-176
 Hallway Fountain Across from Room 138
Collected: 5/1/2021 7:39:00 AM
Lab ID: 012104885-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 16:52

Client Sample Description DE-177
 Room 140 Bathroom Sink
Collected: 5/1/2021 7:39:00 AM
Lab ID: 012104885-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.53	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 16:54

Client Sample Description DE-179
 Room 141 Bathroom Sink
Collected: 5/1/2021 7:40:00 AM
Lab ID: 012104885-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.38	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 16:55

Client Sample Description DE-181
 Room 142 Bathroom Sink
Collected: 5/1/2021 7:41:00 AM
Lab ID: 012104885-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.86	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:00

Client Sample Description DE-183
 Room 143 Bathroom Sink
Collected: 5/1/2021 7:42:00 AM
Lab ID: 012104885-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.93	1.00 µg/L	5/24/2021 VD	5/25/2021 VD 08:50

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-185
Room 144 Bathroom Sink
Collected: 5/1/2021 7:43:00 AM
Lab ID: 012104885-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.5	1.00 µg/L	5/24/2021 VD	5/25/2021 VD 08:51

Client Sample Description DE-187
Room 145 Bathroom Sink
Collected: 5/1/2021 7:44:00 AM
Lab ID: 012104885-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.16	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:08

Client Sample Description DE-189
Room 200 Bathroom Sink
Collected: 5/1/2021 7:50:00 AM
Lab ID: 012104885-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.45	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:09

Client Sample Description DE-190
Room 202 Bathroom Sink
Collected: 5/1/2021 7:53:00 AM
Lab ID: 012104885-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.33	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:11

Client Sample Description DE-191
Room 204 Bathroom Sink
Collected: 5/1/2021 7:56:00 AM
Lab ID: 012104885-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-192
 Room 206 Bathroom Sink
Collected: 5/1/2021 7:57:00 AM
Lab ID: 012104885-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.41	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:17

Client Sample Description DE-193
 Room 207 Bathroom Sink
Collected: 5/1/2021 7:54:00 AM
Lab ID: 012104885-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.01	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:19

Client Sample Description DE-194
 Room 209 Bathroom Sink
Collected: 5/1/2021 7:56:00 AM
Lab ID: 012104885-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.74	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:20

Client Sample Description DE-195
 Room 211 Bathroom Sink
Collected: 5/1/2021 7:58:00 AM
Lab ID: 012104885-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.40	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:22

Client Sample Description DE-197
 Hallway Fountain Across from Room 202
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104885-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 17:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-198
 Basement Break Room Sink
Collected: 5/1/2021 8:09:00 AM
Lab ID: 012104885-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.19	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:25

Client Sample Description DE-199
 Basement Boiler Room Sample
Collected: 5/1/2021 8:09:00 AM
Lab ID: 012104885-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	42.7	1.00 µg/L	5/18/2021 JD	5/18/2021 JW 15:34

Client Sample Description DE-200
 Kitchen Bathroom Sink
Collected: 5/1/2021 8:06:00 AM
Lab ID: 012104885-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.1	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:30

Client Sample Description DE-201
 Kitchen Sink #1
Collected: 5/1/2021 8:04:00 AM
Lab ID: 012104885-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.57	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:31

Client Sample Description DE-202
 Kitchen Sink #2
Collected: 5/1/2021 8:04:00 AM
Lab ID: 012104885-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.80	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:33

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-203
 Kitchen Sink #3
Collected: 5/1/2021 8:04:00 AM
Lab ID: 012104885-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.48	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:34

Client Sample Description DE-204
 Kitchen Sink #4
Collected: 5/1/2021 8:04:00 AM
Lab ID: 012104885-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.57	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:39

Client Sample Description DE-205
 Girls Bathroom Across from Room 139 Sink #1
Collected: 5/1/2021 7:45:00 AM
Lab ID: 012104885-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:41

Client Sample Description DE-206
 Girls Bathroom Across from Room 139 Sink #2
Collected: 5/1/2021 7:45:00 AM
Lab ID: 012104885-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.50	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:42

Client Sample Description DE-207
 Girls Bathroom Across from Room 205 Sink #1
Collected: 5/1/2021 7:54:00 AM
Lab ID: 012104885-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.90	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-208
 Girls Bathroom Across from Room 205 Sink #2
Collected: 5/1/2021 7:54:00 AM
Lab ID: 012104885-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.90	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:45

Client Sample Description DE-209
 Girls Locker Room Sink #1
Collected: 5/1/2021 7:22:00 AM
Lab ID: 012104885-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.17	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:47

Client Sample Description DE-210
 Girls Locker Room Sink #2
Collected: 5/1/2021 7:22:00 AM
Lab ID: 012104885-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:51

Client Sample Description DE-211
 Girls Locker Room Sink #3
Collected: 5/1/2021 7:23:00 AM
Lab ID: 012104885-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:53

Client Sample Description DE-212
 Girls Coaches Office Bathroom Sink
Collected: 5/1/2021 7:23:00 AM
Lab ID: 012104885-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.55	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104885
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description DE-213 **Collected:** 5/1/2021 **Lab ID:** 012104885-0036
 Boys Bathroom Across from Room 211 Sink #1 7:59:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 09:59

Client Sample Description DE-214 **Collected:** 5/1/2021 **Lab ID:** 012104885-0037
 Boys Bathroom Across from Room 211 Sink #2 7:59:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 10:01

Client Sample Description DE-216 **Collected:** 5/1/2021 **Lab ID:** 012104885-0038
 Custodial Area Sink 8:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	43.5	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 10:02

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107324. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-100
Boiler Room Source Sample
Collected: 6/12/2021 6:15:00 AM
Lab ID: 012107324-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.72	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:13

Client Sample Description EH-101
Custodial Area Bathroom Sink
Collected: 6/12/2021 6:21:00 AM
Lab ID: 012107324-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.31	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:17

Client Sample Description EH-102
Pool Chemical Room eye wash
Collected: 6/12/2021 6:22:00 AM
Lab ID: 012107324-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2080 D	50.0 µg/L	7/9/2021 JD	7/12/2021 JW 20:22

Client Sample Description EH-103
Men Faculty Lav/Blue Com Sink
Collected: 6/12/2021 6:23:00 AM
Lab ID: 012107324-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:18

Client Sample Description EH-104
Women Faculty Lav/Blue Com Sink
Collected: 6/12/2021 6:24:00 AM
Lab ID: 012107324-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-105
 Green Girls Lav Sink # 1
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107324-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.56	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:23

Client Sample Description EH-106
 Green Girls Lav Sink # 2
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107324-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.55	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:24

Client Sample Description EH-107
 Green Boys Lav Sink # 1
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107324-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:26

Client Sample Description EH-108
 Green Boys Lav Sink # 2
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107324-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:27

Client Sample Description EH-110
 Water Fountain in Common # 2
Collected: 6/12/2021 6:29:00 AM
Lab ID: 012107324-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:28

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-111
 Water Fountain in Common # 3
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107324-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:30

Client Sample Description EH-112
 Kitchen Sink # 1
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107324-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:31

Client Sample Description EH-113
 Kitchen Sink # 2
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107324-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.00	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:35

Client Sample Description EH-114
 Kitchen Sink # 3
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107324-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.63	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 12:31

Client Sample Description EH-116
 Kitchen Sink # 5
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107324-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-117
 Kitchen Sink # 6
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107324-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:42

Client Sample Description EH-118
 Kitchen Sink # 7
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107324-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:43

Client Sample Description EH-119
 Kitchen Sink # 8
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107324-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	27.5	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:45

Client Sample Description EH-120
 Kitchen Sink # 9
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107324-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.62	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:46

Client Sample Description EH-121
 Kitchen Bathroom Sink
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107324-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.12	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-122
Room 102 Sink # 1
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107324-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:48

Client Sample Description EH-123
Room 103 Sink # 2
Collected: 6/12/2021 6:42:00 AM
Lab ID: 012107324-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.48	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 08:56

Client Sample Description EH-124
Room 103 Sink # 3
Collected: 6/12/2021 6:42:00 AM
Lab ID: 012107324-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.0	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:00

Client Sample Description EH-125
Room 103 Sink # 4
Collected: 6/12/2021 6:43:00 AM
Lab ID: 012107324-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:02

Client Sample Description EH-126
Room 101 Sink
Collected: 6/12/2021 6:42:00 AM
Lab ID: 012107324-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-127
Kiln Roon Sink
Collected: 6/12/2021 6:46:00 AM
Lab ID: 012107324-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:04

Client Sample Description EH-128
Room 108 Sink
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107324-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.16	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:05

Client Sample Description EH-129
Room 106 Sink
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107324-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.74	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:07

Client Sample Description EH-130
Room 117 Photo Sink # 1
Collected: 6/12/2021 6:36:00 AM
Lab ID: 012107324-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.87	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:11

Client Sample Description EH-131
Room 117 Photo Sink # 2
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107324-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.40	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-132
 Room 117 Photo Sink # 3
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107324-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:13

Client Sample Description EH-133
 Room 117 Photo Sink # 4
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107324-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	52.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:15

Client Sample Description EH-134
 Room 117 Photo Sink # 5
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107324-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.55	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:19

Client Sample Description EH-135
 Room 117 Photo Sink # 6
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107324-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	97.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:20

Client Sample Description EH-136
 Room 117 Photo Sink # 7
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107324-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	101 D	5.00 µg/L	7/15/2021 VD	7/16/2021 VD 12:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-137
 Room 117 Photo Sink # 8
Collected: 6/12/2021 6:39:00 AM
Lab ID: 012107324-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	44.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:22

Client Sample Description EH-138
 Boys Orange Lav Sink # 1
Collected: 6/12/2021 6:53:00 AM
Lab ID: 012107324-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.10	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:26

Client Sample Description EH-139
 Boys Orange Lav Sink # 2
Collected: 6/12/2021 6:53:00 AM
Lab ID: 012107324-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.74	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:28

Client Sample Description EH-140
 Boys Orange Lav Sink # 3
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107324-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:29

Client Sample Description EH-141
 Girls Red Lav Sink # 1
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107324-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-142
Girls Red Lav Sink # 2
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107324-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.14	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:32

Client Sample Description EH-143
Girls Red Lav Sink # 3
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107324-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:53

Client Sample Description EH-144
Room 119 Sink # 1
Collected: 6/12/2021 6:58:00 AM
Lab ID: 012107324-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	32.6	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:58

Client Sample Description EH-145
Room 119 Sink # 2
Collected: 6/12/2021 6:59:00 AM
Lab ID: 012107324-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.0	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:00

Client Sample Description EH-146
Room 119 Sink # 3
Collected: 6/12/2021 6:59:00 AM
Lab ID: 012107324-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	71.2	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-147
 Room 119 Sink # 4
Collected: 6/12/2021 6:57:00 AM
Lab ID: 012107324-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	50.4	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:08

Client Sample Description EH-148
 Room 119 Sink # 5
Collected: 6/12/2021 6:57:00 AM
Lab ID: 012107324-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.4	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:10

Client Sample Description EH-149
 Room 113 Sink
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107324-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	38.3	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:12

Client Sample Description EH-150
 Mens Lav by Aud Sink
Collected: 6/12/2021 7:02:00 AM
Lab ID: 012107324-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.2	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:13

Client Sample Description EH-151
 Health Office Sink # 1
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107324-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.8	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description EH-152
 Health Office Sink # 2
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107324-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.90	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:17

Client Sample Description EH-153
 Health Office Bathroom Sink
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107324-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.16	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:19

Client Sample Description EH-154
 Bathrm near school store sink
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107324-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.36	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:29

Client Sample Description EH-155
 Band Room Office Sink
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107324-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.70	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:30

Client Sample Description EH-157
 Boys Lav Music Sink
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107324-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.38	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107324

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-158 **Collected:** 6/12/2021 **Lab ID:** 012107324-0056
Ladies Lav Music Sink 7:05:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.68	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 19:34

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107291. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-159 **Collected:** 6/12/2021 **Lab ID:** 012107291-0001
 Womans PE Coaches Office Lav Sink 7:08:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:30

Client Sample Description EH-160 **Collected:** 6/12/2021 **Lab ID:** 012107291-0002
 Girls Yellow Locker Room Sink (Bradley) 7:09:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:31

Client Sample Description EH-161 **Collected:** 6/12/2021 **Lab ID:** 012107291-0003
 Boys Red Locker Room Sink (Bradley) 7:10:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:32

Client Sample Description EH-162 **Collected:** 6/12/2021 **Lab ID:** 012107291-0004
 Hallway Fountain by Team Rm 7:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:35

Client Sample Description EH-163 **Collected:** 6/12/2021 **Lab ID:** 012107291-0005
 Mens PE Coaches Office Sink #1 7:11:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.09	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-165
Boys Team Room #1 Sink
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107291-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:38

Client Sample Description EH-166
Small Blue Team Coach Rm #1Sink
Collected: 6/12/2021 7:15:00 AM
Lab ID: 012107291-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.78	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:39

Client Sample Description EH-167
B Team Coach Rm #1 Ice Mach
Collected: 6/12/2021 7:15:00 AM
Lab ID: 012107291-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:41

Client Sample Description EH-168
Big Blue Team Room #2 Sink
Collected: 6/12/2021 7:13:00 AM
Lab ID: 012107291-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:42

Client Sample Description EH-169
2nd Floor Mens Lav Sink
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107291-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-170
2nd Floor Womens Lav Sink
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107291-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:47

Client Sample Description EH-171
Hallway fount/2nd floor/Fac Lav
Collected: 6/12/2021 6:31:00 AM
Lab ID: 012107291-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:49

Client Sample Description EH-172
2nd Flr Boys Lav Orange Sink #1
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107291-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.57	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:50

Client Sample Description EH-173
2nd Flr Boys Lav Orange Sink #2
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107291-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.00	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:54

Client Sample Description EH-174
2nd Flr Boys Lav Orange Sink #3
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107291-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-175
 2nd Flr Boys Lav Red Sink #1
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107291-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:56

Client Sample Description EH-176
 2nd Flr Boys Lav Red Sink #2
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107291-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:58

Client Sample Description EH-177
 2nd Flr Boys Lav Red Sink #3
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107291-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.52	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:02

Client Sample Description EH-180
 Faculty Lounge Sink #1
Collected: 6/12/2021 6:44:00 AM
Lab ID: 012107291-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.16	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:03

Client Sample Description EH-183
 Hallway Fountain Green #1
Collected: 6/12/2021 6:40:00 AM
Lab ID: 012107291-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-185
 2nd flr Boys Lav Green Sink #1
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107291-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.47	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:06

Client Sample Description EH-186
 2nd flr Boys Lav Green Sink #2
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107291-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.05	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:07

Client Sample Description EH-187
 2nd flr Girls Lav Green Sink #1
Collected: 6/12/2021 6:40:00 AM
Lab ID: 012107291-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:12

Client Sample Description EH-188
 2nd flr Girls Lav Green Sink #2
Collected: 6/12/2021 6:40:00 AM
Lab ID: 012107291-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.08	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:19

Client Sample Description EH-189
 IMC Sink
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107291-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.51	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-190
 Boys Changing Room Sink #1 (Bradley) **Collected:** 6/12/2021 6:50:00 AM **Lab ID:** 012107291-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:21

Client Sample Description EH-191
 Girls Changing Room Sink #1 (Bradley) **Collected:** 6/12/2021 6:48:00 AM **Lab ID:** 012107291-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:23

Client Sample Description EH-193
 Fitness Room Fountain #1 **Collected:** 6/12/2021 6:46:00 AM **Lab ID:** 012107291-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:24

Client Sample Description EH-194
 3rd Floor Mens Lav Sink **Collected:** 6/12/2021 6:21:00 AM **Lab ID:** 012107291-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:25

Client Sample Description EH-195
 Hallway Fountain/3rd FI Fac Lav **Collected:** 6/12/2021 6:21:00 AM **Lab ID:** 012107291-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-196
 3rd Floor Womens Lav Sink
Collected: 6/12/2021 6:21:00 AM
Lab ID: 012107291-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:28

Client Sample Description EH-197
 3rd Floor Boys Lav Orange Sink #1
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107291-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.85	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:29

Client Sample Description EH-198
 3rd Floor Boys Lav Orange Sink #2
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107291-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.86	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:33

Client Sample Description EH-199
 3rd Floor Boys Lav Orange Sink #3
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107291-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.05	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:37

Client Sample Description EH-200
 3rd FI Girls Lav Red Sink #1
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107291-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-201
 3rd Flr Girls Lav Red Sink #2
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107291-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:39

Client Sample Description EH-202
 3rd Flr Girls Lav Red Sink #3
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107291-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.59	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:41

Client Sample Description EH-209
 3rd Flr Girls Lav Green Sink #1
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107291-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.74	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:42

Client Sample Description EH-210
 3rd Flr Girls Lav Green Sink #2
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107291-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:43

Client Sample Description EH-211
 3rd Flr Boys Lav Green Sink #1
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107291-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.88	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:45

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107291

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description EH-212
 3rd Flr Boys Lav Green Sink #2
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107291-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.68	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:49

Client Sample Description EH-213
 Hallway Fountain Green Girls
Collected: 6/12/2021 6:33:00 AM
Lab ID: 012107291-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:50

Client Sample Description EH-215
 Kitchen Sink #10
Collected: 6/12/2021 6:33:00 AM
Lab ID: 012107291-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:12

Client Sample Description EH-216
 Kiln Room Sink #2
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107291-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:13

Client Sample Description EH-217
 Coaches Offices Sink #2
Collected: 6/12/2021 7:15:00 AM
Lab ID: 012107291-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.26	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:14



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012107291
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104987. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-100
 Custodial Office Bathroom Sink
Collected: 5/1/2021 5:58:00 AM
Lab ID: 012104987-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.07	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:09

Client Sample Description FE-102
 Room 38 Sink
Collected: 5/1/2021 6:03:00 AM
Lab ID: 012104987-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:13

Client Sample Description FE-103
 Room 38 Bathroom Sink #1
Collected: 5/1/2021 6:04:00 AM
Lab ID: 012104987-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	98.1 D	5.00 µg/L	5/20/2021 VD	5/21/2021 VD 08:30

Client Sample Description FE-105
 Room 47 Kitchen Sink
Collected: 5/1/2021 6:05:00 AM
Lab ID: 012104987-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.03	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:15

Client Sample Description FE-106
 Boys Lav by Room 47 Sink #1
Collected: 5/1/2021 6:09:00 AM
Lab ID: 012104987-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.11	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:17

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-107
Boys Lav by Room 47 Sink #2
Collected: 5/1/2021 6:10:00 AM
Lab ID: 012104987-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:21

Client Sample Description FE-108
Boys Lav by Room 47 Sink #3
Collected: 5/1/2021 6:11:00 AM
Lab ID: 012104987-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:22

Client Sample Description FE-109
Girls Lav by Room 36 Sink #1
Collected: 5/1/2021 6:12:00 AM
Lab ID: 012104987-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:23

Client Sample Description FE-110
Girls Lav by Room 36 Sink #2
Collected: 5/1/2021 6:13:00 AM
Lab ID: 012104987-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:25

Client Sample Description FE-111
Girls Lav by Room 36 Sink #3
Collected: 5/1/2021 6:13:00 AM
Lab ID: 012104987-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-112
 Girls Lav by Room 36 Sink #4
Collected: 5/1/2021 6:13:00 AM
Lab ID: 012104987-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:27

Client Sample Description FE-113
 Room 36 Classroom Sink
Collected: 5/1/2021 6:15:00 AM
Lab ID: 012104987-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.8	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:31

Client Sample Description FE-115
 Room 45 Classroom Sink
Collected: 5/1/2021 6:16:00 AM
Lab ID: 012104987-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.54	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:32

Client Sample Description FE-117
 Room 34 Classroom Sink
Collected: 5/1/2021 6:17:00 AM
Lab ID: 012104987-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:36

Client Sample Description FE-119
 Room 43 Classroom Sink
Collected: 5/1/2021 6:18:00 AM
Lab ID: 012104987-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.94	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-121
 Room 32 Classroom Sink
Collected: 5/1/2021 6:19:00 AM
Lab ID: 012104987-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.54	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:39

Client Sample Description FE-123
 Room 41 Classroom Sink
Collected: 5/1/2021 6:21:00 AM
Lab ID: 012104987-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.89	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:40

Client Sample Description FE-125
 Room 39 Classroom Sink
Collected: 5/1/2021 6:22:00 AM
Lab ID: 012104987-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:42

Client Sample Description FE-127
 Room 30 Classroom Sink
Collected: 5/1/2021 6:23:00 AM
Lab ID: 012104987-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.25	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:43

Client Sample Description FE-129
 Room 37 Classroom Sink
Collected: 5/1/2021 6:24:00 AM
Lab ID: 012104987-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.36	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-131
 Room 28 Classroom Sink
Collected: 5/1/2021 6:26:00 AM
Lab ID: 012104987-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:52

Client Sample Description FE-133
 Room 28 Bathroom Sink
Collected: 5/1/2021 6:27:00 AM
Lab ID: 012104987-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:56

Client Sample Description FE-134
 Room 26 Classroom Sink
Collected: 5/1/2021 6:29:00 AM
Lab ID: 012104987-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.27	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:57

Client Sample Description FE-136
 Room 35 Classroom Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012104987-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.10	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 16:59

Client Sample Description FE-138
 Room 33 Classroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.98	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-140
 Room 24 Classroom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012104987-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:01

Client Sample Description FE-142
 Room 22 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104987-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.68	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:02

Client Sample Description FE-144
 Room 31 Classroom Sink
Collected: 5/1/2021 6:35:00 AM
Lab ID: 012104987-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:04

Client Sample Description FE-146
 Room 20 Classroom Sink #1
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.89	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:08

Client Sample Description FE-147
 Room 20 Classroom Sink #2
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.77	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-148
 Room 20 Classroom Sink #3
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104987-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.5	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:10

Client Sample Description FE-149
 Room 29 Classroom Sink
Collected: 5/1/2021 6:38:00 AM
Lab ID: 012104987-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.49	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:14

Client Sample Description FE-150
 Room 27 Classroom Sink
Collected: 5/1/2021 6:40:00 AM
Lab ID: 012104987-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:16

Client Sample Description FE-151
 Boys Lav by Room 27 Sink #1
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012104987-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:17

Client Sample Description FE-152
 Boys Lav by Room 27 Sink #2
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012104987-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-153
 Girls Lav by Room 27 Sink #1
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104987-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.17	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:19

Client Sample Description FE-154
 Girls Lav by Room 27 Sink #1
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104987-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:23

Client Sample Description FE-155
 Hallway fountain by Room 27
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012104987-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:25

Client Sample Description FE-156
 Lav by Room 23
Collected: 5/1/2021 6:47:00 AM
Lab ID: 012104987-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.63	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:26

Client Sample Description FE-157
 Room 21 Classroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012104987-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.05	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:27

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-159
 Room 18 Classroom Sink
Collected: 5/1/2021 6:50:00 AM
Lab ID: 012104987-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:23

Client Sample Description FE-162
 Room 19 Classroom Sink
Collected: 5/1/2021 6:51:00 AM
Lab ID: 012104987-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:27

Client Sample Description FE-164
 Room 16 Classroom Sink
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104987-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.70	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:28

Client Sample Description FE-165
 Room 14 Classroom Sink
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012104987-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:30

Client Sample Description FE-167
 Room 17 Classroom Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012104987-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:33

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-169
Room 15 Kitchen Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012104987-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:35

Client Sample Description FE-170
Girls Lav by Room 13 Sink #1
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104987-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.93	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:36

Client Sample Description FE-171
Girls Lav by Room 13 Sink #2
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104987-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.25	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:37

Client Sample Description FE-172
Boys Lav by Room 13 Sink #1
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104987-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:39

Client Sample Description FE-174
Room 12 Classroom Sink
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012104987-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:40

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104987
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-175
Room 12 Bathroom Sink
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012104987-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.7	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:41

Client Sample Description FE-177
Room 11 Classroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104987-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.5	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:45

Client Sample Description FE-178
Room 11 Bathroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104987-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:49

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104947. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-180
Room 9 Classroom Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012104947-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.09	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:15

Client Sample Description FE-181
Room 9 Bathroom Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012104947-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.58	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:18

Client Sample Description FE-183
Room 10 Classroom Sink
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012104947-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:20

Client Sample Description FE-184
Room 9 Bathroom Sink
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012104947-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:21

Client Sample Description FE-186
Room 7 Classroom Sink
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012104947-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.90	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-187
Room 7 Bathroom Sink
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012104947-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.19	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:26

Client Sample Description FE-189
Room 5 Classroom Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104947-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.02	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:28

Client Sample Description FE-190
Room 5 Bathroom Sink
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012104947-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:29

Client Sample Description FE-193
Room 6 Classroom Sink
Collected: 5/1/2021 7:15:00 AM
Lab ID: 012104947-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.18	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:30

Client Sample Description FE-194
Room 6 Bathroom Sink
Collected: 5/1/2021 7:15:00 AM
Lab ID: 012104947-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.0	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-196
 Room 3 Classroom Sink
Collected: 5/1/2021 7:17:00 AM
Lab ID: 012104947-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.69	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:33

Client Sample Description FE-197
 Room 3 Bathroom Sink
Collected: 5/1/2021 7:17:00 AM
Lab ID: 012104947-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.93	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:37

Client Sample Description FE-198
 Room 4 Classroom Sink
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104947-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.26	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:38

Client Sample Description FE-199
 Room 4 Bathroom Sink
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104947-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.70	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:42

Client Sample Description FE-201
 Room 1 Classroom Sink
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104947-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	138 D	5.00 µg/L	5/20/2021 VD	5/21/2021 VD 08:33

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-202
 Room 1 Bathroom Sink
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104947-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.58	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:45

Client Sample Description FE-203
 Room 2 Classroom Sink
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104947-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.77	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:46

Client Sample Description FE-204
 Room 2 Bathroom Sink
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104947-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:47

Client Sample Description FE-206
 Room 51 Classroom Sink
Collected: 5/1/2021 7:25:00 AM
Lab ID: 012104947-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:49

Client Sample Description FE-207
 Room 51 Bathroom Sink
Collected: 5/1/2021 7:25:00 AM
Lab ID: 012104947-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:50

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-208
 Womens Bathroom Sink by Room 48
Collected: 5/1/2021 7:23:00 AM
Lab ID: 012104947-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:33

Client Sample Description FE-209
 Unisex Bathroom Sink by Room 48
Collected: 5/1/2021 7:24:00 AM
Lab ID: 012104947-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:39

Client Sample Description FE-210
 Library Office Sink
Collected: 5/1/2021 7:25:00 AM
Lab ID: 012104947-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	140 D	5.00 µg/L	5/20/2021 VD	5/21/2021 VD 08:31

Client Sample Description FE-211
 Boys Shower Room Sink #1
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012104947-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.0	1.00 µg/L	5/18/2021 JD	5/18/2021 JW 15:49

Client Sample Description FE-212
 Boys Shower Room Sink #2
Collected: 5/1/2021 7:27:00 AM
Lab ID: 012104947-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.0	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-213
Boys Coaches Office Sink
Collected: 5/1/2021 7:30:00 AM
Lab ID: 012104947-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.21	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:43

Client Sample Description FE-214
Womens Bathroom by Shower Sink #1
Collected: 5/1/2021 7:32:00 AM
Lab ID: 012104947-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.0	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:44

Client Sample Description FE-215
Womens Bathroom by Shower Sink #2
Collected: 5/1/2021 7:32:00 AM
Lab ID: 012104947-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.00	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:46

Client Sample Description FE-216
Hallway Fountain by Room 44
Collected: 5/1/2021 7:33:00 AM
Lab ID: 012104947-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:47

Client Sample Description FE-217
Girls Lav by Room 44
Collected: 5/1/2021 7:34:00 AM
Lab ID: 012104947-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-218
Café Sink
Collected: 5/1/2021 7:35:00 AM
Lab ID: 012104947-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.99	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:50

Client Sample Description FE-219
Café Water Fountain
Collected: 5/1/2021 7:35:00 AM
Lab ID: 012104947-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:51

Client Sample Description FE-221
Kitchen Bathroom Sink
Collected: 5/1/2021 7:37:00 AM
Lab ID: 012104947-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.08	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:57

Client Sample Description FE-222
Kitchen Sink West Wall
Collected: 5/1/2021 7:35:00 AM
Lab ID: 012104947-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.66	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 17:59

Client Sample Description FE-223
Kitchen Sink East Wall at Dishwasher
Collected: 5/1/2021 7:39:00 AM
Lab ID: 012104947-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.16	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104947
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description FE-224 Kitchen Sink at Dishwasher Sprayer #1
Collected: 5/1/2021 7:40:00 AM
Lab ID: 012104947-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.48	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:01

Client Sample Description FE-225 Kitchen Prep Sink at Dishwasher Sprayer #2
Collected: 5/1/2021 7:41:00 AM
Lab ID: 012104947-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.72	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:03

Client Sample Description FE-226 Boiler Room Eye Wash Station
Collected: 5/1/2021 7:48:00 AM
Lab ID: 012104947-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:04

Client Sample Description FE-227 Boiler Room Source Sample
Collected: 5/1/2021 7:48:00 AM
Lab ID: 012104947-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.32	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:05

Client Sample Description FE-232 Room 49 Office Sink
Collected: 5/1/2021 7:44:00 AM
Lab ID: 012104947-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.7	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 18:07



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012104947
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107288. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-100
 Girl's Lav by Room 150 Bathroom Sink
Collected: 6/12/2021 7:02:00 AM
Lab ID: 012107288-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.37	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:41

Client Sample Description HE-101
 Room 150 Classroom Sink
Collected: 6/12/2021 7:08:00 AM
Lab ID: 012107288-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:48

Client Sample Description HE-102
 Hallway Fountain by Room 160
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107288-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:49

Client Sample Description HE-103
 Room 160 Bathroom Sink #1
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107288-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:50

Client Sample Description HE-104
 Room 160 Bathroom Sink #2
Collected: 6/12/2021 7:06:00 AM
Lab ID: 012107288-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.00	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-105
 Room 150 Classroom Sink
Collected: 6/12/2021 7:50:00 AM
Lab ID: 012107288-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.19	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:53

Client Sample Description HE-106
 Room 151 Classroom Sink
Collected: 6/12/2021 7:50:00 AM
Lab ID: 012107288-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.00	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:54

Client Sample Description HE-107
 Boys Lav by Room 151 Sink
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107288-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.80	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:55

Client Sample Description HE-108
 Room 159 Classroom Sink #1
Collected: 6/12/2021 7:16:00 AM
Lab ID: 012107288-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.33	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:57

Client Sample Description HE-110
 Room 158 Classroom Sink
Collected: 6/12/2021 7:15:00 AM
Lab ID: 012107288-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.19	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-112
 Room 157 Classroom Sink
Collected: 6/12/2021 7:15:00 AM
Lab ID: 012107288-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.34	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:02

Client Sample Description HE-114
 Room 156 Classroom Sink
Collected: 6/12/2021 7:14:00 AM
Lab ID: 012107288-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:06

Client Sample Description HE-116
 Room 155 Classroom Sink
Collected: 6/12/2021 7:13:00 AM
Lab ID: 012107288-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:07

Client Sample Description HE-118
 Room 154 Classroom Sink
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107288-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:08

Client Sample Description HE-120
 Room 153 Classroom Sink
Collected: 6/12/2021 7:09:00 AM
Lab ID: 012107288-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-122
 Room 153 Bathroom Sink
Collected: 6/12/2021 7:10:00 AM
Lab ID: 012107288-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.72	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:11

Client Sample Description HE-123
 Room 188 Classroom Sink
Collected: 6/12/2021 6:42:00 AM
Lab ID: 012107288-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.0	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:12

Client Sample Description HE-124
 Room 140 Classroom Sink
Collected: 6/12/2021 7:19:00 AM
Lab ID: 012107288-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.55	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:16

Client Sample Description HE-126
 Hallway Fountain by Room 140
Collected: 6/12/2021 7:20:00 AM
Lab ID: 012107288-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:18

Client Sample Description HE-127
 Room 142 Classroom Sink
Collected: 6/12/2021 7:20:00 AM
Lab ID: 012107288-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-129
 Room 143 Classroom Sink
Collected: 6/12/2021 7:21:00 AM
Lab ID: 012107288-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.05	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:01

Client Sample Description HE-131
 Room 144 Classroom Sink
Collected: 6/12/2021 7:22:00 AM
Lab ID: 012107288-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.23	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:05

Client Sample Description HE-133
 Room 145 Classroom Sink
Collected: 6/12/2021 7:23:00 AM
Lab ID: 012107288-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.02	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:06

Client Sample Description HE-135
 Room 146 Classroom Sink
Collected: 6/12/2021 7:25:00 AM
Lab ID: 012107288-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.54	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:07

Client Sample Description HE-137
 Room 147 Classroom Sink
Collected: 6/12/2021 7:25:00 AM
Lab ID: 012107288-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.44	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-139
 Room 148 Classroom Sink
Collected: 6/12/2021 7:26:00 AM
Lab ID: 012107288-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:10

Client Sample Description HE-141
 Café Classroom Sink
Collected: 6/12/2021 7:27:00 AM
Lab ID: 012107288-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.43	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:14

Client Sample Description HE-142
 Hallway Fountain Outside Room 130
Collected: 6/12/2021 7:37:00 AM
Lab ID: 012107288-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:15

Client Sample Description HE-143
 Room 131 Classroom Sink
Collected: 6/12/2021 7:38:00 AM
Lab ID: 012107288-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.89	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:16

Client Sample Description HE-144
 Room 132 Classroom Sink
Collected: 6/12/2021 7:39:00 AM
Lab ID: 012107288-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.92	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-146
Room 134 Classroom Sink
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107288-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.93	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:19

Client Sample Description HE-148
Room 135 Classroom Sink
Collected: 6/12/2021 7:41:00 AM
Lab ID: 012107288-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:23

Client Sample Description HE-150
Room 136 Classroom Sink
Collected: 6/12/2021 7:42:00 AM
Lab ID: 012107288-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.85	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:24

Client Sample Description HE-152
Room 137 Classroom Sink
Collected: 6/12/2021 7:43:00 AM
Lab ID: 012107288-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.97	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:26

Client Sample Description HE-154
Room 138 Classroom Sink
Collected: 6/12/2021 7:43:00 AM
Lab ID: 012107288-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.28	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-158 **Collected:** 6/12/2021 **Lab ID:** 012107288-0036
 Boys Lav by Gym Bathroom Sink #3 7:34:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.09	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:31

Client Sample Description HE-159 **Collected:** 6/12/2021 **Lab ID:** 012107288-0037
 Boys Lav by Gym Bathroom Sink #4 7:35:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.78	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:32

Client Sample Description HE-160 **Collected:** 6/12/2021 **Lab ID:** 012107288-0038
 Boys Lav by Gym Bathroom Sink #5 7:36:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.81	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:33

Client Sample Description HE-161 **Collected:** 6/12/2021 **Lab ID:** 012107288-0039
 Girls Lav by Gym Bathroom Sink #1 7:37:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:35

Client Sample Description HE-162 **Collected:** 6/12/2021 **Lab ID:** 012107288-0040
 Girls Lav by Gym Bathroom Sink #2 7:32:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.24	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 04:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-163
 Girls Lav by Gym Bathroom Sink #3
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107288-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.57	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:32

Client Sample Description HE-164
 Staff Bathroom by Clinic Bathroom Sink #1
Collected: 6/12/2021 7:53:00 AM
Lab ID: 012107288-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.30	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:38

Client Sample Description HE-165
 Staff Bathroom by Clinic Bathroom Sink #2
Collected: 6/12/2021 7:53:00 AM
Lab ID: 012107288-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.45	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:39

Client Sample Description HE-166
 Main Office Kitchen Sink
Collected: 6/12/2021 7:49:00 AM
Lab ID: 012107288-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.85	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:41

Client Sample Description HE-167
 Clinic Bathroom Sink
Collected: 6/12/2021 7:51:00 AM
Lab ID: 012107288-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-168
Clinic Classroom Sink
Collected: 6/12/2021 7:51:00 AM
Lab ID: 012107288-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.61	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:43

Client Sample Description HE-169
Room 100 Classroom Sink
Collected: 6/12/2021 7:54:00 AM
Lab ID: 012107288-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.44	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:45

Client Sample Description HE-171
Hallway Fountain by Room 100
Collected: 6/12/2021 7:55:00 AM
Lab ID: 012107288-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:46

Client Sample Description HE-172
Room 102 Classroom Sink
Collected: 6/12/2021 7:57:00 AM
Lab ID: 012107288-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.12	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:47

Client Sample Description HE-174
Room 103 Classroom Sink
Collected: 6/12/2021 8:00:00 AM
Lab ID: 012107288-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.47	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-176
 Room 104 Classroom Sink
Collected: 6/12/2021 8:08:00 AM
Lab ID: 012107288-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.19	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:52

Client Sample Description HE-178
 Room 105 Classroom Sink
Collected: 6/12/2021 8:04:00 AM
Lab ID: 012107288-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:56

Client Sample Description HE-180
 Room 106 Classroom Sink
Collected: 6/12/2021 8:05:00 AM
Lab ID: 012107288-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:58

Client Sample Description HE-182
 Room 107 Classroom Sink
Collected: 6/12/2021 8:06:00 AM
Lab ID: 012107288-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.9	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 11:59

Client Sample Description HE-184
 Room 108 Classroom Sink
Collected: 6/12/2021 8:09:00 AM
Lab ID: 012107288-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.87	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-186
 Room 109 Classroom Sink
Collected: 6/12/2021 8:10:00 AM
Lab ID: 012107288-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.83	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:02

Client Sample Description HE-187
 Hallway Fountain Outside Room 120
Collected: 6/12/2021 8:13:00 AM
Lab ID: 012107288-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:03

Client Sample Description HE-188
 Room 120 Classroom Sink
Collected: 6/12/2021 8:12:00 AM
Lab ID: 012107288-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.02	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:07

Client Sample Description HE-190
 Room 121 Classroom Sink
Collected: 6/12/2021 8:13:00 AM
Lab ID: 012107288-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.60	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:08

Client Sample Description HE-192
 Room 122 Classroom Sink
Collected: 6/12/2021 8:18:00 AM
Lab ID: 012107288-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.86	1.00 µg/L	7/13/2021 KB	7/14/2021 KB 12:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-194
 Room 123 Classroom Sink
Collected: 6/12/2021 8:19:00 AM
Lab ID: 012107288-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.51	1.00 µg/L	7/13/2021 VD	7/13/2021 23:14 KB

Client Sample Description HE-196
 Room 124 Classroom Sink
Collected: 6/12/2021 8:21:00 AM
Lab ID: 012107288-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.72	1.00 µg/L	7/13/2021 VD	7/13/2021 23:15 KB

Client Sample Description HE-198
 Room 125 Classroom Sink
Collected: 6/12/2021 8:22:00 AM
Lab ID: 012107288-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.55	1.00 µg/L	7/16/2021 KB	7/16/2021 23:05 VD

Client Sample Description HE-200
 Room 126 Classroom Sink
Collected: 6/12/2021 8:23:00 AM
Lab ID: 012107288-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.30	1.00 µg/L	7/16/2021 KB	7/16/2021 23:09 VD

Client Sample Description HE-202
 Room 127 Classroom Sink
Collected: 6/12/2021 8:23:00 AM
Lab ID: 012107288-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	7/16/2021 KB	7/16/2021 23:10 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-204
 Kitchen Bathroom Sink
Collected: 6/12/2021 6:40:00 AM
Lab ID: 012107288-0066

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:14

Client Sample Description HE-205
 Boys Locker Room Bathroom Sink
Collected: 6/12/2021 6:36:00 AM
Lab ID: 012107288-0067

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:15

Client Sample Description HE-206
 Handicapped Lav by Kitchen Bathroom Sink
Collected: 6/12/2021 6:36:00 AM
Lab ID: 012107288-0068

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:17

Client Sample Description HE-207
 Kitchen Sink #1
Collected: 6/12/2021 6:29:00 AM
Lab ID: 012107288-0069

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:18

Client Sample Description HE-208
 Kitchen Sink #2
Collected: 6/12/2021 6:33:00 AM
Lab ID: 012107288-0070

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-209
 Kitchen Sink #3
Collected: 6/12/2021 6:33:00 AM
Lab ID: 012107288-0071

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:21

Client Sample Description HE-210
 Kitchen Pot Filler
Collected: 6/12/2021 6:34:00 AM
Lab ID: 012107288-0072

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.04	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:22

Client Sample Description HE-211
 Custodial Area Bathroom Sink
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107288-0073

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.47	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:23

Client Sample Description HE-212
 Girls Locker Room Bathroom Sink #1
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107288-0074

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:30

Client Sample Description HE-213
 Boiler Room Source
Collected: 6/12/2021 6:12:00 AM
Lab ID: 012107288-0075

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.67	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107288

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HE-214
Girls Locker Room Sink #2
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107288-0076

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:32

Client Sample Description HE-215
Room 103 Classroom Sink #2
Collected: 6/12/2021 8:01:00 AM
Lab ID: 012107288-0077

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.52	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:34

Client Sample Description HE-216
Room 102 Classroom Sink #2
Collected: 6/12/2021 7:57:00 AM
Lab ID: 012107288-0078

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.49	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:35

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107299. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-100
Boiler Room Source
Collected: 6/5/2021 7:30:00 AM
Lab ID: 012107299-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.1	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:57

Client Sample Description HM-101
Custodial Area Bathroom Sink
Collected: 6/5/2021 6:08:00 AM
Lab ID: 012107299-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:16

Client Sample Description HM-102
Custodial Area Sink
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107299-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:17

Client Sample Description HM-103
Room D7 Classroom Sink # 1
Collected: 6/5/2021 7:02:00 AM
Lab ID: 012107299-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:18

Client Sample Description HM-104
Room D7 Classroom Sink # 2
Collected: 6/5/2021 7:04:00 AM
Lab ID: 012107299-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.21	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-105
 Room D7 Classroom Sink # 3
Collected: 6/5/2021 7:03:00 AM
Lab ID: 012107299-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:21

Client Sample Description HM-106
 Room D7 Classroom Sink # 4
Collected: 6/5/2021 7:00:00 AM
Lab ID: 012107299-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.22	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:22

Client Sample Description HM-107
 Room D7 Wash Machine Room Sink
Collected: 6/5/2021 6:59:00 AM
Lab ID: 012107299-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:23

Client Sample Description HM-108
 Hallway fountain by D6
Collected: 6/5/2021 7:06:00 AM
Lab ID: 012107299-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:25

Client Sample Description HM-109
 Room D4 Sink
Collected: 6/5/2021 7:12:00 AM
Lab ID: 012107299-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.69	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-110
 Room D3 Sink # 1
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107299-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.53	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:33

Client Sample Description HM-111
 Room D3 Sink # 2
Collected: 6/5/2021 7:15:00 AM
Lab ID: 012107299-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:34

Client Sample Description HM-112
 Room D6 Sink # 1
Collected: 6/5/2021 7:09:00 AM
Lab ID: 012107299-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:35

Client Sample Description HM-113
 Room D3 Sink # 3
Collected: 6/5/2021 7:16:00 AM
Lab ID: 012107299-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.89	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:37

Client Sample Description HM-114
 Room D11 Sink # 1
Collected: 6/5/2021 7:19:00 AM
Lab ID: 012107299-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.6	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-115
Room D11 Sink # 2
Collected: 6/5/2021 7:21:00 AM
Lab ID: 012107299-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.66	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:39

Client Sample Description HM-116
Room D11 Sink # 3
Collected: 6/5/2021 7:22:00 AM
Lab ID: 012107299-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.12	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:41

Client Sample Description HM-117
Boys Gym Teachers Office Sink
Collected: 6/5/2021 7:27:00 AM
Lab ID: 012107299-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.13	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:42

Client Sample Description HM-118
Fountain Boys Locker Room
Collected: 6/5/2021 7:25:00 AM
Lab ID: 012107299-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:43

Client Sample Description HM-119
Boys Locker Room # 1
Collected: 6/5/2021 7:25:00 AM
Lab ID: 012107299-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.7	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-120
Boys Locker Room # 2
Collected: 6/5/2021 7:25:00 AM
Lab ID: 012107299-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:22

Client Sample Description HM-121
Water Fountain Hall by Gym/Café
Collected: 6/5/2021 7:30:00 AM
Lab ID: 012107299-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:23

Client Sample Description HM-122
Girls Locker Room # 1
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107299-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:27

Client Sample Description HM-123
Girls Locker Room # 2
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107299-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.82	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:28

Client Sample Description HM-124
Fountain in Girls Locker Room
Collected: 6/5/2021 7:35:00 AM
Lab ID: 012107299-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.41	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-125
 Girls Gym Teacher Office Sink
Collected: 6/5/2021 7:39:00 AM
Lab ID: 012107299-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.97	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:30

Client Sample Description HM-126
 Stage Sink
Collected: 6/5/2021 7:42:00 AM
Lab ID: 012107299-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.14	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:31

Client Sample Description HM-127
 Handicapped Bathroom Sink by D-1
Collected: 6/5/2021 7:43:00 AM
Lab ID: 012107299-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.20	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:32

Client Sample Description HM-128
 Hallway Fountain Near Aud
Collected: 6/5/2021 7:45:00 AM
Lab ID: 012107299-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:33

Client Sample Description HM-129
 Boys Lav by C-15 Sink # 1
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:35

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-130
Boys Lav by C-15 Sink # 2
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:36

Client Sample Description HM-131
Boys Lav by C-15 Sink # 3
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:43

Client Sample Description HM-132
Boys Lav by C-15 Sink # 4
Collected: 6/5/2021 7:49:00 AM
Lab ID: 012107299-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:44

Client Sample Description HM-133
Girls Lav by C-15 Sink # 1
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.51	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:45

Client Sample Description HM-134
Girls Lav by C-15 Sink # 2
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.23	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-135
 Girls Lav by C-15 Sink # 3
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.66	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:48

Client Sample Description HM-136
 Girls Lav by C-15 Sink # 4
Collected: 6/5/2021 7:51:00 AM
Lab ID: 012107299-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.05	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:49

Client Sample Description HM-137
 Classroom C-13 Eye Wash
Collected: 6/5/2021 7:55:00 AM
Lab ID: 012107299-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	51.7 D	5.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:35

Client Sample Description HM-138
 Classroom C-11 Eye Wash
Collected: 6/5/2021 8:12:00 AM
Lab ID: 012107299-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	93.9 D	5.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:44

Client Sample Description HM-139
 Classroom C-12 Eye Wash
Collected: 6/5/2021 8:18:00 AM
Lab ID: 012107299-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.4	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-140
 Classroom C-14 Eye Wash
Collected: 6/5/2021 8:51:00 AM
Lab ID: 012107299-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.64	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:50

Client Sample Description HM-141
 Hallway fountain by C-13
Collected: 6/5/2021 7:59:00 AM
Lab ID: 012107299-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:52

Client Sample Description HM-142
 Library Office Sink
Collected: 6/5/2021 8:42:00 AM
Lab ID: 012107299-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.31	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:53

Client Sample Description HM-143
 Boys Bathroom by B-Wing Sink # 1
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:35

Client Sample Description HM-144
 Boys Bathroom by B-Wing Sink # 2
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.05	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-145
 Boys Bathroom by B-Wing Sink # 3
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:41

Client Sample Description HM-146
 Boys Bathroom by B-Wing Sink # 4
Collected: 6/5/2021 8:00:00 AM
Lab ID: 012107299-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.05	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:43

Client Sample Description HM-147
 Girls Bathroom by B-Wing Sink # 1
Collected: 6/5/2021 8:49:00 AM
Lab ID: 012107299-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.53	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:44

Client Sample Description HM-148
 Girls Bathroom by B-Wing Sink # 2
Collected: 6/5/2021 8:49:00 AM
Lab ID: 012107299-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.27	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:45

Client Sample Description HM-149
 Girls Bathroom by B-Wing Sink # 3
Collected: 6/5/2021 8:50:00 AM
Lab ID: 012107299-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.27	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:47

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-150
 Girls Bathroom by B-Wing Sink # 4
Collected: 6/5/2021 8:50:00 AM
Lab ID: 012107299-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:48

Client Sample Description HM-151
 Hallway fountain by C-14
Collected: 6/5/2021 9:06:00 AM
Lab ID: 012107299-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:49

Client Sample Description HM-152
 IMC Sink
Collected: 6/5/2021 8:01:00 AM
Lab ID: 012107299-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.39	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:51

Client Sample Description HM-153
 Room A-16 Sink
Collected: 6/5/2021 8:55:00 AM
Lab ID: 012107299-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:52

Client Sample Description HM-154
 Mens Lav A-Wing Sink # 1
Collected: 6/5/2021 8:56:00 AM
Lab ID: 012107299-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 02:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-155
 Mens Lav A-Wing Sink # 2
Collected: 6/5/2021 8:56:00 AM
Lab ID: 012107299-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:02

Client Sample Description HM-156
 Mens Lav A-Wing Sink # 3
Collected: 6/5/2021 8:56:00 AM
Lab ID: 012107299-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.01	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:16

Client Sample Description HM-157
 Mens Lav A-Wing Sink # 4
Collected: 6/5/2021 8:57:00 AM
Lab ID: 012107299-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.67	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:04

Client Sample Description HM-158
 Womens Lav A-Wing Sink # 1
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:05

Client Sample Description HM-159
 Womens Lav A-Wing Sink # 2
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 20:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107299

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-160
 Womens Lav A-Wing Sink # 3
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:06

Client Sample Description HM-161
 Womens Lav A-Wing Sink # 4
Collected: 6/5/2021 8:58:00 AM
Lab ID: 012107299-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.82	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:07

Client Sample Description HM-162
 Classroom A-13 Eye Wash
Collected: 6/5/2021 8:59:00 AM
Lab ID: 012107299-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.47	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:11

Client Sample Description HM-163
 Hallway Fountain By A-13
Collected: 6/5/2021 9:03:00 AM
Lab ID: 012107299-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 03:13

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/20/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107289. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107289

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-164
 Classroom A-11 Eye Wash
Collected: 6/5/2021 8:59:00 AM
Lab ID: 012107289-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.2 D	5.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:54

Client Sample Description HM-165
 Health Office Sink
Collected: 6/5/2021 8:54:00 AM
Lab ID: 012107289-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:48

Client Sample Description HM-166
 Health Office Bathroom Sink
Collected: 6/5/2021 7:43:00 AM
Lab ID: 012107289-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.65	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:57

Client Sample Description HM-167
 Main Office Sink
Collected: 6/5/2021 7:45:00 AM
Lab ID: 012107289-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 15:58

Client Sample Description HM-168
 Hallway Fountain by Aud
Collected: 6/5/2021 7:47:00 AM
Lab ID: 012107289-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107289
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-169 **Collected:** 6/5/2021 **Lab ID:** 012107289-0006
 Womens Faculty by Aud Sink #1 7:51:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.06	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:01

Client Sample Description HM-170 **Collected:** 6/5/2021 **Lab ID:** 012107289-0007
 Womens Faculty by Aud Sink #2 7:52:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.0	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:02

Client Sample Description HM-171 **Collected:** 6/5/2021 **Lab ID:** 012107289-0008
 Faculty Dining Sink 7:53:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.63	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:03

Client Sample Description HM-172 **Collected:** 6/5/2021 **Lab ID:** 012107289-0009
 Kitchen Sink #1 8:02:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.56	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:05

Client Sample Description HM-173 **Collected:** 6/5/2021 **Lab ID:** 012107289-0010
 Kitchen Sink #2 7:56:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.98	1.00 µg/L	7/19/2021 KB	7/19/2021 KB 16:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107289

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-174
Kitchen Sink #3
Collected: 6/5/2021 7:57:00 AM
Lab ID: 012107289-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.52	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 09:58

Client Sample Description HM-175
Kitchen Sink #4
Collected: 6/5/2021 7:57:00 AM
Lab ID: 012107289-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.15	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:02

Client Sample Description HM-176
Kitchen Sink #5
Collected: 6/5/2021 7:58:00 AM
Lab ID: 012107289-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.86	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:03

Client Sample Description HM-177
Outlet by Steamer in Kitchen
Collected: 6/5/2021 8:05:00 AM
Lab ID: 012107289-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	119 D	5.00 µg/L	7/13/2021 JD	7/20/2021 JW 12:31

Client Sample Description HM-178
Kitchen Sink by Dishwasher #1
Collected: 6/5/2021 7:59:00 AM
Lab ID: 012107289-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.83	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107289

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description HM-179 **Collected:** 6/5/2021 **Lab ID:** 012107289-0016
 Kitchen Sink by Dishwasher #2 7:58:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.21	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:05

Client Sample Description HM-180 **Collected:** 6/5/2021 **Lab ID:** 012107289-0017
 Kitchen Staff Bathroom Sink 8:06:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.74	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:07

Client Sample Description HM-181 **Collected:** 6/5/2021 **Lab ID:** 012107289-0018
 Boiler Room Eye Wash 8:38:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	46.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:08

Client Sample Description HM-182 **Collected:** 6/5/2021 **Lab ID:** 012107289-0019
 Basement Pool Eye Wash 8:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.91	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:09

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107286. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107286
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description LB-100 Upstairs Office Sink		Collected: 6/30/2021 7:12:00 AM		Lab ID: 012107286-0001	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:45
Client Sample Description LB-101 Source		Collected: 6/30/2021 7:24:00 AM		Lab ID: 012107286-0002	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.63	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:28
Client Sample Description LB-102 Child Nutrition Sink		Collected: 6/30/2021 7:27:00 AM		Lab ID: 012107286-0003	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:46
Client Sample Description LB-103 Child Nutrition Womens Bathroom Sink		Collected: 6/30/2021 7:17:00 AM		Lab ID: 012107286-0004	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:47
Client Sample Description LB-104 Child Nutrition Mens Bathroom Sink		Collected: 6/30/2021 7:21:00 AM		Lab ID: 012107286-0005	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:49

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107286

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description LB-105
 Receiving Room Work Sink
Collected: 6/30/2021 7:23:00 AM
Lab ID: 012107286-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:52

Client Sample Description LB-106
 Grounds Room Break Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107286-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:54

Client Sample Description LB-107
 Grounds Bathroom Sink #1
Collected: 6/30/2021 7:35:00 AM
Lab ID: 012107286-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.32	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:55

Client Sample Description LB-108
 Grounds Bathroom Sink #2
Collected: 6/30/2021 7:39:00 AM
Lab ID: 012107286-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.75	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:56

Client Sample Description LB-109
 Print Shop Sink
Collected: 6/30/2021 7:42:00 AM
Lab ID: 012107286-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107286
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description LB-110
Laundry Room Sink
Collected: 6/30/2021 7:47:00 AM
Lab ID: 012107286-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:02

Client Sample Description LB-111
Water Fountain Hallway by Time Clock
Collected: 6/30/2021 7:49:00 AM
Lab ID: 012107286-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.38	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:03

Client Sample Description LB-112
Mechanics Break Room Sink
Collected: 6/30/2021 7:53:00 AM
Lab ID: 012107286-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:04

Client Sample Description LB-113
Parts Room Sink
Collected: 6/30/2021 7:58:00 AM
Lab ID: 012107286-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:08

Client Sample Description LB-114
Auto Shop Eye Wash
Collected: 6/30/2021 7:59:00 AM
Lab ID: 012107286-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.92	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107286

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:00 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description LB-115 **Collected:** 6/30/2021 **Lab ID:** 012107286-0016
Carpenters Shop Sink 7:57:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 03:11 VD

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/25/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/14/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012105071. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		ME-180 Room 12 Bathroom Sink	Collected: 5/1/2021 7:48:00 AM		Lab ID: 012105071-0001			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	3.06	1.00 µg/L		5/24/2021	VD	5/24/2021 19:06	VD
Client Sample Description		ME-181 Hallway Fountain by Room 13	Collected: 5/1/2021 7:51:00 AM		Lab ID: 012105071-0002			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/24/2021	VD	5/24/2021 19:10	VD
Client Sample Description		ME-182 Room 10 Classroom Sink	Collected: 5/1/2021 7:55:00 AM		Lab ID: 012105071-0003			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	1.45	1.00 µg/L		5/24/2021	VD	5/24/2021 19:12	VD
Client Sample Description		ME-184 Room 10 Bathroom Sink	Collected: 5/1/2021 7:56:00 AM		Lab ID: 012105071-0004			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	2.44	1.00 µg/L		5/24/2021	VD	5/24/2021 19:13	VD
Client Sample Description		ME-185 Room 11 Classroom Sink	Collected: 5/1/2021 7:53:00 AM		Lab ID: 012105071-0005			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	2.94	1.00 µg/L		5/24/2021	VD	5/24/2021 19:15	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-187
Room 11 Bathroom Sink
Collected: 5/1/2021 7:54:00 AM
Lab ID: 012105071-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.44	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:17

Client Sample Description ME-188
Room 9 Classroom Sink
Collected: 5/1/2021 7:58:00 AM
Lab ID: 012105071-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.67	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:18

Client Sample Description ME-190
Room 9 Bathroom Sink
Collected: 5/1/2021 7:57:00 AM
Lab ID: 012105071-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.31	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:23

Client Sample Description ME-191
Room 8 Classroom Sink
Collected: 5/1/2021
Lab ID: 012105071-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.6	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:24

Client Sample Description ME-193
Room 8 Bathroom Sink
Collected: 5/1/2021
Lab ID: 012105071-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.57	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-194
 Room 6 Classroom Sink
Collected: 5/1/2021 8:07:00 AM
Lab ID: 012105071-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.36	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:27

Client Sample Description ME-196
 Room 6 Bathroom Sink
Collected: 5/1/2021 8:06:00 AM
Lab ID: 012105071-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.14	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:32

Client Sample Description ME-197
 Room 5 Classroom Sink
Collected: 5/1/2021 8:16:00 AM
Lab ID: 012105071-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.96	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:34

Client Sample Description ME-199
 Room 5 Bathroom Sink
Collected: 5/1/2021 8:17:00 AM
Lab ID: 012105071-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.94	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:35

Client Sample Description ME-201
 Room 4 Classroom Sink
Collected: 5/1/2021 8:20:00 AM
Lab ID: 012105071-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-203
Room 4 Bathroom Sink
Collected: 5/1/2021 8:21:00 AM
Lab ID: 012105071-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.64	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:41

Client Sample Description ME-204
Room 3 Classroom Sink
Collected: 5/1/2021 8:18:00 AM
Lab ID: 012105071-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.43	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:43

Client Sample Description ME-206
Room 3 Bathroom Sink
Collected: 5/1/2021 8:19:00 AM
Lab ID: 012105071-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.77	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:45

Client Sample Description ME-207
Room 2 Classroom Sink
Collected: 5/1/2021 8:22:00 AM
Lab ID: 012105071-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.77	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:46

Client Sample Description ME-208
Room 2 Bathroom Sink
Collected: 5/1/2021 8:23:00 AM
Lab ID: 012105071-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.17	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 19:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		ME-209 Room 1 Classroom Sink	Collected: 5/1/2021 8:24:00 AM		Lab ID: 012105071-0021			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	6.04	1.00 µg/L		5/24/2021	VD	5/24/2021 19:54	VD
Client Sample Description		ME-211 Room 1 Bathroom Sink	Collected: 5/1/2021 8:25:00 AM		Lab ID: 012105071-0022			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	5.00	1.00 µg/L		5/24/2021	VD	5/24/2021 20:02	VD
Client Sample Description		ME-212 Clinic Sink #1	Collected: 5/1/2021 8:30:00 AM		Lab ID: 012105071-0023			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/24/2021	VD	5/24/2021 20:03	VD
Client Sample Description		ME-213 Clinic Sink #2	Collected: 5/1/2021 8:31:00 AM		Lab ID: 012105071-0024			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	1.04	1.00 µg/L		5/24/2021	VD	5/24/2021 20:05	VD
Client Sample Description		ME-214 Room 69 Sink	Collected: 5/1/2021 8:31:00 AM		Lab ID: 012105071-0025			
Method	Parameter	Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS								
200.8	Lead	ND	1.00 µg/L		5/24/2021	VD	5/24/2021 20:06	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-215
Room 70 Sink
Collected: 5/1/2021 8:33:00 AM
Lab ID: 012105071-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.77	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:08

Client Sample Description ME-216
Library Office Sink
Collected: 5/1/2021 8:34:00 AM
Lab ID: 012105071-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.3	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:09

Client Sample Description ME-218
Room 61 Sink
Collected: 5/1/2021 8:36:00 AM
Lab ID: 012105071-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.08	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:11

Client Sample Description ME-219
Room 57 Sink #1
Collected: 5/1/2021 8:37:00 AM
Lab ID: 012105071-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.79	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:12

Client Sample Description ME-220
Café Sink
Collected: 5/1/2021 8:40:00 AM
Lab ID: 012105071-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.50	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-221
Café Fountain
Collected: 5/1/2021 8:41:00 AM
Lab ID: 012105071-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:19

Client Sample Description ME-222
Kitchen Bathroom Sink
Collected: 5/1/2021 8:45:00 AM
Lab ID: 012105071-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.61	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:23

Client Sample Description ME-223
Kitchen Sink #1
Collected: 5/1/2021 8:46:00 AM
Lab ID: 012105071-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.78	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:25

Client Sample Description ME-224
Kitchen Sink #2
Collected: 5/1/2021 8:47:00 AM
Lab ID: 012105071-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:26

Client Sample Description ME-225
Kitchen Sink #3
Collected: 5/1/2021 8:48:00 AM
Lab ID: 012105071-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.82	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:28

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-226
Kitchen Sink #4
Collected: 5/1/2021 8:48:00 AM
Lab ID: 012105071-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:30

Client Sample Description ME-227
Kitchen Sink #5
Collected: 5/1/2021 8:45:00 AM
Lab ID: 012105071-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.48	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:31

Client Sample Description ME-229
Room 57 Classroom Sink #2
Collected: 5/1/2021 8:38:00 AM
Lab ID: 012105071-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.91	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:33

Client Sample Description ME-230
Room 56C Sink
Collected: 5/1/2021 8:42:00 AM
Lab ID: 012105071-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.66	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:37

Client Sample Description ME-231
Girls Bathroom by Room 50 Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012105071-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/24/2021 VD	5/24/2021 VD 20:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105071

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-232
Hallway Fountain Across from Room 26

Collected: 5/1/2021 7:11:00 AM

Lab ID: 012105071-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/25/2021 VD	5/25/2021 VD 10:04

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012105066. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-100
Boiler Room Source Sample
Collected: 5/1/2021 6:07:00 AM
Lab ID: 012105066-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:55

Client Sample Description ME-101
Boiler Room Eye Wash Station
Collected: 5/1/2021 6:09:00 AM
Lab ID: 012105066-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	47.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 23:59

Client Sample Description ME-102
Custodial Bathroom Sink
Collected: 5/1/2021 6:12:00 AM
Lab ID: 012105066-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:00

Client Sample Description ME-103
Room 56-c Sink
Collected: 5/1/2021 6:17:00 AM
Lab ID: 012105066-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.06	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:01

Client Sample Description ME-104
Hallway Fountain by Gym
Collected: 5/1/2021 6:18:00 AM
Lab ID: 012105066-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:02

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-105
 Room 49 Girls Shower Room Bathroom Sink
Collected: 5/1/2021 6:20:00 AM
Lab ID: 012105066-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1220 D	20.0 µg/L	5/20/2021 JD	5/21/2021 JW 14:57

Client Sample Description ME-106
 Girls Coaches Office Bathroom Sink
Collected: 5/1/2021 6:21:00 AM
Lab ID: 012105066-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.58	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:04

Client Sample Description ME-107
 Room 50 Classroom Sink
Collected: 5/1/2021 6:21:00 AM
Lab ID: 012105066-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:05

Client Sample Description ME-109
 Boys Bathroom by Room 50 Sink #1
Collected: 5/1/2021 6:24:00 AM
Lab ID: 012105066-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:06

Client Sample Description ME-110
 Boys Bathroom by Room 50 Sink #2
Collected: 5/1/2021 6:24:00 AM
Lab ID: 012105066-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:10

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-111
 Boys Bathroom by Room 50 Sink #3
Collected: 5/1/2021 6:26:00 AM
Lab ID: 012105066-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:12

Client Sample Description ME-112
 Girls Bathroom by Room 50 Sink #1
Collected: 5/1/2021 6:28:00 AM
Lab ID: 012105066-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:13

Client Sample Description ME-113
 Girls Bathroom by Room 50 Sink #2
Collected: 5/1/2021 6:29:00 AM
Lab ID: 012105066-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:17

Client Sample Description ME-114
 Girls Bathroom by Room 50 Sink #3
Collected: 5/1/2021 6:29:00 AM
Lab ID: 012105066-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:18

Client Sample Description ME-115
 Room 45 Classroom Sink
Collected: 5/1/2021 6:32:00 AM
Lab ID: 012105066-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.79	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:19

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-117
 Room 46 Classroom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012105066-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.2	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:21

Client Sample Description ME-120
 Room 43 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012105066-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.40	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:22

Client Sample Description ME-122
 Room 44 Classroom Sink
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012105066-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.03	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:26

Client Sample Description ME-124
 Room 41 Classroom Sink
Collected: 5/1/2021 6:39:00 AM
Lab ID: 012105066-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.56	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:27

Client Sample Description ME-126
 Room 42 Classroom Sink
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012105066-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.2	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-128
Room 39 Classroom Sink
Collected: 5/1/2021 6:42:00 AM
Lab ID: 012105066-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.9	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:30

Client Sample Description ME-130
Room 40 Classroom Sink
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012105066-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.31	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:35

Client Sample Description ME-132
Room 38 Classroom Sink
Collected: 5/1/2021 6:46:00 AM
Lab ID: 012105066-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:42

Client Sample Description ME-134
Room 37 Classroom Sink
Collected: 5/1/2021 6:47:00 AM
Lab ID: 012105066-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:43

Client Sample Description ME-135
Room 37 Bathroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012105066-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-137
Room 35 Classroom Sink
Collected: 5/1/2021 6:50:00 AM
Lab ID: 012105066-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:46

Client Sample Description ME-139
Room 36 Classroom Sink
Collected: 5/1/2021 6:52:00 AM
Lab ID: 012105066-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:47

Client Sample Description ME-141
Room 34 Classroom Sink
Collected: 5/1/2021 6:52:00 AM
Lab ID: 012105066-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:48

Client Sample Description ME-143
Room 33 Classroom Sink
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012105066-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:49

Client Sample Description ME-145
Room 32 Classroom Sink
Collected: 5/1/2021 6:58:00 AM
Lab ID: 012105066-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-147
 Room 29 Classroom Sink #1
Collected: 5/1/2021 7:01:00 AM
Lab ID: 012105066-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:52

Client Sample Description ME-148
 Room 29 Classroom Sink #2
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012105066-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 00:53

Client Sample Description ME-149
 Room 29 Classroom Sink #3
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012105066-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	52.3	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:00

Client Sample Description ME-150
 Room 30 Classroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012105066-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.10	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:01

Client Sample Description ME-152
 Room 28 Classroom Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012105066-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.47	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:02

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-153
 Room 31 Classroom Sink
Collected: 5/1/2021 6:57:00 AM
Lab ID: 012105066-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.02	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:04

Client Sample Description ME-154
 Boys Bathroom by Room 28 Sink #1
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012105066-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.33	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:05

Client Sample Description ME-155
 Boys Bathroom by Room 28 Sink #2
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012105066-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:06

Client Sample Description ME-156
 Girls Bathroom by Room 28 Sink #1
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012105066-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:08

Client Sample Description ME-157
 Girls Bathroom by Room 28 Sink #2
Collected: 5/1/2021 7:12:00 AM
Lab ID: 012105066-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-158
 Bathroom Sink 25-A
Collected: 5/1/2021 7:35:00 AM
Lab ID: 012105066-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 08:23

Client Sample Description ME-159
 Room 22 Classroom Sink
Collected: 5/1/2021 7:37:00 AM
Lab ID: 012105066-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.3	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:18

Client Sample Description ME-161
 Room 21 Classroom Sink
Collected: 5/1/2021 7:36:00 AM
Lab ID: 012105066-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.69	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:22

Client Sample Description ME-162
 Room 19 Classroom Sink
Collected: 5/1/2021 7:39:00 AM
Lab ID: 012105066-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.69	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:23

Client Sample Description ME-164
 Room 20 Classroom Sink
Collected: 5/1/2021 7:41:00 AM
Lab ID: 012105066-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.21	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:25

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-166
Room 18 Classroom Sink
Collected: 5/1/2021 7:42:00 AM
Lab ID: 012105066-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.14	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:29

Client Sample Description ME-168
Room 17 Classroom Sink
Collected: 5/1/2021 7:42:00 AM
Lab ID: 012105066-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.21	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:30

Client Sample Description ME-170
Girls Bathroom by Room 14 Sink #1
Collected: 5/1/2021 7:44:00 AM
Lab ID: 012105066-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.52	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:31

Client Sample Description ME-171
Girls Bathroom by Room 14 Sink #2
Collected: 5/1/2021 7:45:00 AM
Lab ID: 012105066-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.02	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:32

Client Sample Description ME-172
Boys Bathroom by Room 14 Sink #1
Collected: 5/1/2021 7:46:00 AM
Lab ID: 012105066-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.96	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012105066

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description ME-173 **Collected:** 5/1/2021 **Lab ID:** 012105066-0051
Boys Bathroom by Room 14 Sink #2 7:46:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.87	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:35

Client Sample Description ME-175 **Collected:** 5/1/2021 **Lab ID:** 012105066-0052
Room 13 Classroom Sink 7:50:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.12	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:36

Client Sample Description ME-177 **Collected:** 5/1/2021 **Lab ID:** 012105066-0053
Room 13 Bathroom Sink 7:50:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.58	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:40

Client Sample Description ME-178 **Collected:** 5/1/2021 **Lab ID:** 012105066-0054
Room 12 Classroom Sink 7:48:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.13	1.00 µg/L	5/20/2021 VD	5/21/2021 VD 01:44

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104879. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-100
Hallway Fountain by Room 129
Collected: 5/1/2021 6:42:00 AM
Lab ID: 012104879-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:34

Client Sample Description MW-101
Room 128 Classroom Sink
Collected: 5/1/2021 6:43:00 AM
Lab ID: 012104879-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.55	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:38

Client Sample Description MW-103
Room 127 Classroom Sink
Collected: 5/1/2021 6:44:00 AM
Lab ID: 012104879-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.31	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:39

Client Sample Description MW-105
Classroom 126 sink
Collected: 5/1/2021 6:45:00 AM
Lab ID: 012104879-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.47	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:40

Client Sample Description MW-107
Room 125 Classroom Sink
Collected: 5/1/2021 6:46:00 AM
Lab ID: 012104879-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.62	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-109
Room 124 Classroom Sink
Collected: 5/1/2021 6:47:00 AM
Lab ID: 012104879-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:45

Client Sample Description MW-111
Room 121 Classroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012104879-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:47

Client Sample Description MW-113
Room 123 Classroom Sink
Collected: 5/1/2021 6:48:00 AM
Lab ID: 012104879-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.54	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:48

Client Sample Description MW-116
Girls Lav by Gym Bathroom Sink #1
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104879-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:49

Client Sample Description MW-117
Girls Lav by Gym Bathroom Sink #2
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104879-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.83	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-118
Girls Lav by Gym Bathroom Sink #3
Collected: 5/1/2021 6:53:00 AM
Lab ID: 012104879-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.20	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:52

Client Sample Description MW-121
Boys Lav by Gym Bathroom Sink #1
Collected: 5/1/2021 6:55:00 AM
Lab ID: 012104879-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.13	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:56

Client Sample Description MW-122
Boys Lav by Gym Bathroom Sink #2
Collected: 5/1/2021 6:56:00 AM
Lab ID: 012104879-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.39	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 14:57

Client Sample Description MW-123
Boys Lav by Gym Bathroom Sink #3
Collected: 5/1/2021 6:56:00 AM
Lab ID: 012104879-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.32	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:01

Client Sample Description MW-124
Room 120 Classroom Sink
Collected: 5/1/2021 7:02:00 AM
Lab ID: 012104879-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:02

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-126
 Room 122 Classroom Sink
Collected: 5/1/2021 7:03:00 AM
Lab ID: 012104879-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.37	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:04

Client Sample Description MW-128
 Room 119 Classroom Sink
Collected: 5/1/2021 7:05:00 AM
Lab ID: 012104879-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.35	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:05

Client Sample Description MW-130
 Room 118 Classroom Sink
Collected: 5/1/2021 7:04:00 AM
Lab ID: 012104879-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.71	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:06

Client Sample Description MW-132
 Room 117 Classroom Sink
Collected: 5/1/2021 7:07:00 AM
Lab ID: 012104879-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.42	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:08

Client Sample Description MW-134
 Room 116 Classroom Sink
Collected: 5/1/2021 7:08:00 AM
Lab ID: 012104879-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.84	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-136
Custodial Bathroom sink
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104879-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.30	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:17

Client Sample Description MW-137
Hand Sink Receiving
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104879-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:21

Client Sample Description MW-138
Kitchen Bathroom Sink
Collected: 5/1/2021 7:52:00 AM
Lab ID: 012104879-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:22

Client Sample Description MW-139
Kitchen Sink #1
Collected: 5/1/2021 6:25:00 AM
Lab ID: 012104879-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:23

Client Sample Description MW-140
Room 10 Classroom Sink
Collected: 5/1/2021 7:58:00 AM
Lab ID: 012104879-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.29	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:25

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-142
 Hallway Fountain by Room 138
Collected: 5/1/2021 6:38:00 AM
Lab ID: 012104879-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:26

Client Sample Description MW-143
 Boys Lav by Room 137 Bathroom Sink
Collected: 5/1/2021 6:26:00 AM
Lab ID: 012104879-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.93	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:27

Client Sample Description MW-144
 Room 138 Classroom Sink
Collected: 5/1/2021 6:23:00 AM
Lab ID: 012104879-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:29

Client Sample Description MW-145
 Room 137 Classroom Sink
Collected: 5/1/2021 6:27:00 AM
Lab ID: 012104879-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:33

Client Sample Description MW-146
 Faculty Mens Bathroom Sink #1
Collected: 5/1/2021 6:37:00 AM
Lab ID: 012104879-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-147
 Faculty Womens Bathroom Sink #2
Collected: 5/1/2021 6:36:00 AM
Lab ID: 012104879-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.35	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:35

Client Sample Description MW-148
 Conference Room Sink
Collected: 5/1/2021 6:37:00 AM
Lab ID: 012104879-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.01	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:39

Client Sample Description MW-149
 Room 136 Classroom Sink
Collected: 5/1/2021 6:30:00 AM
Lab ID: 012104879-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:41

Client Sample Description MW-151
 Room 137 Bathroom Sink
Collected: 5/1/2021 6:29:00 AM
Lab ID: 012104879-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:42

Client Sample Description MW-152
 Room 135 Classroom Sink
Collected: 5/1/2021 6:31:00 AM
Lab ID: 012104879-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-154
 Room 134 Classroom Sink
Collected: 5/1/2021 6:32:00 AM
Lab ID: 012104879-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.33	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:44

Client Sample Description MW-156
 Room 133 Classroom Sink
Collected: 5/1/2021 6:32:00 AM
Lab ID: 012104879-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:48

Client Sample Description MW-158
 Room 132 Classroom Sink
Collected: 5/1/2021 6:33:00 AM
Lab ID: 012104879-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:50

Client Sample Description MW-160
 Room 131 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104879-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:51

Client Sample Description MW-162
 Room 130 Classroom Sink
Collected: 5/1/2021 6:34:00 AM
Lab ID: 012104879-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 15:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-164
 Room 129 Classroom Sink
Collected: 5/1/2021 6:41:00 AM
Lab ID: 012104879-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.77	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:46

Client Sample Description MW-166
 Faculty Room Sink
Collected: 5/1/2021 7:10:00 AM
Lab ID: 012104879-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.25	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:50

Client Sample Description MW-168
 Staff Bathroom by Gym Bathroom Sink #1
Collected: 5/1/2021 7:43:00 AM
Lab ID: 012104879-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.95	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:52

Client Sample Description MW-169
 Staff Bathroom by Gym Bathroom Sink #2
Collected: 5/1/2021 7:43:00 AM
Lab ID: 012104879-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:53

Client Sample Description MW-170
 Room 115 Classroom Sink
Collected: 5/1/2021 7:13:00 AM
Lab ID: 012104879-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.14	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-172
 Hallway Fountain by Room 115
Collected: 5/1/2021 7:14:00 AM
Lab ID: 012104879-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:56

Client Sample Description MW-173
 Room 114 Classroom Sink
Collected: 5/1/2021 7:15:00 AM
Lab ID: 012104879-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.66	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:57

Client Sample Description MW-175
 Room 113 Classroom Sink #1
Collected: 5/1/2021 7:16:00 AM
Lab ID: 012104879-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.74	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:58

Client Sample Description MW-176
 Room 113 Classroom Sink #2
Collected: 5/1/2021 7:16:00 AM
Lab ID: 012104879-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:02

Client Sample Description MW-178
 Room 112 Classroom Sink #1
Collected: 5/1/2021 7:17:00 AM
Lab ID: 012104879-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.53	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-180
 Room 111 Classroom Sink #1
Collected: 5/1/2021 7:18:00 AM
Lab ID: 012104879-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:05

Client Sample Description MW-182
 Room 110 Classroom Sink #1
Collected: 5/1/2021 7:19:00 AM
Lab ID: 012104879-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.41	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:09

Client Sample Description MW-184
 Room 109 Classroom Sink #1
Collected: 5/1/2021 7:20:00 AM
Lab ID: 012104879-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:10

Client Sample Description MW-186
 Room 107 Classroom Sink
Collected: 5/1/2021 7:21:00 AM
Lab ID: 012104879-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.06	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:11

Client Sample Description MW-188
 Hallway Fountain by Room 100
Collected: 5/1/2021 7:23:00 AM
Lab ID: 012104879-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104879

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-189 **Collected:** 5/1/2021 **Lab ID:** 012104879-0056
Library Office Sink 7:24:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 21:14

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

5/24/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/11/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012104883. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104883

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-190
 Room 106 Classroom Sink
Collected: 5/1/2021 7:26:00 AM
Lab ID: 012104883-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.46	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:44

Client Sample Description MW-192
 Room 108 Classroom Sink
Collected: 5/1/2021 7:28:00 AM
Lab ID: 012104883-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.88	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:47

Client Sample Description MW-194
 Room 105 Classroom Sink
Collected: 5/1/2021 7:28:00 AM
Lab ID: 012104883-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.15	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:49

Client Sample Description MW-196
 Room 104 Classroom Sink
Collected: 5/1/2021 7:30:00 AM
Lab ID: 012104883-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.42	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:50

Client Sample Description MW-198
 Room 103 Classroom Sink
Collected: 5/1/2021 7:32:00 AM
Lab ID: 012104883-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.80	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:51

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104883
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-200
Room 102 Classroom Sink
Collected: 5/1/2021 7:34:00 AM
Lab ID: 012104883-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.2	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:53

Client Sample Description MW-202
Room 101 Classroom Sink
Collected: 5/1/2021 7:36:00 AM
Lab ID: 012104883-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.8	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:54

Client Sample Description MW-204
Room 100 Classroom Sink
Collected: 5/1/2021 7:37:00 AM
Lab ID: 012104883-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.81	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:55

Client Sample Description MW-206
Main Office Sink
Collected: 5/1/2021 7:39:00 AM
Lab ID: 012104883-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.84	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 19:59

Client Sample Description MW-207
Clinic Sink
Collected: 5/1/2021 7:40:00 AM
Lab ID: 012104883-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.00	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104883

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-208
Clinic Bathroom Sink
Collected: 5/1/2021 7:41:00 AM
Lab ID: 012104883-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.44	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:02

Client Sample Description MW-209
Girls Shower Bathroom Sink #1
Collected: 5/1/2021 7:45:00 AM
Lab ID: 012104883-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:06

Client Sample Description MW-210
Girls Shower Bathroom Sink #2
Collected: 5/1/2021 7:45:00 AM
Lab ID: 012104883-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:07

Client Sample Description MW-211
Boys Shower Bathroom Sink
Collected: 5/1/2021 7:48:00 AM
Lab ID: 012104883-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:08

Client Sample Description MW-212
Boiler Room Eye Wash
Collected: 5/1/2021 7:50:00 AM
Lab ID: 012104883-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	200 D	5.00 µg/L	5/14/2021 JD	5/17/2021 JW 18:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104883
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-213
Boiler Room Source Sample
Collected: 5/1/2021 8:03:00 AM
Lab ID: 012104883-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.8	1.00 µg/L	5/14/2021 JD	5/17/2021 JW 17:33

Client Sample Description MW-214
Room 102 Sink #2
Collected: 5/1/2021 7:35:00 AM
Lab ID: 012104883-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.4	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:10

Client Sample Description MW-215
Room 101 Sink #2
Collected: 5/1/2021 7:36:00 AM
Lab ID: 012104883-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	76.0	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:11

Client Sample Description MW-217
Hallway Fountain by Café
Collected: 5/1/2021 6:58:00 AM
Lab ID: 012104883-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:15

Client Sample Description MW-218
Handicapped Bathroom Sink Custodial Hallway
Collected: 5/1/2021 7:47:00 AM
Lab ID: 012104883-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:16

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104883

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-219
Café Stage Sink
Collected: 5/1/2021 7:00:00 AM
Lab ID: 012104883-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.76	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:18

Client Sample Description MW-220
Boys Lav Sink Sink #4
Collected: 5/1/2021 6:54:00 AM
Lab ID: 012104883-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.88	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:19

Client Sample Description MW-222
Kitchen Sink #2
Collected: 5/1/2021 7:58:00 AM
Lab ID: 012104883-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.75	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:24

Client Sample Description MW-223
Kitchen Pot Filler
Collected: 5/1/2021
Lab ID: 012104883-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.3	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:31

Client Sample Description MW-224
Kitchen Steamer
Collected: 5/1/2021 8:05:00 AM
Lab ID: 012104883-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.43	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012104883
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
490 Lawrence Bell Dr
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 5/11/2021 09:30 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MW-225
Boys Lav by Gym Sink #3

Collected: 5/1/2021 6:56:00 AM

Lab ID: 012104883-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.61	1.00 µg/L	5/20/2021 VD	5/20/2021 VD 20:33

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107278. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 101
 Lav Across from café sink
Collected: 6/30/2021 6:07:00 AM
Lab ID: 012107278-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.33	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:05

Client Sample Description MM - 102
 Womens Bathroom across from main entrance sink #1
Collected: 6/30/2021 6:09:00 AM
Lab ID: 012107278-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.63	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:10

Client Sample Description MM - 103
 Womens Bathroom across from main entrance sink #2
Collected: 6/30/2021 6:10:00 AM
Lab ID: 012107278-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.56	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:12

Client Sample Description MM - 104
 Main Office Sink
Collected: 6/30/2021 6:11:00 AM
Lab ID: 012107278-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.47	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:14

Client Sample Description MM - 105
 Principles Office Lav Sink
Collected: 6/30/2021 6:12:00 AM
Lab ID: 012107278-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 106
 Storage Room next to Assistance Principals Sink
Collected: 6/30/2021 6:14:00 AM
Lab ID: 012107278-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	202 D	10.0 µg/L	7/16/2021 KB	7/19/2021 KB 15:40

Client Sample Description MM - 107
 Clinic Office Sink
Collected: 6/30/2021 6:16:00 AM
Lab ID: 012107278-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.0	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:23

Client Sample Description MM - 108
 Slinic Bathroom Sink
Collected: 6/30/2021 6:17:00 AM
Lab ID: 012107278-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	26.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:25

Client Sample Description MM - 109
 Clinic Eye Wash
Collected: 6/30/2021 6:18:00 AM
Lab ID: 012107278-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:27

Client Sample Description MM - 110
 Room A-1 Sink
Collected: 6/30/2021 6:20:00 AM
Lab ID: 012107278-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	36.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 111
Room A-6 Sink **Collected:** 6/30/2021 6:22:00 AM **Lab ID:** 012107278-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	40.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:31

Client Sample Description MM - 112
Room A-8 Sink **Collected:** 6/30/2021 6:22:00 AM **Lab ID:** 012107278-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:37

Client Sample Description MM - 113
Room A-9 Sink **Collected:** 6/30/2021 6:23:00 AM **Lab ID:** 012107278-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:42

Client Sample Description MM - 114
Boys Lav Across from A-11 Sink #1 **Collected:** 6/30/2021 6:28:00 AM **Lab ID:** 012107278-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.68	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:44

Client Sample Description MM - 115
Boys Lav Across from A-11 Sink #2 **Collected:** 6/30/2021 6:28:00 AM **Lab ID:** 012107278-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.35	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 117
 Hallway fountain across from room A-11 #1
Collected: 6/30/2021 6:32:00 AM
Lab ID: 012107278-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:48

Client Sample Description MM - 119
 Girls Lav across from Room A-11 Sink #1
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	22.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:50

Client Sample Description MM - 120
 Girls Lav across from Room A-11 Sink #2
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.06	1.00 µg/L	7/12/2021 KB	7/13/2021 KB 05:03

Client Sample Description MM - 121
 Girls Lav across from Room A-11 Sink #3
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.34	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:52

Client Sample Description MM - 122
 Girls Lav across from Room A-11 Sink #4
Collected: 6/30/2021 6:34:00 AM
Lab ID: 012107278-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.69	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 123
 Room A-11 Classroom Sink
Collected: 6/30/2021 6:37:00 AM
Lab ID: 012107278-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	48.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:56

Client Sample Description MM - 124
 Room A-10 Classroom Sink
Collected: 6/30/2021 6:38:00 AM
Lab ID: 012107278-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	45.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:46

Client Sample Description MM - 125
 Room A-13 Classroom Sink
Collected: 6/30/2021 6:39:00 AM
Lab ID: 012107278-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	27.9	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:50

Client Sample Description MM - 126
 Library Office Sink
Collected: 6/30/2021 6:42:00 AM
Lab ID: 012107278-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:51

Client Sample Description MM - 127
 Faculty Lav Near Library Sink
Collected: 6/30/2021 6:45:00 AM
Lab ID: 012107278-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.79	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 128
 Handicapped Lav Across from Library Sink
Collected: 6/30/2021 6:43:00 AM
Lab ID: 012107278-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	26.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:54

Client Sample Description MM - 129
 Hallway fountain Near Library
Collected: 6/30/2021 6:48:00 AM
Lab ID: 012107278-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 16:59

Client Sample Description MM - 130
 Room 8 Classroom Sink
Collected: 6/30/2021 6:50:00 AM
Lab ID: 012107278-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:00

Client Sample Description MM - 131
 Room B-6 Classroom Sink
Collected: 6/30/2021 6:51:00 AM
Lab ID: 012107278-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:01

Client Sample Description MM - 132
 Storage Room next to Assistance Principals Sink
Collected: 6/30/2021 6:57:00 AM
Lab ID: 012107278-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.0	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		MM - 133 Clinic Office Sink	Collected:	6/30/2021 6:54:00 AM	Lab ID:	012107278-0031	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	2.45	1.00 µg/L	7/16/2021	KB	7/16/2021 17:04	VD
Client Sample Description		MM - 134 Slinic Bathroom Sink	Collected:	6/30/2021 6:54:00 AM	Lab ID:	012107278-0032	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	3.34	1.00 µg/L	7/16/2021	KB	7/16/2021 17:05	VD
Client Sample Description		MM - 135 Clinic Eye Wash	Collected:	6/30/2021 6:56:00 AM	Lab ID:	012107278-0033	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	9.11	1.00 µg/L	7/16/2021	KB	7/16/2021 17:09	VD
Client Sample Description		MM - 136 Room A-1 Sink	Collected:	6/30/2021 6:56:00 AM	Lab ID:	012107278-0034	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	4.42	1.00 µg/L	7/16/2021	KB	7/16/2021 17:11	VD
Client Sample Description		MM - 137 Room A-6 Sink	Collected:	6/30/2021 6:56:00 AM	Lab ID:	012107278-0035	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	2.22	1.00 µg/L	7/16/2021	KB	7/16/2021 17:14	VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 138
Room A-8 Sink
Collected: 6/30/2021 6:56:00 AM
Lab ID: 012107278-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.70	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:16

Client Sample Description MM - 139
Room A-9 Sink
Collected: 6/30/2021 6:59:00 AM
Lab ID: 012107278-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:17

Client Sample Description MM - 140
Boys Lav across from A-11 Sink #1
Collected: 6/30/2021 7:00:00 AM
Lab ID: 012107278-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	49.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:18

Client Sample Description MM - 141
Boys Lav across from A-11 Sink #2
Collected: 6/30/2021 7:01:00 AM
Lab ID: 012107278-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:20

Client Sample Description MM - 142
Hallway fountain across from room A-11 #1
Collected: 6/30/2021 7:14:00 AM
Lab ID: 012107278-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	42.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:21

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 143
 Girls Lav Across from Room A-11 Sink #1
Collected: 6/30/2021 7:16:00 AM
Lab ID: 012107278-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 17:22

Client Sample Description MM - 144
 Girls Lav Across from Room A-11 Sink #2
Collected: 6/30/2021 7:16:00 AM
Lab ID: 012107278-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.14	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:20

Client Sample Description MM - 145
 Girls Lav Across from Room A-11 Sink #3
Collected: 6/30/2021 7:16:00 AM
Lab ID: 012107278-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.7	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:29

Client Sample Description MM - 146
 Girls Lav Across from Room A-11 Sink #4
Collected: 6/30/2021 7:21:00 AM
Lab ID: 012107278-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.40	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:30

Client Sample Description MM - 149
 Room A-11 Classroom Sink
Collected: 6/30/2021 7:22:00 AM
Lab ID: 012107278-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	36.8	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 150
Room A-10 Classroom Sink
Collected: 6/30/2021 7:23:00 AM
Lab ID: 012107278-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	53.0	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:33

Client Sample Description MM - 151
Room A-13 Classroom Sink
Collected: 6/30/2021 7:23:00 AM
Lab ID: 012107278-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.00	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:34

Client Sample Description MM - 152
Library Office Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.55	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:35

Client Sample Description MM - 153
Faculty Lav Near Library Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.16	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:39

Client Sample Description MM - 154
Handicapped Lav Across from Library Sink
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.73	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 155
 Hallway fountain near library
Collected: 6/30/2021 7:27:00 AM
Lab ID: 012107278-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.35	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:42

Client Sample Description MM - 156
 Room 8 Classroom Sink
Collected: 6/30/2021 7:25:00 AM
Lab ID: 012107278-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.55	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:43

Client Sample Description MM - 157
 Room B-6 Classroom Sink
Collected: 6/30/2021 7:22:00 AM
Lab ID: 012107278-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:47

Client Sample Description MM - 159
 Room C-11 Classroom Sink
Collected: 6/30/2021 7:25:00 AM
Lab ID: 012107278-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	63.9	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:48

Client Sample Description MM - 160
 Room C-10 Classroom Sink
Collected: 6/30/2021 7:26:00 AM
Lab ID: 012107278-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	41.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:50

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107278

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM - 161
Room C-13 Classroom Sink

Collected: 6/30/2021
7:26:00 AM

Lab ID: 012107278-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.4	1.00 µg/L	7/16/2021 KB	7/17/2021 03:51 VD

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107315. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-162
 Room E-1 Classroom Sink #1
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107315-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.73	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 10:55

Client Sample Description MM-163
 Room E-1 Classroom Sink #2
Collected: 6/5/2021 7:16:00 AM
Lab ID: 012107315-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:02

Client Sample Description MM-164
 Room E-3 Classroom Sink #1
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107315-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.62	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:03

Client Sample Description MM-165
 Room E-3 Classroom Sink #2
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107315-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.13	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:04

Client Sample Description MM-166
 Room E-3 Classroom Sink #3
Collected: 6/5/2021 6:17:00 AM
Lab ID: 012107315-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.86	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-167
 Room E-3 Teachers Storage Sink
Collected: 6/5/2021 6:15:00 AM
Lab ID: 012107315-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.1	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:07

Client Sample Description MM-168
 Room E-5 Classroom Sink #1
Collected: 6/5/2021 6:13:00 AM
Lab ID: 012107315-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.72	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:08

Client Sample Description MM-169
 Room E-5 Classroom Sink #2
Collected: 6/5/2021 6:14:00 AM
Lab ID: 012107315-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.39	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:09

Client Sample Description MM-170
 Room E-5 Classroom Sink #3
Collected: 6/5/2021 6:14:00 AM
Lab ID: 012107315-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.8	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:11

Client Sample Description MM-171
 Room E-2 Classroom Sink #1
Collected: 6/5/2021 6:09:00 AM
Lab ID: 012107315-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.3	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-172
 Room E-2 Classroom Sink #2
Collected: 6/5/2021 6:10:00 AM
Lab ID: 012107315-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	53.5	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:19

Client Sample Description MM-173
 Room E-2 Classroom Sink #3
Collected: 6/5/2021 6:11:00 AM
Lab ID: 012107315-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	20.0	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:23

Client Sample Description MM-174
 Room E-2 Classroom Sink #4
Collected: 6/5/2021 6:11:00 AM
Lab ID: 012107315-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	34.3	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:24

Client Sample Description MM-175
 Hallway Fountain Across from E-2
Collected: 6/5/2021 7:28:00 AM
Lab ID: 012107315-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:25

Client Sample Description MM-177
 Room E-4 Classroom Sink
Collected: 6/5/2021 6:12:00 AM
Lab ID: 012107315-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-178
 Room E-7 Classroom Sink #1
Collected: 6/5/2021 6:21:00 AM
Lab ID: 012107315-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	45.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:28

Client Sample Description MM-179
 Room E-7 Classroom Sink #2
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107315-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:32

Client Sample Description MM-181
 Room E-9 Classroom Sink
Collected: 6/5/2021 6:22:00 AM
Lab ID: 012107315-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.79	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:33

Client Sample Description MM-183
 Boys Gym Teachers Office Sink
Collected: 6/5/2021 6:23:00 AM
Lab ID: 012107315-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.33	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:34

Client Sample Description MM-184
 Boys Locker Room Sink
Collected: 6/5/2021 6:24:00 AM
Lab ID: 012107315-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.1	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 11:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-187
 Girls Locker Room Sink # 1
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107315-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.06	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:55

Client Sample Description MM-188
 Girls Locker Room Sink # 2
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107315-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	40.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 18:59

Client Sample Description MM-189
 Girls Locker Room Sink # 3
Collected: 6/5/2021 6:28:00 AM
Lab ID: 012107315-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:00

Client Sample Description MM-191
 Unisex Bathroom Across from Gym Sink
Collected: 6/5/2021 6:31:00 AM
Lab ID: 012107315-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.71	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:04

Client Sample Description MM-192
 Cafeteria Fountain
Collected: 6/5/2021 7:30:00 AM
Lab ID: 012107315-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-193
 Hallway Fountain by Stage and Main Hall
Collected: 6/5/2021 7:31:00 AM
Lab ID: 012107315-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:07

Client Sample Description MM-194
 Room M-3 Classroom Sink
Collected: 6/5/2021 6:33:00 AM
Lab ID: 012107315-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.78	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:08

Client Sample Description MM-195
 Kitchen Sink # 1
Collected: 6/5/2021 6:36:00 AM
Lab ID: 012107315-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.76	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:09

Client Sample Description MM-196
 Kitchen Sink # 2
Collected: 6/5/2021 6:35:00 AM
Lab ID: 012107315-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:11

Client Sample Description MM-197
 Kitchen Sink # 3
Collected: 6/5/2021 6:34:00 AM
Lab ID: 012107315-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.69	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-198
 Kitchen Sink # 4
Collected: 6/5/2021 6:34:00 AM
Lab ID: 012107315-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:13

Client Sample Description MM-199
 Kitchen Sink # 5
Collected: 6/5/2021 6:38:00 AM
Lab ID: 012107315-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.58	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:20

Client Sample Description MM-200
 Kitchen Sink # 6
Collected: 6/5/2021 6:37:00 AM
Lab ID: 012107315-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.20	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:21

Client Sample Description MM-201
 Womens Locker Room Off Kitchen Sink
Collected: 6/5/2021 6:42:00 AM
Lab ID: 012107315-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.8	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:22

Client Sample Description MM-202
 Womens Locker Room Off Kitchen Bathroom Sink
Collected: 6/5/2021 6:42:00 AM
Lab ID: 012107315-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.16	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-203
Mens Bathroom in Basement
Collected: 6/5/2021 6:45:00 AM
Lab ID: 012107315-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.32	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:25

Client Sample Description MM-204
Basement Storage Sink # 1
Collected: 6/5/2021 6:44:00 AM
Lab ID: 012107315-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:26

Client Sample Description MM-207
Girls Coaches Office Sink
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107315-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.94	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:28

Client Sample Description MM-208
Cooks Sink
Collected: 6/5/2021 6:35:00 AM
Lab ID: 012107315-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.85	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:29

Client Sample Description MM-209
Mens Bathroom Off of Kitchen
Collected: 6/5/2021 6:42:00 AM
Lab ID: 012107315-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.23	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107315
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description MM-210
Basement Storage Sink # 2
Collected: 6/5/2021 6:44:00 AM
Lab ID: 012107315-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.35	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:15

Client Sample Description MM-211
Faculty Lav by Library Sink # 2
Collected: 6/5/2021 6:45:00 AM
Lab ID: 012107315-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.45	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:17

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107313. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-100
Boiler Room Source
Collected: 6/12/2021 6:02:00 AM
Lab ID: 012107313-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.5	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:01

Client Sample Description NH-101
Basement Break Room Sink # 1
Collected: 6/12/2021 6:05:00 AM
Lab ID: 012107313-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.11	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:07

Client Sample Description NH-102
Basement Break Room Sink # 2
Collected: 6/12/2021 6:05:00 AM
Lab ID: 012107313-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.03	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:09

Client Sample Description NH-103
Basement Lockr Rm Bathrm Sink
Collected: 6/12/2021 6:09:00 AM
Lab ID: 012107313-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.26	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:11

Client Sample Description NH-104
A Wing Girls Lav Sink # 1
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107313-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.95	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-105
 A Wing Girls Lav Sink # 2
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107313-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.14	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:18

Client Sample Description NH-106
 A Wing Girls Lav Sink # 3
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107313-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.05	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:20

Client Sample Description NH-107
 A Wing Girls Lav Sink # 4
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107313-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.15	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:22

Client Sample Description NH-108
 A Wing Boys Lav Sink # 1
Collected: 6/12/2021 6:29:00 AM
Lab ID: 012107313-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.10	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:24

Client Sample Description NH-109
 A Wing Boys Lav Sink # 2
Collected: 6/12/2021 6:29:00 AM
Lab ID: 012107313-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.10	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-111
 Room A-159 Sink
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107313-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.72	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:28

Client Sample Description NH-112
 Conference Room Sink # 1
Collected: 6/12/2021 6:34:00 AM
Lab ID: 012107313-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:33

Client Sample Description NH-113
 Conference Room Sink # 2
Collected: 6/12/2021 6:34:00 AM
Lab ID: 012107313-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:35

Client Sample Description NH-114
 Guidance Office Sink
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107313-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:41

Client Sample Description NH-115
 Room A-103 Sink
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107313-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.93	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-116
Room A-109 Sink
Collected: 6/12/2021 6:43:00 AM
Lab ID: 012107313-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:45

Client Sample Description NH-117
Hallway Fountain by Rm A-105
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107313-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:46

Client Sample Description NH-120
Room A-134 Bathroom Sink
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107313-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:48

Client Sample Description NH-121
Kitchen Sink # 1
Collected: 6/12/2021 6:47:00 AM
Lab ID: 012107313-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:50

Client Sample Description NH-122
Kitchen Sink # 2
Collected: 6/12/2021 6:47:00 AM
Lab ID: 012107313-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-123
Kitchen Sink # 3
Collected: 6/12/2021 6:47:00 AM
Lab ID: 012107313-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.27	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:24

Client Sample Description NH-124
Kitchen Sink # 4
Collected: 6/12/2021 6:48:00 AM
Lab ID: 012107313-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:28

Client Sample Description NH-125
Kitchen Sink # 5
Collected: 6/12/2021 6:48:00 AM
Lab ID: 012107313-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:34

Client Sample Description NH-126
Kitchen Sink # 6
Collected: 6/12/2021 6:48:00 AM
Lab ID: 012107313-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:36

Client Sample Description NH-127
Kitchen Sink # 7
Collected: 6/12/2021 6:49:00 AM
Lab ID: 012107313-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.03	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-128
Serving Area Sink # 1
Collected: 6/12/2021 6:51:00 AM
Lab ID: 012107313-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:38

Client Sample Description NH-129
Serving Area Sink # 2
Collected: 6/12/2021 6:52:00 AM
Lab ID: 012107313-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.62	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:40

Client Sample Description NH-130
Kitchen Dish Room Sink # 1
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107313-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.86	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:41

Client Sample Description NH-131
Kitchen Dish Room Sink # 2
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107313-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.9	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:42

Client Sample Description NH-132
Hallway Fountain by Rm A-120
Collected: 6/12/2021 6:59:00 AM
Lab ID: 012107313-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-166
 Hallway Fountain by B-103
Collected: 6/12/2021 7:01:00 AM
Lab ID: 012107313-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:47

Client Sample Description NH-178
 Girls Lav by Rm A-123 Sink # 1
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107313-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.43	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:51

Client Sample Description NH-179
 Girls Lav by Rm A-123 Sink # 2
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107313-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:53

Client Sample Description NH-180
 Girls Lav by Rm A-123 Sink # 3
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107313-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.87	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:54

Client Sample Description NH-181
 Girls Lav by Rm A-123 Sink # 4
Collected: 6/12/2021 7:04:00 AM
Lab ID: 012107313-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.89	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-182
Boys Lav by Rm A-123 Sink # 1
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107313-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.69	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:56

Client Sample Description NH-183
Boys Lav by Rm A-123 Sink # 2
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107313-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.78	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:58

Client Sample Description NH-184
Boys Lav by Rm A-123 Sink # 3
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107313-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.42	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 05:59

Client Sample Description NH-200
Womens Lav by C-108 Sink # 1
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107313-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.65	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:03

Client Sample Description NH-201
Womens Lav by C-108 Sink # 2
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107313-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.1	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-202
 Womens Lav by C-108 Sink # 3
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107313-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.4	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:09

Client Sample Description NH-203
 Room C-108 Sink # 1
Collected: 6/12/2021 7:20:00 AM
Lab ID: 012107313-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	24.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:13

Client Sample Description NH-204
 Room C-108 Sink # 2
Collected: 6/12/2021 7:21:00 AM
Lab ID: 012107313-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.1	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:15

Client Sample Description NH-205
 Hallway Fountain by C-108
Collected: 6/12/2021 7:22:00 AM
Lab ID: 012107313-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:19

Client Sample Description NH-206
 Room C-107 Sink # 1
Collected: 6/12/2021 7:24:00 AM
Lab ID: 012107313-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.91	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:20

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-207
 Room C-107 Sink # 2
Collected: 6/12/2021 7:24:00 AM
Lab ID: 012107313-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.69	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:21

Client Sample Description NH-208
 Room C-105 (Dark Room) Sink # 1
Collected: 6/12/2021 7:27:00 AM
Lab ID: 012107313-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.54	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:22

Client Sample Description NH-209
 Room C-105 (Clay Room) Sink # 1
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107313-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	53.6	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:24

Client Sample Description NH-210
 Room C-103 Sink # 1
Collected: 6/12/2021 7:32:00 AM
Lab ID: 012107313-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.40	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:25

Client Sample Description NH-211
 Room C-103 Sink # 2
Collected: 6/12/2021 7:32:00 AM
Lab ID: 012107313-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.50	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-212
 Room C-102 Sink # 1
Collected: 6/12/2021 7:33:00 AM
Lab ID: 012107313-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.54	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:28

Client Sample Description NH-213
 Room C-102 Sink # 2
Collected: 6/12/2021 7:33:00 AM
Lab ID: 012107313-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.49	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:34

Client Sample Description NH-214
 Room C-101 Sink # 1
Collected: 6/12/2021 7:35:00 AM
Lab ID: 012107313-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.3	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:35

Client Sample Description NH-215
 Room C-101 Sink # 2
Collected: 6/12/2021 7:35:00 AM
Lab ID: 012107313-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.96	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:37

Client Sample Description NH-216
 C-162 Auto Shop Sink # 1
Collected: 6/12/2021 7:37:00 AM
Lab ID: 012107313-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107313

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description NH-217 **Collected:** 6/12/2021 **Lab ID:** 012107313-0056
C-162 Auto Shop Sink # 2 7:37:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	92.2	1.00 µg/L	7/15/2021 VD	7/16/2021 VD 06:39

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107287. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-220
 Mens Lav by C-137 Sink # 1
Collected: 6/12/2021 7:43:00 AM
Lab ID: 012107287-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.00	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 03:59

Client Sample Description NH-221
 Mens Lav by C-137 Sink # 2
Collected: 6/12/2021 7:43:00 AM
Lab ID: 012107287-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:03

Client Sample Description NH-222
 Womens Lav by C-137 Sink # 1
Collected: 6/12/2021 7:41:00 AM
Lab ID: 012107287-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.26	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:04

Client Sample Description NH-223
 Womens Lav by C-137 Sink # 2
Collected: 6/12/2021 7:41:00 AM
Lab ID: 012107287-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.20	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:05

Client Sample Description NH-224
 Health Office Sink # 1
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.8	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-225
 Health Office Sink # 2
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:06

Client Sample Description NH-226
 Health Office Bathroom Sink
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107287-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.97	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:10

Client Sample Description NH-227
 Bathroom C-122 Sink
Collected: 6/12/2021 8:09:00 AM
Lab ID: 012107287-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.10	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:12

Client Sample Description NH-229
 Mens Lav by 130 Sink # 1
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107287-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	28.0	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:13

Client Sample Description NH-230
 Mens Lav by 130 Sink # 2
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107287-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-231
 Mens Lav by 130 Sink # 3
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107287-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.7	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:16

Client Sample Description NH-232
 D-102 Bathroom Sink
Collected: 6/12/2021 6:40:00 AM
Lab ID: 012107287-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.57	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:17

Client Sample Description NH-233
 Boys Locker Room Ice Machine
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107287-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:21

Client Sample Description NH-234
 Boys Locker Rm Bathrm (Bradely) Sink # 1
Collected: 6/12/2021 6:34:00 AM
Lab ID: 012107287-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.09	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:22

Client Sample Description NH-235
 Hallwy Fountain/Boys Lock Rm
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107287-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-236
 Water Fountain Gym by D-126
Collected: 6/12/2021 6:32:00 AM
Lab ID: 012107287-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:27

Client Sample Description NH-240
 Boys Lav by D-121 Sink # 1
Collected: 6/12/2021 6:43:00 AM
Lab ID: 012107287-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:29

Client Sample Description NH-241
 Boys Lav by D-121 Sink # 2
Collected: 6/12/2021 6:43:00 AM
Lab ID: 012107287-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.82	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:30

Client Sample Description NH-242
 Girls Lav by D-121 Sink # 1
Collected: 6/12/2021 6:44:00 AM
Lab ID: 012107287-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.13	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:31

Client Sample Description NH-243
 Girls Lav by D-121 Sink # 2
Collected: 6/12/2021 6:44:00 AM
Lab ID: 012107287-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.12	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:32

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-244
 Hallway fountrn/D-123 Pool Stair
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107287-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:34

Client Sample Description NH-245
 Girl Locker Rm Bathrm (Bradley) Sink # 1
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107287-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.00	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:42

Client Sample Description NH-246
 Handicapped Locker Room Sink
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107287-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:45

Client Sample Description NH-247
 Handicap Lockr Rm Shower # 1
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107287-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.9	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:47

Client Sample Description NH-248
 Handicap Lockr Rm Shower # 2
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107287-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-249 **Collected:** 6/12/2021 **Lab ID:** 012107287-0026
 Girls Pool Locker Rm Bathrm Sink 6:54:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.46	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:49

Client Sample Description NH-250 **Collected:** 6/12/2021 **Lab ID:** 012107287-0027
 Boy Pool Locker Rm Bathrm Sink 6:54:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.27	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:51

Client Sample Description NH-252 **Collected:** 6/12/2021 **Lab ID:** 012107287-0028
 Mens Bathroom by 2B Sink # 1 7:44:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:52

Client Sample Description NH-253 **Collected:** 6/12/2021 **Lab ID:** 012107287-0029
 Mens Bathroom by 2B Sink # 2 7:44:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.32	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:53

Client Sample Description NH-254 **Collected:** 6/12/2021 **Lab ID:** 012107287-0030
 Mens Bathroom by 2B Sink # 3 7:44:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.71	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-255
 Womens Bathrm by 2B Sink # 1
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.67	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 04:59

Client Sample Description NH-256
 Womens Bathrm by 2B Sink # 2
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.20	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:00

Client Sample Description NH-257
 Womens Bathrm by 2B Sink # 3
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.52	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:04

Client Sample Description NH-258
 Womens Bathrm by 2B Sink # 4
Collected: 6/12/2021 7:45:00 AM
Lab ID: 012107287-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.90	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:05

Client Sample Description NH-259
 Library Office Sink
Collected: 6/12/2021 7:47:00 AM
Lab ID: 012107287-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.31	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-260
 Hallway Fountain by B201
Collected: 6/12/2021 7:48:00 AM
Lab ID: 012107287-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:08

Client Sample Description NH-261
 Hallway Fountain by B220
Collected: 6/12/2021 7:50:00 AM
Lab ID: 012107287-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:09

Client Sample Description NH-262
 2nd Floor Kitchen Sink # 1
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:13

Client Sample Description NH-263
 2nd Floor Kitchen Sink # 2
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:14

Client Sample Description NH-264
 2nd Floor Kitchen Sink # 3
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.01	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-265
 2nd Floor Kitchen Sink # 4
Collected: 6/12/2021 7:40:00 AM
Lab ID: 012107287-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.47	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:17

Client Sample Description NH-266
 Girls Lav by 2-A Sink # 1
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.03	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:22

Client Sample Description NH-267
 Girls Lav by 2-A Sink # 2
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.46	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:28

Client Sample Description NH-268
 Girls Lav by 2-A Sink # 3
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.19	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:30

Client Sample Description NH-269
 Girls Lav by 2-A Sink # 4
Collected: 6/12/2021 7:30:00 AM
Lab ID: 012107287-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.89	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-270
Boys Lav by 2-A Sink # 1
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.81	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:32

Client Sample Description NH-271
Boys Lav by 2-A Sink # 2
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.58	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:34

Client Sample Description NH-272
Boys Lav by 2-A Sink # 3
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:35

Client Sample Description NH-273
Boys Lav by 2-A Sink # 4
Collected: 6/12/2021 7:31:00 AM
Lab ID: 012107287-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.59	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:36

Client Sample Description NH-274
Fountain by Staff Work Rooms
Collected: 6/12/2021 7:36:00 AM
Lab ID: 012107287-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:38

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-275
Staff Work Room Sink
Collected: 6/12/2021 7:36:00 AM
Lab ID: 012107287-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.87	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:39

Client Sample Description NH-276
Womens Lav by A-210 Sink
Collected: 6/12/2021 7:34:00 AM
Lab ID: 012107287-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.54	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:40

Client Sample Description NH-277
Mens Lav by A-210 Sink
Collected: 6/12/2021 7:34:00 AM
Lab ID: 012107287-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.79	1.00 µg/L	7/13/2021 JD	7/15/2021 JW 19:38

Client Sample Description NH-278
Hallway Fountain by A-244
Collected: 6/12/2021 7:38:00 AM
Lab ID: 012107287-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:47

Client Sample Description NH-279
Water Fountains Outside # 1
Collected: 6/12/2021 7:05:00 AM
Lab ID: 012107287-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-281
 Unisex Bathroom Sink
Collected: 6/12/2021 7:06:00 AM
Lab ID: 012107287-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:49

Client Sample Description NH-282
 Boys Lav Sink
Collected: 6/12/2021 7:06:00 AM
Lab ID: 012107287-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:51

Client Sample Description NH-283
 Girls Lav Sink
Collected: 6/12/2021 7:06:00 AM
Lab ID: 012107287-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:52

Client Sample Description NH-284
 Sink in Concessions # 1
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107287-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:53

Client Sample Description NH-285
 Sink in Concessions # 2
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107287-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107287

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description NH-286
 Sink in Concessions # 3
Collected: 6/12/2021 7:03:00 AM
Lab ID: 012107287-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 05:56

Client Sample Description NH-287
 Womens 1st Floor Coaches Office Bathroom Sink
Collected: 6/12/2021 7:13:00 AM
Lab ID: 012107287-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	305 D	10.0 µg/L	7/13/2021 JD	7/15/2021 JW 20:30

Client Sample Description NH-288
 Accessible Bathroom Sink in Music Room
Collected: 6/12/2021 7:59:00 AM
Lab ID: 012107287-0063

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:03

Client Sample Description NH-289
 Pump Room Eye Wash
Collected: 6/12/2021 8:25:00 AM
Lab ID: 012107287-0064

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	30.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:08

Client Sample Description NH-290
 Dark Room Eye Wash
Collected: 6/12/2021 7:28:00 AM
Lab ID: 012107287-0065

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.35	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 06:12



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012107287
CustomerID:	WCSD21A
CustomerPO:	20-04919
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/20/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107306. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-102
 Hallway Fountain by E2
Collected: 6/12/2021 6:20:00 AM
Lab ID: 012107306-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:42

Client Sample Description SH-103
 Mens Room by E2 Sink # 1
Collected: 6/12/2021 6:21:00 AM
Lab ID: 012107306-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.22	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:51

Client Sample Description SH-104
 Womens Room by E3 Sink # 1
Collected: 6/12/2021 6:22:00 AM
Lab ID: 012107306-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.14	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:53

Client Sample Description SH-110
 Room E-7 Shower
Collected: 6/12/2021 6:22:00 AM
Lab ID: 012107306-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.29	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:30

Client Sample Description SH-112
 Room E-8 Vacuum Cabinet Sink
Collected: 6/12/2021 6:23:00 AM
Lab ID: 012107306-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:55

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-113
 Old Girls Squad Room Sink # 1
Collected: 6/12/2021 6:24:00 AM
Lab ID: 012107306-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.20	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:57

Client Sample Description SH-114
 Old Girls Squad Room Sink # 2
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107306-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.06	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:59

Client Sample Description SH-115
 Girls Coach Office Sink
Collected: 6/12/2021 6:26:00 AM
Lab ID: 012107306-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:01

Client Sample Description SH-117
 Boys Lav by Room 107 Sink # 1
Collected: 6/12/2021 6:27:00 AM
Lab ID: 012107306-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.82	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:03

Client Sample Description SH-118
 Boys Lav by Room 107 Sink # 2
Collected: 6/12/2021 6:28:00 AM
Lab ID: 012107306-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.79	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306
CustomerID: WCSD21A
CustomerPO: 20-4919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-119
Hallway Fountain/Main Entr
Collected: 6/12/2021
6:29:00 AM
Lab ID: 012107306-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:06

Client Sample Description SH-121
Room 135 Sink # 1
Collected: 6/12/2021
6:30:00 AM
Lab ID: 012107306-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:08

Client Sample Description SH-122
Room 135 Sink # 2
Collected: 6/12/2021
6:31:00 AM
Lab ID: 012107306-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:18

Client Sample Description SH-123
Room 135 Sink # 3
Collected: 6/12/2021
6:32:00 AM
Lab ID: 012107306-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.84	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:20

Client Sample Description SH-124
Room 135 Sink # 4
Collected: 6/12/2021
6:34:00 AM
Lab ID: 012107306-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:21

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-125
Room 135 Sink # 5
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107306-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:23

Client Sample Description SH-126
Room 133 Sink # 1
Collected: 6/12/2021 6:35:00 AM
Lab ID: 012107306-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.31	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:25

Client Sample Description SH-127
Room 133 Sink # 2
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107306-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.45	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:27

Client Sample Description SH-128
Room 133 Sink # 3
Collected: 6/12/2021 6:38:00 AM
Lab ID: 012107306-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.44	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:29

Client Sample Description SH-129
Room 133 Sink # 4
Collected: 6/12/2021 6:39:00 AM
Lab ID: 012107306-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description		SH-130 Room 133 Sink # 5	Collected:		6/12/2021 6:40:00 AM	Lab ID:		012107306-0021
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	4.88	1.00 µg/L	7/16/2021	KB	7/16/2021 20:37	VD	
Client Sample Description		SH-131 Mens Coaches Office (corner) Lav Sink	Collected:		6/12/2021 6:41:00 AM	Lab ID:		012107306-0022
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	6.15	1.00 µg/L	7/16/2021	KB	7/16/2021 20:52	VD	
Client Sample Description		SH-132 Mens Coach officie Sink	Collected:		6/12/2021 6:42:00 AM	Lab ID:		012107306-0023
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	3.77	1.00 µg/L	7/16/2021	KB	7/16/2021 20:57	VD	
Client Sample Description		SH-133 Fountain Boys Locker Room	Collected:		6/12/2021 6:43:00 AM	Lab ID:		012107306-0024
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	ND	1.00 µg/L	7/16/2021	KB	7/16/2021 20:59	VD	
Client Sample Description		SH-134 Old Boys Locker Room Sink # 1	Collected:		6/12/2021 6:44:00 AM	Lab ID:		012107306-0025
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	2.67	1.00 µg/L	7/16/2021	KB	7/16/2021 21:01	VD	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-135
 Old Boys Locker Room Sink # 2
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107306-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.57	1.00 µg/L	7/16/2021 KB	7/16/2021 21:03 VD

Client Sample Description SH-136
 Room 129 P Dark Room Sink
Collected: 6/12/2021 6:46:00 AM
Lab ID: 012107306-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.8	1.00 µg/L	7/16/2021 KB	7/19/2021 21:14 KB

Client Sample Description SH-137
 Room 129 P Sink # 1
Collected: 6/12/2021 6:47:00 AM
Lab ID: 012107306-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.69	1.00 µg/L	7/16/2021 KB	7/19/2021 21:15 KB

Client Sample Description SH-138
 Room 129 P Sink # 2
Collected: 6/12/2021 6:48:00 AM
Lab ID: 012107306-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	7/16/2021 KB	7/19/2021 21:17 KB

Client Sample Description SH-139
 Room 129 Sink
Collected: 6/12/2021 6:29:00 AM
Lab ID: 012107306-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.93	1.00 µg/L	7/16/2021 KB	7/19/2021 21:18 KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-140
 Room 129 D Sink # 1
Collected: 6/12/2021 6:50:00 AM
Lab ID: 012107306-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	59.4	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:19

Client Sample Description SH-141
 Room 129 D Sink # 2
Collected: 6/12/2021 6:51:00 AM
Lab ID: 012107306-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.1	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:21

Client Sample Description SH-142
 Room 129 D Sink # 3
Collected: 6/12/2021 6:52:00 AM
Lab ID: 012107306-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.8	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:25

Client Sample Description SH-143
 Room 129 D Sink # 4
Collected: 6/12/2021 6:53:00 AM
Lab ID: 012107306-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	34.0	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:26

Client Sample Description SH-144
 Unisex Bathroom by 129T Sink
Collected: 6/12/2021 6:54:00 AM
Lab ID: 012107306-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.82	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 21:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-145
 Room 129 W sink # 1
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107306-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.42	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:33

Client Sample Description SH-146
 Room 129 W sink # 2
Collected: 6/12/2021 6:56:00 AM
Lab ID: 012107306-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.94	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:35

Client Sample Description SH-147
 Room 129 T Sink # 1
Collected: 6/12/2021 6:57:00 AM
Lab ID: 012107306-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:37

Client Sample Description SH-150
 Women lav/New Gym Sink # 1
Collected: 6/12/2021 6:58:00 AM
Lab ID: 012107306-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.54	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:39

Client Sample Description SH-151
 Women lav/New Gym Sink # 2
Collected: 6/12/2021 6:59:00 AM
Lab ID: 012107306-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.90	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-152 **Collected:** 6/12/2021 **Lab ID:** 012107306-0041
 Men lav by New Gym Sink # 1 7:00:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.61	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 21:43

Client Sample Description SH-153 **Collected:** 6/12/2021 **Lab ID:** 012107306-0042
 Men lav by New Gym Sink # 2 7:01:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.66	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:22

Client Sample Description SH-155 **Collected:** 6/12/2021 **Lab ID:** 012107306-0043
 New Gym Boy Locker Rm Sink 7:02:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.96	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:42

Client Sample Description SH-156 **Collected:** 6/12/2021 **Lab ID:** 012107306-0044
 New Boys Coaches Office Sink 7:03:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:29

Client Sample Description SH-157 **Collected:** 6/12/2021 **Lab ID:** 012107306-0045
 New Boys Coaches Off Shower 7:04:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.69	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:30

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306

CustomerID: WCSD21A

CustomerPO: 20-4919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-159 **Collected:** 6/12/2021 **Lab ID:** 012107306-0046
 New Gym Girl Locker Rm Sink 7:05:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:31

Client Sample Description SH-160 **Collected:** 6/12/2021 **Lab ID:** 012107306-0047
 New Gym Girl Locker Rm Sink # 2 7:06:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:32

Client Sample Description SH-161 **Collected:** 6/12/2021 **Lab ID:** 012107306-0048
 New Girls Coaches Office Sink 7:07:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.65	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 22:34

Client Sample Description SH-162 **Collected:** 6/12/2021 **Lab ID:** 012107306-0049
 New Girls Coaches Off Shower 7:08:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	193 D	10.0 µg/L	7/16/2021 KB	7/19/2021 KB 15:37

Client Sample Description SH-165 **Collected:** 6/12/2021 **Lab ID:** 012107306-0050
 New Gym Foyer Girl Lav Sink # 1 6:18:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/19/2021 KB 15:39

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306
 CustomerID: WCSD21A
 CustomerPO: 20-4919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-166
 New Gym Foyer Girl Lav Sink # 2
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 22:38 VD

Client Sample Description SH-167
 New Gym Foyer Girl Lav Sink # 3
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 22:39 VD

Client Sample Description SH-168
 New Gym Foyer Girl Lav Sink # 4
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 22:43 VD

Client Sample Description SH-169
 New Gym Foyer Girl Lav Sink # 5
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 22:47 VD

Client Sample Description SH-170
 New Gym Foyer Girl Lav Sink # 6
Collected: 6/12/2021 6:18:00 AM
Lab ID: 012107306-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 22:48 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107306
CustomerID: WCSD21A
CustomerPO: 20-4919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description SH-171
New Gym Foyer Boy Lav Sink # 1

Collected: 6/12/2021
6:25:00 AM

Lab ID: 012107306-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 22:49 VD

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107279. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-172
 New Gym Foyer Boy Lav Sink # 2
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:27

Client Sample Description SH-173
 New Gym Foyer Boy Lav Sink # 3
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:29

Client Sample Description SH-174
 New Gym Foyer Boy Lav Sink # 4
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:30

Client Sample Description SH-175
 New Gym Foyer Boy Lav Sink # 5
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:32

Client Sample Description SH-176
 New Gym Foyer Boy Lav Sink # 6
Collected: 6/12/2021 6:25:00 AM
Lab ID: 012107279-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:34

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-177
Room 134 Sink # 1
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107279-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	23.5	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:36

Client Sample Description SH-178
Room 134 Sink # 2
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107279-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	31.3	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:38

Client Sample Description SH-179
Room 134 Bathroom Sink
Collected: 6/12/2021 6:30:00 AM
Lab ID: 012107279-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.00	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:40

Client Sample Description SH-181
ic Bathrm/Rm 132 Sink # 1
Collected: 6/12/2021 6:37:00 AM
Lab ID: 012107279-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.1	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:51

Client Sample Description SH-182
Fountain in Café # 1
Collected: 6/12/2021 6:39:00 AM
Lab ID: 012107279-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-184
 Staf Unisex Bathrm/Caf Sink # 1
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107279-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.9	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 16:59

Client Sample Description SH-185
 Staf Unisex Bathrm/Caf Sink # 2
Collected: 6/12/2021 6:41:00 AM
Lab ID: 012107279-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.47	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:01

Client Sample Description SH-186
 Kitchen Sink # 1
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107279-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.06	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:03

Client Sample Description SH-187
 Kitchen Sink # 2
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107279-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:05

Client Sample Description SH-188
 Kitchen Sink # 3
Collected: 6/12/2021 6:45:00 AM
Lab ID: 012107279-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:07

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-189 **Collected:** 6/12/2021 **Lab ID:** 012107279-0016
 Kitchen Sink # 4 6:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.45	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:12

Client Sample Description SH-190 **Collected:** 6/12/2021 **Lab ID:** 012107279-0017
 Kitchen Sink # 5 6:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:14

Client Sample Description SH-191 **Collected:** 6/12/2021 **Lab ID:** 012107279-0018
 Kitchen Pot Filler 6:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.72	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:16

Client Sample Description SH-192 **Collected:** 6/12/2021 **Lab ID:** 012107279-0019
 Kitchen Locker Room Sink 6:45:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.35	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:18

Client Sample Description SH-193 **Collected:** 6/12/2021 **Lab ID:** 012107279-0020
 Womens Lav by 122B Sink # 1 6:55:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.90	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-194
 Womens Lav by 122B Sink # 2
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107279-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.95	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:26

Client Sample Description SH-195
 Mens Lav by 122B Sink # 1
Collected: 6/12/2021 6:55:00 AM
Lab ID: 012107279-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.25	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:27

Client Sample Description SH-197
 Girls Lab by 118 Sink # 1
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107279-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.87	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:29

Client Sample Description SH-198
 Girls Lab by 118 Sink # 2
Collected: 6/12/2021 7:00:00 AM
Lab ID: 012107279-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.75	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:35

Client Sample Description SH-199
 Boy Bathrm by Main Off Sink # 1
Collected: 6/12/2021 7:01:00 AM
Lab ID: 012107279-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.13	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-200
 Boy Bathrm by Main Off Sink # 2
Collected: 6/12/2021 7:01:00 AM
Lab ID: 012107279-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.59	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:39

Client Sample Description SH-201
 Principal Office Bathrm Sink
Collected: 6/12/2021 7:02:00 AM
Lab ID: 012107279-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.43	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:41

Client Sample Description SH-203
 Mens Lav by Room 200 Sink
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107279-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.99	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:43

Client Sample Description SH-204
 Womens Lav by Room 200 Sink
Collected: 6/12/2021 7:07:00 AM
Lab ID: 012107279-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.98	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 17:50

Client Sample Description SH-205
 Room 200 Sink
Collected: 6/12/2021 7:10:00 AM
Lab ID: 012107279-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.22	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-207
Boys Lav by Room 204 Sink # 1
Collected: 6/12/2021 7:11:00 AM
Lab ID: 012107279-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.18	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:02

Client Sample Description SH-208
Boys Lav by Room 204 Sink # 2
Collected: 6/12/2021 7:11:00 AM
Lab ID: 012107279-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.49	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:04

Client Sample Description SH-209
Hallway fountain by Room 218
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107279-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:05

Client Sample Description SH-210
Room 220 Sink
Collected: 6/12/2021 7:14:00 AM
Lab ID: 012107279-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.49	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:07

Client Sample Description SH-211
Room 226 Sink
Collected: 6/12/2021 7:12:00 AM
Lab ID: 012107279-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.80	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:09

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-213
 Unisex Bathrm Sink by Rm 230
Collected: 6/12/2021 7:16:00 AM
Lab ID: 012107279-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.07	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:11

Client Sample Description SH-214
 Library Sink
Collected: 6/12/2021 7:20:00 AM
Lab ID: 012107279-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.65	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:13

Client Sample Description SH-215
 Hallway Fountain near Library
Collected: 6/12/2021 7:20:00 AM
Lab ID: 012107279-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:15

Client Sample Description SH-216
 Womens Lav by Library Sink
Collected: 6/12/2021 7:24:00 AM
Lab ID: 012107279-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.97	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:21

Client Sample Description SH-217
 Library Storeroom Sink
Collected: 6/12/2021 7:25:00 AM
Lab ID: 012107279-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	14.6	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-218
 Room 223 IMC Sink
Collected: 6/12/2021
 7:28:00 AM
Lab ID: 012107279-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.10	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:28

Client Sample Description SH-219
 Boys Lav by Room 207 Sink # 1
Collected: 6/12/2021
 7:35:00 AM
Lab ID: 012107279-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:30

Client Sample Description SH-220
 Boys Lav by Room 207 Sink # 2
Collected: 6/12/2021
 6:35:00 AM
Lab ID: 012107279-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.09	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:32

Client Sample Description SH-221
 Hallway Fountain by 221
Collected: 6/12/2021
 6:31:00 AM
Lab ID: 012107279-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:34

Client Sample Description SH-222
 Girl Handi lav by 219 Sink # 1
Collected: 6/12/2021
 6:33:00 AM
Lab ID: 012107279-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.12	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:36

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107279
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in WaterTesting

Analytical Results

Client Sample Description SH-223 **Collected:** 6/12/2021 **Lab ID:** 012107279-0046
Girl Handi lav by 219 Sink # 2 6:35:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.09	1.00 µg/L	7/14/2021 KB	7/16/2021 VD 18:38

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107277. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-100
 Source Sample Boiler Room
Collected: 6/5/2021 8:10:00 AM
Lab ID: 012107277-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	39.9	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:46

Client Sample Description TM-101
 Boiler Room Sink
Collected: 6/5/2021 8:06:00 AM
Lab ID: 012107277-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:14

Client Sample Description TM-102
 Water Fountain in Café A/B
Collected: 6/5/2021 6:13:00 AM
Lab ID: 012107277-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:20

Client Sample Description TM-103
 Kitchen Sink #1
Collected: 6/5/2021 6:20:00 AM
Lab ID: 012107277-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.29	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:22

Client Sample Description TM-104
 Kitchen Sink #2
Collected: 6/5/2021 6:32:00 AM
Lab ID: 012107277-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-105
Kitchen Sink #3
Collected: 6/5/2021 6:18:00 AM
Lab ID: 012107277-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.47	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:24

Client Sample Description TM-106
Kitchen Sink #4
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107277-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:25

Client Sample Description TM-107
Kitchen Sink #5
Collected: 6/5/2021 6:22:00 AM
Lab ID: 012107277-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.13	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:27

Client Sample Description TM-108
Kitchen Sink #6
Collected: 6/5/2021 6:26:00 AM
Lab ID: 012107277-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.73	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:28

Client Sample Description TM-109
Kitchen Sink #7
Collected: 6/5/2021 6:25:00 AM
Lab ID: 012107277-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.59	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860

Fax:

Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-110
Kitchen Sink #8
Collected: 6/5/2021 6:26:00 AM
Lab ID: 012107277-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:31

Client Sample Description TM-111
Kitchen Sink #9
Collected: 6/5/2021 6:28:00 AM
Lab ID: 012107277-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.3	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:35

Client Sample Description TM-112
Kitchen Sink #10
Collected: 6/5/2021 6:28:00 AM
Lab ID: 012107277-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.03	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:38

Client Sample Description TM-113
Kitchen Bathroom Sink
Collected: 6/5/2021 6:35:00 AM
Lab ID: 012107277-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:40

Client Sample Description TM-114
Water Fountain in Café C/D
Collected: 6/5/2021 6:37:00 AM
Lab ID: 012107277-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-115
 Hallway Fountain Across from Gym
Collected: 6/5/2021 6:38:00 AM
Lab ID: 012107277-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:42

Client Sample Description TM-116
 Boys Locker Room Coaches Sink
Collected: 6/5/2021 6:39:00 AM
Lab ID: 012107277-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.52	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:44

Client Sample Description TM-117
 Boys Locker Room Coaches Shower
Collected: 6/5/2021 6:40:00 AM
Lab ID: 012107277-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	69.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:45

Client Sample Description TM-118
 Boys Locker Room Sink #1
Collected: 6/5/2021 6:42:00 AM
Lab ID: 012107277-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:46

Client Sample Description TM-119
 Boys Locker Room Sink#2
Collected: 6/5/2021 6:43:00 AM
Lab ID: 012107277-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:50

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-120
Boys Locker Room Sink #3
Collected: 6/5/2021 6:43:00 AM
Lab ID: 012107277-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:51

Client Sample Description TM-122
Boys Bathroom Sports Hallway Sink #1
Collected: 6/5/2021 6:51:00 AM
Lab ID: 012107277-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:57

Client Sample Description TM-123
Boys Bathroom Sports Hallway Sink #2
Collected: 6/5/2021 6:49:00 AM
Lab ID: 012107277-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.18	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:00

Client Sample Description TM-124
Girls Bathroom Sports Hallway Sink #1
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107277-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:02

Client Sample Description TM-125
Girls Bathroom Sports Hallway Sink #2
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107277-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-126
 Girls Locker Room Coaches Sink
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107277-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:07

Client Sample Description TM-127
 Girls Locker Room Sink#1
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107277-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:08

Client Sample Description TM-128
 Girls Locker Room Sink#2
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107277-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:10

Client Sample Description TM-129
 Girls Locker Room Sink#3
Collected: 6/5/2021 6:55:00 AM
Lab ID: 012107277-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:11

Client Sample Description TM-131
 Pool Chem Eye Wash
Collected: 6/5/2021 7:03:00 AM
Lab ID: 012107277-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-133
Ice Machine Sports Hallway
Collected: 6/5/2021 7:06:00 AM
Lab ID: 012107277-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:48

Client Sample Description TM-141
Room D108 Classroom Sink #8
Collected: 6/5/2021 7:11:00 AM
Lab ID: 012107277-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:13

Client Sample Description TM-142
Room D106 Classroom Sink
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107277-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:15

Client Sample Description TM-143
Room D104 Classroom Sink
Collected: 6/5/2021 7:17:00 AM
Lab ID: 012107277-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.07	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:21

Client Sample Description TM-144
Room D104 Classroom Bubbler
Collected: 6/5/2021 7:17:00 AM
Lab ID: 012107277-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.48	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:23

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-145
 Room C103 (IMC) Sink
Collected: 6/5/2021 7:21:00 AM
Lab ID: 012107277-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.24	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:24

Client Sample Description TM-146
 Room C106 (Clinic) Classroom Sink #1
Collected: 6/5/2021 7:24:00 AM
Lab ID: 012107277-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:25

Client Sample Description TM-147
 Room C106 (Clinic) Classroom Sink #2
Collected: 6/5/2021 7:26:00 AM
Lab ID: 012107277-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.43	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:26

Client Sample Description TM-148
 Room C106 (Clinic) Bathroom Sink
Collected: 6/5/2021 7:27:00 AM
Lab ID: 012107277-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:28

Client Sample Description TM-149
 Room B114 Classroom Sink
Collected: 6/5/2021 7:30:00 AM
Lab ID: 012107277-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.65	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-150
 Room B115 Classroom Sink
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107277-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.88	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:30

Client Sample Description TM-151
 Room B123 Classroom Sink#1
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107277-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.5	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:32

Client Sample Description TM-153
 Room B123 Classroom Sink#3
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107277-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	25.2	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:16

Client Sample Description TM-154
 Room B123 Classroom Sink#4
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107277-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:22

Client Sample Description TM-155
 Room B123 Classroom Sink#5
Collected: 6/5/2021 7:36:00 AM
Lab ID: 012107277-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	168 D	5.00 µg/L	7/9/2021 JD	7/12/2021 JW 20:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-160
C104 Left Bathroom Sink
Collected: 6/5/2021 7:56:00 AM
Lab ID: 012107277-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:24

Client Sample Description TM-161
C104 Right Bathroom Sink
Collected: 6/5/2021 7:56:00 AM
Lab ID: 012107277-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:25

Client Sample Description TM-162
C104 Classroom Sink
Collected: 6/5/2021 7:57:00 AM
Lab ID: 012107277-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:26

Client Sample Description TM-163
Girls Lav by C102 Sink #1
Collected: 6/5/2021 7:54:00 AM
Lab ID: 012107277-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:28

Client Sample Description TM-164
Girls Lav by C102 Sink #2
Collected: 6/5/2021 7:54:00 AM
Lab ID: 012107277-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-165
 Girls Lav by C102 Sink #3
Collected: 6/5/2021 7:55:00 AM
Lab ID: 012107277-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:30

Client Sample Description TM-166
 Girls Lav by C102 Sink #4
Collected: 6/5/2021 7:55:00 AM
Lab ID: 012107277-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:31

Client Sample Description TM-167
 Boys Lav by C102 Sink#1
Collected: 6/5/2021 7:58:00 AM
Lab ID: 012107277-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:33

Client Sample Description TM-168
 Boys Lav by C102 Sink#2
Collected: 6/5/2021 7:58:00 AM
Lab ID: 012107277-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:34

Client Sample Description TM-169
 Boys Lav by C102 Sink#3
Collected: 6/5/2021 7:58:00 AM
Lab ID: 012107277-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:41

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107277
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-171
Hallway Fountain by C102
Collected: 6/5/2021 7:59:00 AM
Lab ID: 012107277-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:42

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107290. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-172
 Room A102 Classroom Sink
Collected: 6/5/2021 7:50:00 AM
Lab ID: 012107290-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.34	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:48

Client Sample Description TM-173
 Room A108 Classroom Sink
Collected: 6/5/2021 7:50:00 AM
Lab ID: 012107290-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.37	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:52

Client Sample Description TM-174
 Room A110 Classroom Sink
Collected: 6/5/2021 7:48:00 AM
Lab ID: 012107290-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:53

Client Sample Description TM-179
 Library Office Sink
Collected: 6/5/2021 8:03:00 AM
Lab ID: 012107290-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.95	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:55

Client Sample Description TM-180
 Main Office Bathroom Sink
Collected: 6/5/2021 7:48:00 AM
Lab ID: 012107290-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 23:56

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290
 CustomerID: WCSD21A
 CustomerPO: 20-04919
 ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-181
Main Office Kitchen Sink
Collected: 6/5/2021 7:38:00 AM
Lab ID: 012107290-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 23:57 VD

Client Sample Description TM-182
C117 Handicapped bathroom Sink
Collected: 6/5/2021 7:37:00 AM
Lab ID: 012107290-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 00:01 VD

Client Sample Description TM-183
C Wing Music Breakroom Sink
Collected: 6/5/2021 7:46:00 AM
Lab ID: 012107290-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 00:02 VD

Client Sample Description TM-186
Girls Bathroom near Music Sink # 1
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 00:04 VD

Client Sample Description TM-187
Girls Bathroom near Music Sink # 2
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.18	1.00 µg/L	7/16/2021 KB	7/17/2021 00:05 VD

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-188
Girls Bathroom near Music Sink # 3
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.49	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:54

Client Sample Description TM-189
Girls Bathroom near Music Sink # 4
Collected: 6/5/2021 7:34:00 AM
Lab ID: 012107290-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:06

Client Sample Description TM-190
Boys Bathroom near Music Sink # 1
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.48	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:10

Client Sample Description TM-191
Boys Bathroom near Music Sink # 2
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:11

Client Sample Description TM-192
Boys Bathroom near Music Sink # 3
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.09	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-193
Boys Bathroom near Music Sink # 4
Collected: 6/5/2021 7:32:00 AM
Lab ID: 012107290-0016

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:17

Client Sample Description TM-199
Room B229 Sink # 6
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107290-0017

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	19.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:18

Client Sample Description TM-200
Room B229 Sink # 7
Collected: 6/5/2021 7:14:00 AM
Lab ID: 012107290-0018

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	76.4	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:19

Client Sample Description TM-206
Room B229 Teachers Office Sink
Collected: 6/5/2021 7:11:00 AM
Lab ID: 012107290-0019

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.52	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:21

Client Sample Description TM-208
Room B227 Sink # 1
Collected: 6/5/2021 7:10:00 AM
Lab ID: 012107290-0020

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	18.1	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-209
 Room B227 Sink # 2
Collected: 6/5/2021 7:10:00 AM
Lab ID: 012107290-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	73.2	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:23

Client Sample Description TM-213
 Room B221 Sink
Collected: 6/5/2021 7:08:00 AM
Lab ID: 012107290-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:28

Client Sample Description TM-214
 Room B218 Sink
Collected: 6/5/2021 7:05:00 AM
Lab ID: 012107290-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:35

Client Sample Description TM-215
 Room B219 Sink
Collected: 6/5/2021 6:59:00 AM
Lab ID: 012107290-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:36

Client Sample Description TM-216
 Room B217 Sink # 1
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.67	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:37

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-217
 Room B217 Sink # 2
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0026

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:39

Client Sample Description TM-218
 Room B217 Sink # 3
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0027

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:40

Client Sample Description TM-219
 Room B217 Sink # 4
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0028

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.94	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:41

Client Sample Description TM-220
 Room B217 Sink # 5
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0029

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.02	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:43

Client Sample Description TM-221
 Room B215 Sink # 1
Collected: 6/5/2021 6:54:00 AM
Lab ID: 012107290-0030

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.80	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:44

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-222
 Room B215 Sink # 2
Collected: 6/5/2021 6:44:00 AM
Lab ID: 012107290-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.7	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:19

Client Sample Description TM-223
 Hallway Fountain Near B215
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107290-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:50

Client Sample Description TM-224
 Girls bathroom by B215 Sink # 1
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107290-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:52

Client Sample Description TM-225
 Girls bathroom by B215 Sink # 2
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107290-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:56

Client Sample Description TM-226
 Girls bathroom by B215 Sink # 3
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107290-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-227
 Girls bathroom by B215 Sink # 4
Collected: 6/5/2021 6:50:00 AM
Lab ID: 012107290-0036

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:58

Client Sample Description TM-228
 Boys bathroom by B215 Sink # 1
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107290-0037

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 00:59

Client Sample Description TM-229
 Boys bathroom by B215 Sink # 2
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107290-0038

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:03

Client Sample Description TM-230
 Boys bathroom by B215 Sink # 3
Collected: 6/5/2021 6:53:00 AM
Lab ID: 012107290-0039

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:05

Client Sample Description TM-231
 Room A202 Sink # 1
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107290-0040

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-232
Room A202 Sink # 2
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107290-0041

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:07

Client Sample Description TM-233
Room A204 Sink # 1
Collected: 6/5/2021 6:45:00 AM
Lab ID: 012107290-0042

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 01:09

Client Sample Description TM-234
Room A204 Sink # 2
Collected: 6/5/2021 6:45:00 AM
Lab ID: 012107290-0043

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:41

Client Sample Description TM-235
Room A206 Sink
Collected: 6/5/2021 6:25:00 AM
Lab ID: 012107290-0044

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:45

Client Sample Description TM-236
Room A212 Sink # 1
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107290-0045

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	21.6	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-237
Room A212 Sink # 2
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107290-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.3	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:47

Client Sample Description TM-238
Room A212 Sink # 3
Collected: 6/5/2021 6:27:00 AM
Lab ID: 012107290-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	46.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:51

Client Sample Description TM-240
Room A214 Sink # 1
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	79.7	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:52

Client Sample Description TM-241
Room A214 Sink # 2
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	47.9	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:54

Client Sample Description TM-242
Room A214 Sink # 3
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	78.4	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-243
Room A214 Sink # 4
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0051

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.3	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:25

Client Sample Description TM-244
Room A214 Sink # 5
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0052

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	47.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:55

Client Sample Description TM-245
Room A214 Sink # 6
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0053

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	33.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:56

Client Sample Description TM-246
Room 214 Sink # 7
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0054

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	44.8	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 18:37

Client Sample Description TM-247
Room 214 Sink # 8
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0055

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	43.1	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:58

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-248
Room 214 Sink # 9
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0056

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	29.4	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 19:59

Client Sample Description TM-249
Room 214 Sink # 10
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0057

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	13.5	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:03

Client Sample Description TM-250
Room 214 Sink # 11
Collected: 6/5/2021 6:31:00 AM
Lab ID: 012107290-0058

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	63.5	1.00 µg/L	7/9/2021 JD	7/12/2021 JW 19:28

Client Sample Description TM-252
Room A214 Teachers Office Sink
Collected: 6/5/2021 6:30:00 AM
Lab ID: 012107290-0059

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.12	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:07

Client Sample Description TM-253
Custodial Break Room Sink
Collected: 6/5/2021 8:05:00 AM
Lab ID: 012107290-0060

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:08

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107290
CustomerID: WCSD21A
CustomerPO: 20-04919
ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description TM-254
Room B219 Bathroom Sink # 1
Collected: 6/5/2021 8:07:00 AM
Lab ID: 012107290-0061

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:09

Client Sample Description TM-255
Room B219 Bathroom Sink # 2
Collected: 6/5/2021 8:07:00 AM
Lab ID: 012107290-0062

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/16/2021 VD 20:11

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

7/19/2021

Phone: (716) 626-8860


Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 7/5/2021. The results are tabulated on the attached data pages for the following client designated project:

2021 Lead in Water Testing

The reference number for these samples is EMSL Order #012107292. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:



Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107292

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description Trans-100
Eye Wash Bay #1
Collected: 6/5/2021 6:25:00 AM
Lab ID: 012107292-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:37

Client Sample Description Trans-101
Drinking Fountain Bay #1
Collected: 6/5/2021 6:23:00 AM
Lab ID: 012107292-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:40

Client Sample Description Trans-102
Bay #1 Sink
Collected: 6/5/2021 6:19:00 AM
Lab ID: 012107292-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:43

Client Sample Description Trans-103
Mens Mechanics Bathroom Sink
Collected: 6/5/2021 6:24:00 AM
Lab ID: 012107292-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:51

Client Sample Description Trans-104
Mens Staff Bathroom Sink#1
Collected: 6/5/2021 6:20:00 AM
Lab ID: 012107292-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.27	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 00:53

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107292

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
 Fax:
 Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description Trans-105
 Mens Staff Bathroom Sink #2
Collected: 6/5/2021 6:17:00 AM
Lab ID: 012107292-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:01

Client Sample Description Trans-106
 Womens Staff Bathroom Sink #1
Collected: 6/5/2021 6:22:00 AM
Lab ID: 012107292-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.23	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:04

Client Sample Description Trans-107
 Womens Staff Bathroom Sink #2
Collected: 6/5/2021 6:18:00 AM
Lab ID: 012107292-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	17.1	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:07

Client Sample Description Trans-108
 Womens Staff Bathroom Sink #3
Collected: 6/5/2021 6:16:00 AM
Lab ID: 012107292-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:09

Client Sample Description Trans-109
 Supervisors Bathroom Sink
Collected: 6/5/2021 6:21:00 AM
Lab ID: 012107292-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/14/2021 JW	7/15/2021 JW 01:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012107292

CustomerID: WCSD21A

CustomerPO: 20-04919

ProjectID:

Attn: **Keith Langlotz**
Williamsville CSD - Facilities Dept
480 Lawrence Bell Dr.
Williamsville, NY 14221

Phone: (716) 626-8860
Fax:
Received: 7/5/2021 11:15 AM

Project: 2021 Lead in Water Testing

Analytical Results

Client Sample Description Trans-110
Break Room Sink **Collected:** 6/5/2021 6:04:00 AM **Lab ID:** 012107292-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:39

Client Sample Description Trans-111
Mechanics Break Room Sink **Collected:** 6/5/2021 6:15:00 AM **Lab ID:** 012107292-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.51	1.00 µg/L	7/16/2021 KB	7/17/2021 VD 02:43

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occuring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Forest								
Location	38 Bathroom Sink # 1	36 Classroom Sink	20 Classroom Sink # 3	19 Classroom Sink	12 Classroom Sink	9 Bathroom Sink	1 Classroom Sink	Library Offcie Sink
Test results	98.10	16.80	20.50	15.10	21.60	15.60	138.00	140.00
Remediation								
Results								
Results								
Results								
Back in use								
Location								
Test results								
Remediation								
Results								
Back in use								

Williamsville CSD								
Locations of Water Test Samples Greater than 15 ppb				NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.				
Heim								
Location	Room 142 Sink	Room 146 Sink						
Test results	16.60	16.80						
Remediation								
Results								
Results 2								
Back in use								
Location								
Test results								
Remediation								
Results								
Results								
Results								
Back in use								

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Casey middle									
	Location	Room 114 Sink	Room 129 Sink	Room 132 Sink # 2	Room 132 Sink # 5	Stage Sink	Room 139 Sink # 1	Culty Bathroom Sink # 1	Mezzaninne Sink
	Test results	22.2	20.5	15.6	17.8	96.8	21.3	37.8	65.6
	Test results								
	Remediation								
	Back in use								
	Location								
	Test results								
	Remediation								
	Results								
	Back in use								
	Location								
	Test results								
	Remediation								
	Back in use								
	Location								
	Test results								
Remediation									
Back in use									

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

[illegible]

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Mill middle								
Location	Principals Offcie Lav Sink	Storage Room by AP Sink	Clinic Bathroom Sink	Room A-1 Sink	Room A-6 Sink	Room A-8 Sink	Lav by Room A-11 Sink	Room A-11 Sink
Test results	30.3	202	26.4	36.2	40.2	56.8	22.3	48.4
Remediation								
Back in svc.								
Location	Room A-10 Sink	Room A-13 Sink	apped Lav by Library Sink	Room B-6 Sink	age Room by AP Sink # 2	Boys Lav by A-11 Sink #1	ay Fountain by A-11 #1	ls Lav by A-11 Sink # 1
Test results	46.2	27.9	26.1	18.1	28	49.2	42.3	19.5
Remediation								
Back in svc.								
Location	m A-11 Classroom Sink # 2	n A-11 Classroom Sink # 2	Room C-11 Sink	Room C-10 Sink	Room C-13 Sink	Room E-3 Storage Sink	Room E-5 Sink # 3	Room E-2 Sink # 1
Test results	36.8	53	63.9	41.4	56.4	19.1	17.8	19.3
Remediation								
Test results								
Back in svc.								
Location	Room E-2 Sink # 2	Room E-2 Sink # 3	Room E-2 Sink # 4	Room E-4 Sink	Room E-7 Sink # 1	Room E-7 Sink # 2	Boys Locker Room Sink	Locker Room Sink # 2
Test results	53.5	20	34.3	17.9	45.9	19.4	16.1	40.5
Remediation								
Test results								
Test results								
Back in svc.								
Location	Girls Locker Room Sink # 3	basement Storage Sink # 1						
Test results	15.7	15.7						
Remediation								
Back in svc.								
Location								
Test results								
Remediation								
Back in svc.								

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Transit middle								
Location	Room B229 Sink #6	Room B229 Sink # 7	Room B227 Sink # 1	Room B227 Sink # 2	Room A212 Sink # 1	Room A212 Sink # 2	Room A212 Sink # 3	Room A214 Sink # 1
Test results	19.2	76.4	18.1	73.2	21.6	29.3	46.7	79.7
Test results								
Remediation								
Back in svc.								
Location	Room A214 Sink # 2	Room A214 Sink # 3	Room A214 Sink # 4	Room A214 Sink # 5	Room A214 Sink # 6	Room A214 Sink # 7	Room A214 Sink # 8	Room A214 Sink # 9
Test results	47.9	78.4	56.3	47.5	33.4	44.8	43.1	29.4
Remediation								
Back in svc.								
Location	Room A 214 Sink # 11	Boiler Room Sample	er Room Coaches Shower	Room B123 Sink # 1	Room B123 Sink # 3	Room B123 Sink # 4	Room B123 Sink # 5	
Test results	63.5	39.9	69.4	15.5	25.2	17.6	168	
Remediation								
Back in svc.								
Location								
Test results								
Remediation								
Back in svc.								
Location								
Test results								
Remediation								
Back in svc.								
Location								
Test results								
Remediation								
Back in svc.								

Williamsville CSD								
Locations of Water Test Samples Greater than 15 ppb				NOTE: Fixture replacement is being prioritized by our facility staff and is occuring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.				
<u>East high</u> Location Test results Remediation Back in svc.								
	Pool Room Eye Wash	Kitchen Sink # 5	Kitchen Sink # 8	Room 102 Sink #1	Room 103 Sink # 4	Kiln Room Sink	Room 117 Sink # 4	Room 117 Sink # 6
	2080	20.2	27.5	18.6	20.4	30.4	52.6	97.2
Location Test results Remediation Back in svc.	Room 117 Sink #7	Room 117 Sink # 8	Room 119 Sink # 1	Room 119 Sink # 2	Room 119 Sink # 3	Room 119 Sink # 4	Room 119 Sink # 5	Room 113 Sink
	101	44.9	32.6	23	71.2	50.4	15.4	38.3
Location Test results Remediation Back in svc.	Mens Lav by Aud Sink	Health Office Sink # 1	Coaches Office Lav Sink	Boys Red locker Room Sink	Kiln Room Sink # 2			
	29.2	21.8	21.2	19.2	30.4			
Location Test results Remediation Back in svc.								
Location Test results Remediation Test results Back in svc.								
Location Test results Test results Test results Remediation Back in svc.								

Williamsville CSD								
Locations of Water Test Samples Greater than 15 ppb				NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.				
North high								
	Location	Boiler Room Source	Conference Room Sink # 1	Kitchen Dish room Sink # 2	ens Lav by C-108 Sink # 3	Room C-108 Sink # 1	Room C-108 Sink # 2	Room C-105 Sink # 1
	Test results	23.5	21.3	21.9	21.4	24.6	17.1	53.6
	Remediation							
	Results							
	Back in use							
	Location	Room C-162 Sink # 2	ens Lav by C-130 Sink # 1	ens Lav by C-130 Sink # 2	ens Lav by C-130 Sink # 3	Floor Coaches Office Sink	Pump Room Eye Wash	
	Test results	92.2	28	16.2	15.7	305	30.4	
	Remediation							
Test results								
Back in use								
Location								
Test results								
Remediation								
Results								
Back in use								
Location								
Test results								
Remediation								
Results								
Back in use								

Williamsville CSD								
Locations of Water Test Samples Greater than 15 ppb					NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.			
South high								
	Room 134 Sink # 1	Room 134 Sink # 2	Room E-6 Sink	Room 129 P Dark Room Sink	Room 129 D Sink # 1	Room 129 D Sink # 2	Room 129 D Sink # 3	Room 129 D Sink # 4
	23.5	31.3	18.6	15.8	59.4	16.1	16.8	34
	Coaches Girls Off Shower							
	193							

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occuring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Maple East								
Location	Boiler Room Sample	Boiler Room Eyewash	Girl's ShBathroom Sink	42 Classroom Sink	29 Classroom Sink # 3	22 Classroom Sink	Library Office Sink	
Test results	18.10	47.40	1220.00	16.20	52.30	17.30	22.30	
Remediation								
Results								
Back in use								
Location								
Test results								
Remediation								
Results								
Results								
Back in use								

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Maple West								
Location	109 Classroom Sink # 1	Library Office Sink	102 Classroom Sink	Boiler Room Eyewash	Boiler Room Sample	102 Classroom Sink # 2	101 Classroom Sink # 2	Kitchen Pot Filler
Test results	15.40	18.10	16.20	200.00	15.80	22.40	76.00	28.30
Remediation								
Results								
Test results								
Back in use								
Location								
Test results								
Remediation								
Results								
Results								
Back in use								

Williamsville Central School District
 New York State Public School District
 Water Testing for Lead Report (5/27/2021)

School	Number of Samples Tested (1)	Number of above 15ppb	Location of Samples Tested above 15ppb												Received All Results Yes - No
			Drinking Fountains	Student Lavatories	Classroom Faucets	Classroom Fountains	Science-Tech Classroom	Student-staff Showers/ Locker rooms	Office Sinks	Staff Lavatories	Custodial Outlets	Child Nutrition Faucets	Pool Faucets	Outdoor Faucets	
Country Parkway	81	15	0	0	0	0	0	0	1	1	0	0	NA	NA	Yes
Dodge	91	4	0	2	0	0	0	0	0	0	2	0	NA	NA	Yes
Forest	93	8	0	2	5	0	0	0	1	0	0	0	NA	NA	Yes
Heim													NA	NA	
Maple East	96	7	0	0	3	0	0	1	1	0	2	0	NA	NA	Yes
Maple West	82	8	0	0	4	0	0	0	1	0	2	1	NA	NA	Yes
Casey middle															
Heim middle															
Mill middle															
Transit middle															
East high															
North high															
South high															
AIM building															
District office															
Total Samples	443	42	0	4	12	0	0	1	4	1	6	1	0	0	29

(1) New York State water testing parameters for lead require all water outlets to be tested after water has been stagnant in the water pipes and faucets for a minimur of eight hours. Flushing water through the water outlet is not permitted per the test

Williamsville CSD

Locations of Water Test Samples Greater than 15 ppb

NOTE: Fixture replacement is being prioritized by our facility staff and is occurring in an expedited manner. New water samples are sent to the testing lab with an accelerated turn-around time.

Heim								
Location	Room 142 Sink	Room 146 Sink						
Test results	16.60	16.80						
Remediation	Flushing	Flushing						
Results	12.90	43.30						
Results 2								
Back in use	9/29/2021							
Location								
Test results								
Remediation								
Results								
Results								
Results								
Back in use								