

Automatic Temperaute Controls, Inc. - Kickemuit Middle School Building Survey

Room #	Location	Name	Type	Filtered Air CFM	Airflow Readings (CFM)				Room Size				ACH				Total ACH		Recommendations to meet RORI
					Supply		Exhaust /Return		Length	Width	Height	Cubic Feet	Supply		Exhaust /Return		Normal	100%	
	Normal	100% ODA	Normal		100% ODA	Normal	100% ODA	Normal					100% ODA						
10	1st	Main Office	VAV		761.00	761.00	1004.00	1004.00	40.00	24.00	8.00	7680.00	5.95	5.95	7.84	7.84	13.79	13.79	Meets RORI
11	1st	Principal	VAV		391.00	391.00	292.00	292.00	17.00	23.00	9.00	3519.00	6.67	6.67	4.98	4.98	11.65	11.65	Meets RORI
14	1st	Multi Purpose	VAV		144	144	104	104	12	10	9	1080	8.00	8.00	5.78	5.78	13.78	13.78	Meets RORI
15	1st	Break Room	VAV		145	145	66	66	10	10	9	900	9.67	9.67	4.40	4.40	14.07	14.07	Meets RORI
20	1st		VAV		95.00	95.00	68.50	68.50	8.00	8.00	8.00	512.00	11.13	11.13	8.03	8.03	19.16	19.16	Meets RORI
21	1st		VAV		83.00	83.00	68.50	68.50	8.00	8.00	8.00	512.00	9.73	9.73	8.03	8.03	17.75	17.75	Meets RORI
22	1st	Asst. Principal	VAV		227.00	227.00	102.00	102.00	16.00	12.00	8.00	1536.00	8.87	8.87	3.98	3.98	12.85	12.85	Meets RORI
23	1st	Nurses waiting		218	196	196	66	66	21	7	8	1176.00	21.12	21.12	3.37	3.37	24.49	24.49	Meets RORI
24	1st	Nurses	VAV	218	375.00	375.00	174.00	174.00	31.00	14.00	8.00	3472.00	10.25	10.25	3.01	3.01	13.25	13.25	Meets RORI
27	1st	Girls office			285.00	285.00	0.00	0.00	10.00	16.00	9.00	1440.00	11.88	11.88	0.00	0.00	11.88	11.88	Meets RORI
31	1st	Girls Locker	HV		1089.00	1482.00	0.00	0.00	20.00	28.00	9.00	5040.00	12.96	17.64	0.00	0.00	12.96	17.64	Meets RORI
35	1st	Boys Locker	HV									0.00	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!			Needs additional info
37	1st	Boy's Office																	Needs additional info
43	1st	Classroom	UV	654	269.00	255.00	0.00	0.00	32.00	38.00	9.00	10944.00	5.06	4.98	0.00	0.00	5.06	4.98	Meets RORI
44	1st	Shipwright	UV	436	378.00	384.00	0.00	0.00	30.00	38.00	9.00	10260.00	4.76	4.80	0.00	0.00	4.76	4.80	Meets RORI
46	1st	Technology	UV	218	704.00	678.00	0.00	0.00	34.00	28.00	9.00	8568.00	6.46	6.27	0.00	0.00	6.46	6.27	Meets RORI
49	1st	IT	AHU		1093.00	1256.00	315.00	315.00	30.00	34.00	9.00	9180.00	7.14	8.21	2.06	2.06	9.20	10.27	Meets RORI
50	1st	GYM	HV	2616	18740.00	12176.00	4592.00	4992.00	95.00	80.00	25.00	190000.00	6.74	4.67	1.45	1.58	8.19	6.25	Meets RORI
57 / 58	1st			436	1942.00	1942.00	858.00	858.00	25.00	56.00	9.00	12600.00	11.32	11.32	4.09	4.09	15.41	15.41	Meets RORI
59	1st	Art		218	1771.00	1771.00	918.00	918.00	26.00	44.00	9.00	10296.00	11.59	11.59	5.35	5.35	16.94	16.94	Meets RORI
60	1st	Art		218	1184.00	1184.00	0.00	0.00	30.00	44.00	9.00	11880.00	7.08	7.08	0.00	0.00	7.08	7.08	Meets RORI
65	1st	GYM							42.00	80.00	25.00	84000.00	0.00	0.00	0.00	0.00	0.00	0.00	Not yet tested
75	1st	Band		218	4216.00	4259.00	1701.00	1641.00	52.00	42.00	12.00	26208.00	10.15	10.25	3.89	3.76	14.05	14.01	Meets RORI
76	1st	Music Office			682.00	717.00	220.00	220.00	12.00	22.00	9.00	2376.00	17.22	18.11	5.56	5.56	22.78	23.66	Meets RORI
77	1st	Practice			562	562	248	248	8	7	9	504	66.9	66.9	29.52	29.52	96.43	96.43	Meets RORI
78	1st	Practice			554	554	235	235	8	7	9	504	65.95	65.95	27.98	27.98	93.93	93.93	Meets RORI
79	1st	Music-Jamb			1919.00	2146.00	798.00	801.00	20.00	24.00	10.00	4800.00	23.99	26.83	9.98	10.01	33.96	36.84	Meets RORI
80	1st	Cafeteria	AHU		15704.00	17160.00	2649.00	2728.00	75.00	75.00	12.00	67500.00	13.96	15.25	2.35	2.42	16.31	17.68	Meets RORI
??	1st	Cafeteria	Ex		0.00	0.00	238.00	238.00	13.50	10.00	10.00	1350.00	0.00	0.00	10.58	10.58	10.58	10.58	Meets RORI
??	1st	Break Room			145.00	145.00	66.00	66.00	10.00	10.00	9.00	900.00	9.67	9.67	4.40	4.40	14.07	14.07	Meets RORI
90	1st	Chorus			4156.00	5906.00	645.00	679.00	30.00	28.00	10.00	8400.00	29.69	42.19	4.61	4.85	34.29	47.04	Meets RORI
No #	1st	Girls RR	EX		0.00	0.00	285.00	285.00	28.00	16.00	9.00	4032.00	0.00	0.00	4.24	4.24	4.24	4.24	Meets RORI w/ 2 user's
No #	1st	Boys RR	EX		0.00	0.00	225.00	225.00	28.00	16.00	9.00	4032.00	0.00	0.00	3.35	3.35	3.35	3.35	Meets RORI w/ 2 user's
109	1st	Conference			419	413	55	53	18	13	8	1872.00	13.43	13.24	1.76	1.70	15.19	14.94	Meets RORI
111	1st	M Guidance	Reheat		630	628	164	154	18	10	8	1440.00	26.25	26.17	6.83	6.42	33.08	32.58	Meets RORI
111A	1st	Guidance	Reheat		253.00	318.00	42.00	44.00	10.00	8.00	8.00	640.00	23.72	29.81	3.94	4.13	27.66	33.94	Meets RORI
111B	1st	Guidance	Reheat		43.00	45.00	475.00	474.00	10.00	8.00	8.00	640.00	4.03	4.22	44.53	44.44	48.56	48.66	Meets RORI
111C	1st	Guidance	Reheat		193.00	268.00	70.00	72.00	9.00	14.00	8.00	1008.00	11.49	15.95	4.17	4.29	15.65	20.24	Meets RORI
111D	1st	Guidance	Reheat	218	422.00	383.00	55.00	33.00	10.00	9.00	8.00	720.00	53.33	50.08	4.58	2.75	57.92	52.83	Meets RORI
111E	1st	Guidance	Reheat		309.00	352.00	53.00	30.00	10.00	8.00	8.00	640.00	28.97	33.00	4.97	2.81	33.94	35.81	Meets RORI
111F	1st	Guidance	Reheat		100.00	108.00	24.00	24.00	10.00	10.00	8.00	800.00	7.50	8.10	1.80	1.80	9.30	9.90	Meets RORI
111G	1st	Guidance	Reheat		127.00	113.00	26.00	21.00	10.00	8.00	8.00	640.00	11.91	10.59	2.44	1.97	14.34	12.56	Meets RORI
111H ?	1st	Guidance	Reheat		419.00	413.00	55.00	53.00	18.00	13.00	8.00	1872.00	13.43	13.24	1.76	1.70	15.19	14.94	Meets RORI
113	1st	S R O	UV		495.00	495.00	164.00	164.00	16.00	30.00	9.00	4320.00	6.88	6.88	2.28	2.28	9.15	9.15	Meets RORI
115	1st	Psychologist	Reheat	218	239.00	289.00	293.00	0.00	26.00	12.00	9.00	2808.00	9.76	10.83	6.26	0.00	16.03	10.83	Meets RORI
117	1st	Classroom	UV		792.00	894.00	428.00	428.00	30.00	28.00	9.00	7560.00	6.29	7.10	3.40	3.40	9.68	10.49	Meets RORI
118	1st	Classroom	Reheat	218	88.00	88.00	0.00	0.00	26.00	12.00	9.00	2808.00	6.54	6.54	0.00	0.00	6.54	6.54	Meets RORI
119	1st	Classroom	UV	218	645.00	682.00	408.00	408.00	22.00	28.00	9.00	5544.00	9.34	9.74	4.42	4.42	13.76	14.16	Meets RORI
120	1st	Classroom	UV	218	480.00	606.00	0.00	0.00	28.00	28.00	9.00	7056.00	5.94	7.01	0.00	0.00	5.94	7.01	Meets RORI
121	1st	Classroom	UV	218	433.00	440.00	280.00	280.00	22.00	28.00	9.00	5544.00	7.05	7.12	3.03	3.03	10.08	10.15	Meets RORI
122	1st	Classroom	2 -UV	218	996.00	1000.00	2835.00	2835.00	28.00	48.00	9.00	12096.00	6.02	6.04	14.06	14.06	20.08	20.10	Meets RORI

Automatic Temperaute Controls, Inc. - Kickemuit Middle School Building Survey

Room #	Location	Name	Type	Filtered Air CFM	Airflow Readings (CFM)				Room Size				ACH				Total ACH		Recommendations to meet RORI	
	Floor					Supply		Exhaust /Return		Length	Width	Height	Cubic Feet	Supply		Exhaust /Return		Normal		100%
						Normal	100% ODA	Normal	100% ODA					Normal	100% ODA	Normal	100% ODA			
123	1st	Classroom	UV	218	590.00	560.00	289.00	289.00	28.00	28.00	9.00	7056.00	6.87	6.62	2.46	2.46	9.33	9.07	Meets RORI	
124	1st	Classroom	UV	218	1098.00	1060.00	381.00	381.00	28.00	28.00	9.00	7056.00	11.19	10.87	3.24	3.24	14.43	14.11	Meets RORI	
127	1st	Classroom	UV	218	818.00	742.00	742.00	742.00	32.00	28.00	9.00	8064.00	7.71	7.14	5.52	5.52	13.23	12.66	Meets RORI	
131	1st	Classroom	UV	218	1219.00	1076.00	1063.00	1063.00	34.00	28.00	9.00	8568.00	10.06	9.06	7.44	7.44	17.51	16.51	Meets RORI	
132	1st	Classroom	UV	218	1016.00	920.00	382.00	376.00	28.00	28.00	9.00	7056.00	10.49	9.68	3.25	3.20	13.74	12.87	Meets RORI	
133	1st	Classroom	UV	218	846.00	896.00	210.00	210.00	28.00	28.00	9.00	7056.00	9.05	9.47	1.79	1.79	10.83	11.26	Meets RORI	
134	1st	Conference	Reheat	218	0.00	0.00	127.00	127.00	17.00	15.00	9.00	2295.00	5.70	5.70	3.32	3.32	9.02	9.02	Meets RORI	
134A	1st	Office	Reheat	218	0.00	0.00	80.00	80.00	8.00	16.00	9.00	1152.00	11.35	11.35	4.17	4.17	15.52	15.52	Meets RORI	
135	1st	Classroom	UV	218	832.00	894.00	326.00	326.00	28.00	28.00	9.00	7056.00	8.93	9.46	2.77	2.77	11.70	12.23	Meets RORI	
137	1st	Classroom	UV	218	872.00	872.00	346.00	346.00	28.00	28.00	9.00	7056.00	9.27	9.27	2.94	2.94	12.21	12.21	Meets RORI	
No #	1st	Boys	EF		0.00	0.00	523.00	523.00	14.00	18.00	9.00	2268.00	0.00	0.00	13.84	13.84	13.84	13.84	Meets RORI	
No #	1st	Faculty Mens	EF		0.00	0.00	70.00	70.00	6.00	6.00	9.00	324.00	0.00	0.00	12.96	12.96	12.96	12.96	Meets RORI	
No #	1st	Faculty Womens	EF		0.00	0.00	67.00	67.00	6.00	6.00	9.00	324.00	0.00	0.00	12.41	12.41	12.41	12.41	Meets RORI	
No #	1st	Girls	EF		0.00	0.00	496.00	496.00	14.00	18.00	9.00	2268.00	0.00	0.00	13.12	13.12	13.12	13.12	Meets RORI	
139	1st	Classroom	UV	218	688.00	662.00	418.00	418.00	28.00	28.00	9.00	7056.00	7.70	7.48	3.55	3.55	11.26	11.04	Meets RORI	
141	1st	Classroom	UV	218	772.00	750.00	387.00	382.00	28.00	28.00	9.00	7056.00	8.42	8.23	3.29	3.25	11.71	11.48	Meets RORI	
143	1st	Classroom	UV	218	802.00	792.00	178.00	175.00	28.00	28.00	9.00	7056.00	8.67	8.59	1.51	1.49	10.19	10.08	Meets RORI	
144	1st	Classroom	UV	218	878.00	838.00	572.00	572.00	28.00	28.00	9.00	7056.00	9.32	8.98	4.86	4.86	14.18	13.84	Meets RORI	
146	1st	Classroom	UV	218	874.00	908.00	778.00	778.00	28.00	28.00	9.00	7056.00	9.29	9.57	6.62	6.62	15.90	16.19	Meets RORI	
147	1st	Classroom	UV	218	770.00	812.00	688.00	688.00	28.00	28.00	9.00	7056.00	8.40	8.76	5.85	5.85	14.25	14.61	Meets RORI	
148	1st	Classroom	UV	218	670.00	660.00	430.00	430.00	28.00	28.00	9.00	7056.00	7.55	7.47	3.66	3.66	11.21	11.12	Meets RORI	
149	1st	Classroom	UV	218	662.00	710.00	822.00	822.00	28.00	28.00	9.00	7056.00	7.48	7.89	6.99	6.99	14.47	14.88	Meets RORI	
150	1st	Classroom	UV	218	1454.00	1398.00	474.00	474.00	28.00	28.00	9.00	7056.00	14.22	13.74	4.03	4.03	18.25	17.77	Meets RORI	
151	1st	Classroom	UV	218	842.00	762.00	5.00	5.00	28.00	28.00	9.00	7056.00	9.01	8.33	0.04	0.04	9.06	8.38	Meets RORI	
153	1st	Classroom	UV	218	832.00	950.00	927.00	927.00	28.00	28.00	9.00	7056.00	8.93	9.93	7.88	7.88	16.81	17.81	Meets RORI	
155	1st	Classroom	UV	218	856.00	850.00	1068.00	1068.00	28.00	28.00	9.00	7056.00	9.13	9.08	9.08	9.08	18.21	18.16	Meets RORI	
157	1st	Classroom	UV	218	784.00	672.00	1087.00	1087.00	28.00	28.00	9.00	7056.00	8.52	7.57	9.24	9.24	17.76	16.81	Meets RORI	
No #	1st	ISO RR	EX		0.00	0.00	182.00	182.00	8.00	5.00	8.00	320.00	0.00	0.00	34.13	34.13	34.13	34.13	Meets RORI	
200	2nd	Storage	EF		0.00	0.00	65.00	65.00	18.00	10.00	9.00	1620.00	0.00	0.00	2.41	2.41	2.41	2.41		
201	2nd	Boys RR	EF		0.00	0.00	369.00	369.00	28.00	16.00	9.00	4032.00	0.00	0.00	5.49	5.49	5.49	5.49	Meets RORI	
205	2nd	Girls RR	EF		0.00	0.00	351.00	351.00	28.00	16.00	9.00	4032.00	0.00	0.00	5.22	5.22	5.22	5.22	Meets RORI	
202 A	2nd	Faculty W RR	EF		0.00	0.00	29.00	29.00	11.00	6.00	9.00	594.00	0.00	0.00	2.93	2.93	2.93	2.93	Meets RORI w/ 1 user	
202 B	2nd	Faculty M RR	EF		0.00	0.00	27.00	27.00	11.00	6.00	9.00	594.00	0.00	0.00	2.73	2.73	2.73	2.73	Meets RORI w/ 1 user	
202	2nd	Teachers	UV	218	1276.00	1218.00	200.00	199.00	12.00	40.00	9.00	4320.00	20.75	19.94	2.78	2.76	23.53	22.71	Meets RORI	
207	2nd	Classroom	UV	218	487.00	550.00	209.00	209.00	22.00	28.00	9.00	5544.00	7.63	8.31	2.26	2.26	9.89	10.57	Meets RORI	
208	2nd	Classroom	UV	218	607.00	562.00	454.00	454.00	28.00	18.00	9.00	4536.00	10.91	10.32	6.01	6.01	16.92	16.32	Meets RORI	
209	2nd	Classroom	UV	218	376.00	333.00	275.00	275.00	24.00	28.00	9.00	6048.00	5.89	5.47	2.73	2.73	8.62	8.19	Meets RORI	
210	2nd	Storage																		
211	2nd	Classroom	UV	218	445.00	477.00	268.00	268.00	24.00	28.00	9.00	6048.00	6.58	6.89	2.66	2.66	9.24	9.55	Meets RORI	
212	2nd	Storage																		
213	2nd	Classroom	UV		378.00	393.00	263.00	263.00	23.00	28.00	9.00	5796.00	3.91	4.07	2.72	2.72	6.64	6.79	Meets RORI	
214	2nd	Conference																	Not yet tested	
215	2nd	Classroom	UV	218	274.00	273.00	709.00	709.00	24.00	28.00	9.00	6048.00	4.88	4.87	7.03	7.03	11.91	11.90	Meets RORI	
216	2nd	Classroom	UV	218	688.00	700.00	192.00	192.00	28.00	30.00	9.00	7560.00	7.19	7.29	1.52	1.52	8.71	8.81	Meets RORI	
217	2nd	Classroom	UV	218	395.00	410.00	714.00	714.00	28.00	28.00	9.00	7056.00	5.21	5.34	6.07	6.07	11.28	11.41	Meets RORI	
218	2nd	Classroom	UV	218	960.00	954.00	246.00	246.00	28.00	28.00	9.00	7056.00	10.02	9.97	2.09	2.09	12.11	12.06	Meets RORI	
219	2nd	Classroom	UV	218	357.00	466.00	720.00	720.00	28.00	28.00	9.00	7056.00	4.89	5.82	6.12	6.12	11.01	11.94	Meets RORI	
220	2nd	Classroom	UV	218	668.00	686.00	270.00	270.00	28.00	28.00	9.00	7056.00	7.53	7.69	2.30	2.30	9.83	9.98	Meets RORI	
221	2nd	Classroom	UV	218	282.00	254.00	630.00	630.00	24.00	28.00	9.00	6048.00	4.96	4.68	6.25	6.25	11.21	10.93	Meets RORI	
222	2nd	Storage																		

Automatic Temperaute Controls, Inc. - Kickemuit Middle School Building Survey

Room #	Location	Name	Type	Filtered Air CFM	Airflow Readings (CFM)				Room Size				ACH				Total ACH		Recommendations to meet RORI
	Floor				Supply		Exhaust /Return		Length	Width	Height	Cubic Feet	Supply		Exhaust /Return		Normal	100%	
					Normal	100% ODA	Normal	100% ODA					Normal	100% ODA	Normal	100% ODA			
223	2nd	Library	4 - UV	2616	2475.00	2794.00	1257.00	1257.00	92.00	60.00	9.00	49680.00	6.15	6.53	1.52	1.52	7.67	8.05	Meets RORI
224	2nd	Classroom	UV	218	1522.00	1518.00	893.00	890.00	28.00	30.00	9.00	7560.00	13.81	13.78	7.09	7.06	20.90	20.84	Meets RORI
224 A	2nd	Prep Room	EF																
225	2nd	Library Work	VAV		845.00	845.00	437.00	437.00	14.00	20.00	9.00	2520.00	20.12	20.12	10.40	10.40	30.52	30.52	Meets RORI
227	2nd	Library Work	VAV		258	258	0	0	14	10	9	1260	12.29	12.29	0	0	12.29	12.29	Meets RORI
228	2nd	Server Room	VAV		688.00	688.00	191.00	191.00	14.00	14.00	9.00	1764.00	23.40	23.40	6.50	6.50	29.90	29.90	Meets RORI
231	2nd	Classroom	VAV's	218	3315.00	3315.00	1660.00	1660.00	28.00	32.00	9.00	8064.00	26.29	26.29	12.35	12.35	38.64	38.64	Meets RORI
232	2nd	Classroom	UV	218	1232.00	1172.00	649.00	638.00	28.00	28.00	9.00	7056.00	12.33	11.82	5.52	5.43	17.85	17.24	Meets RORI
233	2nd	Classroom		218	852	908	478	478	28	28	9	7056.00	9.10	9.57	4.06	4.06	13.16	13.64	Meets RORI
234	2nd	Office	Reheat	218	227.00	227.00	285.00	285.00	16.00	14.00	9.00	2016.00	13.24	13.24	8.48	8.48	21.73	21.73	Meets RORI
234A	2nd	Office	Reheat		215.00	215.00	79.00	79.00	16.00	8.00	9.00	1152.00	11.20	11.20	4.11	4.11	15.31	15.31	Meets RORI
235	2nd	Classroom	UV	218	888.00	920.00	454.00	454.00	28.00	28.00	9.00	7056.00	9.40	9.68	3.86	3.86	13.27	13.54	Meets RORI
236	2nd	Boys RR	EF		235.00	235.00	444.00	444.00	14.00	18.00	9.00	2268.00	6.22	6.22	11.75	11.75	17.96	17.96	Meets RORI
238	2nd	Faculty M. RR	EF		0.00	0.00	107.00	107.00	6.00	6.00	9.00	324.00	0.00	0.00	19.81	19.81	19.81	19.81	Meets RORI
240	2nd	Faculty W. RR	EF		0.00	0.00	93.00	93.00	6.00	6.00	9.00	324.00	0.00	0.00	17.22	17.22	17.22	17.22	Meets RORI
242	2nd	Girls RR	EF		244.00	244.00	351.00	351.00	14.00	18.00	9.00	2268.00	6.46	6.46	9.29	9.29	15.74	15.74	Meets RORI
237	2nd	Classroom	UV	218	1252.00	1443.00	956.00	951.00	29.00	30.00	9.00	7830.00	11.26	12.73	7.33	7.29	18.59	20.02	Meets RORI
239	2nd	Classroom	UV	218	982.00	1024.00	289.00	289.00	28.00	28.00	9.00	7056.00	10.20	10.56	2.46	2.46	12.66	13.02	Meets RORI
239 A	2nd	Storage			409.00	409.00	402.00	402.00	20.00	10.00	9.00	1800.00	13.63	13.63	13.40	13.40	27.03	27.03	Meets RORI
241	2nd	Ed. Resource	Reheat	218	174.00	174.00	283.00	283.00	26.00	10.00	9.00	2340.00	10.05	10.05	7.26	7.26	17.31	17.31	Meets RORI
243	2nd	??	Reheat	218	256.00	256.00	267.00	267.00	17.00	12.00	9.00	1836.00	15.49	15.49	8.73	8.73	24.22	24.22	Meets RORI
244	2nd	Classroom	UV	218	924.00	878.00	1394.00	1394.00	28.00	28.00	9.00	7056.00	9.71	9.32	11.85	11.85	21.56	21.17	Meets RORI
245	2nd	Classroom	UV	218	1036.00	954.00	1175.00	1175.00	28.00	28.00	9.00	7056.00	10.66	9.97	9.99	9.99	20.65	19.96	Meets RORI
246	2nd	Classroom		218	1072.00	1152.00	1081.00	1081.00	28.00	28.00	9.00	7056.00	10.97	11.65	9.19	9.19	20.16	20.84	Meets RORI
247	2nd	Classroom	UV	218	748.00	646.00	1009.00	1009.00	28.00	28.00	9.00	7056.00	8.21	7.35	8.58	8.58	16.79	15.93	Meets RORI
248	2nd	Classroom	UV	218	894.00	832.00	788.00	788.00	28.00	28.00	9.00	7056.00	9.46	8.93	6.70	6.70	16.16	15.63	Meets RORI
249	2nd	Classroom	UV	218	954.00	946.00	1232.00	1227.00	28.00	28.00	9.00	7056.00	9.97	9.90	10.48	10.43	20.44	20.33	Meets RORI
249	2nd	Supply Closet			297.00	297.00	261.00	261.00	18.00	8.00	9.00	1296.00	13.75	13.75	12.08	12.08	25.83	25.83	Meets RORI
250	2nd	Classroom	UV	218	1180.00	1354.00	371.00	371.00	28.00	28.00	9.00	7056.00	11.89	13.37	3.15	3.15	15.04	16.52	Meets RORI
251	2nd	Classroom	UV	218	1094.00	1150.00	880.00	880.00	28.00	28.00	9.00	7056.00	11.16	11.63	7.48	7.48	18.64	19.12	Meets RORI
253	2nd	Classroom	UV	218	704.00	850.00	1095.00	1095.00	28.00	28.00	9.00	7056.00	7.84	9.08	9.31	9.31	17.15	18.39	Meets RORI
255	2nd	Classroom	UV	218	954.00	846.00	1347.00	1347.00	28.00	28.00	9.00	7056.00	9.97	9.05	11.45	11.45	21.42	20.50	Meets RORI
257	2nd	Storage																	

Color Code		
Meets RORI		Instructional Space
Phase One Air Purifier Installed		Non- Instructional Space
Phase Two Air Purifier Installed		Area that needs to be tested
Phase Three Air Purifier Installed		Updated DATA
Phase Four Air Purifier Installed		