



December 31, 2022

Mr. Matthew Griffin
Facilities Supervisor
Kyrene School District No. 28
8700 South Kyrene Road
Tempe, AZ 85284-2197

**Subject: 6-Month Surveillance Inspection
Asbestos-Containing Building Materials
Kyrene Akimel A-al Middle School
2720 East Liberty Lane, Phoenix**

Dear Mr. Griffin:

FM GROUP INC has completed the 6-Month Surveillance Inspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

Items of significance are: None

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

FM GROUP INC

A handwritten signature in blue ink, appearing to read 'Michael Hall', is positioned above the printed name.

Michael Hall
Environmental Division Manager

*Attachments: 6-Month Surveillance Inspection Forms
6-Month Surveillance Inspection Tables*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene Akimel A-al Middle School

Inspection Date: 12/5/22

Building: Concession Building

Inspector: Michael Hall Cert. No.: 4644-13312-011322

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Spray-Applied Texture, White, Chalky	S·SAT·01	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·02	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·03	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", White, Smooth	M·GWT·04	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Blue Smooth	M·GWT·05	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Tan, Smooth	M·GWT·06	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·07	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Tan, Smooth	M·CMT·08	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, White Specks	M·CMT·09	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, White Specks	M·CMT·10	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·11	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Doors, Millwork, Fixtures), White, Pliable	M·SLT·12	Y	N	✓			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S·SAT·13	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·14	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·15	Y	N	✓			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Blue, Vinyl-Like	M·WAB·16	Y	N	✓			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M·ADH·17	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M·CON·18	Y	N	✓			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M·FDI·19	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X16", Gray, Cementitious, Smooth	M·CMU·20	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 4"X16", Gray, Cementitious, Smooth	M·CMU·21	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 4"X16", Gray, Cementitious, Rough	M·CMU·22	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X8", Gray, Cementitious, Smooth	M·CMU·23	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 4"X8", Gray, Cementitious, Smooth	M·CMU·24	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 4"X8", Gray, Cementitious, Rough	M·CMU·25	Y	N	✓			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Mortar, Gray, Cementitious	M-MRT-26	Y	N	✓			1 2 3 4 5 6 7*
Sink Acoustical Coating, Gray, Rough	M-SAC-27	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-28	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-29	Y	N	✓			1 2 3 4 5 6 7*
Stucco, Gray, Cementitious	S-STU-30	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Fixtures), Black, Gummy	M-SLT-31	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Doors, Walls), Brown, Pliable	M-SLT-32	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-33	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 12"X12", Brown, Smooth	M-GWT-34	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Fire Stop), Red, Brittle	M-SLT-35	Y	N	✓			1 2 3 4 5 6 7*
Gasket, 4"-6", Black, Vinyl-Like	M-GAS-36	Y	N	✓			1 2 3 4 5 6 7*
Built-Up Roofing, Black, Asphaltic, Silver Coating	M-BUR-37	Y	N	✓			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Asphaltic	M-MAS-38	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), White, Pliable	M-SLT-39	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), Black, Tar-Like	M-SLT-40	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Duct), White, Pliable	M-SLT-41	Y	N	✓			1 2 3 4 5 6 7*

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S·SAT·01	S	Spray-Applied Texture, White, Chalky	Concession	Assumed	NF	G	900	SF
			Women's Restroom					
			Men's Restroom					
M·GWB·02	M	Gypsum Wallboard, White, Chalky	Concession	Assumed	NF	G	900	SF
			Women's Restroom					
			Men's Restroom					
S·JTC·03	S	Joint Compound, White, Chalky	Concession	Assumed	NF	G	90	SF
			Women's Restroom					
			Men's Restroom					
M·GWT·04	M	Glazed Wall Tile, 4"X4", White, Smooth	Women's Restroom	Assumed	NF	G	1,200	SF
			Men's Restroom					
M·GWT·05	M	Glazed Wall Tile (Pattern), 2"X2", Blue Smooth	Women's Restroom	Assumed	NF	G	150	SF
			Men's Restroom					
M·GWT·06	M	Glazed Wall Tile (Pattern), 2"X2", Tan, Smooth	Women's Restroom	Assumed	NF	G	150	SF
			Men's Restroom					
M·GRT·07	M	Grout, Gray, Cementitious	Women's Restroom	Assumed	NF	G	150	SF
			Men's Restroom					
M·CMT·08	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth	Women's Restroom	Assumed	NF	G	400	SF
			Men's Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CMT-09	M	Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, White Specks	Women's Restroom	Assumed	NF	G	50	SF
			Men's Restroom					
M-CMT-10	M	Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, White Specks	Women's Restroom	Assumed	NF	G	50	SF
			Men's Restroom					
M-GRT-11	M	Grout, Gray, Cementitious	Women's Restroom	Assumed	NF	G	50	SF
			Men's Restroom					
M-SLT-12	M	Sealant (Doors, Millwork, Fixtures), White, Pliable	Concession	Assumed	NF	G	15	SF
			Storage 1					
			Storage 2					
			Electrical					
			Women's Restroom					
			Men's Restroom					
S-SAT-13	M	Spray-Applied Texture, White, Chalky	Storage 1	Assumed	NF	G	700	SF
			Storage 2					
M-GWB-14	M	Gypsum Wallboard, White, Chalky	Storage 1	Assumed	NF	G	700	SF
			Storage 2					
S-JTC-15	S	Joint Compound, White, Chalky	Storage 1	Assumed	NF	G	70	SF
M-WAB-16	M	Wallbase (Coved), 4", Blue, Vinyl- Like	Concession	Assumed	NF	G	40	SF
			Storage 1					
			Storage 2					
M-ADH-17	M	Adhesive, Cream, Pliable	Concession	Assumed	NF	G	40	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 1					
			Storage 2					
M-CON-18	M	Concrete (Foundation), Gray, Cementitious	Concession	Assumed	NF	G	1,500	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Women's Restroom					
			Men's Restroom					
			Exterior					
M-FDI-19	M	Fire Door Insulation, Metal/Wood Cladding	Concession	Assumed	NF	G	126	SF
			Storage 1					
			Storage 2					
			Electrical					
			Women's Restroom					
			Men's Restroom					
M-CMU-20	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious, Smooth	Concession	Assumed	NF	G	800	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					
M-CMU-21	M	Concrete Masonry Unit, 4"X16", Gray, Cementitious, Smooth	Concession	Assumed	NF	G	800	SF
			Storage 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					
M-CMU-22	M	Concrete Masonry Unit, 4"X16", Gray, Cementitious, Rough	Concession	Assumed	NF	G	400	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					
M-CMU-23	M	Concrete Masonry Unit, 8"X8", Gray, Cementitious, Smooth	Concession	Assumed	NF	G	800	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					
M-CMU-24	M	Concrete Masonry Unit, 4"X8", Gray, Cementitious, Smooth	Concession	Assumed	NF	G	800	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CMU-25	M	Concrete Masonry Unit, 4"X8", Gray, Cementitious, Rough	Concession	Assumed	NF	G	400	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					
M-MRT-26	M	Mortar, Gray, Cementitious	Concession	Assumed	NF	G	100	SF
			Storage 1					
			Storage 2					
			Electrical					
			Maintenance					
			Equipment Yard					
			Exterior					
M-SAC-27	M	Sink Acoustical Coating, Gray, Rough	Concession	Assumed	NF	G	8	SF
M-GWB-28	M	Gypsum Wallboard, White, Chalky	Electrical	Assumed	NF	G	200	SF
S-JTC-29	S	Joint Compound, White, Chalky	Electrical	Assumed	NF	G	20	SF
S-STU-30	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	100	SF
M-SLT-31	M	Sealant (Fixtures), Black, Gummy	Exterior	Assumed	NF	G	2	SF
M-SLT-32	M	Sealant (Doors, Walls), Brown, Pliable	Exterior	Assumed	NF	G	10	SF
M-CON-33	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	2,000	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-GWT-34	M	Glazed Wall Tile, 12"X12", Brown, Smooth	Exterior	Assumed	NF	G	4	SF
M-SLT-35	M	Sealant (Fire Stop), Red, Brittle	Maintenance	Assumed	NF	G	1	SF
M-GAS-36	M	Gasket, 4"-6", Black, Vinyl-Like	Equipment Yard	Assumed	NF	G	7	SF
M-BUR-37	M	Built-Up Roofing, Black, Asphaltic, Silver Coating	Roof	Assumed	NF	G	1,400	SF
M-MAS-38	M	Mastic (Penetrations And Flashings), Black, Asphaltic	Roof	Assumed	NF	G	140	SF
M-SLT-39	M	Sealant (Flashings), White, Pliable	Roof	Assumed	NF	G	15	SF
M-SLT-40	M	Sealant (Flashings), Black, Tar-Like	Roof	Assumed	NF	G	15	SF
M-SLT-41	M	Sealant (Duct), White, Pliable	Roof	Assumed	NF	G	10	SF



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene Akimel A-al Middle School

Inspection Date: 12/5/22

Building: Gym Building

Inspector: Michael Hall Cert. No.: 4644-13312-011322

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	M-VCT-10	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Blue, Smooth, Dark Blue Specks	M-VCT-11	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Gray Mottles	M-VCT-12	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Black Specks	M-VCT-13	Y	N	✓			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-14	Y	N	✓			1 2 3 4 5 6 7*
Sink Acoustical Coating, Black, Rough	M-SAC-15	Y	N	✓			1 2 3 4 5 6 7*
Pipe End Sealant (Fire Sprinklers), White, Pliable	M-PSL-18	Y	N	✓			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-19	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-21	Y	N	✓			1 2 3 4 5 6 7*
Woven Duct Boot, 4", Black, Canvas	M-WDB-22	Y	N	✓			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-31	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-32	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-33	Y	N	✓			1 2 3 4 5 6 7*
Pipe End Sealant, White, Pliable	M-PES-34	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky, Vinyl Cover	M-GWB-35	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-36	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Gray, Smooth, Dark Gray Mottles	M-VCT-37	Y	N	✓			1 2 3 4 5 6 7*
Wallbase (Coved), 4", Blue, Vinyl-Like	M-WAB-38	Y	N	✓			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M-ADH-39	Y	N	✓			1 2 3 4 5 6 7*
Quarry/Paver Tile, 12"X12", Tan, Smooth, Blue Specks	M-QPT-42	Y	N	✓			1 2 3 4 5 6 7*
Quarry/Paver Tile, 12"X12", Blue, Smooth, Blue Specks	M-QPT-43	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-44	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Coved), 4"X6", Tan, Smooth, Blue Specks	M-GWT-45	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-46	Y	N	✓			1 2 3 4 5 6 7*
Adhesive (FRP), Black, Brittle	M-ADH-47	Y	N	✓			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Sealant (Duct), Gray, Pliable	M·SLT·49	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), White, Brittle	M·SLT·53	Y	N	✓			1 2 3 4 5 6 7*
Pipe End Sealant, Gray, Pliable	M·PES·54	Y	N	✓			1 2 3 4 5 6 7*
Mastic (Penetrations And Flashings), Black, Tar-Like	M·MAS·56	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), White, Pliable	M·SLT·57	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M·SLT·58	Y	N	✓			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Rolled), Black, Asphaltic, White Coating	M·APR·59	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), Black, Pliable	M·SLT·60	Y	N	✓			1 2 3 4 5 6 7*
Woven Duct Boot, 4", Gray, Cloth-Like	M·WDB·61	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Skylights), Gray, Pliable	M·SLT·62	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Stair Tread, 12"X36", Blue, Textured, Circle Pattern	M·VST·63	Y	N	✓			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M·MAS·64	Y	N	✓			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S·SAT·65	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·66	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·67	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 12"X12", Red, Smooth	M·GWT·68	Y	N	✓			1 2 3 4 5 6 7*
Mortar (GWT And Glass Block), Gray, Cementitious	M·MRT·69	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Doors), Black, Pliable	M·SLT·70	Y	N	✓			1 2 3 4 5 6 7*
Carpet (Pattern), Blue, Fibrous	M·CPT·71	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M·GWB·72	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S·JTC·73	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", White, Smooth	M·GWT·74	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Blue, Smooth	M·GWT·75	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Tan, Smooth	M·GWT·76	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·77	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", White, Smooth, Peppered	M·CMT·78	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, Peppered	M·CMT·79	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, Peppered	M·CMT·80	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·81	Y	N	✓			1 2 3 4 5 6 7*
Wallbase (L-Shaped), 4", Black, Vinyl-Like	M·WAB·82	Y	N	✓			1 2 3 4 5 6 7*
Adhesive, Cream, Pliable	M·ADH·83	Y	N	✓			1 2 3 4 5 6 7*
Adhesive (FRP), Black, Brittle	M·ADH·84	Y	N	✓			1 2 3 4 5 6 7*
Quarry/Paver Tile, 12"X12", White, Textured	M·QPT·85	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·86	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Coved), 4"X6", White, Textured	M·GWT·87	Y	N	✓			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Grout, Gray, Cementitious	M-GRT-88	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-89	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-90	Y	N	✓			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M-EXJ-91	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Doors, Windows), Brown, Pliable	M-SLT-92	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Entries), Gray, Cementitious	M-CON-93	Y	N	✓			1 2 3 4 5 6 7*
Expansion Joint, Gray, Pliable	M-EXJ-94	Y	N	✓			1 2 3 4 5 6 7*
Concrete Masonry Unit, 8"X8", Gray, Cementitious, Cross Cut Pattern	M-CMU-96	Y	N	✓			1 2 3 4 5 6 7*

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

D:\Shared\2020 Projects\10 ENVKSD\20-265 6-Mo Surv Insp\2.0\2.3\2.3.1\Akime\6-MoSur-Gym.doc

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-VCT-10	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Classroom D-1	Assumed	NF	G	6,000	SF
			Storage 15					
			Storage 16					
			Storage 17					
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Storage 14					
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Custodian					
			Multi-Purpose					
			Music					
			Band Room					
			Band Restroom					
			Storage 9					
			Storage 10					
			Storage 11					
			Storage 12					
			Storage 13					
			Storage 7					
			Storage 6					
			Home Economics					
			Laundry					
			Home Ec Restroom					
			Art					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Art Hall					
			Electrical 1					
			Storage 5					
			Storage 4					
			Storage 1					
			Storage 2					
			Corridor 1					
			Corridor 2					
			Corridor 4					
M-VCT-11	M	Vinyl Composition Tile (Pattern), 12"X12", Blue, Smooth, Dark Blue Specks	Classroom D-1	Assumed	NF	G	200	SF
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Home Economics					
			Art					
			Art Hall					
M-VCT-12	M	Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Gray Mottles	Classroom D-1	Assumed	NF	G	200	SF
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Home Economics					
			Art					
			Art Hall					
M-VCT-13	M	Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Black Specks	Classroom D-1	Assumed	NF	G	50	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Home Economics					
			Art					
			Art Hall					
M-MAS-14	M	Mastic, Yellow, Tacky	Classroom D-1	Assumed	NF	G	6,000	SF
			Storage 15					
			Storage 16					
			Storage 17					
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Storage 14					
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Custodian					
			Multi-Purpose					
			Music					
			Band Room					
			Band Restroom					
			Storage 9					
			Storage 10					
			Storage 11					
			Storage 12					
			Storage 13					
			Storage 7					
			Storage 6					
			Home Economics					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Laundry					
			Home Economics Restroom					
			Art					
			Art Hall					
			Electrical 1					
			Storage 5					
			Storage 4					
			Storage 1					
			Storage 2					
			Corridor 1					
			Corridor 2					
			Corridor 4					
M·SAC·15	M	Sink Acoustical Coating, Black, Rough	Classroom D-1	Assumed	NF	G	24	SF
			Band Room					
			Home Economics					
			Art					
M·PSL·18	M	Pipe End Sealant (Fire Sprinklers), White, Pliable	Lobby	Assumed	NF	G	25	SF
			Storage 18					
			Classroom D-1					
			Gymnasium					
			Storage 15					
			Boy's Locker Room					
			Storage 16					
			Storage 17					
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Girl's Locker Room					
			Electrical 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Water/Heater					
			Men's Restroom 1					
			Women's Restroom 1					
			Kitchen					
			Freezer					
			Storage 14					
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Maintenance					
			Cafeteria					
			Custodian					
			Service Room					
			Multi-Purpose					
			Music					
			Band Room					
			Storage 8					
			Band Restroom					
			Band Office					
			Practice					
			Storage 9					
			Storage 10					
			Storage 11					
			Storage 12					
			Storage 13					
			Storage 7					
			Storage 6					
			Home Economics					
			Laundry					
			Home Economics Restroom					
			Art					
			Art Hall					
			Electrical 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 5					
			Storage 4					
			Storage 1					
			Storage 2					
			Storage 3					
			Computer Lab					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Corridor 5					
M-FDI-19	M	Fire Door Insulation, Metal/Wood Cladding	Lobby	Assumed	NF	G	2,520	SF
			Storage 18					
			Classroom D-1					
			Gymnasium					
			Storage 15					
			Boy's Locker Room					
			Storage 16					
			Storage 17					
			Office 1					
			Office 2					
			Girl's Locker Room					
			Electrical 2					
			Water/Heater					
			Kitchen					
			Storage 14					
			Kitchen Service Yard					
			Locker					
			Maintenance					
			Cafeteria					
			Custodian					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Service Room					
			Multi-Purpose					
			Music					
			Band Room					
			Storage 8					
			Band Restroom					
			Band Office					
			Storage 9					
			Storage 10					
			Storage 11					
			Storage 12					
			Storage 13					
			Storage 7					
			Storage 6					
			Home Economics					
			Home Economics Service Yard					
			Art					
			Art Hall					
			Art Service Yard					
			Electrical 1					
			Storage 5					
			Storage 4					
			Weight Room					
			Storage 2					
			Storage 3					
			Service Yard					
			Computer Lab					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Corridor 5					
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CON-21	M	Concrete (Foundation), Gray, Cementitious	Lobby	Assumed	NF	G	45,000	SF
			Storage 18					
			Classroom D-1					
			Gymnasium					
			Storage 15					
			Boy's Locker Room					
			Storage 16					
			Storage 17					
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Girl's Locker Room					
			Electrical 2					
			Water/Heater					
			Men's Restroom 1					
			Women's Restroom 1					
			Kitchen					
			Freezer					
			Storage 14					
			Kitchen Service Yard					
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Maintenance					
			Cafeteria					
			Custodian					
			Service Room					
			Multi-Purpose					
			Music					
			Band Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 8					
			Band Restroom					
			Band Office					
			Practice					
			Storage 9					
			Storage 10					
			Storage 11					
			Storage 12					
			Storage 13					
			Mechanical Yard					
			Storage 7					
			Storage 6					
			Home Economics					
			Laundry					
			Home Economics Restroom					
			Home Economics Service Yard					
			Art					
			Art Hall					
			Art Service Yard					
			Electrical 1					
			Storage 5					
			Storage 4					
			Weight Room					
			Storage 1					
			Storage 2					
			Storage 3					
			Service Yard					
			Computer Lab					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Corridor 5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Exterior					
M-WDB-22	M	Woven Duct Boot, 4", Black, Canvas	Storage 15	Assumed	NF	G	10	SF
			Weight Room					
S-SAT-31	S	Spray-Applied Texture, White, Chalky	Lobby	Assumed	NF	G	7,000	SF
			Boy's Locker Room					
			Office 1 Restroom					
			Office 2 Restroom					
			Girl's Locker Room					
			Men's Restroom 1					
			Women's Restroom 1					
			Kitchen					
			Kitchen Restroom					
			Custodian					
			Service Room					
			Band Restroom					
			Home Economics Restroom					
			Laundry					
			Storage 1					
M-GWB-32	M	Gypsum Wallboard, White, Chalky	Lobby	Assumed	NF	G	7,000	SF
			Boy's Locker Room					
			Office 1 Restroom					
			Office 2 Restroom					
			Girl's Locker Room					
			Men's Restroom 1					
			Women's Restroom 1					
			Kitchen					
			Kitchen Restroom					
			Custodian					
			Service Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Band Restroom					
			Home Economics Restroom					
			Laundry					
			Storage 1					
S-JTC-33	S	Joint Compound, White, Chalky	Lobby	Assumed	NF	G	700	SF
			Boy's Locker Room					
			Office 1 Restroom					
			Office 2 Restroom					
			Girl's Locker Room					
			Men's Restroom 1					
			Women's Restroom 1					
			Kitchen					
			Kitchen Restroom					
			Custodian					
			Service Room					
			Band Restroom					
			Home Economics Restroom					
			Laundry					
			Storage 1					
M-PES-34	M	Pipe End Sealant, White, Pliable	Weight Room	Assumed	NF	G	20	SF
M-GWB-35	M	Gypsum Wallboard, White, Chalky, Vinyl Cover	Band Restroom	Assumed	NF	G	4,000	SF
			Home Economics					
			Art					
			Art Hall					
S-JTC-36	S	Joint Compound, White, Chalky	Band Restroom	Assumed	NF	G	400	SF
			Home Economics					
			Art					
			Art Hall					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-VCT-37	M	Vinyl Composition Tile (Pattern), 12"X12", Gray, Smooth, Dark Gray Mottles	Art	Assumed	NF	G	50	SF
M-WAB-38	M	Wallbase (Coved), 4", Blue, Vinyl-Like	Music	Assumed	NF	G	15	SF
M-ADH-39	M	Adhesive, Cream, Pliable	Music	Assumed	NF	G	15	SF
M-QPT-42	M	Quarry/Paver Tile, 12"X12", Tan, Smooth, Blue Specks	Lobby	Assumed	NF	G	450	SF
M-QPT-43	M	Quarry/Paver Tile, 12"X12", Blue, Smooth, Blue Specks	Lobby	Assumed	NF	G	50	SF
M-GRT-44	M	Grout, Gray, Cementitious	Lobby	Assumed	NF	G	500	SF
M-GWT-45	M	Glazed Wall Tile (Coved), 4"X6", Tan, Smooth, Blue Specks	Kitchen	Assumed	NF	G	150	SF
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Cafeteria					
M-GRT-46	M	Grout, Gray, Cementitious	Kitchen	Assumed	NF	G	150	SF
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Cafeteria					
M-ADH-47	M	Adhesive (FRP), Black, Brittle	Kitchen	Assumed	NF	G	800	SF
			Custodian					
			Multi-Purpose					
M-SLT-49	M	Sealant (Duct), Gray, Pliable	Lobby	Assumed	NF	G	50	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 18					
			Classroom D-1					
			Gymnasium					
			Storage 15					
			Boy's Locker Room					
			Storage 16					
			Storage 17					
			Office 1					
			Office 1 Restroom					
			Office 2 Restroom					
			Office 2					
			Girl's Locker Room					
			Electrical 2					
			Water/Heater					
			Men's Restroom 1					
			Women's Restroom 1					
			Kitchen					
			Freezer					
			Storage 14					
			Kitchen Restroom					
			Locker					
			Kitchen Office					
			Maintenance					
			Cafeteria					
			Custodian					
			Service Room					
			Multi-Purpose					
			Music					
			Band Room					
			Storage 8					
			Band Restroom					
			Band Office					
			Practice					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 9					
			Storage 10					
			Storage 11					
			Storage 12					
			Storage 13					
			Storage 7					
			Storage 6					
			Home Economics					
			Laundry					
			Home Economics Restroom					
			Art					
			Art Hall					
			Electrical 1					
			Storage 5					
			Storage 4					
			Weight Room					
			Storage 1					
			Storage 2					
			Storage 3					
			Computer Lab					
			Corridor 1					
			Corridor 2					
			Corridor 3					
			Corridor 4					
			Corridor 5					
M·SLT·53	M	Sealant (Flashings), White, Brittle	Roof	Assumed	NF	G	200	SF
M·PES·54	M	Pipe End Sealant, Gray, Pliable	Roof	Assumed	NF	G	15	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M·MAS·56	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	60	SF
M·SLT·57	M	Sealant (Flashings), White, Pliable	Roof	Assumed	NF	G	5	SF
M·SLT·58	M	Sealant (Duct), Gray, Pliable	Roof	Assumed	NF	G	50	SF
M·APR·59	M	Asphalt Prepared Roofing (Rolled), Black, Asphaltic, White Coating	Roof	Assumed	NF	G	100	SF
M·SLT·60	M	Sealant (Flashings), Black, Pliable	Roof	Assumed	NF	G	10	SF
M·WDB·61	M	Woven Duct Boot, 4", Gray, Cloth-Like	Roof	Assumed	NF	G	1	SF
M·SLT·62	M	Sealant (Skylights), Gray, Pliable	Roof	Assumed	NF	G	25	SF
M·VST·63	M	Vinyl Stair Tread, 12"X36", Blue, Textured, Circle Pattern	Multi-Purpose	Assumed	NF	G	30	SF
			Corridor 1					
M·MAS·64	M	Mastic, Black, Brittle	Multi-Purpose	Assumed	NF	G	30	SF
			Corridor 1					
S·SAT·65	S	Spray-Applied Texture, White, Chalky	Lobby	Assumed	NF	G	2,500	SF
			Corridor 1					
			Corridor 2					
M·GWB·66	M	Gypsum Wallboard, White, Chalky	Lobby	Assumed	NF	G	2,500	SF
			Corridor 1					
			Corridor 2					
S·JTC·67	S	Joint Compound, White, Chalky	Lobby	Assumed	NF	G	250	SF
			Corridor 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Corridor 2					
M·GWT·68	M	Glazed Wall Tile, 12"X12", Red, Smooth	Lobby	Assumed	NF	G	20	SF
M·MRT·69	M	Mortar (GWT And Glass Block), Gray, Cementitious	Lobby	Assumed	NF	G	45	SF
M·SLT·70	M	Sealant (Doors), Black, Pliable	Lobby	Assumed	NF	G	20	SF
			Storage 18					
			Classroom D-1					
			Gymnasium					
			Storage 15					
			Electrical 2					
			Water/Heater					
			Corridor 4					
			Exterior					
M·CPT·71	M	Carpet (Pattern), Blue, Fibrous	Lobby	Assumed	NF	G	50	SF
M·GWB·72	M	Gypsum Wallboard, White, Chalky	Lobby	Assumed	NF	G	175	SF
S·JTC·73	S	Joint Compound, White, Chalky	Lobby	Assumed	NF	G	20	SF
M·GWT·74	M	Glazed Wall Tile, 4"X4", White, Smooth	Boy's Locker Room	Assumed	NF	G	4,000	SF
			Girl's Locker Room					
			Men's Restroom 1					
			Women's Restroom 1					
			Corridor 3					
			Corridor 5					
M·GWT·75	M	Glazed Wall Tile (Pattern), 2"X2", Blue, Smooth	Boy's Locker Room	Assumed	NF	G	500	SF
			Girl's Locker Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Men's Restroom 1					
			Women's Restroom 1					
			Corridor 3					
			Corridor 5					
M-GWT-76	M	Glazed Wall Tile (Pattern), 2"X2", Tan, Smooth	Boy's Locker Room	Assumed	NF	G	500	SF
			Girl's Locker Room					
			Men's Restroom 1					
			Women's Restroom 1					
			Corridor 3					
			Corridor 5					
M-GRT-77	M	Grout, Gray, Cementitious	Boy's Locker Room	Assumed	NF	G	500	SF
			Girl's Locker Room					
			Men's Restroom 1					
			Women's Restroom 1					
			Corridor 3					
			Corridor 5					
M-CMT-78	M	Ceramic Mosaic Tile, 2"X2", White, Smooth, Peppered	Men's Restroom 1	Assumed	NF	G	400	SF
			Women's Restroom 1					
M-CMT-79	M	Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, Peppered	Men's Restroom 1	Assumed	NF	G	50	SF
			Women's Restroom 1					
M-CMT-80	M	Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, Peppered	Men's Restroom 1	Assumed	NF	G	50	SF
			Women's Restroom 1					
M-GRT-81	M	Grout, Gray, Cementitious	Men's Restroom 1	Assumed	NF	G	40	SF
			Women's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-WAB-82	M	Wallbase (L-Shaped), 4", Black, Vinyl-Like	Gymnasium	Assumed	NF	G	100	SF
M-ADH-83	M	Adhesive, Cream, Pliable -Like	Gymnasium	Assumed	NF	G	100	SF
M-ADH-84	M	Adhesive (FRP), Black, Brittle	Corridor 3	Assumed	NF	G	750	SF
			Corridor 5					
M-QPT-85	M	Quarry/Paver Tile, 12"X12", White, Textured	Boy's Locker Room	Assumed	NF	G	3,000	SF
			Girls' Locker Room					
			Corridor 3					
			Corridor 5					
M-GRT-86	M	Grout, Gray, Cementitious	Boy's Locker Room	Assumed	NF	G	300	SF
			Girls' Locker Room					
			Corridor 3					
			Corridor 5					
M-GWT-87	M	Glazed Wall Tile (Coved), 4"X6", White, Textured	Boy's Locker Room	Assumed	NF	G	15	SF
			Girls' Locker Room					
M-GRT-88	M	Grout, Gray, Cementitious	Boy's Locker Room	Assumed	NF	G	2	SF
			Girls' Locker Room					
M-GWB-89	M	Gypsum Wallboard, White, Chalky	Boy's Locker Room	Assumed	NF	G	3,000	SF
			Girls' Locker Room					
S-JTC-90	S	Joint Compound, White, Chalky	Boy's Locker Room	Assumed	NF	G	300	SF
			Girls' Locker Room					
M-EXJ-91	M	Expansion Joint, Brown, Pliable	Mechanical Yard	Assumed	NF	G	100	SF
			Home Economics Service Yard					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Art Service Yard					
			Storage 3					
			Service Yard					
			Exterior					
M-SLT-92	M	Sealant (Doors, Windows), Brown, Pliable	Kitchen Service Yard	Assumed	NF	G	40	SF
			Home Economics Service Yard					
			Art Service Yard					
			Service Yard					
			Exterior					
M-CON-93	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	10,000	SF
M-EXJ-94	M	Expansion Joint, Gray, Pliable	Exterior	Assumed	NF	G	50	SF
M-CMU-96	M	Concrete Masonry Unit, 8"X8", Gray, Cementitious, Cross Cut Pattern	Exterior	Assumed	NF	G	150	SF



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

School/Facility: Kyrene Akimel A-al Middle School

Inspection Date: 12/5/22

Building: Main Building

Inspector: Michael Hall Cert. No.: 4644-13312-011322

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	M-VCT-10	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Blue, Smooth, Dark Blue Specks	M-VCT-11	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Gray Mottles	M-VCT-12	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Black Specks	M-VCT-13	Y	N	✓			1 2 3 4 5 6 7*
Mastic, Black, Brittle	M-MAS-14	Y	N	✓			1 2 3 4 5 6 7*
Fire Door Insulation, Metal/Wood Cladding	M-FDI-18	Y	N	✓			1 2 3 4 5 6 7*
Pipe End Sealant (Fire Sprinklers), White, Pliable	M-PSL-20	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Duct), Gray, Pliable	M-SLT-21	Y	N	✓			1 2 3 4 5 6 7*
Sink Acoustical Coating, Gray, Rough	M-SAC-22	Y	N	✓			1 2 3 4 5 6 7*
Tackable Wall Panel, White, Chalky, Vinyl Cover	M-TWP-23	Y	N	✓			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-25	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-26	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-27	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X4", White, Smooth	M-GWT-28	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Tan, Smooth	M-GWT-29	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Pattern), 2"X2", Blue, Smooth	M-GWT-30	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-31	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", Tan, Smooth	M-CMT-32	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, White, Specks	M-CMT-33	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, White Specks	M-CMT-34	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-35	Y	N	✓			1 2 3 4 5 6 7*
Spray-Applied Texture, White, Chalky	S-SAT-36	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-37	Y	N	✓			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Joint Compound, White, Chalky	S-JTC-38	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile, 2"X2", White, Smooth, Peppered	M-CMT-39	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, Brown Specks	M-CMT-40	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, Brown Specks	M-CMT-41	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-42	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile (Coved), 4"X6", White, Smooth	M-GWT-43	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-44	Y	N	✓			1 2 3 4 5 6 7*
Troweled-On Texture, White, Chalky	S-TOT-52	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-53	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-54	Y	N	✓			1 2 3 4 5 6 7*
Troweled-On Texture, White, Chalky	S-TOT-55	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-56	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-57	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Equipment Pad), Gray, Cementitious	M-CON-58	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Composition Tile, 24"X24", Blue, Textured, Circle Pattern	M-VCT-59	Y	N	✓			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-60	Y	N	✓			1 2 3 4 5 6 7*
Vinyl Stair Tread, 12"X36", Blue, Textured, Circle Pattern	M-VST-61	Y	N	✓			1 2 3 4 5 6 7*
Mastic, Yellow, Tacky	M-MAS-62	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky, Vinyl Cover	M-GWB-67	Y	N	✓			1 2 3 4 5 6 7*
Joint Compound, White, Chalky	S-JTC-68	Y	N	✓			1 2 3 4 5 6 7*
Mortar (Glass Block And GWT), Gray, Cementitious	M-MRT-69	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 12"X12", Brown, Smooth	M-GWT-72	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-73	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 8"X8", Brown, Smooth	M-GWT-74	Y	N	✓			1 2 3 4 5 6 7*
Quarry/Paver Tile, 12"X12", White, Smooth	M-QPT-75	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M-GRT-76	Y	N	✓			1 2 3 4 5 6 7*
Quarry/Paver Tile, 12"X12", Blue, Smooth	M-QPT-77	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-78	Y	N	✓			1 2 3 4 5 6 7*
Gypsum Wallboard, White, Chalky	M-GWB-79	Y	N	✓			1 2 3 4 5 6 7*
Joint, Compound, White, Chalky	S-JTC-80	Y	N	✓			1 2 3 4 5 6 7*
Mortar (Glass Block) Gray, Cementitious	M-MRT-86	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), Tan, Pliable	M-SLT-88	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Flashings), White, Brittle	M-SLT-89	Y	N	✓			1 2 3 4 5 6 7*
Sealant (Doors, Windows), Brown, Pliable	M-SLT-91	Y	N	✓			1 2 3 4 5 6 7*



6-MONTH SURVEILLANCE INSPECTION ASBESTOS-CONTAINING BUILDING MATERIALS

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Concrete (Entries), Gray, Cementitious	M·CON·92	Y	N	✓			1 2 3 4 5 6 7*
Expansion Joint, Gray, Pliable	M·EXJ·93	Y	N	✓			1 2 3 4 5 6 7*
Concrete, Gray, Cementitious	M·CON·94	Y	N	✓			1 2 3 4 5 6 7*
Expansion Joint, Brown, Pliable	M·EXJ·95	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 8"X8", Brown, Smooth	M·GWT·96	Y	N	✓			1 2 3 4 5 6 7*
Glazed Wall Tile, 4"X8", Brown, Smooth	M·GWT·97	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·98	Y	N	✓			1 2 3 4 5 6 7*
Ceramic Mosaic Tile (Mosaic), Various Sizes, White, Smooth, Various Colors	M·CMT·99	Y	N	✓			1 2 3 4 5 6 7*
Grout, Gray, Cementitious	M·GRT·100	Y	N	✓			1 2 3 4 5 6 7*

*Assessment Classifications

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE

IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-VCT-10	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Athletic Storage	Assumed	NF	G	10,000	SF
			Storage 17					
			Work Room					
			Supply Room 1					
			Supply Room 2					
			Mail Room					
			Faculty Lounge					
			Water Heater					
			Storage 16					
			Room D-12 Time Out					
			Room D-12 Restroom					
			Electrical 6					
			Storage 18					
			Health Restroom					
			Treatment					
			Teacher Workroom					
			Storage 20					
			Classroom D-8					
			Classroom D-9					
			Storage 19					
			Room D-9 Restroom					
			Room D-9 Time Out					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Classroom A-5					
			Classroom A-6					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Special Ed A-9					
			Special Ed A-10					
			Custodial 4					
			Workroom 1					
			Storage 13					
			Electrical 5					
			Storage 12					
			Custodial 3					
			Storage 9					
			Storage 10					
			Electrical 04					
			Storage 11					
			Classroom B-5					
			Classroom B-7					
			Classroom B-8					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Electrical 03					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 7					
			Computer Lab 2					
			Storage 8					
			Custodian 2					
			Storage 6					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Storage 2					
			Classroom C-5					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Riser Room					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
			Electrical 02					
			Storage 4					
			Storage 5					
			Computer Lab 1					
			Custodian 1					
			Storage 3					
			Corridor 1-2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-VCT-11	M	Vinyl Composition Tile (Pattern), 12"X12", Blue, Smooth, Dark Blue Specks	Treatment	Assumed	NF	G	500	SF
			Classroom D-8					
			Classroom D-9					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Special Ed A-9					
			Special Ed A-10					
			Classroom B-5					
			Classroom B-7					
			Classroom B-8					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom C-4					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
M-VCT-12	M	Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Gray Mottles	Faculty Lounge	Assumed	NF	G	500	SF
			Treatment					
			Teacher Workroom					
			Classroom D-8					
			Classroom D-9					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Special Ed A-9					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Special Ed A-10					
			Classroom B-5					
			Classroom B-7					
			Classroom B-8					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-VCT-13	M	Vinyl Composition Tile (Pattern), 12"X12", Tan, Smooth, Black Specks	Faculty Lounge	Assumed	NF	G	500	SF
			Treatment					
			Teacher Workroom					
			Classroom D-8					
			Classroom D-9					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Special Ed A-9					
			Special Ed A-10					
			Classroom B-5					
			Classroom B-7					
			Classroom B-8					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Classroom C-1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
M-MAS-14	M	Mastic, Black, Brittle	Athletic Storage	Assumed	NF	G	11,500	SF
			Storage 17					
			Work Room					
			Supply Room 1					
			Supply Room 2					
			Mail Room					
			Faculty Lounge					
			Water Heater					
			Storage 16					
			Room D-12 Time Out					
			Room D-12 Restroom					
			Electrical 6					
			Storage 18					
			Health Restroom					
			Treatment					
			Teacher Workroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 20					
			Classroom D-8					
			Classroom D-9					
			Storage 19					
			Room D-9 Restroom					
			Room D-9 Time Out					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Classroom A-5					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Special Ed A-9					
			Special Ed A-10					
			Custodial 4					
			Workroom 1					
			Storage 13					
			Electrical 5					
			Storage 12					
			Custodial 3					
			Storage 9					
			Storage 10					
			Electrical 04					
			Storage 11					
			Classroom B-5					
			Classroom B-6					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom B-7					
			Classroom B-8					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Electrical 3					
			Storage 7					
			Computer Lab 2					
			Storage 8					
			Custodian 2					
			Storage 6					
			Special Ed B-9					
			Special Ed B-10					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Storage 2					
			Classroom C-5					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Riser Room					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
			Electrical 2					
			Storage 4					
			Storage 5					
			Computer Lab 1					
			Custodian 1					
			Storage 3					
			Corridor 1-2					
M-FDI-18	M	Fire Door Insulation, Metal/Wood Cladding	Office	Assumed	NF	G	3,780	SF
			Assistant Principal					
			Principal					
			Secretary					
			Athletic Storage					
			Storage 17					
			Work Room					
			Supply Room 1					
			Supply Room 2					
			Tele 1					
			Tele 2					
			Mail Room					
			Faculty Lounge					
			Conference 2					
			Water Heater					
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Stairs					
			Room D-12					
			Room D-12 Time Out					
			Room D-12 Restroom					
			Electrical 6					
			Cot Room					
			Storage 18					
			Health					
			Custodial 6					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Storage 20					
			Teacher Workroom					
			Classroom D-8					
			Classroom D-9					
			Storage 19					
			Corridor 1-1					
			Corridor 2-1					
			Corridor 3-1					
			Corridor 4-1					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Classroom A-5					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom A-14					
			Classroom A-15					
			Classroom A-16					
			Classroom A-17					
			Classroom A-18					
			Special Ed A-9					
			Special Ed A-10					
			Custodial 4					
			Storage 14					
			Workroom 1					
			Men's Restroom 3					
			Storage 13					
			Electrical 5					
			Women's Restroom 3					
			Storage 12					
			Classroom B-1					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Custodial 3					
			Girl's Restroom 6					
			Break Out 2					
			Break Out 3					
			Boy's Restroom 6					
			Electrical 04					
			Storage 11					
			Classroom B-5					
			Classroom B-6					
			Classroom B-7					
			Classroom B-8					
			Storage 1					
			Classroom B-11					
			Classroom B-12					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Storage 8					
			Computer Lab 2					
			Women's Restroom 2					
			Storage 7					
			Men's Restroom 2					
			Storage 6					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Girl's Restroom 1					
			Electrical 1					
			Boy's Restroom 1					
			Classroom C-5					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Storage					
			Riser Room					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
			Electrical 2					
			Storage 5					
			Computer Lab 1					
			Men's Restroom 1					
			Storage 4					
			Custodial 1					
			Women's Restroom 1					
			Storage 3					
			Storage 15					
			Office					
			Library Office					
			Library Storage					
			Media Classroom					
			Computer Lab 3					
			Media Center					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
			Exterior					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-PSL-20	M	Pipe End Sealant (Fire Sprinklers), White, Pliable	Office	Assumed	NF	G	200	SF
			Server Room					
			Assistant Principal					
			Assistant Principal Closet					
			Principal					
			Office 4					
			Counselor					
			Psychology					
			Office 3					
			Office 2					
			Conference 1					
			Secretary					
			Athletic Storage					
			Storage 17					
			Work Room					
			Supply Room 1					
			Supply Room 2					
			Tele 1					
			Tele 2					
			Mail Room					
			Faculty Lounge					
			Conference 2					
			Water Heater					
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					
			Stairs					
			Room D-12					
			Room D-12 Time Out					
			Room D-12 Restroom					
			Electrical 6					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Cot Room					
			Storage 18					
			Health Restroom					
			Nurse					
			Health					
			Treatment					
			Hearing					
			Custodial 6					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Storage 20					
			Teacher Workroom					
			Classroom D-8					
			Classroom D-9					
			Storage 19					
			Room D-9 Restroom					
			Room D-9 Shower					
			Room D-9 Time Out					
			Corridor 1-1					
			Corridor 2-1					
			Corridor 3-1					
			Corridor 4-1					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Classroom A-5					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Classroom A-16					
			Classroom A-17					
			Classroom A-18					
			Special Ed A-9					
			Special Ed A-10					
			Custodial 4					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Storage 14					
			Workroom 1					
			Men's Restroom 3					
			Storage 13					
			Electrical 5					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Storage 12					
			Classroom B-1					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Custodial 3					
			Girl's Restroom 6					
			Storage 9					
			Storage 10					
			Break Out 2					
			Break Out 3					
			Boy's Restroom 6					
			Electrical 04					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 11					
			Classroom B-5					
			Classroom B-6					
			Classroom B-7					
			Classroom B-8					
			Storage 1					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Electrical 3					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Storage 8					
			Computer Lab 2					
			Women's Restroom 2					
			Storage 7					
			Custodial 2					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Storage 6					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Girl's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Break Out 1					
			Storage 2					
			Electrical 1					
			Boy's Restroom 1					
			Classroom C-5					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Storage					
			Riser Room					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
			Electrical 2					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Storage 5					
			Computer Lab 1					
			Men's Restroom 1					
			Storage 4					
			Custodial 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Storage 3					
			Storage 15					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Office					
			Library Office					
			Library Storage					
			Media Classroom					
			Computer Lab 3					
			Media Center					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
M-SLT-21	M	Sealant (Duct), Gray, Pliable	Office	Assumed	NF	G	150	SF
			Server Room					
			Assistant Principal					
			Assistant Principal Closet					
			Principal					
			Office 4					
			Counselor					
			Psychology					
			Office 3					
			Office 2					
			Conference 1					
			Secretary					
			Athletic Storage					
			Storage 17					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Work Room					
			Supply Room 1					
			Supply Room 2					
			Tele 1					
			Tele 2					
			Mail Room					
			Faculty Lounge					
			Conference 2					
			Water Heater					
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					
			Stairs					
			Room D-12					
			Room D-12 Time Out					
			Room D-12 Restroom					
			Electrical 6					
			Cot Room					
			Storage 18					
			Health Restroom					
			Nurse					
			Health					
			Treatment					
			Hearing					
			Custodial 6					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Storage 20					
			Teacher Workroom					
			Classroom D-8					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom D-9					
			Storage 19					
			Room D-9 Restroom					
			Room D-9 Shower					
			Room D-9 Time Out					
			Corridor 1-1					
			Corridor 2-1					
			Corridor 3-1					
			Corridor 4-1					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Classroom A-5					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					
			Classroom A-14					
			Classroom A-15					
			Classroom A-16					
			Classroom A-17					
			Classroom A-18					
			Special Ed A-9					
			Special Ed A-10					
			Custodial 4					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Storage 14					
			Workroom 1					
			Men's Restroom 3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Storage 13					
			Electrical 5					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Storage 12					
			Classroom B-1					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Custodial 3					
			Girl's Restroom 6					
			Storage 9					
			Storage 10					
			Break Out 2					
			Break Out 3					
			Boy's Restroom 6					
			Electrical 04					
			Storage 11					
			Classroom B-5					
			Classroom B-6					
			Classroom B-7					
			Classroom B-8					
			Storage 1					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Special Ed B-10					
			Electrical 3					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Storage 8					
			Computer Lab 2					
			Women's Restroom 2					
			Storage 7					
			Custodial 2					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Storage 6					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Girl's Restroom 1					
			Break Out 1					
			Storage 2					
			Electrical 1					
			Boy's Restroom 1					
			Classroom C-5					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Storage					
			Riser Room					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
			Electrical 2					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Storage 5					
			Computer Lab 1					
			Men's Restroom 1					
			Storage 4					
			Custodial 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Storage 3					
			Storage 15					
			Office					
			Library Office					
			Library Storage					
			Media Classroom					
			Computer Lab 3					
			Media Center					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
M-SAC-22	M	Sink Acoustical Coating, Gray, Rough	Classroom A-14	Assumed	NF	G	10	SF
			Classroom A-15					
			Classroom B-5					
			Classroom C-13					
			Classroom C-14					
M-TWP-23	M	Tackable Wall Panel, White, Chalky, Vinyl Cover	Classroom A-14	Assumed	NF	G	250	SF
			Classroom A-15					
			Break Out 2					
			Break Out 3					
S-SAT-25	S	Spray-Applied Texture, White, Chalky	Water Heater	Assumed	NF	G	6,500	SF
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					
			Room D-12 Restroom					
			Health Restroom					
			Women's Restroom 5					
			Men's Restroom 5					
			Room D-9 Restroom					
			Room D-9 Shower					
			Custodial 4					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Restroom 7					
			Girl's Restroom 6					
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Women's Restroom 2					
			Custodial 2					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Custodial 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GWB-26	M	Gypsum Wallboard, White, Chalky	Water Heater	Assumed	NF	G	6,500	SF
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					
			Room D-12 Restroom					
			Health Restroom					
			Women's Restroom 5					
			Men's Restroom 5					
			Room D-9 Restroom					
			Room D-9 Shower					
			Custodial 4					
			Boy's Restroom 8					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Girl's Restroom 6					
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Women's Restroom 2					
			Custodial 2					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Custodial 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
S-JTC-27	S	Joint Compound, White, Chalky	Water Heater	Assumed	NF	G	650	SF
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					
			Room D-12 Restroom					
			Health Restroom					
			Women's Restroom 5					
			Men's Restroom 5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Room D-9 Restroom					
			Room D-9 Shower					
			Custodial 4					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Girl's Restroom 6					
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Women's Restroom 2					
			Custodial 2					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Custodial 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GWT-28	M	Glazed Wall Tile, 4"X4", White, Smooth	Boy's Restroom 9	Assumed	NF	G	5,000	SF
			Girl's Restroom 9					
			Room D-9 Shower					
			Boy's Restroom 8					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Restroom 8					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Girl's Restroom 6					
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GWT-29	M	Glazed Wall Tile (Pattern), 2"X2", Tan, Smooth	Boy's Restroom 9	Assumed	NF	G	500	SF
			Girl's Restroom 9					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Girl's Restroom 6					
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Girl's Restroom 3					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GWT-30	M	Glazed Wall Tile (Pattern), 2"X2", Blue, Smooth	Boy's Restroom 9	Assumed	NF	G	500	SF
			Girl's Restroom 9					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Girl's Restroom 6					
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GRT-31	M	Grout, Gray, Cementitious	Boy's Restroom 9	Assumed	NF	G	600	SF
			Girl's Restroom 9					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Girl's Restroom 6					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Restroom 6					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Girl's Restroom 1					
			Boy's Restroom 1					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-CMT-32	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth	Girl's Restroom 6	Assumed	NF	G	800	SF
			Boy's Restroom 6					
			Girl's Restroom 1					
			Boy's Restroom 1					
M-CMT-33	M	Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, White, Specks	Girl's Restroom 6	Assumed	NF	G	100	SF
			Boy's Restroom 6					
			Girl's Restroom 1					
			Boy's Restroom 1					
M-CMT-34	M	Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, White Specks	Girl's Restroom 6	Assumed	NF	G	100	SF
			Boy's Restroom 6					
			Girl's Restroom 1					
			Boy's Restroom 1					
M-GRT-35	M	Grout, Gray, Cementitious	Girl's Restroom 6	Assumed	NF	G	100	SF
			Boy's Restroom 6					
			Girl's Restroom 1					
			Boy's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S-SAT-36	S	Spray-Applied Texture, White, Chalky	Office	Assumed	NF	G	7,000	SF
			Electrical 6					
			Custodial 6					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
M-GWB-37	M	Gypsum Wallboard, White, Chalky	Office	Assumed	NF	G	7,000	SF
			Electrical 6					
			Custodial 6					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
S-JTC-38	S	Joint Compound, White, Chalky	Office	Assumed	NF	G	700	SF
			Electrical 6					
			Custodial 6					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
M-CMT-39	M	Ceramic Mosaic Tile, 2"X2", White, Smooth, Peppered	Men's Restroom 4	Assumed	NF	G	3,500	SF
			Women's Restroom 4					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Boy's Restroom 5					
			Girl's Restroom 5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-CMT-40	M	Ceramic Mosaic Tile (Pattern), 2"X2", Tan, Smooth, Brown Specks	Men's Restroom 4	Assumed	NF	G	250	SF
			Women's Restroom 4					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Women's Restroom 1					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Boy's Restroom 2					
			Girl's Restroom 2					
M-CMT-41	M	Ceramic Mosaic Tile (Pattern), 1"X1", Tan, Smooth, Brown Specks	Men's Restroom 4	Assumed	NF	G	250	SF
			Women's Restroom 4					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GRT-42	M	Grout, Gray, Cementitious	Men's Restroom 4	Assumed	NF	G	400	SF
			Women's Restroom 4					
			Boy's Restroom 9					
			Girl's Restroom 9					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Women's Restroom 5					
			Men's Restroom 5					
			Room D-9 Shower					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Men's Restroom 3					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Men's Restroom 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
M-GWT-43	M	Glazed Wall Tile (Coved), 4"X6", White, Smooth	Men's Restroom 4	Assumed	NF	G	500	SF
			Women's Restroom 4					
			Men's Restroom 3					
			Women's Restroom 3					
			Women's Restroom 2					
			Men's Restroom 2					
			Men's Restroom 1					
			Women's Restroom 1					
M-GRT-44	M	Grout, Gray, Cementitious	Men's Restroom 4	Assumed	NF	G	50	SF
			Women's Restroom 4					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Men's Restroom 3					
			Women's Restroom 3					
			Women's Restroom 2					
			Men's Restroom 2					
			Men's Restroom 1					
			Women's Restroom 1					
S·TOT·52	S	Troweled-On Texture, White, Chalky	Custodial 3	Assumed	NF	G	200	SF
M·GWB·53	M	Gypsum Wallboard, White, Chalky	Custodial 3	Assumed	NF	G	200	SF
S·JTC·54	S	Joint Compound, White, Chalky	Custodial 3	Assumed	NF	G	20	SF
S·TOT·55	S	Troweled-On Texture, White, Chalky	Electrical 04	Assumed	NF	G	150	SF
M·GWB·56	M	Gypsum Wallboard, White, Chalky	Electrical 04	Assumed	NF	G	150	SF
S·JTC·57	S	Joint Compound, White, Chalky	Electrical 04	Assumed	NF	G	15	SF
M·CON·58	M	Concrete (Equipment Pad), Gray, Cementitious	Electrical 04	Assumed	NF	G	10	SF
M·VCT·59	M	Vinyl Composition Tile, 24"X24", Blue, Textured, Circle Pattern	Stairs	Assumed	NF	G	200	SF
M·MAS·60	M	Mastic, Yellow, Tacky	Stairs	Assumed	NF	G	200	SF
M·VST·61	M	Vinyl Stair Tread, 12"X36", Blue, Textured, Circle Pattern	Stairs	Assumed	NF	G	200	SF
M·MAS·62	M	Mastic, Yellow, Tacky	Stairs	Assumed	NF	G	200	SF
M·GWB·67	M	Gypsum Wallboard, White, Chalky, Vinyl Cover	Office	Assumed	NF	G	18,000	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Cot Room					
			Health					
			Treatment					
			Hearing					
			Corridor 1-1					
			Corridor 2-1					
			Corridor 3-1					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
S-JTC-68	S	Joint Compound, White, Chalky	Office	Assumed	NF	G	1,800	SF
			Cot Room					
			Health					
			Treatment					
			Hearing					
			Corridor 1-1					
			Corridor 2-1					
			Corridor 3-1					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
M-MRT-69	M	Mortar (Glass Block And GWT), Gray, Cementitious	Exterior	Assumed	NF	G	100	SF
M-GWT-72	M	Glazed Wall Tile, 12"X12", Brown, Smooth	Corridor 2-2	Assumed	NF	G	100	SF
			Corridor 11-2					
			Corridor 12-2					
M-GRT-73	M	Grout, Gray, Cementitious	Corridor 2-2	Assumed	NF	G	15	SF
			Corridor 11-2					
			Corridor 12-2					
M-GWT-74	M	Glazed Wall Tile, 8"X8", Brown, Smooth	Corridor 2-2	Assumed	NF	G	50	SF
			Corridor 11-2					
			Corridor 12-2					
M-QPT-75	M	Quarry/Paver Tile, 12"X12", White, Smooth	Office	Assumed	NF	G	100	SF
M-GRT-76	M	Grout, Gray, Cementitious	Office	Assumed	NF	G	10	SF
M-QPT-77	M	Quarry/Paver Tile, 12"X12", Blue, Smooth	Office	Assumed	NF	G	20	SF
M-CON-78	M	Concrete (Foundation), Gray, Cementitious	Office	Assumed	NF	G	115,000	SF
			Server Room					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Assistant Principal					
			Assistant Principal Closet					
			Principal					
			Office 4					
			Counselor					
			Psychology					
			Office 3					
			Office 2					
			Conference 1					
			Secretary					
			Athletic Storage					
			Storage 17					
			Work Room					
			Supply Room 1					
			Supply Room 2					
			Tele 1					
			Tele 2					
			Mail Room					
			Faculty Lounge					
			Conference 2					
			Water Heater					
			Men's Restroom 4					
			Custodial 5					
			Women's Restroom 4					
			Storage 16					
			Stairs					
			Room D-12					
			Room D-12 Time Out					
			Room D-12 Restroom					
			Electrical 6					
			Cot Room					
			Storage 18					
			Health Restroom					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Nurse					
			Health					
			Treatment					
			Hearing					
			Custodial 6					
			Boy's Restroom 9					
			Girl's Restroom 9					
			Women's Restroom 5					
			Men's Restroom 5					
			Storage 20					
			Teacher Workroom					
			Classroom D-8					
			Classroom D-9					
			Storage 19					
			Room D-9 Restroom					
			Room D-9 Shower					
			Room D-9 Time Out					
			Corridor 1-1					
			Corridor 2-1					
			Corridor 3-1					
			Corridor 4-1					
			Elevator 1					
			Classroom A-1					
			Classroom A-2					
			Classroom A-3					
			Classroom A-4					
			Classroom A-5					
			Classroom A-6					
			Classroom A-7					
			Classroom A-8					
			Classroom A-11					
			Classroom A-12					
			Classroom A-13					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom A-14					
			Classroom A-15					
			Classroom A-16					
			Classroom A-17					
			Classroom A-18					
			Special Ed A-9					
			Special Ed A-10					
			Custodial 4					
			Boy's Restroom 8					
			Girl's Restroom 8					
			Storage 14					
			Workroom 1					
			Men's Restroom 3					
			Storage 13					
			Electrical 5					
			Women's Restroom 3					
			Boy's Restroom 7					
			Girl's Restroom 7					
			Storage 12					
			Classroom B-1					
			Classroom B-2					
			Classroom B-3					
			Classroom B-4					
			Custodial 3					
			Girl's Restroom 6					
			Storage 9					
			Storage 10					
			Break Out 2					
			Break Out 3					
			Boy's Restroom 6					
			Electrical 04					
			Storage 11					
			Classroom B-5					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Classroom B-6					
			Classroom B-7					
			Classroom B-8					
			Storage 1					
			Classroom B-11					
			Classroom B-12					
			Classroom B-13					
			Classroom B-14					
			Classroom B-15					
			Classroom B-16					
			Classroom B-17					
			Classroom B-18					
			Special Ed B-9					
			Special Ed B-10					
			Electrical 3					
			Boy's Restroom 5					
			Girl's Restroom 5					
			Storage 8					
			Computer Lab 2					
			Women's Restroom 2					
			Storage 7					
			Custodial 2					
			Men's Restroom 2					
			Boy's Restroom 4					
			Girl's Restroom 4					
			Storage 6					
			Classroom C-1					
			Classroom C-2					
			Classroom C-3					
			Classroom C-4					
			Girl's Restroom 1					
			Break Out 1					
			Storage 2					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Electrical 1					
			Boy's Restroom 1					
			Classroom C-5					
			Classroom C-6					
			Classroom C-7					
			Science Classroom C-8					
			Science Storage					
			Riser Room					
			Science Classroom C-11					
			Classroom C-12					
			Classroom C-13					
			Classroom C-14					
			Classroom C-15					
			Classroom C-16					
			Classroom C-17					
			Classroom C-18					
			Special Ed C-9					
			Special Ed C-10					
			Electrical 2					
			Boy's Restroom 3					
			Girl's Restroom 3					
			Storage 5					
			Computer Lab 1					
			Men's Restroom 1					
			Storage 4					
			Custodial 1					
			Women's Restroom 1					
			Boy's Restroom 2					
			Girl's Restroom 2					
			Storage 3					
			Storage 15					
			Office					
			Library Office					

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
			Library Storage					
			Media Classroom					
			Computer Lab 3					
			Media Center					
			Elevator 2					
			Corridor 1-2					
			Corridor 2-2					
			Corridor 3-2					
			Corridor 4-2					
			Corridor 5-2					
			Corridor 6-2					
			Corridor 7-2					
			Corridor 8-2					
			Corridor 9-2					
			Corridor 10-2					
			Corridor 11-2					
			Corridor 12-2					
			Exterior					
M·GWB·79	M	Gypsum Wallboard, White, Chalky	Boy's Restroom 9	Assumed	NF	G	400	SF
			Girl's Restroom 9					
S·JTC·80	S	Joint, Compound, White, Chalky	Boy's Restroom 9	Assumed	NF	G	20	SF
			Girl's Restroom 9					
M·MRT·86	M	Mortar (Glass Block), Gray, Cementitious	Roof	Assumed	NF	G	10	SF
M·SLT·88	M	Sealant (Flashings), Tan, Pliable	Exterior	Assumed	NF	G	25	SF
M·SLT·89	M	Sealant (Flashings), White, Brittle	Roof	Assumed	NF	G	15	SF
M·SLT·91	M	Sealant (Doors, Windows), Brown, Pliable	Exterior	Assumed	NF	G	5	SF

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CON-92	M	Concrete (Entries), Gray, Cementitious	Exterior	Assumed	NF	G	3,000	SF
M-EXJ-93	M	Expansion Joint, Gray, Pliable	Exterior	Assumed	NF	G	25	SF
M-CON-94	M	Concrete, Gray, Cementitious	Exterior	Assumed	NF	G	250	SF
M-EXJ-95	M	Expansion Joint, Brown, Pliable	Stairs	Assumed	NF	G	250	SF
			Elevator 1					
			Custodial 3					
			Electrical 04					
			Electrical 1					
			Elevator 2					
			Corridor 2-2					
			Corridor 11-2					
			Corridor 12-2					
			Exterior					
M-GWT-96	M	Glazed Wall Tile, 8"X8", Brown, Smooth	Exterior	Assumed	NF	G	100	SF
M-GWT-97	M	Glazed Wall Tile, 4"X8", Brown, Smooth	Exterior	Assumed	NF	G	100	SF
M-GRT-98	M	Grout, Gray, Cementitious	Exterior	Assumed	NF	G	10	SF
M-CMT-99	M	Ceramic Mosaic Tile (Mosaic), Various Sizes, White, Smooth, Various Colors	Exterior	Assumed	NF	G	10	SF
M-GRT-100	M	Grout, Gray, Cementitious	Exterior	Assumed	NF	G	1	SF



**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Kyrene Akimel A-al Middle School

Inspection Date: 12/5/22

Building: Storage 1 Building

Inspector: Michael Hall Cert. No.: 4644-13312-011322

Signature:

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Concrete Masonry Unit, 8"X16", Gray, Cementitious, Smooth	M-CMU-01	Y	N	✓			1 2 3 4 5 6 7*
Mortar, Gray, Cementitious	M-MRT-02	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-03	Y	N	✓			1 2 3 4 5 6 7*
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Brown Mineral Cap	M-APR-04	Y	N	✓			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-05	Y	N	✓			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-CMU-01	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious, Smooth	Storage 1	Assumed	NF	G	1,600	SF
			Exterior					
M-MRT-02	M	Mortar, Gray, Cementitious	Storage 1	Assumed	NF	G	160	SF
			Exterior					
M-CON-03	M	Concrete (Foundation), Gray, Cementitious	Storage 1	Assumed	NF	G	400	SF
			Exterior					
M-APR-04	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Brown Mineral Cap	Roof	Assumed	NF	G	400	SF
M-VBF-05	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	400	SF



**6-MONTH SURVEILLANCE INSPECTION
ASBESTOS-CONTAINING BUILDING MATERIALS**

School/Facility: Kyrene Akimel A-al Middle School

Inspection Date: 12/5/22

Building: Storage 2 Building

Inspector: Michael Hall Cert. No.: 4644-13312-011322

Signature: 

Material Description	Material Code	Material Observed		Material Condition Status		Material Condition Description (If Change Noted)	Assessment Classification
				Same	Changed		
Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Tan Mineral Cap	M-APR-01	Y	N	✓			1 2 3 4 5 6 7*
Vapor Barrier Felt, Black, Asphaltic	M-VBF-02	Y	N	✓			1 2 3 4 5 6 7*
Concrete (Foundation), Gray, Cementitious	M-CON-03	Y	N	✓			1 2 3 4 5 6 7*

***Assessment Classifications**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

6-MONTH SURVEILLANCE INSPECTION TABLE
IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA
M-APR-01	M	Asphalt Prepared Roofing (Shingles), Black, Asphaltic, Tan Mineral Cap	Roof	Assumed	NF	G	100	SF
M-VBF-02	M	Vapor Barrier Felt, Black, Asphaltic	Roof	Assumed	NF	G	100	SF
M-CON-03	M	Concrete (Foundation), Gray, Cementitious	Storage 2	Assumed	NF	G	100	SF
			Exterior					

APR-01-VBF-02 Portion Missing