

November 2, 2021

Mr. Mike Williams  
Facilities Supervisor  
Kyrene School District No. 28  
8700 South Kyrene Road  
Tempe, AZ 85284-2197

**Subject: 3-Year Reinspection  
Asbestos-Containing Building Materials  
Kyrene de los Ninos Elementary School  
1330 East Dava Drive, Phoenix  
FM Project 21-343**

Dear Mr. Williams:

FM GROUP INC has completed the 3-Year Reinspection of Asbestos-Containing Building Materials (ACBM) at the subject school. The forms detailing the results of this reinspection and reassessment of known ACBM are attached.

The attached tables and forms have been updated to reflect the findings as of the date of this Reinspection and should serve as the Management Plan update.

**Items of significance are: None.**

If you have any questions regarding this correspondence, please contact us immediately.

Sincerely,

**FM GROUP INC**



Michael Hall  
Environmental Division Manager

Attachments: *3-Year Reinspection Tables*  
*3-Year Reinspection Forms*

G:\2021 Projects\10 ENVKSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Cvr Ltr.doc

### 3-YEAR REINSPECTION TABLE

#### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-VCT-07	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Supplies B15	Assumed	NF	G	4,000	SF	09/27/21
			Classroom B45						
			Storage B45B						
			Classroom B46						
			Classroom E1						
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						
			Vestibule E103						
			Vestibule E105						
			Work Room E110						
			Work Room E114						
			Classroom W1						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						
			Classroom W11						
			Work Room W105						
			Work Room W108						
M-MAS-08	M	Mastic, Yellow, Tacky	Supplies B15	Assumed	NF	G	4,000	SF	09/27/21

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Classroom B45						
			Storage B45B						
			Classroom B46						
			Classroom E1						
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						
			Vestibule E103						
			Vestibule E105						
			Work Room E110						
			Work Room E114						
			Classroom W1						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						
			Classroom W11						
			Work Room W105						
			Work Room W108						
M-WAB-09	M	Wallbase (Coved), 4", Blue, Vinyl-Like	Art Room N5	Assumed	NF	G	100	SF	09/27/21
			Classroom W1						
			Classroom W11						
M-ADH-10	M	Adhesive, Cream, Pliable	Art Room N5	Assumed	NF	G	100	SF	09/27/21
			Classroom W1						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Classroom W11						
M-SAC-11	M	Sink Acoustical Coating, White, Rough	Classroom E1	Assumed	NF	G	36	SF	09/27/21
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						
			Classroom W1						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						
			Classroom W11						
M-SLT-12	M	Sealant (Doors, Windows, Millwork), White, Pliable	Reception B01	Assumed	NF	G	250	SF	09/27/21
			Secretary B02						
			Lounge B04						
			Men's Restroom B05						
			Telephone B07						
			Work Room B08						
			Storage B09						
			Women's Restroom B10						
			Alcove B12						
			Principal B13						
			Room B13A						
			Student B14						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Supplies B15						
			Nurse B16						
			Toilet B18						
			Treatment B19						
			Psych. B21						
			Room B21A						
			Assistant Principal B22						
			Room B22A						
			Electrical Room B25						
			Conf/Clrm B27						
			Work Room B28						
			A.V. Storage B29						
			Break-Out B30						
			Media Center B35						
			Control B36						
			Computer B40						
			Resource 1 B41						
			Time Out Room B41A						
			Resource 2 B42						
			Resource 3 B43						
			Restroom B43A						
			Classroom B45						
			Restroom B45A						
			Storage B45B						
			Classroom B46						
			Storage B46A						
			Classroom E1						
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Janitor E101						
			Electrical Room E102						
			Vestibule E103						
			Boy's Restroom E104						
			Vestibule E105						
			Girl's Restroom E106						
			Work Room E110						
			Work Room E114						
			Classroom N1						
			Work Room N1A						
			Electrical Room N1B						
			Classroom N2						
			Classroom N3						
			Classroom N4						
			Art Room N5						
			Kiln Room N5A						
			Girl's Restroom N6						
			Electrical Room N7						
			Janitor N8						
			Boy's Restroom N9						
			Classroom W1						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						
			Classroom W11						
			Electrical Room W102						
			Work Room W105						
			Work Room W108						
			Restroom W113						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Restroom W114						
			Corridor B17						
			Corridor B24						
			Corridor B32						
			Corridor B33						
			Corridor B44						
M-SLT-13	M	Sealant (Millwork), Brown, Pliable	Classroom E1	Assumed	NF	G	25	SF	09/27/21
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						
			Classroom W1						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						
			Classroom W11						
M-FDI-14	M	Fire Door Insulation, Wood Cladding	Women's Restroom B10	Assumed	NF	G	672	SF	09/27/21
			Alcove B12						
			Student B14						
			Assistant Principal B22						
			Electrical Room B25						
			Conf/Clrm B27						
			Work Room B28						
			A.V. Storage B29						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Break-Out B30						
			Media Center B35						
			Control B36						
			Computer B40						
			Resource 1 B41						
			Resource 3 B43						
			Classroom B45						
			Classroom B46						
			Classroom E1						
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom N1						
			Work Room N1A						
			Classroom N2						
			Classroom N3						
			Classroom N4						
			Art Room N5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						
			Classroom W11						
			Corridor B24						
			Corridor B32						
			Corridor B33						
			Corridor B44						
M-FDI-15	M	Fire Door Insulation, Metal Cladding	Reception B01	Assumed	NF	G	756	SF	09/27/21
			Nurse B16						
			Classroom E1						
			Vestibule E103						
			Vestibule E105						
			Electrical Room N1B						



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Girl's Restroom N6						
			Electrical Room N7						
			Janitor N8						
			Boy's Restroom N9						
			Classroom W1						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W11						
			Electrical Room W102						
			Corridor B32						
			Corridor B33						
			Exterior						
M-GWT-19	M	Glazed Wall Tile, 4"X4", Tan, Smooth	Restroom W113	Assumed	NF	G	200	SF	09/27/21
			Restroom W114						
M-GRT-20	M	Grout, Gray, Cementitious	Restroom W113	Assumed	NF	G	20	SF	09/27/21
			Restroom W114						
M-CMT-21	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth, Peppered	Men's Restroom B05	Assumed	NF	G	900	SF	09/27/21
			Women's Restroom B10						
			Toilet B18						
			Restroom B43A						
			Restroom B45A						
			Boy's Restroom E104						
			Girl's Restroom E106						
			Girl's Restroom N6						
			Boy's Restroom N9						
			Restroom W113						
			Restroom W114						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-GRT-22	M	Grout, Gray, Cementitious	Men's Restroom B05	Assumed	NF	G	100	SF	09/27/21
			Women's Restroom B10						
			Toilet B18						
			Restroom B43A						
			Restroom B45A						
			Boy's Restroom E104						
			Girl's Restroom E106						
			Girl's Restroom N6						
			Boy's Restroom N9						
			Restroom W113						
			Restroom W114						
M-WAB-23	M	Wallbase (Coved), 4", Gray, Vinyl-Like	Storage B09	Assumed	NF	G	1,500	SF	09/27/21
			Supplies B15						
			Electrical Room B25						
			Work Room B28						
			A.V. Storage B29						
			Janitor E101						
			Electrical Room E102						
			Electrical Room N7						
M-ADH-24	M	Adhesive, Cream, Pliable	Storage B09	Assumed	NF	G	1,500	SF	09/27/21
			Supplies B15						
			Electrical Room B25						
			Work Room B28						
			A.V. Storage B29						
			Janitor E101						
			Electrical Room E102						
			Electrical Room N7						
M-TWP-25	M	Tackable Wall Panel, Brown, Fibrous, Tan, Vinyl Cover	Reception B01	Assumed	NF	G	800	SF	09/27/21
			Lounge B04						
			Telephone B07						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Work Room B08						
			Alcove B12						
			Principal B13						
			Psych. B21						
			Assistant Principal B22						
			Conf./Cirm B27						
			Media Center B35						
			Computer B40						
			Resource 1 B41						
			Resource 2 B42						
			Resource 3 B43						
			Classroom B45						
			Classroom B46						
			Classroom E1						
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						
			Classroom N1						
			Classroom N2						
			Classroom N3						
			Classroom N4						
			Art Room N5						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						
			Classroom W8						
			Classroom W9						
			Classroom W10						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-ADH-26	M	Adhesive, Brown, Brittle	Reception B01	Assumed	NF	G	800	SF	09/27/21
			Lounge B04						
			Telephone B07						
			Work Room B08						
			Alcove B12						
			Principal B13						
			Psych. B21						
			Assistant Principal B22						
			Conf./Clrm B27						
			Media Center B35						
			Computer B40						
			Resource 1 B41						
			Resource 2 B42						
			Resource 3 B43						
			Classroom B45						
			Classroom B46						
			Classroom E1						
			Classroom E2						
			Classroom E3						
			Classroom E4						
			Classroom E9						
			Classroom E10						
			Classroom E11						
			Classroom E12						
			Classroom N1						
			Classroom N2						
			Classroom N3						
			Classroom N4						
			Art Room N5						
			Classroom W2						
			Classroom W3						
			Classroom W4						
			Classroom W5						
			Classroom W7						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Classroom W8						
			Classroom W9						
			Classroom W10						
M-CMU-31	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious	Janitor E101	Assumed	NF	G	500	SF	09/27/21
			Electrical Room E102						
			Electrical Room N7						
			Janitor N8						
M-MRT-32	M	Mortar, Gray, Cementitious	Janitor E101	Assumed	NF	G	50	SF	09/27/21
			Electrical Room E102						
			Electrical Room N7						
			Janitor N8						
M-ADH-33	M	Adhesive (FRP), Brown, Brittle	Janitor E101	Assumed	NF	G	50	SF	09/27/21
M-GWT-34	M	Glazed Wall Tile, 4"X4", White, Smooth	Boy's Restroom E104	Assumed	NF	G	1,500	SF	09/27/21
			Girl's Restroom E106						
			Girl's Restroom N8						
			Electrical Room N7						
			Boy's Restroom N9						
M-GRT-35	M	Grout, Gray, Cementitious	Boy's Restroom E104	Assumed	NF	G	150	SF	09/27/21
			Girl's Restroom E106						
			Girl's Restroom N8						
			Electrical Room N7						
			Boy's Restroom N9						
M-SLT-36	M	Sealant (Windows), Black, Tar- Like	Principal B13	Assumed	NF	G	20	SF	09/27/21
			Student B14						
			Nurse B16						
			Psych. B21						
			Conf./Clrm B27						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Work Room B28						
			Break-Out B30						
			Media Center B35						
			Computer B40						
			Classroom N3						
			Classroom N4						
M-GWT-37	M	Glazed Wall Tile, 4"X4", Pink, Smooth	Men's Restroom B05	Assumed	NF	G	500	SF	09/27/21
			Women's Restroom B10						
			Toilet B16						
			Restroom B43A						
			Restroom B45A						
M-GRT-38	M	Grout, White, Cementitious	Men's Restroom B05	Assumed	NF	G	50	SF	09/27/21
			Women's Restroom B10						
			Toilet B16						
			Restroom B43A						
			Restroom B45A						
M-MRT-39	M	Mortar (Glass Block), White, Cementitious	Reception B01	Assumed	NF	G	100	SF	09/27/21
			Corridor B24						
			Corridor B32						
			Corridor B33						
			Exterior						
M-SAC-40	M	Sink Acoustical Coating, Gray, Rough	Lounge B04	Assumed	NF	G	30	SF	09/27/21
			Work Room B08						
			Conf./Cirm B27						
			Work Room B28						
			Computer B40						
			Resource 1 B41						
			Resource 2 B42						
			Classroom B45						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Classroom B46						
			Classroom N1						
			Classroom N2						
			Classroom N3						
			Classroom N4						
			Art Room N5						
M-SLT-41	M	Sealant (Fire Stop), Red, Pliable	Electrical Room B25	Assumed	NF	G	5	SF	09/27/21
S-PLA-47	S	Plaster, Gray, Cementitious	Corridor B24	Assumed	NF	G	4,000	SF	09/27/21
			Corridor B32						
			Corridor B33						
			Corridor B44						
M-PES-48	M	Pipe End Sealant, White, Pliable	Corridor B24	Assumed	NF	G	50	SF	09/27/21
			Corridor B32						
			Corridor B33						
M-BUR-49	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	3,500	SF	09/27/21
M-BUR-50	M	Built-Up Roofing, Black, Asphaltic, Metal Cap	Roof	Assumed	NF	G	40,000	SF	09/27/21
M-MAS-51	M	Mastic (Penetrations and Flashings), Black, Tar-Like	Roof	Assumed	NF	G	1,000	SF	09/27/21
M-PNT-52	M	Paint (Penetrations and Flashings), Silver, Pliable	Roof	Assumed	NF	G	1,000	SF	09/27/21
M-BUR-53	M	Built-Up Roofing, Black, Asphaltic, Silver Coating	Roof	Assumed	NF	G	500	SF	09/27/21
S-STU-54	S	Stucco, Gray, Cementitious	Exterior	Assumed	NF	G	10,000	SF	09/27/21
			Roof						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-SLT-55	M	Sealant (Parapet Walls, Flashings), White, Brittle	Roof	Assumed	NF	G	500	SF	09/27/21
M-PES-56	M	Pipe End Sealant, White, Brittle	Roof	Assumed	NF	G	50	SF	09/27/21
M-EXJ-61	M	Expansion Joint, Brown, Pliable	Exterior	Assumed	NF	G	500	SF	09/27/21
M-GAS-62	M	Gasket, 8", Black, Paper-Like	Janitor N8	Assumed	NF	G	2	SF	09/27/21
M-FDI-117	M	Fire Door Insulation, Metal/Wood Cladding	Exterior	Assumed	NF	G	126	SF	09/27/21
M-FDI-226	M	Fire Door Insulation, Metal/Wood Cladding	Classroom N10	Assumed	NF	G	651	SF	09/27/21
			Classroom N11						
			Classroom N12						
			Classroom N13						
			Storage W03						
			Electrical W04						
			Classroom W12						
			Vestibule W01						
			Classroom W13						
			Classroom W14						
			Vestibule W02						
			Classroom W15						
			Corridor B34						
			Electrical E107						
			Foyer						
			Restroom E108						
			Storage E109						
			Storage E110						
			Exterior						



### 3-YEAR REINSPECTION TABLE

#### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-TWP-05	M	Tackable Wall Panel, Brown, Fibrous, Vinyl Cover	Art Room E10	Assumed	NF	G	200	SF	09/27/21
M-ADH-06	M	Adhesive, Brown, Brittle	Art Room E10	Assumed	NF	G	200	SF	09/27/21
M-VCT-09	M	Vinyl Composition Tile, 12"X12", Pink, Smooth, White and Brown Mottles	Instruments Storage E08	Assumed	NF	G	700	SF	09/27/21
			Music E09						
			Art Room E10						
			Room E11A						
M-MAS-10	M	Mastic, Yellow, Tacky	Instruments Storage E08	Assumed	NF	G	700	SF	09/27/21
			Music E09						
			Art Room E10						
			Room E11A						
M-WAB-11	M	Wallbase (Coved), 4", Gray, Vinyl- Like	Wing E03	Assumed	NF	G	400	SF	09/27/21
			Storage E06						
			Storage E07						
			Instruments Storage E08						
			Instruments Storage E09A						
			Office E15						
			P.E. Storage E16						
			Electrical E25						
			Custodian E26						
			Corridor E02						
			Corridor E02A						
M-ADH-12	M	Adhesive, Cream, Pliable	Wing E03	Assumed	NF	G	400	SF	09/27/21
			Storage E06						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Storage E07						
			Instruments Storage E08						
			Instruments Storage E09A						
			Office E15						
			P.E. Storage E16						
			Electrical E25						
			Custodian E26						
			Corridor E02						
			Corridor E02A						
M-SLT-13	M	Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable	Living Room A02	Assumed	NF	G	100	SF	09/27/21
			Kitchen A03						
			Dining A04						
			Hall A05						
			Bedroom A07						
			Bathroom A09						
			Hall A10						
			Pantry A11						
			Closet A12						
			Bath A13						
			Bedroom A14						
			Multi-Purpose E01						
			Vestibule E01A						
			Wing E03						
			Boy's Restroom E04						
			Girl's Restroom E05						
			Storage E06						
			Storage E07						
			Instruments Storage E08						
			Music E09						
			Instruments Storage E09A						
			Art Room E10						
			Stage E11						
			Room E11A						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Room E11B						
			Storage E12						
			Office E15						
			P.E. Storage E16						
			Kitchen E18						
			Office E19						
			Water Heater Closet E19						
			Boy' Restroom E21						
			Girl's Restroom E22						
			Electrical E25						
			Custodian E26						
			Corridor E02						
			Corridor E02A						
M-FDI-15	M	Fire Door Insulation, Wood Cladding	Vestibule E01A	Assumed	NF	G	357	SF	09/27/21
			Wing E003						
			Stage E11						
			Room E11A						
			Room E11B						
			Office E15						
			P.E. Storage E16						
			Kitchen E18						
			Office E19						
			Storage E20						
			Boy's Restroom E21						
			Girl's Restroom E22						
			Custodian E26						
			Corridor E02A						
M-FDI-16	M	Fire Door Insulation, Metal Cladding	Multi-Purpose E01	Assumed	NF	G	525	SF	09/27/21
			Boy's Restroom E04						
			Girl's Restroom E05						
			Storage E06						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Storage E07						
			Music E09						
			Art Room E10						
			Kitchen E18						
			Kitchen Yard						
			Water Heater Closet E19						
			Electrical E25						
			Electrical E27						
			Cooling Tower Yard						
			Mechanical Plant						
			Electrical Yard						
			Corridor E02						
			Corridor E02A						
			Exterior						
M-MRT-17	M	Mortar (Glass Block), White, Cementitious	Living Room A02	Assumed	NF	G	100	SF	09/27/21
			Multi-Purpose E01						
			Music E09						
			Art Room E10						
			Corridor E02						
			Exterior						
M-VST-18	M	Vinyl Stair Tread, 12"X36", Brown, Vinyl-Like, Circle Pattern	Wing E03	Assumed	NF	G	50	SF	09/27/21
			Room E11A						
			Room E11B						
M-ADH-19	M	Adhesive, Yellow, Tacky	Wing E03	Assumed	NF	G	50	SF	09/27/21
			Room E11A						
			Room E11B						
M-VCT-20	M	Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles	Wing E03	Assumed	NF	G	2,600	SF	09/27/21
			Stage E11						
			Storage E12						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Office E15						
			P.E. Storage E16						
			Storage E20						
			Custodian E26						
			Corridor E02						
			Corridor E02A						
M-MAS-21	M	Mastic, Yellow, Tacky	Wing E03	Assumed	NF	G	2,600	SF	09/27/21
			Stage E11						
			Storage E12						
			Office E15						
			P.E. Storage E16						
			Storage E20						
			Custodian E26						
			Corridor E02						
			Corridor E02A						
M-ADH-23	M	Adhesive (ACT), Brown, Brittle	Stage E11	Assumed	NF	G	300	SF	09/27/21
			Corridor E02						
			Stage E11						
M-CMU-24	M	Concrete Masonry Unit, 8"X16", Gray, Cementitious	Multi-Purpose E01	Assumed	NF	G	5,000	SF	09/27/21
			Storage E06						
			Storage E07						
			Electrical E25						
			Custodian E26						
			Electrical E27						
			Cooling Tower Yard						
			Mechanical Plant						
M-PES-29	M	Pipe End Sealant, White, Pliable	Mechanical Plant	Assumed	NF	G	10	SF	09/27/21
M-GAS-30	M	Gasket, 6", Black, Vinyl Like	Cooling Tower Yard	Assumed	NF	G	8	SF	09/27/21
			Mechanical Plant						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-GAS-31	M	Gasket, 8", Black, Vinyl-Like	Cooling Tower Yard	Assumed	NF	G	2	SF	09/27/21
			Mechanical Plant						
M-SLT-33	M	Sealant (Doors, Expansion), Tan, Pliable	Electrical E27	Assumed	NF	G	50	SF	09/27/21
			Kitchen Yard						
			Cooling Tower Yard						
			Mechanical Plant						
			Electrical Yard						
			Exterior						
M-SLT-35	M	Sealant (Equipment), Black, Tar-Like	Cooling Tower Yard	Assumed	NF	G	10	SF	09/27/21
M-CMU-37	M	Concrete Masonry Unit, 8"X8", Gray, Cementitious	Electrical Yard	Assumed	NF	G	20	SF	09/27/21
			Roof						
M-GWT-38	M	Glazed Wall Tile, 4"X4", White, Smooth	Bathroom A09	Assumed	NF	G	2,500	SF	09/27/21
			Bath A13						
			Vestibule E01A						
			Boy's Restroom E04						
			Girl's Restroom E05						
			Boy's Restroom E21						
			Girl's Restroom E22						
			Custodian E26						
M-GRT-39	M	Grout, Gray, Cementitious	Bathroom A09	Assumed	NF	G	250	SF	09/27/21
			Bath A13						
			Vestibule E01A						
			Boy's Restroom E04						
			Girl's Restroom E05						
			Boy's Restroom E21						
			Girl's Restroom E22						

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
			Custodian E26						
M-SLT-40	M	Sealant (Mechanical), White, Pliable	Kitchen E18	Assumed	NF	G	10	SF	09/27/21
M-ADH-42	M	Adhesive (FRP), Brown, Brittle	Kitchen E18	Assumed	NF	G	700	SF	09/27/21
M-QPT-43	M	Quarry/Paver Tile, 6"X6", Tan, Smooth	Living Room A02	Assumed	NF	G	500	SF	09/27/21
M-GRT-44	M	Grout, Gray, Cementitious	Living Room A02	Assumed	NF	G	50	SF	09/27/21
M-CPT-45	M	Carpet, Brown, Fibrous	Living Room A02	Assumed	NF	G	300	SF	09/27/21
			Bedroom A07						
			Closet A08						
			Bedroom A14						
			Closet A15						
M-MAS-46	M	Mastic, Yellow, Tacky	Living Room A02	Assumed	NF	G	300	SF	09/27/21
			Bedroom A07						
			Closet A08						
			Bedroom A14						
			Closet A15						
M-GWT-50	M	Glazed Wall Tile, 2"X2", Brown, Smooth	Bathroom A09	Assumed	NF	G	5	SF	09/27/21
M-SAC-51	M	Sink Acoustical Coating, Gray, Rough	Kitchen A03	Assumed	NF	G	2	SF	09/27/21
M-VCT-52	M	Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles	Multi-Purpose E01	Assumed	NF	G	2,000	SF	09/27/21
M-VCT-53	M	Vinyl Composition Tile (Strip), 2"X24", Black, Smooth	Multi-Purpose E01	Assumed	NF	G	50	SF	09/27/21
M-VCT-54	M	Vinyl Composition Tile (Strip), 2"X24", Red, Smooth	Multi-Purpose E01	Assumed	NF	G	50	SF	09/27/21

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-VCT-55	M	Vinyl Composition Tile (Strip), 2"X24", Blue, Smooth	Multi-Purpose E01	Assumed	NF	G	50	SF	09/27/21
M-VCT-56	M	Vinyl Composition Tile (Strip), 2"X24", Green, Smooth	Multi-Purpose E01	Assumed	NF	G	50	SF	09/27/21
M-VCT-57	M	Vinyl Composition Tile (Strip), 2"X24", Yellow, Smooth	Multi-Purpose E01	Assumed	NF	G	50	SF	09/27/21
M-VCT-58	M	Vinyl Composition Tile, 24"X24", Red, Vinyl-Like, Circle Pattern	Vestibule E01A	Assumed	NF	G	50	SF	09/27/21
M-MAS-59	M	Mastic, Yellow, Tacky	Multi-Purpose E01 Vestibule E01A	Assumed	NF	G	2,300	SF	09/27/21
M-WAB-60	M	Wallbase (Coved), 4", Blue, Vinyl- Like	Multi-Purpose E01	Assumed	NF	G	100	SF	09/27/21
M-ADH-61	M	Adhesive, Cream, Pliable	Multi-Purpose E01	Assumed	NF	G	100	SF	09/27/21
M-CMT-62	M	Ceramic Mosaic Tile, 2"X2", Tan, Smooth, Peppered	Boy's Restroom E04 Girl's Restroom E05 Boy's Restroom E21 Girl's Restroom E22	Assumed	NF	G	700	SF	09/27/21
M-GRT-63	M	Grout, Gray, Cementitious	Boy's Restroom E04 Girl's Restroom E05 Boy's Restroom E21 Girl's Restroom E22	Assumed	NF	G	70	SF	09/27/21
M-BUR-64	M	Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap	Roof	Assumed	NF	G	17,000	SF	09/27/21
M-MAS-65	M	Mastic (Penetrations And Flashings), Black, Tar-Like	Roof	Assumed	NF	G	750	SF	09/27/21



MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-SLT-66	M	Sealant (Flashings), White, Pliable	Roof	Assumed	NF	G	50	SF	09/27/21
M-PNT-67	M	Paint (Penetrations And Flashings), White, Pliable	Roof	Assumed	NF	G	750	SF	09/27/21
M-PNT-68	M	Paint (Penetrations And Flashings), Silver, Pliable	Roof	Assumed	NF	G	750	SF	09/27/21
M-CON-70	M	Concrete, Gray, Cementitious	Cooling Tower Yard	Assumed	NF	G	1,000	SF	09/27/21
			Mechanical Plant						
			Electrical Yard						
M-WAB-71	M	Wallbase (Straight), 12", Brown, Vinyl-Like	Wing E03	Assumed	NF	G	12	SF	09/27/21
			Room E11A						
			Room E11B						
M-FDI-114	M	Fire Door Insulation, Metal/Wood Cladding	Exterior	Assumed	NF	G	105	SF	09/27/21

### 3-YEAR REINSPECTION TABLE

#### IN-PLACE ASBESTOS-CONTAINING MATERIALS

MATERIAL SAMPLE CODE	MTL TYPE	MATERIAL DESCRIPTION	MATERIAL LOCATION	ANALYTICAL RESULTS	FRIABILITY	MATERIAL ASSESS. CLASS	MTL QUAN	UNITS	DATE LAST INSPECTED
	M/S/T			%/ASSUMED	NF/F	G/D/SD		LF/SF/EA	
M-FDI-126	M	Fire Door Insulation, Metal/Wood Cladding	Classroom 1	Assumed	NF	G	105	SF	01/03/19
			Electrical Room 1						
			Electrical Room 2						
			Fire Riser						
			Classroom 2						
			Shop						
			Exterior						

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Winos\FRC-Tbl.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4376125112316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-07, Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find       

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain:       

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain:       

**Assessment:**

Evidence of Physical Damage:        Yes / No  
Evidence of Water Damage:        Yes / No  
Evidence of Delamination or Other Damage:        Yes / No  
Explain:       

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection?        Yes / No  
Explain:       

Degree of Accessibility of the Material: High ✓ Medium        Low         
Degree of Activity Near the Material: High ✓ Medium        Low         
Location in an Air Plenum, Air Shaft, or Airstream:        Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed?        Yes / No  
Explain:       

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\07.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hill  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 13C1251234 Signature of Inspector: Corbyn Hill

\*Material Reinspected: M-MAS-08, Mastic, Yellow, Tacky

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI (3) Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\08.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 430151216 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-WAB-09, Wallbase (Coved), 4", Blue, Vinyl-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③. Misc.

**Material Status:** 1. In-Place / 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High / Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High / Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\09.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/07/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

ASHERA certification number: 438105113169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-10, Adhesive, Cream, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

#### Assessment:

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

#### Assessment Classification:

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\10.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43812511314 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SAC-11, Sink Acoustical Coating, White, Rough

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③. Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ☒ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ☒ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

*\*Reference the original Management Plan for additional information.*

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\11.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 430000123164 Signature of Inspector: Carbyn Hall

\*Material Reinspected: M-SLT-12, Sealant (Doors, Windows, Millwork), White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\12.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hill  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4301291234 Signature of Inspector: Corbyn Hill

\*Material Reinspected: M-SLT-13, Sealant (Millwork), Brown, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ☒ Low \_\_\_\_\_

Degree of Activity Near the Material: High ☒ Medium \_\_\_\_\_ Low \_\_\_\_\_

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\13.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/11 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4301250123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-FDI-14, Fire Door Insulation, Wood Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

*\*Reference the original Management Plan for additional information.*

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\14.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carlyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 13012511236 Signature of Inspector: Carlyn Hall

\*Material Reinspected: M-FDI-15, Fire Door Insulation, Metal Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\15.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Coryn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 430125012316 Signature of Inspector: Coryn Hall

\*Material Reinspected: M-GWT-19, Glazed Wall Tile, 4"X4", Tan, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐  
Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\19.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4561356123456 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GRT-20, Grout, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI (3) Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\20.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 438212510516 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-CMT-21, Ceramic Mosaic Tile, 2"X2", Tan, Smooth, Peppered

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI (3) Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ☒ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENVKSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\21.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43501250123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GRT-22, Grout, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\22.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4370 12501 123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-WAB-23, Wallbase (Coved), 4", Gray, Vinyl-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③. Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐  
Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\23.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43001255112346 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-24, Adhesive, Cream, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③. Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☒ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ☒ Medium ☒ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\24.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43101250112314 Signature of Inspector: Carbyn Hall

\*Material Reinspected: M-TWP-25, Tackable Wall Panel, Brown, Fibrous, Tan, Vinyl Cover

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\25.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Coryn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4380 12541234 Signature of Inspector: Coryn Hall

\*Material Reinspected: M-ADH-26, Adhesive, Brown, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\26.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 430120112269 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-CMU-31, Concrete Masonry Unit, 8"X16", Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\31.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main  
AHERA certification number: 4380254123165 Signature of Inspector: Corbyn Hall  
\*Material Reinspected: M-MRT-32, Mortar, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\32.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hank  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4382 12501 125064 Signature of Inspector: Corbyn Hank

\*Material Reinspected: M-ADH-33, Adhesive (FRP), Brown, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\33.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 438012501236 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GWT-34, Glazed Wall Tile, 4"X4", White, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_

Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENVKSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\34.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 438012501123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GRT-35, Grout, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\35.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801250112316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-36, Sealant (Windows), Black, Tar-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\36.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 438012512345 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GWT-37, Glazed Wall Tile, 4"X4", Pink, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\37.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4326126012316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GRT-38, Grout, White, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\38.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801250123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-MRT-39, Mortar (Glass Block), White, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENVKSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\39.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801258123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SAC-40, Sink Acoustical Coating, Gray, Rough

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

*\*Reference the original Management Plan for additional information.*

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\40.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4380 1250 123469 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-41, Sealant (Fire Stop), Red, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\41.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 438612571 128169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: S-PLA-47, Plaster, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\47.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4380128123169 Signature of Inspector: Carbyn Hall

\*Material Reinspected: M-PES-48, Pipe End Sealant, White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\48.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801250123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-BUR-49, Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\49.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801250123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-BUR-50, Built-Up Roofing, Black, Asphaltic, Metal Cap

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\50.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 436126012344 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-MAS-51, Mastic (Penetrations and Flashings), Black, Tar-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\51.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4380 MS128169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-PNT-52, Paint (Penetrations and Flashings), Silver, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\52.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801250412316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-BUR-53, Built-Up Roofing, Black, Asphaltic, Silver Coating

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\53.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Cerbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4320 125212369 Signature of Inspector: Cerbyn Hall

\*Material Reinspected: S-STU-54, Stucco, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\54.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4380120012305 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-55, Sealant (Parapet Walls, Flashings), White, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Winos\Forms\Main\55.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 4380 12561 129465 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-PES-56, Pipe End Sealant, White, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\56.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 938512011236 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-EXJ-61, Expansion Joint, Brown, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\61.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 43801252123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GAS-62, Gasket, 8", Black, Paper-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\62.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

AHERA certification number: 13001250113161 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-FDI-117, Fire Door Insulation, Metal/Wood Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\117.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Main

ASHERA certification number: 438-1231123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-FDI-226, Fire Door Insulation, Metal/Wood Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Main\226.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380128112869 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-TWP-05, Tackable Wall Panel, Brown, Fibrous, Vinyl Cover

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\05.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380 1201 123161 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-06, Adhesive, Brown, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

#### Assessment:

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

#### Assessment Classification:

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\06.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Coryn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43701254123164 Signature of Inspector: Coryn Hall

\*Material Reinspected: M-VCT-09, Vinyl Composition Tile, 12"X12", Pink, Smooth, White and Brown Mottles

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\09.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4360125012569 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-MAS-10, Mastic, Yellow, Tacky

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\10.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4370 1204/2316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-WAB-11, Wallbase (Coved), 4", Gray, Vinyl-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\11.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43801261128164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-12, Adhesive, Cream, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\12.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380 12501 122164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-13, Sealant (Doors, Windows, Millwork, Fixtures), White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\13.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380 1254 123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-FDI-15, Fire Door Insulation, Wood Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_

Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\15.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 438012501120064 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-FDI-16, Fire Door Insulation, Metal Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\16.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4310 1264 123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-MRT-17, Mortar (Glass Block), White, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\17.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43801251123469 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VST-18, Vinyl Stair Tread, 12"X36", Brown, Vinyl-Like, Circle Pattern

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\18.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43801251123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-19, Adhesive, Yellow, Tacky

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\19.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 430120112316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-20, Vinyl Composition Tile, 12"X12", Tan, Smooth, Brown Mottles

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Mult\20.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4310 DSI 12264 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-MAS-21, Mastic, Yellow, Tacky

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\21.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Coryn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 436 DSD 2501 Signature of Inspector: Coryn Hall

\*Material Reinspected: M-ADH-23, Adhesive (ACT), Brown, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\23.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4390 12501 123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-CMU-24, Concrete Masonry Unit, 8"X16", Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\24.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hull  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose  
AHERA certification number: 4380 12501 123164 Signature of Inspector: Corbyn Hull  
\*Material Reinspected: M-PES-29, Pipe End Sealant, White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\29.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4370125d 123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GAS-30, Gasket, 6", Black, Vinyl Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\30.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4350 D02 123167 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GAS-31, Gasket, 8", Black, Vinyl Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\31.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 452125103169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-33, Sealant (Doors, Expansion), Tan, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\33.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380 12501 123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-CMU-37, Concrete Masonry Unit, 8"X8", Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\37.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose  
AHERA certification number: 4370 12501 12316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GWT-38, Glazed Wall Tile, 4"X4", White, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Winos\Forms\Multi\38.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380 12501 12312 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GRT-39, Grout, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\39.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380120012300 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-40, Sealant (Mechanical), White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\40.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 438012001123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-42, Adhesive (FRP), Brown, Brittle

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\42.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Cecryn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4301201125161 Signature of Inspector: Cecryn Hall

\*Material Reinspected: M-QPT-43, Quarry/Paver Tile, 6"X6", Tan, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐  
Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi43.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380122112369 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-GRT-44, Grout, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\44.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corsyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4301250112316 Signature of Inspector: Corsyn Hall

\*Material Reinspected: M-CPT-45, Carpet, Brown, Fibrous

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐

Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\45.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hull  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4386125212314 Signature of Inspector: Corbyn Hull

\*Material Reinspected: M-MAS-46, Mastic, Yellow, Tacky

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\46.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose  
AHERA certification number: 9300 D3501 D3501 Signature of Inspector: Carbyn Hall  
\*Material Reinspected: M-GWT-50, Glazed Wall Tile, 2"X2", Brown, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\50.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 138012501123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SAC-51, Sink Acoustical Coating, Gray, Rough

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☒ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ☒ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\51.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4300125012016 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-52, Vinyl Composition Tile, 12"X12", White, Smooth, Gray Mottles

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③. Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐  
Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\52.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 438012501123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-53, Vinyl Composition Tile (Strip), 2"X24", Black, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\53.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Cosby Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4300001630 Signature of Inspector: Cosby Hall

\*Material Reinspected: M-VCT-54, Vinyl Composition Tile (Strip), 2"X24", Red, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\54.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 437042112316 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-55, Vinyl Composition Tile (Strip), 2"X24", Blue, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐  
Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi55.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 458012501286 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-56, Vinyl Composition Tile (Strip), 2"X24", Green, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\56.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose  
AHERA certification number: 4300 1251 123121 Signature of Inspector: Corbyn Hall  
\*Material Reinspected: M-VCT-57, Vinyl Composition Tile (Strip), 2"X24", Yellow, Smooth

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3 Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\57.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4580125012364 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-VCT-58, Vinyl Composition Tile, 24"X24", Red, Vinyl-Like, Circle Pattern

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI (3) Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\58.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Coryn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4350 12501 125154 Signature of Inspector: Coryn Hall

\*Material Reinspected: M-MAS-59, Mastic, Yellow, Tacky

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ☒ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ☒ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\59.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hull  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4300 12001 123169 Signature of Inspector: Corbyn Hull

\*Material Reinspected: M-WAB-60, Wallbase (Coved), 4", Blue, Vinyl-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\60.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4380 1221 12304 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-ADH-61, Adhesive, Cream, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\61.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carlyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4370125012364 Signature of Inspector: Carlyn Hall

\*Material Reinspected: M-CMT-62, Ceramic Mosaic Tile, 2"X2", Tan, Smooth, Peppered

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\62.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 438012501123169 Signature of Inspector: Carbyn Hall

\*Material Reinspected: M-GRT-63, Grout, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_

Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\63.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43701250128104 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-BUR-64, Built-Up Roofing, Black, Asphaltic, Gray Mineral Cap

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI (3) Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\64.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose  
AHERA certification number: 4380 1251123164 Signature of Inspector: Corbyn Hall  
\*Material Reinspected: M-MAS-65, Mastic (Penetrations and Flashings), Black, Tar-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\65.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43801250112304 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-SLT-66, Sealant (Flashings), White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\66.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Carbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4386125012314 Signature of Inspector: Carbyn Hall

\*Material Reinspected: M-PNT-67, Paint (Penetrations and Flashings), White, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒

Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ☒

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\67.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/17/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43801250122164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-PNT-68, Paint (Penetrations and Flashings), Silver, Pliable

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No

Evidence of Water Damage: \_\_\_\_\_ Yes / No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Degree of Activity Near the Material: High \_\_\_\_\_ Medium \_\_\_\_\_ Low ✓

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENVKSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\68.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall  
Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 43801250123164 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-CON-70, Concrete, Gray, Cementitious

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐  
Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi70.doc





15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 4350 1252 123169 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-WAB-71, Wallbase (Straight), 12", Brown, Vinyl-Like

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI ③ Misc.

**Material Status:** 1. In-Place ☒ 2. Did Not Find ☐

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / ☒ No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Water Damage: \_\_\_\_\_ Yes / ☒ No

Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ☒ Medium ☐ Low ☐

Degree of Activity Near the Material: High ☒ Medium ☐ Low ☐

Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / ☒ No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / ☒ No

Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\71.doc



15974 North 77<sup>th</sup> Street, Suite 100  
Scottsdale, AZ 85260

### 3 YEAR REINSPECTION OF ASBESTOS-CONTAINING BUILDING MATERIALS

Reinspection Date: 9/27/21 Person performing reinspection: Corbyn Hall

Facility: Kyrene de los Ninos Elementary School Building Name/Number: Multi-Purpose

AHERA certification number: 438012501123166 Signature of Inspector: Corbyn Hall

\*Material Reinspected: M-FDI-114, Fire Door Insulation, Metal/Wood Cladding

**Type of Asbestos-Containing Material:** 1. Surf. 2. TSI 3. Misc.

**Material Status:** 1. In-Place ✓ 2. Did Not Find \_\_\_\_\_

**Material Condition:** Has the condition of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Material Friability:** Has the friability of this material changed since the last inspection? Yes / No  
Explain: \_\_\_\_\_

**Assessment:**

Evidence of Physical Damage: \_\_\_\_\_ Yes / No  
Evidence of Water Damage: \_\_\_\_\_ Yes / No  
Evidence of Delamination or Other Damage: \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

**Potential for Disturbance:** Has the potential for disturbance of this material changed since the last inspection? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

Degree of Accessibility of the Material: High ✓ Medium ✓ Low \_\_\_\_\_  
Degree of Activity Near the Material: High ✓ Medium \_\_\_\_\_ Low \_\_\_\_\_  
Location in an Air Plenum, Air Shaft, or Airstream: \_\_\_\_\_ Yes / No

**Assessment Classification:**

1. Damaged or significantly damaged thermal system insulation ACBM.
2. Damaged friable surfacing ACBM.
3. Significantly damaged friable surfacing ACBM.
4. Damaged or significantly damaged friable miscellaneous ACBM.
5. ACBM with potential for damage.
6. ACBM with potential for significant damage.
7. Any remaining friable ACBM or friable suspected ACBM.

**Recommended Action:** As a result of this reinspection, has the recommended response action for this material changed? \_\_\_\_\_ Yes / No  
Explain: \_\_\_\_\_

\*Reference the original Management Plan for additional information.

G:\2021 Projects\10 ENV\KSD\21-343 3-Year Reinspection\2.0\2.3\2.3.1\Ninos\Forms\Multi\114.doc