



NOTES:
ALL DUCTWORK FROM NEW UNITS ARE TO BE 1" ACOUSTICALLY LINED 15'-0" FROM DISCHARGE OF UNIT.
SIZES SHOWN OR STATED ARE INSIDE DIAMETER CLEAR.

Project Title:
HVAC ROOFTOP UNIT REPLACEMENT:
REGIONAL SCHOOL DISTRICT 10
LEWIS S. MILLS HAR-BUR COMPLEX
24/26 LYON ROAD
BURLINGTON, CONNECTICUT 06013

S+PA
SILVER PETRUCELLI + ASSOCIATES
3190 WHITNEY AVENUE HAMDEN CT 06518
311 STATE STREET NEW LONDON CT 06320
203 230 9007 silverpetrucelli.com

Revision	Description	Date	Revised By

Drawing Title:
MECHANICAL ROOFTOP PLAN-
NEW

Date:
February 1, 2024
Scale:
1/8" = 1'-0"
Drawn By:
Project Number:
23.138

M101