

Addendum 3

Project Stadium New Press Box – Marlin ISD
Issued February 1st, 2024 by CEI Engineering Associates, Inc.
Proposal Opening February 6th, 2024 at 2:00 PM

The following additions and changes are to be made to the Contract Documents; and hereby become part of the Contract.

Item 1 – Press Box Electrical Scope Clarification

1. Sheet E6.01 – Electrical Site Plan has had its notes revised to clearly indicate the scope of this project.


Changes include clarification regarding what portions of the work at the stadium are to be included as part of this proposal and which are to be performed by others.

2. For clarification purposes, the scope of this project does not include any work in the parking lot area show on the stadium site plan. That work will be preformed by others. Also, the new scoreboard will be provided and installed by others.

END OF ADDENDUM

This addendum that consists of one (1) addenda sheet and one (1) drawing sheet which shall be included as part of the proposal documents.

This addenda and Addendum No1 & Addendum No.2 must be acknowledged on the Proposal Form



Jeffery J. Bresee
06/01/24

ARCHITECT

HKS, INC.
350 N SAINT PAUL ST
SUITE 100
DALLAS, TX 75201

CIVIL ENGINEER

CEI ENGINEERING ASSOCIATES, INC.
3030 LBJ FREEWAY
SUITE 100
DALLAS, TX 75234

LANDSCAPE

CEI ENGINEERING ASSOCIATES, INC.
3030 LBJ FREEWAY
SUITE 100
DALLAS, TX 75234

STRUCTURAL

HKS, INC.
350 N SAINT PAUL ST
SUITE 100
DALLAS, TX 75201

MEP

ROMINE, ROMINE & BURGESS, INC.
300 GREENLEAF ST
FORT WORTH, TX 76107



MARLIN ISD PRESS BOX
678 SUCCESS DR B
MARLIN, TX 76661

OWNER

MARLIN ISD
678 SUCCESS DR B
MARLIN, TX 76661

Romine, Romine, & Burgess
Mechanical/Electrical Engineers

300 Greenleaf
St. Worth,
Texas 76107
817.336.4633
Registration #E-509
WWW.ROMINEINC.COM
RRB@ROMINEINC.COM
JOB# 2812



Lance Morrow
11/16/2023

REVISION	NO.	DESCRIPTION	DATE
1	ADDENDUM 2	01/31/24	
2	ADDENDUM 3	02/01/24	

HKS PROJECT NUMBER

26095.000

DATE

11/16/23

ISSUE

ISSUE FOR BID AND

PERMIT

ELECTRICAL_SITE_PLAN

NEW_WORK

SHEET NO.


E6.01

NOTES BY SYMBOL:

- NOT USED.
- NOT USED.
- IN-GRADE TELECOMMUNICATIONS PULL BOX TO BE INSTALLED IN PHASE 1 ELECTRICAL SITE DRAWINGS. NOT IN THIS CONTRACT. SHOWN FOR REFERENCE ONLY.
- NOT USED.
- ELECTRICAL EQUIPMENT ON PIPE RACK, INCLUDING PANELBOARDS "DH" AND "DL" TO BE INSTALLED IN PHASE 1 ELECTRICAL SITE DRAWINGS. NOT IN THIS CONTRACT. SHOWN FOR REFERENCE ONLY.
- NOT USED.
- RUN NEW FEEDER FROM PANEL "DH" TO PANEL "HP" IN NEW PRESS BOX BUILDING. REFER TO SH. E1.01 FOR REQUIREMENTS.
- RUN NEW FEEDERS FROM PANEL "DL" TO PANELS "LP" AND "LM" IN NEW PRESS BOX BUILDING. REFER TO SH. E1.01 FOR REQUIREMENTS.
- NOT USED.
- NOT USED.
- PROVIDE (2) 2" UNDERGROUND CONDUITS WITH PULLCORD WITH MIN. 2" COVER, ONE FOR FUTURE FIBER TO SCOREBOARD AND ONE FOR FUTURE TECHNOLOGY, FROM PULL BOX TO PRESS BOX BUILDING. REFER TO SH. E3.01 FOR POINT OF TERMINATION IN PRESS BOX BUILDING.
- NOT USED.
- NOT USED.
- NOT USED.
- EXISTING CONDUIT FROM FIELD HOUSE INSTALLED BY SPORTS TURF CONTRACTOR IN PHASE 1 FIELD TURF IMPROVEMENTS PACKAGE. VERIFY EXACT LOCATION AT SITE. NOT IN THIS CONTRACT. SHOWN FOR REFERENCE ONLY.

GENERAL NOTES:

- A. UNDERGROUND CONDUITS SHALL BE BURIED WITH MINIMUM 24" COVER. REFER TO SPECIFICATIONS FOR SPECIFIC INSTALLATION REQUIREMENTS.
- B. VERIFY LOCATION OF ALL UNDERGROUND UTILITIES IN CONSTRUCTION AREA PRIOR TO BORING OR DIGGING.
- C. SAWCUT AND REPAIR SIDEWALKS AND PAVED AREAS AS/IF REQUIRED TO ACCOMMODATE UNDERGROUND CONDUIT INSTALLATION. FIELD VERIFY EXISTING CONDITIONS PRIOR TO BID TO DETERMINE MOST FEASIBLE ROUTING OF ALL ELECTRICAL FEEDERS AND COMPLETE SCOPE OF WORK.
- D. TWO OR MORE CIRCUITS MAY BE COMBINED IN ONE CONDUIT AT DISCRETION OF CONTRACTOR AS LONG AS INDICATED CONDUIT SIZE IS INCREASED PER NEC REQUIREMENTS.
- E. REFER TO ELECTRICAL SPECIFICATIONS FOR IN-GRADE JUNCTION BOX REQUIREMENTS. PROVIDE BOXES WHERE REQUIRED TO FACILITATE LONG WIRE PULLS.



NOTE: UNDERGROUND CONDUITS ON SITE SHALL BE MIN. 24" DEPTH TO TOP OF CONDUIT.

STATE HIGHWAY 7

FM 2958

NEW PRESS BOX BUILDING

MARLIN

BULLDOGS