



November 18, 2023

Dare County Schools  
Ian Adams  
3020 S. Wrightsville Avenue  
Nags Head, NC

**Re: Limited Indoor Air Quality Sampling with Airborne Fungal Sampling at the Bus Garage and the Maintenance Shop at 1015 Driftwood Drive, Manteo, NC  
LRC Project – 23-2212**

At your request, on November 9, 2023, LRC Indoor Testing & Research, Inc. (LRC) performed a limited environmental fungal Indoor Air Quality (IAQ) sampling that included airborne fungal sampling at the property listed above.

LRC performs all water-damage and fungal investigations with sampling and recommendations in accordance with guidelines published in *Bioaerosols: Assessment and Control*, by the American Conference of Governmental Industrial Hygienists (ACGIH), in *Mold Remediation in Schools and Commercial Buildings* by the United States Environmental Protection Agency (USEPA), and in the currently recognized and accepted industry standards including the ANSI/IICRC S500 *Standard and Reference Guide for Professional Water Damage Restoration*, Fourth Edition (S500) and the ANSI/IICRC S520 *Standard and Reference Guide for Professional Mold Remediation*, Third Edition (S520).

Our inspection included the following:

1. Measure temperature and relative humidity indoors and outdoors.
2. Collect representative non-viable spore trap air samples indoors and one outdoors for comparison.
3. Collect representative Particle Counts, Carbon Dioxide and Carbon Monoxide counts at locations where air samples are collected.
4. Provide a written report describing the survey results and comparing those results to accepted guidelines and directives. This report includes a summary of data and Certificates of Laboratory Analysis.

**BACKGROUND**

This inspection was limited to non-viable spore trap air samples, particle counts, CO and CO<sup>2</sup> measurements that were collected from locations selected at random throughout the building. Descriptions in this report are based on looking at the structure from the street front. Moisture measurements and visual inspections were not conducted on this day.

## SAMPLING METHODOLOGY

### Air Samples:

Currently there are no regulations regarding acceptable airborne fungal levels. Airborne fungal spores are ubiquitous in the outdoor and indoor environment. The guidelines followed in this report for the assessment and/or remediation of airborne and surface fungi are published in *Bioaerosols: Assessment and Control*, by the American Conference of Governmental Industrial Hygienists (ACGIH), in *Mold Remediation in Schools and Commercial Buildings* by the United States Environmental Protection Agency (USEPA), in *Recognition, Evaluation, and Control of Indoor Mold* by the American Industrial Hygiene Association (AIHA), and in the ANSI/IICRC S520 *Standard and Reference Guide for Professional Mold Remediation*, Third Edition (S520). Airborne fungal assessments are performed by comparing results from volumetric samples taken indoors to samples taken outdoors. Airborne fungi levels in non-problem indoor environments generally are less than or approximately the same as that outdoors and also show a similar composition and/or taxonomic predominance. Problems are usually implicated in the indoor air when one or more fungal genera or species are present in a much greater concentration indoors compared to outdoors. Sampling results are shown in the Certificates of Laboratory Analysis attached to this report. Results are discussed below.

### Temperature and Relative Humidity

Temperature and relative humidity readings were recorded by the Lighthouse Handheld 3016 Particle Counter. ASHRAE Standard 55 for thermal comfort suggested that the indoor temperature should be between 73°F to 79°F in the summer and 68°F to 75°F in the winter and that the indoor relative humidity should be between 20% to 65%.

The temperature and relative humidity are summarized in Table A below. The relative humidity met the current ASHRAE Standard to maintain indoor relative humidity below 65%.

## SAMPLING RESULTS

### Total Non-Viable Spore Air Sample Results:

Representative samples were taken for total airborne fungal spores with a calibrated Buck spore trap. Total airborne fungal spore sample volumes were 75-liters. The outdoor total fungal spore level (Sample 6) was measured at 6187 Spores/m<sup>3</sup> and was comprised of *Cladosporium* (44%), *Curvularia* (12%), *Penicillium/Aspergillus* group (9%), Smuts (8%), Ascospores (7%), Basidiospores (5%) and 3% or less of various other fungal spores. The air sample results are summarized below in Table A.

**Table A – Air Sampling Results**

Sample #	Location	Total Airborne Spore Count (Spores/m <sup>3</sup> )	*Non-Fungal Background Particulate Level	Temperature °F	Relative Humidity %
01	Maintenance-Front office	1067	Moderate-heavy	78	57
02	Maintenance-Rear Break Room	533	Moderate	77	42
03	Bus Garage-Shop office	640	Moderate-heavy	77	34
04	Bus Garage-Parts	627	Moderate-heavy	75	39
05	Bus Garage-2 <sup>nd</sup> Floor office	787	Moderate	74	45
06	Outdoor Air	6187	Moderate	77	45

\*The Background Particulate Level refers to non-fungal debris seen in the air sample; such as skin cells, hair, fibers, dust, dirt, etc.

The total fungal spore counts in the areas sampled indoors were lower than that found in the outdoor air. The types of fungal spores found in the indoor air samples were all common outdoor-type fungi present in low concentrations with no spikes in water loss fungi. Therefore, the results suggested a normal indoor fungal ecology in the areas sampled. All of the tested areas are frequently open to the outdoors, therefore, the samples contained somewhat higher spore counts and more closely mirrored the outdoor air.

The particulate in the indoor air samples was in the moderate to moderate-heavy range. The particulate that we see in the microscope at the magnification used is usually called ‘course particulate’ and consist of many things and can include the following: dirt, dust, mold, pollen, fiber, hair, skin cells, dust mites and other insects. Fine particulates (to include VOC’s – volatile organic compounds) are not seen with the magnification used for these samples.

Particle Count

A Lighthouse Handheld 3016 Particle Counter was used to measure the levels of airborne particulates. Airborne particles are solids suspended in the air. In a commercial setting, particle levels should be significantly less than outside readings due to better filtration and better dilution with outside air.

Particle Count:

Table B below summarizes the minimum, maximum, and average particle count in the building in each size category during the sampling period. Each time one liter of air was drawn into the Particle Counter, the Particle Counter calculated all particles that are greater than or equal to the particle size indicated in the size categories.

**Table B – Indoor Particle Count Sampling Results Bus Garage**

	<b>0.3 micron</b>	<b>0.5 micron</b>	<b>1.0 micron</b>	<b>2.5 micron</b>	<b>5.0 micron</b>	<b>10.0 micron</b>
Minimum	37204	1813	715	471	191	30
Maximum	39844	3228	1954	1267	428	70
Average	38574	2294	1161	762	277	45

**Table B – Indoor Particle Count Sampling Results Maintenance Office**

	<b>0.3 micron</b>	<b>0.5 micron</b>	<b>1.0 micron</b>	<b>2.5 micron</b>	<b>5.0 micron</b>	<b>10.0 micron</b>
Minimum	48323	1587	311	147	52	12
Maximum	59275	2672	681	289	59	9
Average	53799	2130	496	218	56	11

Table C below summarizes the average particle count in the outdoor air at the time of sampling. Each time one liter of air was drawn into the Particle Counter, and the Particle Counter calculated all particles that are greater than or equal to the particle size indicated in the size categories. In addition, temperature and relative humidity information were included.

**Table C – Outdoor Particle Count Sampling Results**

	<b>0.3 micron</b>	<b>0.5 micron</b>	<b>1.0 micron</b>	<b>2.5 micron</b>	<b>5.0 micron</b>	<b>10.0 micron</b>
Outdoor Air Average	59270	2954	751	336	80	23

#### Carbon Monoxide and Carbon Dioxide

A TSI IAQ-Calc Indoor Air Quality Meter (Model 7545) was used to measure the concentrations of CO and CO<sub>2</sub>. CO is a dangerous gas caused by incomplete combustion. The level of CO in an indoor environment should be low (none detected to 4 parts per million [ppm] depending on fuel sources used indoors) or same as outdoors. CO<sub>2</sub> is commonly used as an indicator of ventilation adequacy. American Society of Heating, Refrigeration, and Air Conditioning Engineers (ASHRAE) Standard 62.1 stated that the indoor concentration of CO<sub>2</sub> should be less than 700 ppm over the outdoor ambient air, which typically is around 400 ppm.

The average CO concentration indoors was similar to the CO concentration outdoors. In addition, the indoor CO concentrations were measured at low ppm in all locations. Therefore, the results suggested that the indoor CO concentrations were within normal ranges. Therefore, the results suggested that the ventilation in the areas sampled was adequate. Individual test results are available upon request.

## CONCLUSIONS

Results as reported by LRC apply only to the day of this inspection. LRC cannot and does not warrant that other parts of the structure were completely free or that the structure will remain free in the future from hidden sources of moisture or fungal contamination.

This inspection was limited to indoor air quality parameters. The indoor air samples did not show a fungal amplification or an altered indoor fungal ecology on this day. Relative humidity was in the recommended range. Particle counts were similar to those found in the outdoor air due to these areas being exposed to the outdoors on a regular basis. Due to the nature of the activity in the Bus Garage the average particle counts in the 1.0 micron, 2.5 micron, 5.0 micron and 10.0 micron were higher on average than that found in the outdoor air. Carbon Dioxide and Carbon Monoxide levels were within the normal recommended range.

This inspection was limited to indoor air quality.

If you have any questions or concerns, please do not hesitate to contact us.

Sincerely,



Cathy Richmond, B.S.  
LRC Indoor Testing & Research



Tony Richmond, BBA, CAI, WRT  
LRC Indoor Testing & Research