

Leslie Barnes
Pasadena Unified School District
351 S Hudson Ave
Pasadena, CA 91109

Reference: The Center for Independent Study (CIS) High School –Mechanical Survey/ Air Flow Assessment

Our team of experts, comprising of engineers, technicians and surveyors recently inspected Pasadena High School. Our specific scope of work was to conduct a thorough mechanical inspection of all HVAC equipment and measure the outside air flow of each classroom with regard to current ASHRAE standards. The survey included each classroom within the school facility.

The Mechanical Inspection was conducted on March 27, 2021. The overall HVAC units were found to be in very good condition with no necessary repairs. It is our recommendation that the district continue to perform their comprehensive HVAC preventative maintenance plan, to include the routine of changing of air filters on a quarterly basis during the COVID-19 pandemic.

Air Quality Survey:

The outside air flow measurements were taken for eleven (11) classrooms. All classrooms evaluated passed and have sufficient outside air flow. All units have the appropriate outside air flow and do not need any modifications at this time.

Sincerely,

Jennifer Lee
Enviser Service Department
SCL# 1005262