



LEARN MORE AT
energystar.gov

ENERGY STAR® Progress & Goals Report

70

ENERGY STAR®
Score¹

Farmington View Elementary

Primary Property Type: K-12 School
Gross Floor Area (ft²): 25,540
Built: 1950

For Year Ending: February 28, 2018
Date Generated: April 18, 2018

Property Address:
Farmington View Elementary
8300 SW Hillsboro Hwy.
Hillsboro, Oregon 97123

Property ID: 1813304

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Performance Comparison

	Progress			Performance Goals		
	Baseline (Ending Date 11/30/2010)	(Ending Date 2/28/2018)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
ENERGY STAR Score	43	70	-63	75	50	75

Energy

Site EUI (kBtu/ft²)	83.5	68.6	-17.8	65.5	83.8	65.5
Source EUI (kBtu/ft²)	155.6	127.2	-18.2	121.5	155.4	121.5
Energy Cost (\$)	41,387.4	46,480.22	12.31	44,388.48	56,761.27	44,388.48
Energy Cost Intensity (\$/ft²)	1.62	1.82	12.31	1.74	2.22	1.74

Greenhouse Gas Emissions

Total GHG Emissions (Metric Tons CO2e)	200	152.3	-23.85	145.4	186	145.4
Total GHG Emissions Intensity (kgCO2e/ft²)	7.8	6	-23.85	5.7	7.3	5.7

Water

All Water Use (kgal)	N/A	N/A	N/A	*	*	*
Indoor Water Use (kgal)	N/A	N/A	N/A	*	*	*
Indoor Water Use Intensity (gal/ft²)	N/A	N/A	N/A	*	*	*
Total Water Cost (\$)	N/A	N/A	N/A	*	*	*

*Setting and managing water targets is not yet available in Portfolio Manager.