



LEARN MORE AT
energystar.gov

ENERGY STAR® Progress & Goals Report

72

ENERGY STAR®
Score¹

Lenox

Primary Property Type: K-12 School
Gross Floor Area (ft²): 51,074
Built: 1978

For Year Ending: February 28, 2018
Date Generated: April 18, 2018

Property Address:
Lenox
21200 NW Rock Creek Blvd.
Portland, Oregon 97229

Property ID: 1813340

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Performance Comparison

	Progress			Performance Goals		
	Baseline (Ending Date 6/30/2008)	(Ending Date 2/28/2018)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
ENERGY STAR Score	54	72	-33	75	50	75

Energy

	Baseline	(Ending Date)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
Site EUI (kBtu/ft²)	38.7	34.8	-10.1	33.9	43.4	33.9
Source EUI (kBtu/ft²)	121.6	109.3	-10.1	106.5	136.2	106.5
Energy Cost (\$)	N/A	46,675.06	N/A	45,490.68	58,170.71	45,490.68
Energy Cost Intensity (\$/ft²)	N/A	0.91	N/A	0.89	1.14	0.89

Greenhouse Gas Emissions

	Baseline	(Ending Date)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
Total GHG Emissions (Metric Tons CO2e)	240.1	215.9	-10.08	210.4	269.1	210.4
Total GHG Emissions Intensity (kgCO2e/ft²)	4.7	4.2	-10.08	4.1	5.3	4.1

Water

	Baseline	(Ending Date)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
All Water Use (kgal)	N/A	N/A	N/A	*	*	*
Indoor Water Use (kgal)	N/A	N/A	N/A	*	*	*
Indoor Water Use Intensity (gal/ft²)	N/A	N/A	N/A	*	*	*
Total Water Cost (\$)	N/A	N/A	N/A	*	*	*

*Setting and managing water targets is not yet available in Portfolio Manager.