



March 8, 2023

Dave Peterson
Hillsboro School District
4901 SE Witch Hazel Road
Hillsboro, Oregon 97123

Via email: petersod@hsd.k12.or.us

Regarding: First Quarter 2023 Drinking Water Report
Farmington View Elementary School
8300 SW Hillsboro Highway
Hillsboro, Oregon
PBS Project 23440.163

Dear Mr. Peterson:

On March 7, 2023, PBS Engineering and Environmental (PBS) collected drinking water samples at Farmington View Elementary School in Hillsboro, Oregon. The purpose of the testing was to document drinking water quality from the on-site well to comply with Oregon Health Authority's Drinking Water Services requirements.

One sample was collected from the girls south restroom and analyzed to document the presence or absence of total coliforms and Escherichia coli (E. coli) concentrations.

The Oregon Health Authority requires that one distribution system sample be collected quarterly and analyzed for total coliforms and E. coli. The sample was submitted to Alexin Analytical in Tigard, Oregon for analysis. Analytical results were forwarded to the Oregon Health Authority Drinking Water Services by the analyzing laboratory.

RESULTS

The analysis shows that total coliform and E. Coli concentrations in drinking water were within acceptable limits. No follow-up testing is required. See the attached laboratory analysis reports for more information.

SAMPLING METHODOLOGY

Total Coliforms and E. coli

PBS collected one 100–120 milliliter (mL) sample of water after running the tap for approximately one minute. Samples were analyzed for Total Coliforms and E. coli per SM 9223 (colilert-18) 21st Edition.

Dave Peterson
First Quarter 2023 Drinking Water Report
Farmington View Elementary School
March 8, 2023
Page 2 of 2

Please feel free to contact me at 503.935.5484 or dale.voeller@pbsusa.com if you have any questions or comments about this report.

Sincerely,

 Digitally signed by Dale
Voeller, CHMM, CSP
Date: 2023.03.08
14:08:46 -08'00'

Dale Voeller, CHMM, CSP
Senior Project Manager

Attachment: Laboratory Analytical Results



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

Reported: 03/08/2023
Received: 3/7/23 14:02
Temp. on Receipt: 14.6 °C

Sampled By:
Work Order: 3066027

C
L
I
E
N
T
PBS Engineering & Environmental
Attn: Dale Voeller
4412 SW Corbett
Portland OR, 97239
Phone: (503) 248-1939

Project # : N/A
PWS Name : Farmington View Elementar
PWSID # : 4190606

Lab Number

3066027-01

Sampled At: South Girls Restroom
Address:
Sample Type: Routine

Sample Matrix: Drinking Water

Sampled: 3/7/23 12:57

	Method	Result	Analysis Begun / Ended			
Microbiological Analysis						
A Total Coliforms	SM 9223B (colilert-18) 21st Ed.	Absent	3/7/23	14:50	3/8/23	11:06
A E. coli	SM 9223B (colilert-18) 21st Ed.	Absent	3/7/23	14:50	3/8/23	11:06

Send results to **DHS-DWP P.O. Box 14350, Portland, OR 97293-0350**

A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: _____

Vandana Gade
Microbiology Technical Director