



November 13, 2018

Dave Peterson
Hillsboro School District
4901 SE Witch Hazel Road
Hillsboro, Oregon 97123

Via email: petersod@hsd.k12.or.us

Regarding: District Wide Radon Testing
 Century High School
 2000 SE Century Boulevard
 Hillsboro, Oregon
 PBS Project 23440.024, Phase 0003

Dear Mr. Peterson:

From November 5 to November 8, 2018, PBS Engineering and Environmental Inc. (PBS) performed short term radon testing at Century High School located at 2000 SE Century Boulevard in Hillsboro, Oregon.

The Environmental Protection Agency (EPA) and Oregon Health Authority (OHA) recommend that buildings be tested for radon and that any radon concentrations be maintained below 4.0 picocuries per liter (pCi/L) of air. PBS used AirChek, Inc. brand single-use, short-term radon test kits to measure radon levels in frequently-occupied rooms that are in contact with the ground or above unoccupied basements or crawlspaces.

Laboratory results indicate all short-term radon tests at Century High School tested below 4.0 pCi/L.

See the attached Laboratory Analysis Report for more details.

In addition to the EPA recommendation that radon concentrations not exceed 4.0 pCi/L, OHA recommends the following steps be conducted based on the results of a room's initial short-term test:

- **If the result is less than 2.0 pCi/L**, school districts are required to test again every 10 years, per Oregon Revised Statute 332.166-167.
- **If the result is between 2.0 pCi/L and 4.0 pCi/L**, consider fixing (i.e., lowering) the radon in that room.
- **If the result is from 4.0 pCi/L to 8.0 pCi/L**, perform a follow-up measurement of that room using a long-term test. This test should be conducted over as much of a nine-month school year as possible, when the room is likely to be occupied. If that result is equal to or greater than 4.0 pCi/L, the radon in the room should be fixed (i.e., lowered).
- **If the initial short-term test result is equal to or greater than 8.0 pCi/L**, conduct a second short-term test and average its result with the initial short-term test result. If the average of the two is equal to or greater than 4.0 pCi/L, radon in the room should be fixed (i.e., lowered).

Note: A great difference in the results of the short-term tests may indicate a flaw in the testing process. Investigate and consider retesting. For situations in which one of the test results is equal to or greater than 4.0 pCi/L, if the higher result is two or more times the lower result, repeat the test.

LIMITATIONS OF SCOPE

This study was limited to the tests and locations as previously indicated. The site as a whole may have other environmental concerns that will not be characterized by this study. The findings and conclusions of this work are not scientific certainties, but probabilities based on professional judgment concerning the significance of the data gathered during the course of this investigation. PBS is not able to represent conditions on the site or adjoining sites beyond those detected or observed by PBS.

Please feel free to contact me at 503.935.5484 or dale.voeller@pbsusa.com with any questions or comments.

Sincerely,

Dale Voeller, CHMM, CSP
Senior Project Manager

Attachment: AirChek, Inc Laboratory Analysis Report

SG::dsv

Radon test result report for:**CENTURY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9119643	A.D. BLANK	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119634	A.D. DUP	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119625	ATHLETIC DEPART.	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119635	ATTENDANCE OFFIC	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9124094	AUDITORIUM 1	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9124100	AUDITORIUM 2	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9124090	BOOKKEEPER OFF.	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119636	CHORAL OFFICE	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119633	CHORAL RM.	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	0.9 ± 0.3	2018-11-12
9119686	COMMONS 1	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119685	COMMONS 2	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9122735	CONCESSIONS	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119624	COUNC. CENTER	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119604	COUNC. CTR. DUP	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9122710	CUSTODIAN MAIN	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	0.6 ± 0.4	2018-11-12
9122709	CUSTODIAN OFF DU	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	0.7 ± 0.3	2018-11-12
9122711	CUSTODIAN OFFICE	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	0.7 ± 0.3	2018-11-12
9122719	DAY CARE	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122726	DAY CARE DUP	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119657	ENSAMBLE	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119691	FACULTY DINING	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9122738	GYM 1	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122737	GYM 2	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119641	HEALTH RM. DUP	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119649	HEALTH ROOM	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119672	J. CONNOR OFFICE	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	0.5 ± 0.3	2018-11-12
9119663	JAG VIDEO RM	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119667	JAGUAR-TV RM	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119677	JAY MEDIA RM	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119692	KITCH. OFF. BLAN	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119693	KITCH. OFF. DUP	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119694	KITCH. OFFICE	2018-11-05 @ 6:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119623	MAIN OFFICE	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119656	MAKE UP RM. BLAN	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119661	MAKE UP ROOM	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9122734	MEN LOCKER OFFIC	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119651	MUSIC ROOM	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12

Radon test result report for:**CENTURY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9122717	N102 OFFICE	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122707	N121 OFFICE	2018-11-05 @ 7:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119626	OFFICE WORK RM	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119642	OFFICER OFFICE	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9122739	P.E. CONFERENCE	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119659	PRACTICE RM 2	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	0.6 ± 0.3	2018-11-12
9119654	PRACTICE RM 3	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119653	PRACTICE RM 4	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119652	PRACTICE RM 6	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119660	PRACTICE RM. 1	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119658	PRACTICE RM. 5	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119629	PRINCIPAL	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9122721	RM N101	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122720	RM N102	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122725	RM N104	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122724	RM N105	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122722	RM N109	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122729	RM N110	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122716	RM N111	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122723	RM N111 WORK RM	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119700	RM N112	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122701	RM N113	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122715	RM N113 BLANK	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122730	RM N114	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119698	RM N115	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119699	RM N115 DUP	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122712	RM N116	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119697	RM N117	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122702	RM N117 DUP	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119696	RM N118	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122713	RM N119	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122703	RM N120	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122705	RM N120 NAP RM	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	0.5 ± 0.3	2018-11-12
9122704	RM N121	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122714	RM N122	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122706	RM N122 MULTIUSE	2018-11-05 @ 7:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9119678	RM S156	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	0.7 ± 0.3	2018-11-12

Radon test result report for:**CENTURY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9119664	RM S156 OFF. DUP	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119679	RM S156 OFFICE	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119665	RM S157	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119666	RM S159	2018-11-05 @ 5:00 pm	2018-11-08 @ 6:00 pm	0.5 ± 0.3	2018-11-12
9119674	RM S167	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119680	RM S171	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	0.9 ± 0.3	2018-11-12
9124097	RM S176	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119676	RM. 166	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119688	RM. C140B	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119662	RM. S158	2018-11-05 @ 5:00 pm	2018-11-08 @ 4:00 pm	0.6 ± 0.3	2018-11-12
9119669	RM. S161	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119670	RM. S162	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119681	RM. S163	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119675	RM. S165	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	0.8 ± 0.3	2018-11-12
9119687	RM. S165 DUP	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	0.7 ± 0.3	2018-11-12
9119690	RM. S172	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	0.8 ± 0.3	2018-11-12
9119673	RM. S173	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119689	RM. S177	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119603	ROOM C143B	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119640	ROOM C143C	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119646	ROOM C143D	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119644	ROOM C143F	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119647	ROOM C143G	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119631	ROOM C143I	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119630	ROOM C143J	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119639	ROOM C143K	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119650	ROOM C144A	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119648	ROOM C144E	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119628	ROOM C145C	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119627	ROOM C145D	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119632	ROOM C145E	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119638	ROOM C145F	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119637	ROOM C145G	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9119645	ROOM C145H	2018-11-05 @ 3:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9122708	ROOM N123	2018-11-05 @ 7:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119668	S160	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119671	S160 DUP	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12

November 12, 2018

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**CENTURY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9119682	S162 PRA. 2 BLAN	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119683	S162 PRACTIC DUP	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	0.9 ± 0.3	2018-11-12
9119684	S162 PRACTICE 1	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	1.1 ± 0.3	2018-11-12
9119695	S162 PRACTICE 2	2018-11-05 @ 5:00 pm	2018-11-08 @ 5:00 pm	< 0.3	2018-11-12
9119655	STAGE OFFICE	2018-11-05 @ 4:00 pm	2018-11-08 @ 4:00 pm	< 0.3	2018-11-12
9122728	TRAINING ROOM	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122731	WEIGHT OFF. BLAN	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122732	WEIGHT RM OFFICE	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	0.5 ± 0.3	2018-11-12
9122718	WEIGHT ROOM	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122733	WOM. LOCKER DUP	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12
9122727	WOMEN LOCKER OFF	2018-11-05 @ 8:00 pm	2018-11-08 @ 6:00 pm	< 0.3	2018-11-12

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Radon test result report for:

**TRANSPORTATION CENTER
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9122782	BUS OFF. RM 1 BL	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	< 0.3	2018-11-12
9122783	BUS OFF. RM 2 DU	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.7 ± 0.3	2018-11-12
9122775	BUS OFFICE 1	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.7 ± 0.3	2018-11-12
9122773	BUS OFFICE RM 2	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.6 ± 0.3	2018-11-12
9122781	DISPATCH OFFICE	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	0.8 ± 0.3	2018-11-12
9122784	LOUNGE\MEETING	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	0.7 ± 0.3	2018-11-12
9122780	OFFICE 1	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.9 ± 0.3	2018-11-12
9122778	OFFICE 2	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	< 0.3	2018-11-12
9122776	OFFICE 3	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.7 ± 0.3	2018-11-12
9122785	OFFICE 4	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.2 ± 0.3	2018-11-12
9122786	OFFICE 5	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	0.7 ± 0.3	2018-11-12
9122779	OFFICE 6	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	0.9 ± 0.3	2018-11-12
9122787	RECEPTION	2018-11-06 @ 11:00 am	2018-11-09 @ 11:00 am	1.7 ± 0.3	2018-11-12

Radon test result report for:**W.L. HENRY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9124111	COMMUNITY OFFICE	2018-11-06 @ 9:00 am	2018-11-09 @ 11:00 am	0.7 ± 0.3	2018-11-12
9124105	COUNSELOR OFFICE	2018-11-06 @ 9:00 am	2018-11-09 @ 11:00 am	0.7 ± 0.3	2018-11-12
9122750	CUSTODIAN OFFICE	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.4 ± 0.3	2018-11-12
9122761	FACULTY LOUNGE	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.3 ± 0.3	2018-11-12
9122740	GYM 1	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.6 ± 0.3	2018-11-12
9122758	GYM 2	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.7 ± 0.3	2018-11-12
9122752	GYM OFF. BLANK	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	< 0.3	2018-11-12
9122751	GYM OFF. DUP	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.9 ± 0.3	2018-11-12
9122757	GYM OFFICE	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.9 ± 0.3	2018-11-12
9124103	HEALTH RM.	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	0.6 ± 0.3	2018-11-12
9124102	LIBRARY 1	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.2 ± 0.3	2018-11-12
9124104	LIBRARY 2	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.4 ± 0.3	2018-11-12
9124109	MAIN OFFICE	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.4 ± 0.3	2018-11-12
9124114	MRS. GOMEZ OFF.	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.2 ± 0.3	2018-11-12
9124107	MUSIC ROOM	2018-11-06 @ 9:00 am	2018-11-09 @ 11:00 am	2.3 ± 0.3	2018-11-12
9124106	OFFICE CONF.	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.0 ± 0.3	2018-11-12
9124110	OFFICE WORK RM.	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	0.9 ± 0.3	2018-11-12
9122769	PORT 22	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.9 ± 0.3	2018-11-12
9122753	PORT 26	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.9 ± 0.3	2018-11-12
9122770	PORT 27	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.9 ± 0.3	2018-11-12
9122768	PORTABLE 21	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.7 ± 0.3	2018-11-12
9122745	RM 1 DUP	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.1 ± 0.3	2018-11-12
9122755	RM 10 BLANK	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	< 0.3	2018-11-12
9122754	RM 11 DUP	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.0 ± 0.3	2018-11-12
9122774	RM 23	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.7 ± 0.3	2018-11-12
9122767	RM 24	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	< 0.3	2018-11-12
9122771	RM 24 DUP	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.6 ± 0.3	2018-11-12
9122777	RM 25	2018-11-06 @ 10:00 am	2018-11-09 @ 11:00 am	0.6 ± 0.3	2018-11-12
9124108	ROOM 1	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.2 ± 0.3	2018-11-12
9122760	ROOM 10	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.0 ± 0.3	2018-11-12
9122764	ROOM 11	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.3 ± 0.3	2018-11-12
9122759	ROOM 12	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.4 ± 0.3	2018-11-12
9122763	ROOM 13	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.9 ± 0.3	2018-11-12
9122766	ROOM 14	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.6 ± 0.3	2018-11-12
9122765	ROOM 15	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.3 ± 0.3	2018-11-12
9122762	ROOM 16	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.2 ± 0.3	2018-11-12
9122756	ROOM 17	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.6 ± 0.3	2018-11-12

November 12, 2018

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**W.L. HENRY
MAIN**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9122744	ROOM 2	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.1 ± 0.3	2018-11-12
9122746	ROOM 3	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.0 ± 0.3	2018-11-12
9124117	ROOM 4	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.5 ± 0.3	2018-11-12
9122741	ROOM 5	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.5 ± 0.3	2018-11-12
9124112	ROOM 6	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.7 ± 0.3	2018-11-12
9124113	ROOM 7	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.6 ± 0.3	2018-11-12
9124115	ROOM 8	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	2.0 ± 0.3	2018-11-12
9124118	ROOM 9	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	2.1 ± 0.4	2018-11-12
9122736	SPEECH BY RM. 6	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.2 ± 0.3	2018-11-12
9124116	SPEECH RM 6 DUP	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.5 ± 0.3	2018-11-12
9122742	TEAM BY RM 11	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.5 ± 0.4	2018-11-12
9122749	TEAM BY RM 14	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	2.6 ± 0.4	2018-11-12
9122748	TEAM BY RM 17	2018-11-06 @ 10:00 am	2018-11-09 @ 10:00 am	1.5 ± 0.3	2018-11-12
9122747	TEAM OFF. BY 2	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.0 ± 0.3	2018-11-12
9124101	WELLNESS CENTER	2018-11-06 @ 9:00 am	2018-11-09 @ 10:00 am	1.4 ± 0.3	2018-11-12

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498