



POCATELLO/CHUBBUCK SCHOOL DISTRICT 25

LEARNING TODAY FOR THE POSSIBILITIES OF TOMORROW

**Administration Office
3115 Pole Line Road
Pocatello, Idaho**

INVITATION TO BID

SPECIFICATIONS FOR

**Reinforced Roofing Projects
Various Site Locations**

BIDS WITH CONDITIONS WILL NOT BE ACCEPTED

BID OPENING

**March 5, 2024
10:00 AM**



POCATELLO/CHUBBUCK SCHOOL DISTRICT 25
LEARNING TODAY FOR THE POSSIBILITIES OF TOMORROW

POCATELLO/CHUBBUCK SCHOOL DISTRICT NO. 25
INVITATION TO BID

Sealed bids will be received by the Pocatello/Chubbuck School District No. 25 Business Office, Bannock County, Idaho at 3115 Pole Line Road, Pocatello, Idaho, 83201 until **10:00 AM on March 5, 2024** for the following:

2024 Reinforced Roofing Projects at Various Site Locations

A mandatory pre-bid conference and walk-thru to review the projects will be held at the District Maintenance Shop, 185 E. Maple, Pocatello, Idaho, on February 29, 2024 at 1:00 PM.

Specifications and additional details, (including bid forms), may be secured at 3115 Pole Line Road, Pocatello, Idaho, 83201, and on the District website at: <https://www.sd25.us/departments/business-office>.

All bids must be on the forms furnished, all blank spaces filled in, and signed with the name and address of the Bidder. No unqualified bids will be read.

Each bid shall be accompanied by a certified check, cashier’s check, or a bidder’s bond, (executed by a qualified surety company with the power to do business in the State of Idaho) in the sum of not less than five percent (5%) of the total bid, made payable to School District No. 25, Bannock County, Pocatello, Idaho. This surety shall be forfeited by the bidder in the event of failure to enter into a contract. Personal or company checks will not be accepted. Compliance with Idaho Public Works Law is required.

The Board of Trustees reserves the right to reject any or all bids or to waive any informalities, or to accept the bid or bids deemed best for Pocatello/Chubbuck School District No. 25, Bannock County, Pocatello, Idaho.

Rena Johnson, Clerk
Pocatello/Chubbuck School District No. 25

Publish dates:

February 17, 2024
February 24, 2024

IDAHO STATE JOURNAL

INSTRUCTIONS TO BIDDERS

BIDS:

Sealed "BIDS" will be received on or before the time and date set forth under "INVITATION TO BID".

The owner reserves the right to accept or reject any part or all bids.

Bidders submitting a "Bid" on this work will be required to figure and furnish everything as called for by these specifications and the requirements of the "Bid" sheet.

All bids will be in a sealed envelope addressed to the Pocatello/Chubbuck School District No. 25 Business Office, Bannock County, Idaho at 3115 Pole Line Road, Pocatello, Idaho, 83201. The following shall be written on the exterior of the envelope:

“BIDS FOR 2024 Reinforced Roofing Projects
TO BE OPENED ON **March 5, 2024 AT 10:00 AM**”

Bids not delivered by contractors at time of bid opening must be received in mail no later than 4:00 PM on March 4, 2024, the day before the bid opening.

EXAMINATION OF THE SITE AND DOCUMENTS:

Refer all questions to Brian Glenn, School Plant Coordinator, 208-235-3280. Contact with other district staff, Board of Trustees, or Administration, will be by written permission only.

A mandatory pre-bid conference and walk-thru to review the projects will be held at the District Maintenance Shop, 185 E. Maple, Pocatello, Idaho, on February 29, 2024 at 1:00 PM.

Before submitting a proposal, the bidder shall:

1. Carefully examine the specifications.
2. Visit the worksite.
3. Be fully informed of existing conditions and limitations.
4. Include in the bid, sums sufficient to cover all items required by the contract, and shall rely entirely upon his own examinations in making his proposal.

INTERPRETATIONS:

Should a bidder find discrepancies in or omissions from the specifications, or be in doubt as to their meaning, he should at once notify the Owner, who will send written instructions or addenda to all bidders. The owner will not be responsible for oral interpretations. Questions received less than 48 hours before time for bid opening cannot be answered. All addenda issued during the time of bidding will be incorporated in the contract.

BID GUARANTEE:

As a guarantee that, if awarded the contract, the bidder will execute same and furnish bond. Each bid will be accompanied by a Certified check, Cashier's Check, or Bid Bond for not less than five percent (5%) of the base bid payable to the Owner. NO PERSONAL OR COMPANY CHECKS WILL BE ACCEPTED.

OBJECTIONS:

Written objections to specifications or bid procedures must be received by the clerk, secretary, or other authorized official of the District at least one (1) business day before the date and time upon which bids are scheduled to be received, per Idaho Code Section 68-2806(c).

LAWS AND ORDINANCES:

The contractor hereby binds himself to protect and save harmless the owner from all damages arising from the violation of any and all Federal, State, County, City, and all other laws, rules, regulations, in the performance of the terms of the contract.

HOLD HARMLESS AGREEMENTS:

The District expects your work to conform to professional standards. The contractor is expected to hold the District harmless for all damages or claims arising out of the work performed by the contractor. The District will not agree to hold the contractor harmless for damages or claims.

EQUIPMENT:

The contractor shall provide all labor, materials, tools, and equipment, etc. necessary for the complete and substantial execution of everything described in the specifications.

STORAGE OF MATERIALS:

The contractor shall make arrangement and coordinate with the Maintenance Department for storage of materials. Any damages of life or property caused by storage of materials on the above indicated place shall be paid for by the contractor, who shall hold the owner harmless for any damages concerning the same.

SUPERVISION:

The supervision of this work will be done by School District #25 Maintenance Department.

EVIDENCE OF QUALIFICATIONS:

Upon request of the owner, a bidder whose bid is under consideration for award of the contract shall submit, promptly, satisfactory evidence of his financial resources, his experiences, and the organization and equipment he has available for performance of the contract.

EMPLOYMENT OF RESIDENTS OF IDAHO:

In compliance with Idaho Laws, Section 44-1001 and 44-1002 Idaho Code, the contractor must employ ninety-five percent 95% bona fide Idaho residents as employees on any such contracts except where under such contracts fifty (50) or less persons are employed the contractor may employ ten percent (10%) nonresidents, provided however, in all cases such employers must give preference to the employment of bona fide Idaho residents in the performance of such work.

CONTRACTOR'S LICENSE:

In compliance with Idaho Laws, the contractor must be registered with the State of Idaho, and hold the required Public Works Contractor's License before obtaining the contract documents and before submitting a bid for this work.

INSURANCE:

All contractors who provide goods or services to the District are required to provide the District with certificates of insurance for General Liability, Auto Liability, Workers Compensation, and Professional Liability if applicable.

The General Liability and/or Professional Liability certificate must name the District as an additional insured under the contractor's policy. Certificates are to be provided to the District prior to any work commencing on District property. This would include the placement of any equipment or materials at the work site

Minimum Insurance Limits

General Liability	\$1,000,000 per occurrence \$1,000,000 products and completed operations \$1,000,000 annual aggregate
Auto Liability	\$1,000,000 per occurrence
Worker' Compensation	Statutory
Professional Liability	\$1,000,000 per occurrence \$1,000,000 annual aggregate

OWNER/CONTRACTOR AGREEMENT:

The Agreement for the work will be written on a District provided Form of Agreement between Owner and Contractor where the basis of payment is a stipulated sum.

PERFORMANCE BOND:

The successful bidder will be required to furnish a 100% performance bond when entering into the contract work, per Idaho Code Section 54-1926, "...conditioned upon the faithful performance of the contract in accordance with the plans, specifications and conditions thereof."

PAYMENT BOND:

The successful bidder will be required to furnish a 100% payment bond when entering into the contract work, per Idaho Code Section 54-1926, "solely for the protection of persons supplying labor or materials, or renting, leasing, or otherwise supplying equipment to the contractor or his subcontractors in the prosecution of the work provided for in such contract."

5% RETAINAGE:

The Owner will retain 5% of the Contractor's earned sum to ensure faithful performance. This 5% will be released to the Contractor upon receipt of approval from State of Idaho.

LIQUIDATED DAMAGES:

Contractor shall be required to pay Owner as liquidated damages the sum of \$500 for each day, after the scheduled completion date, that the project is unfinished.

CHANGES IN THE WORK:

All change orders shall be submitted in written form, for District approval, before any additional work is performed.

The owner, without invalidating the contract, may order extra work or make changes by altering, adding to, or deducting from the work; the contract sum being adjusted accordingly. All such work shall be executed under the conditions of the original contract, except that any claim for extension of the time caused thereby shall be adjusted at the time of ordering such change.

The total allowance for combined overhead and profit for changes shall be included in the total cost to the owner and shall be based on the following schedule:

- a) For the Contractor, 10% over cost;
- b) For the Sub-Contractor, 15% over cost to be divided 10% for Sub-Contractor and 5% for Contractor; and
- c) For any Sub-Subcontractor, 15% over cost to be divided 5% for Contractor, 5% for Sub-Contractor, and 5% for Sub-Subcontractor.

FORM WH5:

Per Idaho Code Section 54-1904A, within thirty (30) days of award of bid, the contractor shall file with the State Tax Commission a form WH-5, Public Works Contract Report.

INSPECTION OF WORK:

The representative of the owner shall at all times have access to the work wherever it is in preparation or progress and the contractor shall provide facilities for such access and for inspection.

WARRANTY:

Manufacturer shall warrant products under normal use and service to be free from defects in materials and workmanship for a period of one year from date of delivery.

Warranty shall cover repair or replacement of such parts determined defective upon inspection. Warranty does not cover any product or part of a product subject to accident, negligence, alteration, abuse or misuse. Warranty does not cover any accessories or parts not supplied by the manufacturer.

Warranty shall not cover any labor expended or materials used to repair any equipment without manufacturer's prior written authorization.

CLEAN UP:

The contractor shall at all times keep the premises free from accumulations of waste material or rubbish caused by his employees or work, and at the completion of the work he shall remove all his rubbish from and about the building and all tools and surplus materials and shall leave his work clean. In case of dispute, the owner shall remove the rubbish and surplus materials and charge the cost to the contractor. At no time shall the School District Dumpsters be used to remove the Contractor's waste, garbage or scraps.

IDAHO EMPLOYER ALCOHOL AND DRUG-FREE WORKPLACE ACT: Include with your bid sheet a contractor's affidavit pursuant to Idaho Code Section 72-1717.

BIDDER CERTIFICATION FORM: All bidders must complete and submit the Bidder Certification Form included with this bid request.

PAYMENT:

Prices must remain firm as quoted by supplier until quantity awarded is received. Application for payment dated on or before the 25th of the month, shall be paid by the 15th of the following month. Application for payment dated after the 25th of the month, shall be paid within 30 days.

Delivery may be accepted any time, however, payment for the 2024-2025 fiscal year cannot be made until after July 1, 2024 when those funds have been released.

BID:

The following universal specifications are being used as a guideline. Alternate bids for equal equipment will be considered upon District approval two weeks prior to the bid due date. Substitutions or major

alternations must be indicated upon the proposal sheet at the time of the bid submission. Bids must be based upon conditions at the site and these specifications. Bids shall be submitted in accordance with the requirements shown on the bid form.

BID EVALUATION CRITERIA:

Contractor selection on this project will be evaluated based on the following:

- 1) Price
- 2) Contractor reputation for quality of work with current customers or past performance with District 25. (please list all jobs/contracts greater than \$50,000 performed in the past two years if contractor has not performed one for the District in past 5 years)
- 3) Vendor ability to best match the listed criteria as specified.
- 4) The contract will be awarded to the lowest responsive and responsible bidder or bid/offer most advantageous to the District with price and other factors considered.

DELIVERY AND START OF WORK:

The time-frame for the reinforced roofing system at Irving Middle School to be completed is **between June 3, 2024 and be completed by August 5, 2024.**

GENERAL SPECIFICATIONS

SCOPE OF WORK: The contractor shall furnish and install all materials, labor, equipment, and other necessary items for the reinforced roofing system for the following locations:

- Project 1 – Century High School 7801 Diamondback Way
- Project 2 – Highland High School, 1800 Bench Road
- Project 3 – Edahow Elementary School, 2020 Pocatello Creek Rd
- Project 4 – Indian Hills Elementary, 666 Cheyenne

PART 1 GENERAL

1.01 SUMMARY

- A. Furnish and install elastomeric sheet roofing system, including:
 - 1. Roofing manufacturer's requirements for the specified warranty.
 - 2. Preparation of roofing substrates.
 - 3. Wood nailers for roofing attachment.
 - 4. Vapor barrier
 - 5. Insulation.
 - 6. Cover boards.
 - 7. Externally reinforced (fleece back) elastomeric membrane roofing.
 - 8. Metal roof edging and copings.
 - 9. Flashings.
 - 10. Walkway pads.
 - 11. Other roofing-related items specified or indicated on the drawings or otherwise necessary to provide a complete weatherproof roofing system.
- B. Disposal of demolition debris and construction waste is the responsibility of Contractor. Perform disposal in manner complying with all applicable federal, state, and local regulations.
- C. Comply with the published recommendations and instructions of the roofing membrane manufacturer, at <http://manual.fsbp.com>.
- D. Commencement of work by the Contractor shall constitute acknowledgement by the Contractor that this specification can be satisfactorily executed, under the project conditions and with all necessary prerequisites for warranty acceptance by roofing membrane manufacturer. No modification of the Contract Sum will be made for failure to adequately examine the Contract Documents or the project conditions.

1.02 RELATED SECTIONS

- A. Section 06 10 00 - Rough Carpentry: Wood nailers associated with roofing and roof insulation.
- B. Section 07 62 00 - Sheet Metal Flashing and Trim: Formed metal flashing and trim items associated with roofing.
- C. Section 07 72 00 - Roof Accessories: Roof hatches, vents, and manufactured curbs.
- D. Section 08 62 00 - Unit Skylights.
- E. Section 22 10 00 - Plumbing Piping and Roof Drains.

1.03 REFERENCES

- A. Referenced Standards: These standards form part of this specification only to the extent they are referenced as specification requirements.
1. ASTM C 1177/C 1177M - Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; 2004.
 2. ASTM C 1289 - Standard Specification for Faced Rigid Cellular Polyisocyanurate Thermal Insulation Board; 2013.
 3. ASTM C 1549 - Standard Test Method for Determination of Solar Reflectance Near Ambient Temperature Using a Portable Solar Reflectometer; 2004.
 4. ASTM D 638 - Standard Test Method for Tensile Properties of Plastics; 2003.
 5. ASTM D 1004 - Standard Test Method for Initial Tear Resistance of Plastic Film and Sheeting; 2003.
 6. ASTM D 3273 - Standard Test Method for Resistance to Growth of Mold on the Surface of Interior Coatings in an Environmental Chamber; 2000.
 7. ASTM D 6878 - Standard Specification for Thermoplastic Polyolefin Based Sheet Roofing; 2003.
 8. ASTM E 84 - Standard Test Method for Surface Burning Characteristics of Building Materials; 2005.
 9. ASTM E 136 - Standard Test Method for Behavior of Materials in a Vertical Tube Furnace At 750 Degrees C; 2004.
 10. FM 1-28 - Design Wind Loads; Factory Mutual System; 2002.
 11. FM 1-29 - Roof Deck Securement and Above Deck Roof Components; Factory Mutual System; 2005.
 12. PS 1 - Construction and Industrial Plywood; 1995.
 13. PS 20 - American Softwood Lumber Standard; 2005.
 14. SPRI ES-1 - Wind Design Standard for Edge Systems Used with Low Slope Roofing Systems; 2003. (ANSI/SPRI ES-1).

1.04 SUBMITTALS

- A. Product Data:
1. Provide membrane manufacturer's printed data sufficient to show that all components of roofing system, including insulation and fasteners, comply with the specified requirements and with the membrane manufacturer's requirements and recommendations for the system type specified; include data for each product used in conjunction with roofing membrane.
 2. Where UL or FM requirements are specified, provide documentation that shows that the roofing system to be installed is UL-Classified or FM-approved, as applicable; include data itemizing the components of the classified or approved system.
 3. Installation Instructions: Provide manufacturer's instructions to installer, marked up to show exactly how all components will be installed; where instructions allow installation options, clearly indicate which option will be used.
- B. Shop Drawings: Provide:
1. The roof membrane manufacturer's standard details customized for this project for all relevant conditions, including flashings, base tie-ins, roof edges, terminations, expansion joints, penetrations, and drains.

- C. Pre-Installation Notice: Copy to show that manufacturer's required Pre Installation Notice (PIN) has been accepted and approved by the manufacturer.
- D. Executed Warranty.
- E. Specimen Warranty: Submit prior to starting work.
- F. Samples: Submit samples of each product to be used.

1.05 QUALITY ASSURANCE

- A. Applicator Qualifications: Roofing installer shall have the following:
 - 1. Current approved Contractor status.
 - 2. At least five years' experience in installing specified system.
 - 3. Capability to provide payment and performance bond to building owner.
- B. Pre-Installation Conference: Before start of roofing work, Contractor shall hold a meeting to discuss the proper installation of materials and requirements to achieve the warranty.
 - 1. Require attendance with all parties directly influencing the quality of roofing work or affected by the performance of roofing work.
 - 2. Notify Architect well in advance of meeting.

1.06 DELIVERY, STORAGE AND HANDLING

- A. Deliver products in manufacturer's original containers, dry and undamaged, with seals and labels intact and legible.
- B. Store materials clear of ground and moisture with weather protective covering.
- C. Keep combustible materials away from ignition sources.

1.07 WARRANTY

- A. Comply with all warranty procedures required by manufacturer, including notifications, scheduling, and inspections.
- B. Warranty: 20 year Red Shield Limited Warranty covering membrane, and membrane accessories.

20 year .060 UltraPly TPO XR

- 1. Limit of Liability: No dollar limitation.
 - a. Scope of Coverage: Repair leaks in the roofing system caused by:
 - b. Ordinary wear and tear of the elements.
 - c. Manufacturing defect in Firestone brand materials.
 - d. Defective workmanship used to install these materials.
 - e. Damage due to winds up to 72. mph.
- 2. Not Covered:
 - a. Damage due to winds in excess of 72,mph.
 - b. Damage due to hurricanes or tornadoes.
 - c. Hail.
 - d. Intentional damage.
 - e. Unintentional damage due to normal rooftop inspections, maintenance, or service.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Acceptable Manufacturer - Roofing System: Firestone Building Products Co.
www.firestonebpco.com.
- B. Roofing systems manufactured by others may be acceptable provided the roofing system is completely equivalent in materials and warranty conditions and the manufacturer meets the following qualifications:
 - 1. Specializing in manufacturing the roofing system to be provided.
 - 2. Minimum ten years of experience manufacturing the roofing system to be provided.
 - 3. Able to provide a no dollar limit, single source roof system warranty that is backed by corporate assets in excess of one billion dollars.
 - 4. ISO 9002 certified.
 - 5. Able to provide polyisocyanurate insulation that is produced in own facilities.
- C. Manufacturer of insulation or Cover Board: Same manufacturer as roof membrane.
- D. Manufacturer of Metal Roof Edging: Same manufacturer as roof membrane.
 - 1. Metal roof edging products by other manufacturers are not acceptable.
 - 2. Field- or shop-fabricated metal roof edgings are not acceptable.
 - 3. If existing metal roof edging is reused it is not part of the roof system warranty.

2.02 ROOFING SYSTEM DESCRIPTION

- A. Roofing System:
 - 1. Membrane: Externally Reinforced (Fleece Backed) Thermoplastic Polyolefin (TPO).
 - 2. Thickness: 60 mil not counting fleece
 - 3. Membrane Attachment: Mechanically attached over existing membrane roof.
 - 4. Slope: If there is no positive drainage add tapered insulation to achieve positive slope.
 - 5. Comply with applicable local building code requirements.
 - 6. Provide assembly having Underwriters Laboratories, Inc. (UL) Class A, Fire Hazard Classification.
 - 7. Provide assembly complying with Factory Mutual Corporation (FM) Roof Assembly Classification, FM DS 1-28 and 1-29, and meeting minimum requirements of FM 1-[60, 90, 120, 160] wind uplift rating.
- B. Vapor Barrier over deck/deck cover:
 - 1. Membrane: High density polyethylene sheet with SBS modified bitumen adhesive.
 - 2. Attachment: Self adhering.
- C. Insulation: Replace wet insulation found with like thickness.
 - 1. Total System R Value: 20, minimum.

ISO Insulation Thickness [IN (mm)]	Insulation R Value*
1.00 (25.4)	5.7
1.50 (38.1)	8.6
1.75 (44.5)	10.0

2.00 (50.8)	11.4
2.30 (58.4)	13.2
2.50 (63.5)	14.4
2.80 (71.1)	16.2
3.00 (76.2)	17.4
3.25 (82.6)	18.9
3.50 (88.9)	20.5
3.75 (95.3)	22.0
4.00 (101.6)	23.6

**Long Term Thermal Resistance (LTTR) values provide a 15-Year time weighted average in accordance with ASTM 1289-13.*

2.03 TPO MEMBRANE MATERIALS

- A. Membrane: Flexible, heat weldable sheet composed of thermoplastic polyolefin polymer and ethylene propylene rubber; complying with ASTM D 6878, with polyester weft inserted reinforcement and an 8 ounce polyester fleece backing and the following additional minimum characteristics:
1. Thickness: 0.060 inch (1.52 mm) plus/minus 10 percent, with coating thickness over reinforcement of 0.021 inch (0.53 mm) plus/minus 10 percent.
 2. Puncture Resistance: 390 lbf (1,735 N), minimum, when tested in accordance FTM 101C Method 2031.
 3. Tear Strength: 120 lbf (534 N)
 4. Solar Reflectance: 0.79, minimum, when tested in accordance with ASTM C 1549. [white]
 5. Solar Reflectance: 0.81, minimum, when tested in accordance with ASTM E 903. [white]
 6. Color: White
 7. Acceptable Product: UltraPly TPO XR.
- A. Membrane Fasteners (supplemental, where required): Type and size as required by roof membrane manufacturer for roofing system and warranty to be provided; use only fasteners furnished by roof membrane manufacturer. Attach per uplift requirements for specified warranty.
- B. Curb and Parapet Flashing: Same material as membrane, with encapsulated edge which eliminates need for seam sealing the flashing-to-roof splice; precut to 18 inches (457 mm) wide.
- C. Formable Flashing: Non-reinforced, flexible, heat weldable sheet, composed of thermoplastic polyolefin polymer and ethylene propylene rubber.
1. Thickness: 0.060 inch (1.52 mm) plus/minus 10 percent.
 2. Tensile Strength: 1550 psi (10.7 MPa), minimum, when tested in accordance with ASTM D 638 after heat aging.
 3. Elongation at Break: 650 percent, minimum, when tested in accordance with ASTM D 638 after heat aging.
 4. Tearing Strength: 12 lbf (53 N), minimum, when tested in accordance with ASTM D 1004 after heat aging.
 5. Color: Same as field membrane.
 6. Acceptable Product: UltraPly TPO Flashing.

- D. Tape Flashing: 5-1/2 inch (140 mm) nominal wide TPO membrane laminated to cured rubber polymer seaming tape, overall thickness 0.065 inch (1.6 mm) nominal; TPO QuickSeam Flashing.
- E. Membrane Adhesive: Nitrile rubber based fluid, formulated for compatibility with the membrane backing and insulation surfaces, specific existing roof surfaces, and other substrates including wood, metal, and masonry; XR Bonding Adhesive by Firestone.
- F. Pourable Sealer: Two-part polyurethane, two-color for reliable mixing; Pourable Sealer by Firestone.
- G. Seam Plates: Steel with barbs and Galvalume coating; corrosion-resistance complying with FM 4470.
- H. Termination Bars: Aluminum bars with integral caulk ledge; 1.3 inches (33 mm) wide by 0.10 inch (2.5 mm) thick; Firestone Termination Bar by Firestone.
- I. Cut Edge Sealant: Synthetic rubber-based, for use where membrane reinforcement is exposed; UltraPly TPO Cut Edge Sealant by Firestone.
- J. General Purpose Sealant: EPDM-based, one part, white general purpose sealant; UltraPly TPO General Purpose Sealant by Firestone.
- K. Molded Flashing Accessories: Unreinforced TPO membrane pre-molded to suit a variety of flashing details, including pipe boots, inside corners, outside corners, etc.; UltraPly TPO Small and Large Pipe Flashing by Firestone.
- L. Roof Walkway Pads: Non-reinforced TPO walkway pads, 0.130 inch (3 mm) by 30 inches (760 mm) by 40 feet (12.19 m) long with patterned traffic bearing surface; UltraPly TPO Walkway Pads by Firestone.
- M. Yellow Safety Strip: To designate areas of caution on the roof or around rooftop objects. 5.5 inches wide (140 mm) by 100 feet long (30 m) strip and nominal 30 mil (0.76 mm) thick yellow TPO membrane laminated to a white, cured, seam tape. Compatible with TPO and EPDM; QuickSeam Yellow Safety Strip by Firestone.

2.04 ROOF INSULATION AND COVER BOARDS

- A. Polyisocyanurate Board Insulation: Closed cell polyisocyanurate foam with black glass reinforced mat laminated to faces, complying with ASTM C 1289 Type II Class 1, with the following additional characteristics:
 1. Thickness: As needed to replace wet insulation.
 2. Size: 48 inches (1220 mm) by 96 inches (2440 mm), nominal.
 3. Exception: Insulation to be attached using adhesive or asphalt may be no larger than 48 inches (1220 mm) by 48 inches (1220 mm), nominal.
 4. R-Value (LTTR): 1.0 inch (25 mm) Thickness: 5.7 R, minimum.
 5. Compressive Strength: 20 psi (138 kPa) when tested in accordance with ASTM C 1289.
 6. Ozone Depletion Potential: Zero; made without CFC or HCFC blowing agents.
 7. Recycled Content: 19 percent post-consumer and 15 percent post-industrial, average.
 8. Acceptable Product: ISO 95+ polyiso board.
- B. Insulation Fasteners: Type and size as required by roof membrane manufacturer for roofing system and warranty to be provided; use only fasteners furnished by roof membrane

manufacturer.

- C. Contact Adhesive: Type as required by roof membrane manufacturer for roofing system and warranty to be provided; use only adhesive furnished by roof membrane manufacturer.
- D. Low Rise Polyurethane Foam Adhesive: Type as required by roof membrane manufacturer for roofing system and warranty to be provided; use only adhesive furnished by roof membrane manufacturer.

2.06 METAL ACCESSORIES

- A. Metal Roof Edging and Fascia: Continuous metal edge member serving as termination of roof membrane and retainer for metal fascia; watertight with no exposed fasteners; mounted to roof edge nailer.
 - 1. Wind Performance:
 - a. Membrane Pull-Off Resistance: 100 lbs/ft (1460 N/m), minimum, when tested in accordance with ANSI/SPRI ES-1 Test Method RE-1, current edition.
 - b. Fascia Pull-Off Resistance: At least the minimum required when tested in accordance with ANSI/SPRI ES-1 Test Method RE-2, current edition.
 - c. Provide product listed in current Factory Mutual Research Corporation Approval Guide with at least FM 1-270 rating.
 - 2. Description: Two-piece; 45 degree sloped galvanized steel sheet edge member securing top and bottom edges of formed metal fascia; Firestone EdgeGard.
 - 3. Fascia Face Height: 5 inches (127 mm).
 - 4. Edge Member Height Above Nailer: 1-1/4 inches (31 mm).
 - 5. Length: 144 inches (3650 mm).
 - 6. Functional Characteristics: Fascia retainer supports while allowing for free thermal cycling of fascia.
 - 7. Aluminum Bar: Continuous 6063-T6 alloy aluminum extrusion with pre-punched slotted holes; miters welded; injection molded EPDM splices to allow thermal expansion.
 - 8. Anchor Bar Cleat: 20 gage, 0.036 inch (0.9 mm) G90 coated commercial type galvanized steel with pre-punched holes.
 - 9. Curved Applications: Factory modified.
 - 10. Fasteners: Factory-provided corrosion resistant fasteners, with drivers; no exposed fasteners permitted.
 - 11. Special Shaped Components: Provide factory-fabricated pieces necessary for complete installation, including miters, scuppers, and end caps; minimum 14 inch (355 mm) long legs on corner pieces.
 - 12. Scuppers: Welded watertight.
 - 13. Accessories: Provide matching brick wall cap, downspout, extenders, and other special fabrications as shown on the drawings.
- B. Parapet Copings: Formed metal coping with galvanized steel anchor/support cleats for capping any parapet wall; watertight, maintenance free, without exposed fasteners; butt type joints with concealed splice plates; mechanically fastened as indicated; Firestone PTCF.
 - 1. Wind Performance:
 - a. At least the minimum required when tested in accordance with ANSI/SPRI ES-1 Test Method RE-3, current edition.

- b. Provide product listed in current Factory Mutual Research Corporation Approval Guide with at least FM 1-90 rating.
2. Description: Coping sections allowed to expand and contract freely while locked in place on anchor cleats by mechanical pressure from hardened stainless steel springs factory attached to anchor cleats; 8 inch (200 mm) wide splice plates with factory applied dual non-curing sealant strips capable of providing watertight seal.
3. Material and Finish: 24 gage, 0.024 inch (0.06 mm) thick galvanized steel with Kynar 500 finish in manufacturer's standard color; matching concealed joint splice plates; factory-installed protective plastic film.
4. Dimensions:
 - a. Wall Width: As indicated on the drawings.
 - b. Piece Length: Minimum 144 inches (3650 mm).
 - c. Curved Application: Factory fabricated in true radius.
5. Anchor/Support Cleats: 20 gage, 0.036 inch (0.9 mm) thick prepunched galvanized cleat with 12 inch (305 mm) wide stainless steel spring mechanically locked to cleat at 72 inches (1820 mm) on center.
6. Special Shaped Components: Provide factory-fabricated pieces necessary for complete installation, including miters, corners, intersections, curves, pier caps, and end caps; minimum 14 inch (355 mm) long legs on corner, intersection, and end pieces.
7. Fasteners: Factory-furnished; electrolytically compatible; minimum pull out resistance of 240 pounds (109 kg) for actual substrate used; no exposed fasteners.

2.06 ACCESSORY MATERIALS

- A. Wood Nailers: PS 20 dimension lumber, Structural Grade No. 2 or better Southern Pine, Douglas Fir; or PS 1, APA Exterior Grade plywood; pressure preservative treated.
 1. Width: 3-1/2 inches (90 mm), nominal minimum, or as wide as the nailing flange of the roof accessory to be attached to it.
 2. Thickness: Same as thickness of roof insulation.

PART 3 INSTALLATION

3.01 GENERAL

- A. Install roofing, insulation, flashings, and accessories in accordance with roofing manufacturer's published instructions and recommendations for the specified roofing system. Where manufacturer provides no instructions or recommendations, follow good roofing practices and industry standards. Comply with federal, state, and local regulations.
- B. Obtain all relevant instructions and maintain copies at project site for duration of installation period.
- C. Do not start work until Pre-Installation Notice has been submitted to manufacturer as notification that this project requires a manufacturer's warranty.
- D. Perform work using competent and properly equipped personnel.
- E. Temporary closures, which ensure that moisture does not damage any completed section of the new roofing system, are the responsibility of the applicator. Completion of flashings, terminations, and temporary closures shall be completed as required to provide a watertight

condition.

- F. Install roofing membrane only when surfaces are clean, dry, smooth and free of snow or ice; do not apply roofing membrane during inclement weather or when ambient conditions will not allow proper application; consult manufacturer for recommended procedures during cold weather. Do not work with sealants and adhesives when material temperature is outside the range of 60 to 80 degrees F (15 to 25 degrees C).
- G. Protect adjacent construction, property, vehicles, and persons from damage related to roofing work; repair or restore damage caused by roofing work.
 - 1. Protect from spills and overspray from bitumen, adhesives, sealants and coatings.
 - 2. Particularly protect metal, glass, plastic, and painted surfaces from bitumen, adhesives, and sealants within the range of wind-borne overspray.
 - 3. Protect finished areas of the roofing system from roofing related work traffic and traffic by other trades.
- H. Until ready for use, keep materials in their original containers as labeled by the manufacturer.
- I. Consult membrane manufacturer's instructions, container labels, and Safety Data Sheets (SDS) for specific safety instructions. Keep all adhesives, sealants, primers and cleaning materials away from all sources of ignition.

3.02 EXAMINATION

- A. Examine roof deck to determine that it is sufficiently rigid to support installers and their mechanical equipment and that deflection will not strain or rupture roof components or deform deck.
- B. Verify that surfaces and site conditions are ready to receive work. Correct defects in the substrate before commencing with roofing work.
- C. Examine roof substrate to verify that it is properly sloped to drains.
- D. Verify that the specifications and drawing details are workable and not in conflict with the roofing manufacturer's recommendations and instructions; start of work constitutes acceptable of project conditions and requirements.

3.03 PREPARATION

- A. Take appropriate measures to ensure that fumes from adhesive solvents are not drawn into the building through air intakes.
- B. Prior to proceeding, prepare existing roof surface so that it is clean, dry, and smooth. Cut existing membrane as required by roofing manufacturer.
- C. Fill all surface voids in the immediate substrate that are greater than 1/4 inch (6 mm) wide with fill material acceptable insulation to membrane manufacturer.
- D. Seal, grout, or tape deck joints, where needed, to prevent material seepage into building.

3.05 INSULATION

- A. Install insulation in configuration and with attachment method(s) specified in PART 2, under Roofing System as needed to replace wet or damaged insulation.
- B. Install insulation in a manner that will not compromise the vapor retarder integrity.

- C. Install only as much insulation as can be covered with the completed roofing system before the end of the day's work or before the onset of inclement weather.
- D. Lay roof insulation in courses parallel to roof edges.
- E. Neatly and tightly fit insulation to all penetrations, projections, and nailers, with gaps not greater than 1/4 inch (6 mm). Fill gaps greater than 1/4 inch (6 mm) with acceptable insulation. Do not leave the roofing membrane unsupported over a space greater than 1/4 inch (6 mm).

Retain following elements as applicable to your project, eliminate others;

- A. Mechanical Fastening: Using specified fasteners and insulation plates, engage fasteners through insulation into deck to depth and in pattern required by Factory Mutual for FM Class specified in PART 2 and membrane manufacturer, whichever is more stringent.
- B. Adhesive Attachment: Using specified adhesive, engage deck to pattern and extent required by Factory Mutual for FM Class specified in PART 2 and membrane manufacturer, whichever is more stringent.

3.06 SINGLE-PLY MEMBRANE INSTALLATION

- A. Beginning at low point of roof, place membrane without stretching over substrate and allow to relax at least 30 minutes before attachment or splicing; in colder weather allow for longer relax time.
- B. Lay out the membrane pieces so that field and flashing splices are installed to shed water.
- C. Install membrane without wrinkles and without gaps or fish mouths in seams; bond and test seams and laps in accordance with membrane manufacturer's instructions and details.
- D. Install membrane adhered to the substrate, with edge securement as specified.
 - 1. Mechanically attach Membrane: Attach Membrane with heavy duty screws as required for warranty requested.
- E. Edge Securement: Secure membrane at all locations where membrane terminates or goes through an angle change greater than 2 in 12 inches (1:6) using mechanically fastened reinforced perimeter fastening strips, plates, or metal edging as indicated or as recommended by roofing manufacturer.
 - 1. Exceptions: Round pipe penetrations less than 18 inches (460 mm) in diameter and square penetrations less than 4 inches (200 mm) square.
 - 2. Metal edging is not merely decorative; ensure anchorage of membrane as intended by roofing manufacturer.

3.07 FLASHING AND ACCESSORIES INSTALLATION

- A. Install flashings, including laps, splices, joints, bonding, adhesion, and attachment, as required by membrane manufacturer's recommendations and details.
- B. Metal Accessories: Install metal edgings, gravel stops, and copings in locations indicated on the drawings, with horizontal leg of edge member over membrane and flashing over metal onto membrane.
 - 1. Follow roofing manufacturer's instructions.
 - 2. Remove protective plastic surface film immediately before installation.
 - 3. Install water block sealant under the membrane anchorage leg.

4. Flash with manufacturer's recommended flashing sheet unless otherwise indicated.
 5. Where single application of flashing will not completely cover the metal flange, install additional piece of flashing to cover the metal edge.
 6. If the roof edge includes a gravel stop and sealant is not applied between the laps in the metal edging, install an additional piece of self-adhesive flashing membrane over the metal lap to the top of the gravel stop; apply seam edge treatment at the intersections of the two flashing sections.
 7. When the roof slope is greater than 1:12, apply seam edge treatment along the back edge of the flashing.
- C. Existing Scuppers: Remove scupper and install new scupper.
- D. Roofing Expansion Joints: Install as shown on drawings and as recommended by roofing manufacturer.
- E. Flashing at Walls, Curbs, and Other Vertical and Sloped Surfaces: Install weathertight flashing at all walls, curbs, parapets, curbs, skylights, and other vertical and sloped surfaces that the roofing membrane abuts to; extend flashing at least 8 inches (200 mm) high above membrane surface.
1. Use the longest practical flashing pieces.
 2. Evaluate the substrate and overlay and adjust installation procedure in accordance with membrane manufacturer's recommendations.
 3. Complete the splice between flashing and the main roof sheet with specified splice adhesive before adhering flashing to the vertical surface.
 4. Provide termination directly to the vertical substrate as shown on roof drawings.
- F. Roof Drains:
1. Existing Drains: Remove all existing flashings, drain leads, roofing materials and cement from the drain; remove clamping ring.
 2. Taper insulation around drain to provide smooth transition from roof surface to drain. Use specified pre-manufactured tapered insulation with facer or suitable bonding surface to achieve slope; slope not to exceed manufacturer's recommendations.
 3. Position membrane, then cut a hole for roof drain to allow 1/2 to 3/4 inch (12 to 19 mm) of membrane to extend inside clamping ring past drain bolts.
 4. Make round holes in membrane to align with clamping bolts; do not cut membrane back to bolt holes.
 5. Apply sealant on top of drain bowl where clamping ring seats below the membrane
 6. Install roof drain clamping ring and clamping bolts; tighten clamping bolts to achieve constant compression.
- G. Flashing at Penetrations: Flash all penetrations passing through the membrane; make flashing seals directly to the penetration.
1. Pipes, Round Supports, and Similar Items: Flash with specified pre-molded pipe flashings wherever practical; otherwise use specified self-curing elastomeric flashing.
 2. Pipe Clusters and Unusual Shaped Penetrations: Provide penetration pocket at least 2 inches (50 mm) deep, with at least 1 inch (25 mm) clearance from penetration, sloped to shed water.
 3. Structural Steel Tubing: If corner radii are greater than 1/4 inch (6 mm) and longest side of tube does not exceed 12 inches (305 mm), flash as for pipes; otherwise, provide a standard curb with flashing.

4. Flexible and Moving Penetrations: Provide weather tight gooseneck set in sealant and secured to deck, flashed as recommended by manufacturer.

3.08 FINISHING AND WALKWAY INSTALLATION

- A. Install walkways at access points to the roof, around rooftop equipment that may require maintenance, and where indicated on the drawings.
- B. Walkway Pads: Adhere to the roofing membrane, spacing each pad at minimum of 1.0 inch (25 mm) and maximum of 3.0 inches (75 mm) from each other to allow for drainage.
 1. If installation of walkway pads over field fabricated splices or within 6 inches (150 mm) of a spliced edge cannot be avoided, adhere another layer of flashing over the splice and extending beyond the walkway pad a minimum of 6 inches (150 mm) on either side.
 2. Prime the membrane, remove the release paper on the pad, press in place, and walk on pad to ensure proper adhesion.

3.09 FIELD QUALITY CONTROL

- A. Inspection by Manufacturer: Provide final inspection of the roofing system by a Technical Representative employed by roofing system manufacturer specifically to inspect installation for warranty purposes (i.e. not a sales person).
- B. Perform all corrections necessary for issuance of warranty.

3.10 CLEANING

- A. Clean all contaminants generated by roofing work from building and surrounding areas, including bitumen, adhesives, sealants, and coatings.
- B. Repair or replace building components and finished surfaces damaged or defaced due to the work of this section; comply with recommendations of manufacturers of components and surfaces.
- C. Remove leftover materials, trash, debris, equipment from project site and surrounding areas.

3.11 PROTECTION

- A. Where construction traffic must continue over finished roof membrane, provide durable protection and replace or repair damaged roofing to original condition.



POCATELLO/CHUBBUCK SCHOOL DISTRICT 25

LEARNING TODAY FOR THE POSSIBILITIES OF TOMORROW

BID PROPOSAL 2024 Reinforced Roofing Project

Board of Trustees
Pocatello/Chubbuck School District No. 25
3115 Pole Line Road
Pocatello, ID 83201

Date: _____

Company Name

We, the undersigned Bidder agrees, if this bid is accepted, to enter into an agreement with Owner to furnish all labor, materials, tools, and equipment and complete all work called for by these specifications under the supervision of the School Plant Coordinator and the Director of Business Operations, for the sum of:

<u>PROJECT</u>	<u>AMOUNT</u>
Project 1 – Century High School, 7801 Diamondback Way	\$ _____
Project 2 – Highland High School, 1800 Bench Road	\$ _____
Project 3 – Edahow Elementary School, 2020 Pocatello Creek Rd	\$ _____
Project 4 – Indian Hills Elementary, 666 Cheyenne	\$ _____
TOTAL BID	\$ _____

We further acknowledge Addendum(s) Received. No. _____, dated _____.

Work can begin June 3, 2024 and must be completed by August 2, 2024.

The Board of Trustees reserves the right to reject any/or all bids or to waive any informalities, or to accept the bid or bids deemed best for Pocatello/Chubbuck School District No. 25, Bannock County, Pocatello, Idaho.

Respectfully submitted,

- Attached, if applicable, is a listing of subcontractors names and addresses for this project.
- Attached is our Affidavit of Alcohol and Drug-Free Worksite, as pursuant to Idaho Code 72-1717.
- Attached is Bidder Certification Form.

Company Name

Authorized Signature / Date

Address

Title

City, State, Zip

Public Works License Number

Phone / Fax Number

Worker's Comp & Liability Insurance Exp. Date

Email, if applicable

CONTRACTOR'S AFFIDAVIT
CONCERNING ALCOHOL AND DRUG-FREE WORKPLACE

STATE OF _____

COUNTY OF _____

Pursuant to the Idaho Code, Section 72-1717, I, the undersigned, being duly sworn, depose and certify that named contractor is in compliance with the provisions of Idaho Code section 72-1717; that named contractor provides a drug-free workplace program that complies with the provisions of Idaho Code, title 72, chapter 17 and will maintain such program throughout the life of a state construction contract and that named contractor shall subcontract work only to subcontractors meeting the requirements of Idaho Code, section 72-1717(1)(a).

Name

Authorized Signature / Date

Company Name

Subscribed and sworn to before me this _____ day of _____, 2024.

Commission expires:

NOTARY PUBLIC, residing at:

BIDDER CERTIFICATION FORM

1. **Debarment and Suspension** – In submitting this bid proposal, we hereby certify that we have not been suspended or in any way excluded from Federal procurement actions by any Federal Agency. We fully understand that if information contrary to this certification subsequently becomes available, such evidence may be grounds for non-award or nullification of a bid contract.
2. **Anti-Collusion** – In submitting this bid proposal, we hereby certify this proposal was developed and prepared without any collusion with any competing bidder or District employee. The content of this proposal has not been disclosed to any competing or potentially competing bidder prior to the proposal due date and time. Furthermore, no action to persuade any person, partnership or corporation to submit or withhold a bid has been made.
3. **Anti-Lobbying** – In submitting this bid proposal, we hereby certify that to the best of our knowledge and belief, no appropriated Federal funds have been paid or will be paid by or on behalf of person associated with this proposal to any person for influencing or attempting to influence and officer or employee of any agency, a member of Congress, an office or employee of Congress or an employee of a member of Congress in connection with the awarding of any Federal contract, the making of any Federal grant, the making of any Federal loan, the entering into of any cooperative agreement and the extension, continuation, renewal, amendment or modification of any Federal contract, grant, loan or cooperative agreement.
4. **National Sexual Offender Registry** – In submitting this bid proposal, you certify to the District that your company will prohibit any persons in your employ who are registered or required to register under the Idaho Sex Offender Registration Act from participation in company business with the District if such participation would require them to be present on school property. You certify further that you have cross checked such employees against the National Sex Offender Registry found at the following web link: <http://www.nsopr.gov/>

Signed: _____ Date: _____

Name & Title: _____

Company: _____ Phone: _____

Address: _____

City/State/Zip: _____