

January 17, 2023

Kevin Roberts  
Professional Service Industries, Inc.  
11826 Borman Dr  
Maryland Heights, MO 63146  
TEL: (314) 432-8073  
FAX: (314) 432-5119



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

**RE:** Edgar Road Elementary 0029-5660

**WorkOrder:** 22121568

Dear Kevin Roberts:

TEKLAB, INC received 33 samples on 12/27/2022 13:50:00 for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Aaron Renner  
Project Manager  
(630)324-6855  
[arenner@teklabinc.com](mailto:arenner@teklabinc.com)



## Report Contents

<http://www.teklabinc.com/>

---

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

---

**This reporting package includes the following:**

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

### Abbr Definition

- \* Analytes on report marked with an asterisk are not NELAP accredited
- CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.
- CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.
- DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.
- DNI Did not ignite
- DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.
- ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.
- IDPH IL Dept. of Public Health
- LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.
- LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.
- MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."
- MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).
- MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).
- MW Molecular weight
- NC Data is not acceptable for compliance purposes
- ND Not Detected at the Reporting Limit
- NELAP NELAP Accredited
- PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.
- RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.
- RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).
- SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.
- Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.
- TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"
- TNTC Too numerous to count ( > 200 CFU )

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

---

### Qualifiers

- |   |  |
|---|--|
| # - Unknown hydrocarbon                               | B - Analyte detected in associated Method Blank              |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range                           |
| H - Holding times exceeded                            | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits        | M - Manual Integration used to determine area response       |
| ND - Not Detected at the Reporting Limit              | R - RPD outside accepted recovery limits                     |
| S - Spike Recovery outside recovery limits            | T - TIC(Tentatively identified compound)                     |
| X - Value exceeds Maximum Contaminant Level           |  |



# Case Narrative

<http://www.teklabinc.com/>

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

**Cooler Receipt Temp:** NA °C

This report was revised on January 17, 2023. The reason for the revision is to reduce the reporting limit for select samples in order to meet regulation requirements. Please replace report dated January 10, 2023 with this report. AR 1/17/23

## Locations

### Collinsville

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** jhriley@teklabinc.com

### Springfield

**Address** 3920 Pintail Dr  
Springfield, IL 62711-9415  
**Phone** (217) 698-1004  
**Fax** (217) 698-1005  
**Email** KKlostermann@teklabinc.com

### Kansas City

**Address** 8421 Nieman Road  
Lenexa, KS 66214  
**Phone** (913) 541-1998  
**Fax** (913) 541-1998  
**Email** jhriley@teklabinc.com

### Collinsville Air

**Address** 5445 Horseshoe Lake Road  
Collinsville, IL 62234-7425  
**Phone** (618) 344-1004  
**Fax** (618) 344-1005  
**Email** EHurley@teklabinc.com

### Chicago

**Address** 1319 Butterfield Rd.  
Downers Grove, IL 60515  
**Phone** (630) 324-6855  
**Fax**  
**Email** arenner@teklabinc.com



## Accreditations

<http://www.teklabinc.com/>

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2023	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2023	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2023	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2023	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2023	Collinsville
Illinois	IDPH	17584		5/31/2023	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2023	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



# Laboratory Results

<http://www.teklabinc.com/>

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

**Matrix:** DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
<b>EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)</b>									
<b>Lead</b>									
22121568-001A	ER-WC-Café-1-1	NELAP		1.0	< 1.0	µg/L	1	01/08/2023 17:09	12/22/2022 10:33
22121568-002A	ER-WC-Café-1-2	NELAP		1.0	< 1.0	µg/L	1	01/09/2023 14:47	12/22/2022 10:34
22121568-003A	ER-KF-Kit-1-3	NELAP		1.0	1.5	µg/L	1	01/08/2023 17:14	12/22/2022 10:36
22121568-004A	ER-KF-Kit-1-4	NELAP		1.0	9.3	µg/L	1	01/08/2023 17:18	12/22/2022 10:37
22121568-005A	ER-DF-118-1-5	NELAP		1.0	< 1.0	µg/L	1	01/06/2023 22:21	12/22/2022 10:40
22121568-006A	ER-F-116-1-6	NELAP		1.0	< 1.0	µg/L	5	01/07/2023 01:11	12/22/2022 10:41
22121568-007A	ER-DF-CA-1-7	NELAP		1.0	< 1.0	µg/L	1	01/06/2023 22:26	12/22/2022 10:42
22121568-008A	ER-DF-CA-1-8	NELAP		1.0	< 1.0	µg/L	1	01/06/2023 22:30	12/22/2022 10:43
22121568-009A	ER-DF-109-1-9	NELAP		1.0	< 1.0	µg/L	1	01/09/2023 17:01	12/22/2022 10:44
22121568-010A	ER-DF-105-1-10	NELAP		1.0	1.4	µg/L	1	01/09/2023 16:44	12/22/2022 10:47
22121568-011A	ER-DF-CA-1-11	NELAP		1.0	< 1.0	µg/L	1	01/10/2023 12:19	12/22/2022 10:48
22121568-012A	ER-DF-CA-1-12	NELAP		1.0	< 1.0	µg/L	1	01/09/2023 16:55	12/22/2022 10:49
22121568-013A	ER-DF-100-1-13	NELAP		1.0	1.0	µg/L	1	01/09/2023 20:34	12/22/2022 10:50
22121568-014A	ER-F-100-1-14	NELAP		1.0	5.3	µg/L	1	01/09/2023 20:40	12/22/2022 10:51
22121568-015A	ER-F-130-1-15	NELAP		1.0	< 1.0	µg/L	1	01/09/2023 20:46	12/22/2022 10:52
22121568-016A	ER-DF-131-1-16	NELAP		1.0	2.0	µg/L	1	01/09/2023 20:52	12/22/2022 10:53
22121568-017A	ER-DF-132-1-17	NELAP		1.0	< 1.0	µg/L	1	01/09/2023 20:57	12/22/2022 10:54
22121568-018A	ER-DF-133-1-18	NELAP		1.0	1.1	µg/L	1	01/06/2023 23:50	12/22/2022 10:55
22121568-019A	ER-F-134-1-19	NELAP		1.0	< 1.0	µg/L	1	01/09/2023 20:23	12/22/2022 10:56
22121568-020A	ER-WC-LH-1-20	NELAP		1.0	< 1.0	µg/L	1	01/06/2023 23:59	12/22/2022 10:58
22121568-021A	ER-WC-GF-1-21	NELAP		1.0	< 1.0	µg/L	1	01/07/2023 00:04	12/22/2022 10:59
22121568-022A	ER-WC-GF-1-22	NELAP		1.0	< 1.0	µg/L	1	01/07/2023 00:08	12/22/2022 11:00
22121568-023A	ER-F-127-1-23	NELAP		1.0	1.1	µg/L	1	01/07/2023 00:13	12/22/2022 11:01
22121568-024A	ER-F-126-1-24	NELAP		1.0	< 1.0	µg/L	1	01/17/2023 03:00	12/22/2022 11:02
22121568-025A	ER-WC-CB-1-25	NELAP		1.0	< 1.0	µg/L	1	01/03/2023 14:18	12/22/2022 11:03
22121568-026A	ER-DF-125-1-26	NELAP		1.0	< 1.0	µg/L	1	01/03/2023 14:23	12/22/2022 11:04
22121568-027A	ER-F-124-1-27	NELAP		1.0	3.5	µg/L	1	01/03/2023 14:27	12/22/2022 11:05
22121568-028A	ER-DF-122-1-28	NELAP		1.0	2.1	µg/L	1	01/03/2023 14:32	12/22/2022 11:06
22121568-029A	ER-NF-120-1-29	NELAP		1.0	1.3	µg/L	1	01/03/2023 14:49	12/22/2022 11:07
22121568-030A	ER-WC-LLF-LL-30	NELAP		1.0	1.3	µg/L	1	01/03/2023 14:36	12/22/2022 11:10
22121568-031A	ER-SN-Kit-1-31	NELAP		1.0	< 1.0	µg/L	1	01/03/2023 14:41	12/22/2022 10:38
22121568-032A	ER-CF-114-1-32	NELAP		1.0	1.5	µg/L	1	01/03/2023 14:45	12/22/2022 10:45
22121568-033A	ER-IM-Kit-1-33	NELAP		1.0	< 1.0	µg/L	1	01/04/2023 12:40	12/22/2022 10:32



# Receiving Check List

<http://www.teklabinc.com/>

**Client:** Professional Service Industries, Inc.

**Work Order:** 22121568

**Client Project:** Edgar Road Elementary 0029-5660

**Report Date:** 17-Jan-23

**Carrier:** Justin Colp

**Received By:** ANC

**Completed by:**

**Reviewed by:**

**On:**

**On:**

27-Dec-22

27-Dec-22

Lindsey Maddox

Elizabeth A. Hurley

**Pages to follow:** Chain of custody

Extra pages included

- |   |  |                              |  |                                  |
|---|--|------------------------------|--|----------------------------------|
| Shipping container/cooler in good condition?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  | Not Present <input type="checkbox"/>   | Temp °C <b>NA</b>                |
| Type of thermal preservation?                           | None <input checked="" type="checkbox"/> | Ice <input type="checkbox"/> | Blue Ice <input type="checkbox"/>      | Dry Ice <input type="checkbox"/> |
| Chain of custody present?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Chain of custody signed when relinquished and received? | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Chain of custody agrees with sample labels?             | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Samples in proper container/bottle?                     | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Sample containers intact?                               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Sufficient sample volume for indicated test?            | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| All samples received within holding time?               | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |
| Reported field parameters measured:                     | Field <input type="checkbox"/>           | Lab <input type="checkbox"/> | NA <input checked="" type="checkbox"/> |                                  |
| Container/Temp Blank temperature in compliance?         | Yes <input checked="" type="checkbox"/>  | No <input type="checkbox"/>  |  |                                  |

*When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.*

- |   |   |                             |   |
|---|---|-----------------------------|---|
| Water – at least one vial per sample has zero headspace?  | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | No VOA vials <input checked="" type="checkbox"/>      |
| Water - TOX containers have zero headspace?               | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | No TOX containers <input checked="" type="checkbox"/> |
| Water - pH acceptable upon receipt?                       | Yes <input checked="" type="checkbox"/> | No <input type="checkbox"/> | NA <input type="checkbox"/>                           |
| NPDES/CWA TCN interferences checked/treated in the field? | Yes <input type="checkbox"/>            | No <input type="checkbox"/> | NA <input checked="" type="checkbox"/>                |

**Any No responses must be detailed below or on the COC.**

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.



# CHAIN OF CUSTODY

pg. 1 of 4 Work order # 22121508

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Professional Service Industries, Inc.  
**Address:** 11826 Borman Dr  
**City / State / Zip:** Maryland Heights, MO 63146  
**Contact:** Kevin Roberts **Phone:** (314) 432-8073  
**E-Mail:** kevin.roberts@intertek.com **Fax:** \_\_\_\_\_

**Samples on:**  ICE  BLUE ICE  NO ICE NA °C LTG# \_\_\_\_\_  
**Preserved in:**  LAB  FIELD **FOR LAB USE ONLY**  
**Lab Notes**

**Client Comments:**  
Courier

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

Project Name/Number Edgar Road Elementary 0029-5660		Sample Collector's Name <i>Greg Chambers / Kevin Roberts</i>				MATRIX				INDICATE ANALYSIS REQUESTED																																
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers								Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																									
Lab Use Only		Sample Identification		Date/Time Sampled		UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH																			NaHSO4	OTHER											
22121508-001	ER-WC-Cafe-1-1	12/22/27 - 1033		1										X		X																										
-002	ER-WC-Cafe-1-2	- 1034		1										X		X																										
003	ER-KF-Kit-1-3	- 1036		1										X		X																										
-004	ER-KF-Kit-1-4	- 1037		1										X		X																										
-005	ER-DF-118-1-5	- 1040		1										X		X																										
006	ER-F-116-1-6	- 1041		1										X		X																										
-007	ER-DF-CA-1-7	- 1042		1										X		X																										
-008	ER-DF-CA-1-8	- 1043		1										X		X																										
-009	ER-DF-109-1-9	- 1044		1										X		X																										
-010	ER-DF-105-1-10	- 1047		1										X		X																										

Relinquished By		Date/Time		Received By		Date/Time	
<i>J. Gelp</i>		12/27/22 @ 0935		<i>J. Gelp</i>		12/27/22 1240	
<i>J. Gelp</i>		12-27-22 1350		<i>Allison Colson</i>		12/27/22 1350	

# CHAIN OF CUSTODY

pg. 2 of 4 Work order # 22121568

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

<b>Client:</b> Professional Service Industries, Inc.	<b>Samples on:</b> <input type="checkbox"/> ICE <input checked="" type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE _____ °C LTG# _____
<b>Address:</b> 11826 Borman Dr	<b>Preserved In:</b> <input type="checkbox"/> LAB <input checked="" type="checkbox"/> FIELD <b>FOR LAB USE ONLY</b>
<b>City / State / Zip:</b> Maryland Heights, MO 63146	<b>Lab Notes:</b>
<b>Contact:</b> Kevin Roberts <b>Phone:</b> (314) 432-8073	
<b>E-Mail:</b> kevin.roberts@intertek.com <b>Fax:</b>	

Client Comments:

**Courier**

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis? If yes, please provide limits in the comment section.  Yes  No

Project Name/Number Edgar Road Elementary 0029-5660		Sample Collector's Name Greg Chambliss / Kevin Roberts								MATRIX		INDICATE ANALYSIS REQUESTED																							
Results Requested		Billing Instructions		# and Type of Containers								Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead																	
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge)	<input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NaHSO4	OTHER																								
Lab Use Only	Sample Identification	Date/Time Sampled																																	
22121568	ER-DF-CA-1-11	12-22-22 / 1048										X					X																		
	-012 ER-DF-CA-1-12	/ 1049										X					X																		
	-013 ER-DF-100-1-13	/ 1050										X					X																		
	-014 ER-F-100-1-14	/ 1051										X					X																		
	-015 ER-F-130-1-15	/ 1052										X					X																		
	-016 ER-DF-131-1-16	/ 1053										X					X																		
	-017 ER-DF-132-1-17	/ 1054										X					X																		
	-018 ER-DF-133-1-18	/ 1055										X					X																		
	-019 ER-F-134-1-19	/ 1056										X					X																		
	-020 ER-WC-LH-1-20	↓ / 1058										X					X																		

Relinquished By	Date/Time	Received By	Date/Time
J. Cole	12/27/22 @ 0935	J. Cole	12-27-22 1240
J. Cole	12-27-22 1350	Allison Cole	12/27/22 1350

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 77182



# CHAIN OF CUSTODY

**TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005**

**Client:** Professional Service Industries, Inc.  
**Address:** 11826 Borman Dr  
**City / State / Zip:** Maryland Heights, MO 63146  
**Contact:** Kevin Roberts **Phone:** (314) 432-8073  
**E-Mail:** kevin.roberts@intertek.com **Fax:**

**Samples on:**  ICE  BLUE ICE  NO ICE \_\_\_\_\_ °C LTG# \_\_\_\_\_  
**Preserved in:**  LAB  FIELD **FOR LAB USE ONLY**  
**Lab Notes**

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

**Client Comments:**

Courier

Project Name/Number		Sample Collector's Name		MATRIX		INDICATE ANALYSIS REQUESTED																	
Edgar Road Elementary 0029-5660		Greg Daniels / Kevin Roberts		Aquous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead													
Results Requested		Billing Instructions	# and Type of Containers																				
<input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)			UNPRES	HNO3	NaOH	H2SO4	HCL	MeOH	NAHSO4	OTHER													
Lab Use Only	Sample Identification	Date/Time Sampled																					
22121568 021	ER-WC-6F-1-21	12-22-22 / 1059									X												
-022	ER-WC-6F-1-22	/ / 1100									X												
-023	ER-F-127-1-23	/ / 1101									X												
-024	ER-F-126-1-24	/ / 1102									X												
-025	ER-WC-CB-1-25	/ / 1103									X												
-026	ER-DF-125-1-26	/ / 1104									X												
-027	ER-F-124-1-27	/ / 1105									X												
-028	ER-DF-122-1-28	/ / 1106									X												
-029	ER-NF-120-1-29	/ / 1107									X												
-030	ER-WC-UF-11-30	↓ / / 1110									X												

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	12/27/22 @ 0935	<i>[Signature]</i>	12-27-22 1240
J. Cole	12-27-22 1350	Allison Cole	12/27/22 1350

# CHAIN OF CUSTODY

 pg. 4 of 4 Work order # 221215168

TEKLAB, INC. 5445 Horseshoe Lake Road - Collinsville, IL 62234 - Phone: (618) 344-1004 - Fax: (618) 344-1005

**Client:** Professional Service Industries, Inc.  
**Address:** 11826 Borman Dr  
**City / State / Zip:** Maryland Heights, MO 63146  
**Contact:** Kevin Roberts **Phone:** (314) 432-8073  
**E-Mail:** kevin.roberts@intertek.com **Fax:**

**Samples on:**  ICE  BLUE ICE  NO ICE °C LTG#  
**Preserved in:**  LAB  FIELD **FOR LAB USE ONLY**  
**Lab Notes**

**Client Comments:**  
Courier

Are these samples known to be involved in litigation? If yes, a surcharge will apply  Yes  No  
 Are these samples known to be hazardous?  Yes  No  
 Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section.  Yes  No

Project Name/Number Edgar Road Elementary 0029-5660		Sample Collector's Name Greg Chambliss / Kevin Roberts							MATRIX			INDICATE ANALYSIS REQUESTED																	
Results Requested <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other <input type="checkbox"/> 3 Day (50% Surcharge)		Billing Instructions		# and Type of Containers							Aqueous	Drinking Water	Soil	Sludge	Special Waste	Groundwater	Lead												
Lab Use Only		Sample Identification		Date/Time Sampled		UNPRES	HNO3	NaOH	H2SO4	HCL								MeOH	NAHSO4	OTHER									
221215168 031		ER-SN-K4-1-31		12/22/22 / 1038		1								X		X													
032		ER-CF-114-1-32		↓ / 1045		1								X		X													
-033		ER-IM-K4-1-33		↓ / 1032		1								X		X													

Relinquished By	Date/Time	Received By	Date/Time
<i>J. Colp</i>	12/27/22 @ 0935	<i>J. Colp</i>	12-27-22 1240
J. Colp	12-27-22 1350	Allison Colp	12/27/22 1350

The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions.

BottleOrder: 77182

