

June 1, 2022

Barnegat Township Schools
550 Barnegat Blvd. North
Barnegat, NJ 08005

Dear Barnegat Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Barnegat Township Schools tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Barnegat Township Schools will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Testing Results

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Barnegat Township Schools. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 218 samples taken, all but 5 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Barnegat Township Schools has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Donahue Elementary / Room 101 / Sink with Bubbler	22.3	Confirmatory sampling conducted 2/25/22. Sample was below standard.
Donahue Elementary / JTD-PF-KIT-28 / Kitchen / Pot filler	45.1	Pot filler removed on 2/25/22.
Donahue Elementary / Class O, Left Side / Sink with Bubbler	50.5	Confirmatory sampling conducted 2/25/22. Sample was below standard.
Lillian M. Dunfee Elementary / Kitchen / Pot Filler	22.3	Pot filler removed on 2/25/22.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt

school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at barnegatschools.com. For more information about water quality in our schools, contact Ben Fazio at the Facilities Office, 609-698-5824.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Stephen J. Brennan
Business Administrator

Barnegat High School

Field ID	Date Sampled	Concentration in ug/L
BHS-BF-HG2-1B	1/20/2022	<1.00
BHS-SF-FAD-2	1/20/2022	1.72
BHS-SF-KIT-3	1/20/2022	<1.00
BHS-PF-KIT-5	1/20/2022	<1.00
BHS-SF-KIT-6	1/20/2022	1.41
BHS-WC-HCAF-7B	1/20/2022	<1.00
BHS-BF-HNU-8B	1/20/2022	<1.00
BHS-SF-NO-10	1/20/2022	1.82
BHS-SF-NO-11	1/20/2022	<1.00
BHS-BF-GYM1-12B	1/20/2022	<1.00
BHS-WC-HAUD-13B	1/20/2022	<1.00
BHS-WC-MOWR-14	1/20/2022	<1.00
BHS-BF-HA103A-15B	1/20/2022	<1.00
BHS-BF-HA103A-16B	1/20/2022	<1.00
BHS-BF-HC109-17B	1/20/2022	<1.00
BHS-BF-HC109-18B	1/20/2022	<1.00
BHS-SF-TRW1-20	1/20/2022	<1.00
BHS-BF-HC109-21B	1/20/2022	<1.00
BHS-BF-2FWS-22B	1/20/2022	<1.00
BHS-BF-HA205-23B	1/20/2022	<1.00
BHS-BF-HA204-25B	1/20/2022	<1.00
BHS-BF-HA209-26B	1/20/2022	<1.00
BHS-IM-ATO-28	1/20/2022	<1.00
BHS-SF-CON-29	1/20/2022	6.68
FIELD BLANK	1/20/2022	<1.00

Joseph T. Donahue

Field ID	Date Sampled	Concentration in ug/L
1 / JTD-SF-FAC2F-1 / Faculty Room, 2nd Floor	1/21/2022	<1.00
2 / JTD-SB-207-2 / Room 207	1/21/2022	4.90
3 / JTD-SB-206-3 / Room 206	1/21/2022	6.53
4 / JTD-SB-205-4 / Room 205	1/21/2022	2.84
5 / JTD-SB-204-5 / Room 204	1/21/2022	<1.00
6 / JTD-SB-203-6 / Room 203	1/21/2022	1.32
7 / JTD-SB-202-7 / Room 202	1/21/2022	<1.00
8 / JTD-SB-201-8 / Room 201	1/21/2022	<1.00
9 / JTD-SB-200-9 / Room 200	1/21/2022	<1.00
10 / JTD-SB-208SGI-10 / Room 208 SGI	1/21/2022	2.86
11B / JTD-BF-H200-11B / Hallway Near Rm 200	1/21/2022	<1.00
13 / JTD-SB-107-13 / Room 107	1/21/2022	<1.00
14 / JTD-SB-106-14 / Room 106	1/21/2022	1.44
15 / JTD-SB-105-15 / Room 105	1/21/2022	<1.00
16 / JTD-SB-104-16 / Room 104	1/21/2022	<1.00
17 / JTD-SB-103-17 / Room 103	1/21/2022	<1.00
18 / JTD-SB-102-18 / Room 102	1/21/2022	<1.00
19 / JTD-SB-101-19 / Room 101	1/21/2022	22.3
20 / JTD-SB-100-20 / Room 100	1/21/2022	1.17
21 / JTD-SB-108-21 / Room 108	1/21/2022	5.38
22B / JTD-BF-H100-22B / Hallway Near Rm 100	1/21/2022	<1.00
24 / JTD-WC-H123-24 / Hallway Near 123	1/21/2022	<1.00
26B / JTD-BF-GYM-26B / Gymnasium	1/21/2022	<1.00
27 / JTD-SF-KIT-27 / Kitchen	1/21/2022	1.56
28 / JTD-PF-KIT-28 / Kitchen	1/21/2022	45.1
30 / JTD-BRAZ-KIT-30 / Kitchen	1/21/2022	5.11
31 / JTD-SF-NRS-31 / Nurse's Office	1/21/2022	<1.00
32 / JTD-SB-CLJ-32 / Class J	1/21/2022	1.71
33 / JTD-SB-CLA-33 / Class A	1/21/2022	3.69
34B / JTD-BF-HRMA-34B / Hallway Near Room A	1/21/2022	<1.00
36 / JTD-SB-CLA-33 / Class B	1/21/2022	1.11
37 / JTD-SB-CLC-37 / Class C	1/21/2022	7.03
38 / JTD-SB-CLD-38 / Class D	1/21/2022	6.93
39 / JTD-SB-CLE-39 / Class E	1/21/2022	<1.00
40 / JTD-SB-CLF-40 / Class F	1/21/2022	<1.00
41 / JTD-SB-CLG-41 / Class G	1/21/2022	<1.00
42 / JTD-SB-CLI-42 / Class I	1/21/2022	2.30
43 / JTD-SB-FRB-43 / Faculty Room H	1/21/2022	1.54
44 / JTD-SB-CLO-44 / Class O, Left Side	1/21/2022	50.5

Lillian M. Dunfee

LABORATORY SAMPLE ID	FIELD ID	DATE COLLECTED	ANALYTE	RESULT
012201396-0001	1 / LMD-PF-KIT-1 / Kitchen	01/26/22	Lead	22.3
012201396-0001	1 / LMD-PF-KIT-1 / Kitchen	01/26/22	Copper	170
012201396-0002	3 / LMD-SF-KIT-3 / Kitchen	01/26/22	Lead	3.96
012201396-0002	3 / LMD-SF-KIT-3 / Kitchen	01/26/22	Copper	79
012201396-0003	4 / LMD-SF-KIT-4 / Kitchen	01/26/22	Lead	3.15
012201396-0003	4 / LMD-SF-KIT-4 / Kitchen	01/26/22	Copper	85
012201396-0004	5 / LMD-SF-NRS-5 / Nurse's Office	01/26/22	Lead	ND
012201396-0004	5 / LMD-SF-NRS-5 / Nurse's Office	01/26/22	Copper	300
012201396-0005	6B / LMD-BF-H103-6B / Hallway Outside Room 103	01/26/22	Lead	ND
012201396-0005	6B / LMD-BF-H103-6B / Hallway Outside Room 103	01/26/22	Copper	88
012201396-0006	8 / LMD-SB-103-8 / Room 103	01/26/22	Lead	ND
012201396-0006	8 / LMD-SB-103-8 / Room 103	01/26/22	Copper	190
012201396-0007	9 / LMD-SB-102-9 / Room 102	01/26/22	Lead	1.13
012201396-0007	9 / LMD-SB-102-9 / Room 102	01/26/22	Copper	83
012201396-0008	10 / LMD-SB-101-10 / Room 101	01/26/22	Lead	ND
012201396-0008	10 / LMD-SB-101-10 / Room 101	01/26/22	Copper	53
012201396-0009	11 / LMD-SB-100-11 / Room 100	01/26/22	Lead	2.05
012201396-0009	11 / LMD-SB-100-11 / Room 100	01/26/22	Copper	49
012201396-0010	12 / LMD-SF-FAC-12 / Faculty Room	01/26/22	Lead	1.29
012201396-0010	12 / LMD-SF-FAC-12 / Faculty Room	01/26/22	Copper	88
012201396-0011	13B / LMD-BF-H104-13B / Hallway Outside Room 104	01/26/22	Lead	ND
012201396-0011	13B / LMD-BF-H104-13B / Hallway Outside Room 104	01/26/22	Copper	76
012201396-0012	15 / LMD-SB-104-15 / Room 104	01/26/22	Lead	ND
012201396-0012	15 / LMD-SB-104-15 / Room 104	01/26/22	Copper	42
012201396-0013	16 / LMD-SB-105-16 / Room 105	01/26/22	Lead	ND
012201396-0013	16 / LMD-SB-105-16 / Room 105	01/26/22	Copper	43
012201396-0014	17 / LMD-SB-106-17 / Room 106	01/26/22	Lead	ND
012201396-0014	17 / LMD-SB-106-17 / Room 106	01/26/22	Copper	47
012201396-0015	18 / LMD-SB-107-18 / Room 107	01/26/22	Lead	ND
012201396-0015	18 / LMD-SB-107-18 / Room 107	01/26/22	Copper	43
012201396-0016	19 / LMD-SB-108-19 / Room 108	01/26/22	Lead	ND
012201396-0016	19 / LMD-SB-108-19 / Room 108	01/26/22	Copper	35
012201396-0017	20 / LMD-SB-109-20 / Room 109	01/26/22	Lead	ND
012201396-0017	20 / LMD-SB-109-20 / Room 109	01/26/22	Copper	54
012201396-0018	21 / LMD-SB-124-21 / Room 124	01/26/22	Lead	ND
012201396-0018	21 / LMD-SB-124-21 / Room 124	01/26/22	Copper	23
012201396-0019	22 / LMD-SB-122-22 / Room 122	01/26/22	Lead	ND
012201396-0019	22 / LMD-SB-122-22 / Room 122	01/26/22	Copper	42
012201396-0020	23 / LMD-SB-121-23 / Room 121	01/26/22	Lead	ND
012201396-0020	23 / LMD-SB-121-23 / Room 121	01/26/22	Copper	30
012201396-0021	24 / LMD-SB-120-24 / Room 120	01/26/22	Lead	ND
012201396-0021	24 / LMD-SB-120-24 / Room 120	01/26/22	Copper	43
012201396-0022	25 / LMD-SB-119-25 / Room 119	01/26/22	Lead	ND
012201396-0022	25 / LMD-SB-119-25 / Room 119	01/26/22	Copper	42

Lillian M. Dunfee

012201396-0023	26 / LMD-SB-118-26 / Room 118	01/26/22	Lead	ND
012201396-0023	26 / LMD-SB-118-26 / Room 118	01/26/22	Copper	33
012201396-0024	30 / LMD-SB-115-30 / Room 115	01/26/22	Lead	ND
012201396-0024	30 / LMD-SB-115-30 / Room 115	01/26/22	Copper	35
012201396-0025	31 / LMD-SB-114-31 / Room 114	01/26/22	Lead	ND
012201396-0025	31 / LMD-SB-114-31 / Room 114	01/26/22	Copper	36
012201396-0026	32 / LMD-SB-113-32 / Room 113	01/26/22	Lead	ND
012201396-0026	32 / LMD-SB-113-32 / Room 113	01/26/22	Copper	29
012201396-0027	33 / LMD-SB-112-33 / Room 112	01/26/22	Lead	ND
012201396-0027	33 / LMD-SB-112-33 / Room 112	01/26/22	Copper	37
012201396-0028	34 / LMD-SB-111-34 / Room 111	01/26/22	Lead	ND
012201396-0028	34 / LMD-SB-111-34 / Room 111	01/26/22	Copper	46
012201396-0029	35 / LMD-SB-110-35 / Room 110	01/26/22	Lead	ND
012201396-0029	35 / LMD-SB-110-35 / Room 110	01/26/22	Copper	33
012201396-0030	36 / LMD-SB-130-36 / Room 130	01/26/22	Lead	ND
012201396-0030	36 / LMD-SB-130-36 / Room 130	01/26/22	Copper	290
012201396-0031	37B / LMD-BF-H131-37B / Hallway Near Room 131	01/26/22	Lead	ND
012201396-0031	37B / LMD-BF-H131-37B / Hallway Near Room 131	01/26/22	Copper	250
012201396-0032	38B / LMD-BF-HCAF-38B / Cafeteria	01/26/22	Lead	ND
012201396-0032	38B / LMD-BF-HCAF-38B / Cafeteria	01/26/22	Copper	34
012201396-0033	39B / LMD-BF-H123-39B / Hallway Near Room 123A	01/26/22	Lead	ND
012201396-0033	39B / LMD-BF-H123-39B / Hallway Near Room 123A	01/26/22	Copper	100
012201396-0034	41 / Nurses Office	01/26/22	Lead	1.81
012201396-0034	41 / Nurses Office	01/26/22	Copper	260
012201396-0035	Blank	01/26/22	Lead	ND
012201396-0035	Blank	01/26/22	Copper	ND

Russell M. Brackman

Field ID	Date Sampled	Concentration in ug/L
1B / ROB-BF-BLOC-1B / Boy's Locker Room	1/28/2022	<1.00
2B / ROB-BF-E148-2B / Special Services Near E148	1/28/2022	<1.00
3B / ROB-BF-HGYM-3B / Hallway Near Gym.E, Leftmost	1/28/2022	<1.00
4B / ROB-BF-HGYM-4B / Hallway Near Gym.E, Center Left	1/28/2022	<1.00
5B / ROB-BF-HGYM-5B / Hallway Near Gym.E, Center Right	1/28/2022	<1.00
7 / ROB-BF-KIT-7 / Kitchen	1/28/2022	8.85
8 / ROB-STM-KIT-8 / Kitchen	1/28/2022	11.3
9 / ROB-SF-KIT-9 / Kitchen	1/28/2022	3.16
10B / ROB-BF-GLOC-10B / Girl's Locker Room	1/28/2022	<1.00
11 / ROB-IM-FIT-11 / Fitness Room	1/28/2022	<1.00
12B / ROB-BF-H130-12B / Hallway Outside Room 130	1/28/2022	<1.00
14 / ROB-SF-NSE-14 / Nurse's Office	1/28/2022	1.17
15B / ROB-BF-HW101-15B / Hallway Near W101	1/28/2022	<1.00
16B / ROB-BF-HE145-16B / Hallway Near E145	1/28/2022	<1.00
17B / ROB-BF-HE145-17B / Hallway Near E145	1/28/2022	<1.00
18 / ROB-SF-N219-18 / Faculty Room N220	1/28/2022	2.74
19B / ROB-BF-HN19-19B / Hallway Near Rm N219, Left	1/28/2022	<1.00
21B / ROB-BF-HN19-21b / Hallway Near Rm N219, Cent	1/28/2022	<1.00
22B / ROB-BF-HN19-22B / Hallway Near Rm N219, Right	1/28/2022	<1.00
23B / ROB-BF-HS232-23B / Hallway Near Room S232	1/28/2022	<1.00
24B / ROB-BF-HS212-24B / Hallway Near Room S212	1/28/2022	<1.00
Blank	1/28/2022	<1.00

Cecil S. Collins

Field ID	Date Sampled	Concentration in ug/L
1A / CSC-WC-MPR-1A / Multipurpose Room, Right	1/27/2022	<1.00
2A / CSC-WC-MPR-2A / Multipurpose Room, Left	1/27/2022	<1.00
3 / CSC-SF-KIT-3 / Kitchen	1/27/2022	<1.00
4 / CSC-ST-KIT-4 / Kitchen	1/27/2022	11.3
5B / CSC-BF-GYMA-5A / Gymnasium A	1/27/2022	<1.00
6 / CSC-SB-211-6 / Room 211	1/27/2022	1.51
7 / CSC-SB-210-7 / Room 210	1/27/2022	1.80
10 / CSC-SF-NRS-10 / Nurse's Office	1/27/2022	<1.00
11B / CSC-BF-HNRS-11B / Hallway Near Nurse, Left	1/27/2022	<1.00
13B / CSC-BF-H225-13B / Hallway Near Room 225, Left	1/27/2022	<1.00

Robert L. Horbelt

Field ID	Date Sampled	Concentration in ug/L
1 / RLH-SF-KIT-1 / Kitchen	1/27/2022	<1.00
2 / RLH-PF-KIT-21 / Kitchen	1/27/2022	13.9
4 / RLH-SB-518-4 / Room 518	1/27/2022	1.17
5 / RLH-BF-HCONF-5 / Hallway Near Conf. Room	1/27/2022	<1.00
6 / RLH-BF-HCONF-6 / Hallway Near Conf. Room	1/27/2022	<1.00
7 / RLH-SF-NSE-7 / Nurse's Office	1/27/2022	<1.00
8 / RLH-SF-NSE-8 / Nurse Exam Room	1/27/2022	9.26
9 / RLH-SF-FAC-9 / Faculty Room	1/27/2022	<1.00
10 / RLH-SB-501-10 / Room 501	1/27/2022	<1.00
14 / RLH-BF-H503-14 / Hallway Near Room 503	1/27/2022	<1.00
16 / RLH-SB-506-16 / Room 506	1/27/2022	1.37
17 / RLH-SB-507-17 / Room 507	1/27/2022	<1.00
18 / RLH-SB-508-18 / Room 508	1/27/2022	<1.00
21 / RLH-SB-511-21 / Room 511	1/27/2022	<1.00
22 / RLH-SB-512-22 / Room 512	1/27/2022	<1.00
24 / RLH-SB-514-24 / Room 514	1/27/2022	1.66
26 / RLH-BF-H601-26 / Hallway Near Room 601	1/27/2022	<1.00
15 / RLH-SB-505-15 / Room 505	1/27/2022	<1.00
23 / RLH-SB-513-23 / Room 513	1/27/2022	<1.00
25 / RLH-SB-515-25 / Room 515	1/27/2022	1.35
Field Blank	1/27/2022	<1.00

Joseph T. Donahue

Field ID	Date Sampled	Concentration in ug/L
1 JTD-WC-H200-11 Hallway near Room 200	4/6/2022	<1.00
2 JTD-WC-H200-12 Hallway near Room 200	4/6/2022	<1.00
3 JTD-WC-H100-22 Hallway near Room 100	4/6/2022	<1.00
4 JTD-WC-H100-23 Hallway near Room 100	4/6/2022	<1.00
5 JTD-WC-H123-24 Hallway near Room 123	4/6/2022	<1.00
6 JTD-WC-H123-25 Hallway near Room 123	4/6/2022	<1.00
7 JTD-WC-GYM-26 Gymnasium	4/6/2022	<1.00
8 JTD-WC-HRMA-34 Hallway near Room A	4/6/2022	<1.00
9 JTD-WC-HRMA-35 Hallway near Room A	4/6/2022	<1.00
10 Blank	4/6/2022	<1.00

Cecil S. Collins

Field ID	Date Sampled	Concentration in ug/L
1 CSC-WC-MPR-1 Multipurpose Room, Right	4/6/2022	<1.00
2 CSC-WC-MPR-2 Multipurpose Room, Left	4/6/2022	<1.00
3 CSC-WC-GYM-5 Gynasium A	4/6/2022	<1.00
4 CSC-WC-H200-8 Hallway near Room 200, Left	4/6/2022	<1.00
5 CSC-WC-H200-9 Hallway near Room 200, Right	4/6/2022	<1.00
6 CSC-WC-HNRS-11 Hallwaynear Nurse, Left	4/6/2022	<1.00
7 CSC-WC-HNRS-12 Hallwaynear Nurse, Right	4/6/2022	<1.00
8 CSC-WC-H225-13 Hallway near Room 225, Left	4/6/2022	<1.00
9 CSC-WC-H225-14 Hallway near Room 225, Right	4/6/2022	<1.00

Barnegat High School

Field ID	Date Sampled	Concentration in ug/L
1 BHS-WC-HG2-1 Hallway near Gymnasium 2	4/6/2022	<1.00
2 BHS-WC-HCAF-7 Hall outside Cafeteria	4/6/2022	<1.00
3 BHS-WC-HNU-8 Hall near Nurse, Left	4/6/2022	<1.00
4 BHS-WC-HNU-9 Hall near Nurse, Right	4/6/2022	<1.00
5 BHS-WC-GYM1-12 Gymnasium 1	4/6/2022	<1.00
6 BHS-WC-HAUD-13 Hall near Auditorium	4/6/2022	<1.00
7 BHS-WC-HA103A-15 Hall near A103A	4/6/2022	<1.00
8 BHS-WC-HC103A-16 Hall near C103	4/6/2022	<1.00
9 BHS-WC-HC109-17 Hall near B107A	4/6/2022	<1.00
10 BHS-WC-HC109-18 Hall near B101, Left	4/6/2022	<1.00
11 BHS-WC-HC109-18 Hall near B101, Right	4/6/2022	<1.00
12 BHS-WC-HC109-21 Hall near C109	4/6/2022	<1.00
13 BHS-WC-2FWS-22 2nd Floor, West Stairwell	4/6/2022	<1.00
14 BHS-WC-HA205-23 Hall near A205A, Left	4/6/2022	<1.00
15 BHS-WC-HA205-24 Hall near A205A, Right	4/6/2022	<1.00
16 BHS-WC-HC204-25 Hall near C204	4/6/2022	<1.00
17 BHS-WC-HC209-26 Hall near C209A, Left	4/6/2022	<1.00
18 BHS-WC-HC209-27 Hall near C209A, Right	4/6/2022	<1.00

Lillian M. Dunfee

Field ID	Date Sampled	Concentration in ug/L
1 / LMD-WC-H103-6 / Hallway Outside Room 103	4/7/2022	<1.00
2 / LMD-WC-H103-7 / Hallway Outside Room 103	4/7/2022	<1.00
3 / LMD-WC-H104-13 / Hallway Near Room 104	4/7/2022	<1.00
4 / LMD-WC-H104-14 / Hallway Near Room 104	4/7/2022	<1.00
5 / LMD-WC-H115-27 / Hallway Near Room 115 (Left)	4/7/2022	<1.00
6 / LMD-WC-H115-28 / Hallway Near Room 115 (Center)	4/7/2022	<1.00
5 / LMD-WC-H131-37 / Hallway Near Room 131	4/7/2022	<1.00
8 / LMD-WC-HCAF-38 / Cafeteria	4/7/2022	<1.00
9 / LMD-WC-H123-39 / Hallway Near Room 123A	4/7/2022	<1.00
10 / LMD-WC-H123-40 / Hallway Near Room 123A	4/7/2022	<1.00
11 / Field Blank	4/7/2022	<1.00

Russell O. Brackman

Field ID	Date Sampled	Concentration in ug/L
1 / ROB-WC-BLOC-1 / Boy's Locker Room	4/7/2022	<1.00
2 / ROB-WC-E148-2 / Special Services Near E148	4/7/2022	<1.00
3 / ROB-WC-HGYM-3 / Hallway Near Gymnasium E,Leftm	4/7/2022	<1.00
4 / ROB-WC-HGYM-4 / Hallway Near Gymnasium E,CenL	4/7/2022	<1.00
5 / ROB-WC-HGYM-5 / Hallway Near Gymnasium E,CenR	4/7/2022	<1.00
6 / ROB-WC-HGYM-6 / Hallway Near Gymnasium E,Right	4/7/2022	<1.00
7 / ROB-WC-GLOC-10 / Girl's Locker Room	4/7/2022	<1.00
8 / ROB-WC-H130-12 / Hallway Outside Room 130	4/7/2022	<1.00
9 / ROB-WC-H130-13 / Hallway Outside Room 130	4/7/2022	<1.00
10 / ROB-WC-HW101-15 / Hallway Near W101	4/7/2022	<1.00
11 / ROB-WC-HE145-16 / Hallway Near E145	4/7/2022	<1.00
12 / ROB-WC-HE145-17 / Hallway Near E145	4/7/2022	<1.00
13 / ROB-WC-HN19-19 / Hallway Near Room N219,Left	4/7/2022	<1.00
14 / ROB-WC-HN19-20 / Hallway Near Room N219,CenL	4/7/2022	<1.00
15 / ROB-WC-HN19-21 / Hallway Near Room N219,CenR	4/7/2022	<1.00
16 / ROB-WC-HN19-22 / Hallway Near Room N219,Right	4/7/2022	<1.00
17 / ROB-WC-HS232-23 / Hallway Near Room S232	4/7/2022	<1.00
18 / ROB-WC-HS212-24 / Hallway Near Room S212	4/7/2022	<1.00
19 / ROB-WC-HS200-25 / Hallway Near Room S200	4/7/2022	<1.00

Joseph T. Donahue

Field ID	Date Sampled	Concentration in ug/L
1 / JTD-SB-101-19 / Room 101	2/25/2022	11.2
2 / JTD-SB-100-20 / Room 100	2/25/2022	<1.00
3 / JTD-SB-CLO-44 / Class O, Left Side	2/25/2022	10.4
5 / CSC-BF-H200-8B / Hallway Near Room 200, Left	2/25/2022	<1.00
Blank	2/25/2022	<1.00