



District Name: Nixa Public Schools				Project Number: B5237062				State Action Level: 5 ppb		Notes - Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample. *Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.		
Campus Name: Faught Administration Building				Faucet Testing								
Faucet Inventory (outlet types: Classroom Faucet-CF, Hall Fountain-HF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Faucet-OF (describe))												

Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Date	Time	Sampler Name	Results ppb	Notes	Recommendations
Faught Administration Building	2nd floor work room	TF	sink north side	N	FAB-WF-5-001	D	7/27/2023	8:19 AM	Mandy Carlson	1.41		NA
	2nd floor restroom	BF	north side of hallway	Y	FAB-NRR-5-002	D	7/27/2023	8:22 AM	Mandy Carlson	4.26		NA
	2nd floor hallway	WF	water bottle filler	N	FAB-SWF-003	D	7/27/2023	8:26 AM	Mandy Carlson	<1.00		NA
	2nd floor restroom	BF	south side of hallway	Y	FAB-SRR-5-004	D	7/27/2023	8:27 AM	Mandy Carlson	<1.00	faucet was used prior to sampling	Resample
	1st floor hallway restroom	BF	south side of hallway, furthest from door	Y	FAB-1SRR-5-005	D	7/27/2023	8:31 AM	Mandy Carlson	16.9		Take out of service and replace or add filter, perform flush (2nd draw) sampling
	1st floor hallway restroom	BF	south side of hallway, closest to the door	Y	FAB-1SRR-5-006	D	7/27/2023	8:32 AM	Mandy Carlson	6.48		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling.
	southside	WF	taller fountain	N	FAB-1WF-007	D	7/27/2023	8:37 AM	Mandy Carlson	6.01	low water pressure	Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling.
	southside	WF	shorter fountain	N	FAB-1WF-008	D	7/27/2023	8:38 AM	Mandy Carlson	2.37	slow leak	NA
	1st floor hallway restroom	BF	north side of hallway, furthest from door	Y	FAB-1NRR-009	D	7/27/2023	8:40 AM	Mandy Carlson	8.21		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling.
	1st floor hallway restroom	BF	north side of hallway	Y	FAB-1NRR-010	D	7/27/2023	8:41 AM	Mandy Carlson	15.3		Take out of service and replace or add filter, perform flush (2nd draw) sampling
	1st floor work room	TF	sink north side	Y	FAB-WR-5-011	D	7/27/2023	8:43 AM	Mandy Carlson	6.59		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling.
	Gym area	WF	hallway	N	FAB-G-WF-012	D	7/27/2023	8:48 AM	Mandy Carlson	<1.00		NA
	gym area	BF	women's restroom, push button faucet right sink	Y	FAB-WRR-5-013	D	7/27/2023	8:50 AM	Mandy Carlson	1.39		NA
gym area	BF	women's restroom, handle faucet left sink	N	FAB-WRR-5-014	D	7/27/2023	8:50 AM	Mandy Carlson	5.36		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling.	
gym area	BF	men's restroom	Y	FAB-MRR-5-015	D	7/27/2023	8:54 AM	Mandy Carlson	<1.00		NA	

**Red = at or above state action level**  
 ppb = parts per billion  
 < = below laboratory reporting limit





District Name: Nixa Public Schools					Project Number: B5237062				State Action Level: 5 ppb		Notes - Notes are about anything out of the ordinary found during sampling. Examples of Notes: automatic hand sensor, water odor, change in water color, low water flow, irregular water spray, does water become warm/hot, water filter attached to faucet, leaky faucet	
Campus Name: Early Childhood Center											Recommendations - *All samples with a value above 5 ppb should be re-sampled with a Flush sample.	
Faucet Inventory (outlet types: Classroom Faucet-CF, Hall Fountain-HF, Kitchen Faucet-KF, Bath Faucet-BF, Ice Maker-IM, Locker Room Faucet-LF, Water Fountain Chilled-WF, Nurse Room Faucet-NF, Teacher Room Faucet-TF, Shop Faucet-SF, Coffee Maker (Java)-JF, Other Faucet-OF (describe), Bottle Refill Faucet-RF)					Faucet Testing						*Flushing and "Do not drink from faucet" signs are only temporary solutions. *Taking a faucet out of service, filters and/or replacement of lead components are permanent solutions. *Any faucet with a value above 15 ppb should be removed from service and/or replaced immediately. *All values above 5.0 ppb must be remediated as soon as possible. *Elementary schools, Kindergarten, Pre-K and day care are highest priorities.	
Building Name	Floor/Room #/Name	Outlet Type	Outlet Name/Sink/Location	Aerator Screen (Y/N)	Sample #	Type (D,F)	Date	Time	Sampler Name	Results ppb	Notes	Recommendations
	155 store room	OF	sink in store room	Y	ECC-155SR-S-001	D	7/27/2023	10:59 AM	Mandy Carlson	1.11		NA
	155 restroom	BF	restroom sink	Y	ECC-155RR-S-002	D	7/27/2023	11:00 AM	Mandy Carlson	4.38		NA
	Family restroom	BF	near office	Y	ECC-FRR-S-003	D	7/27/2023	11:03 AM	Mandy Carlson	1.91		NA
	Hallway	WF	water fountain near office	N	ECC-H-WF-004	D	7/27/2023	11:09 AM	Mandy Carlson	<1.00		NA
	Hallway	WF	taller left side	N	ECC-H-WF-005	D	7/27/2023	11:10 AM	Mandy Carlson	<1.00		NA
	Hallway	RF	botter filler	Y	ECC-H-BF-006	D	7/27/2023	11:11 AM	Mandy Carlson	<1.00		NA
	boy's restroom	BF	near office, furthest from door	Y	ECC-BRR-S-007	D	7/27/2023	11:14 AM	Mandy Carlson	1.88		NA
	boy's restroom	BF	near office, middle sink	Y	ECC-BRR-S-008	D	7/27/2023	11:14 AM	Mandy Carlson	2.08		NA
	boy's restroom	BF	near office, closest to door	Y	ECC-BRR-S-009	D	7/27/2023	11:15 AM	Mandy Carlson	1.74		NA
	girl's restroom	BF	near office, furthest from door	Y	ECC-GRR-S-010	D	7/27/2023	11:22 AM	Mandy Carlson	2.38		NA
	girl's restroom	BF	near office, middle sink	Y	ECC-GRR-S-011	D	7/27/2023	11:22 AM	Mandy Carlson	1.35		NA
	girl's restroom	BF	near office, closest to door	Y	ECC-GRR-S-012	D	7/27/2023	11:23 AM	Mandy Carlson	1.05		NA
	Room's 114 & 116	BF	restroom between classrooms	Y	ECC-114/116-S-013	D	7/27/2023	11:25 AM	Mandy Carlson	1.52		NA
	Room's 117 & 119	BF	restroom between classrooms	Y	ECC-117/119-S-014	D	7/27/2023	11:27 AM	Mandy Carlson	1.11		NA
	Classroom 124	CF	classroom sink	Y	ECC-124-S-015	D	7/27/2023	11:31 AM	Mandy Carlson	1.57		NA
	Classroom 124	WF	classroom water fountain	N	ECC-124-WF-016	D	7/27/2023	11:32 AM	Mandy Carlson	<1.00		NA
	Classroom 124	BF	classroom restroom	Y	ECC-124RR-S-017	D	7/27/2023	11:32 AM	Mandy Carlson	1.25		NA
	Classroom 128	CF	classroom sink	Y	ECC-128-S-018	D	7/27/2023	11:38 AM	Mandy Carlson	1.5		NA
	Classroom 128	WF	classroom water fountain	Y	ECC-128-WF-019	D	7/27/2023	11:39 AM	Mandy Carlson	<1.00		NA
	Classroom 128	BF	classroom restroom	Y	ECC-128RR-S-020	D	7/27/2023	11:39 AM	Mandy Carlson	2.65		NA
	Nurse office	NF	nurse office sink	Y	ECC-NO-S-021	D	7/27/2023	11:43 AM	Mandy Carlson	2.09		NA
	Nurse office	BF	nurse office restroom sink	Y	ECC-NORR-S-022	D	7/27/2023	11:43 AM	Mandy Carlson	1.22		NA
	Classroom 129	CF	classroom sink	Y	ECC-129-S-023	D	7/27/2023	11:48 AM	Mandy Carlson	1.13		NA
	Classroom 129	WF	classroom water fountain	Y	ECC-129-WF-024	D	7/27/2023	11:49 AM	Mandy Carlson	<1.00		NA
	Classroom 129	BF	classroom restroom	Y	ECC-129RR-S-025	D	7/27/2023	11:49 AM	Mandy Carlson	1.95		NA
	Classroom 133	CF	classroom sink	Y	ECC-133-S-026	D	7/27/2023	11:55 AM	Mandy Carlson	1.05		NA
	Classroom 133	WF	classroom water fountain	Y	ECC-133-WF-027	D	7/27/2023	11:56 AM	Mandy Carlson	<1.00		NA
	Classroom 133	BF	classroom restroom	Y	ECC-133RR-S-028	D	7/27/2023	11:56 AM	Mandy Carlson	1.54	air bubbles in line	NA
	Hallway near 133	WF	right side water fountain	N	ECC-H-WF-029	D	7/27/2023	12:01 AM	Mandy Carlson	2.58		NA
	Hallway near 133	WF	left side water fountain	N	ECC-H-WF-030	D	7/27/2023	12:02 PM	Mandy Carlson	1.58		NA
	boy's restroom near 133	BF	furthest from door	Y	ECC-BRR-S-031	D	7/27/2023	12:05 PM	Mandy Carlson	1.97		NA
	boy's restroom near 133	BF	closest to door	Y	ECC-BRR-S-032	D	7/27/2023	12:05 PM	Mandy Carlson	1.47		NA
	girl's restroom near 133	BF	furthest from door	Y	ECC-GRR-S-033	D	7/27/2023	12:09 PM	Mandy Carlson	1.31		NA
	girl's restroom near 133	BF	closest to door	Y	ECC-GRR-S-034	D	7/27/2023	12:09 PM	Mandy Carlson	2.73		NA
	Classroom 134	CF	classroom sink	Y	ECC-134-S-035	D	7/27/2023	12:15 PM	Mandy Carlson	1.29		NA
	Classroom 134	WF	classroom water fountain	N	ECC-134-WF-036	D	7/27/2023	12:16 PM	Mandy Carlson	<1.00		NA
	Classroom 134	BF	classroom restroom	Y	ECC-134RR-S-037	D	7/27/2023		Mandy Carlson	<1.00		NA
	Kitchen	KF	hand washing sink	Y	ECC-K-HS-038	D	8/4/2023		Mandy Carlson	1.5		NA
	Kitchen	KF	dish sink	Y	ECC-K-DS-039	D	8/4/2023		Mandy Carlson	4.3		NA
	Kitchen	KF	sprayer	Y	ECC-K-S-040	D	8/4/2023		Mandy Carlson	5.1		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling
	Kitchen	KF	dish sink, faucet on the left	Y	ECC-K-DS-041	D	8/4/2023		Mandy Carlson	8.6		Post a "Not for Drinking or Cooking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling
	Kitchen	KF	dish sink, faucet on the right	Y	ECC-K-DS-042	D	8/4/2023		Mandy Carlson	2.6		NA
	Hallway near 138	WF	water fountain, right side	N	ECC-H-WF-043	D	8/4/2023		Mandy Carlson	<1.00		NA
	Hallway near 138	WF	water fountain, left side	N	ECC-H-WF-044	D	8/4/2023		Mandy Carlson	1.1		NA
	Classroom 138	CF	classroom sink	Y	ECC-138-S-045	D	8/4/2023		Mandy Carlson	2.4		NA
	Classroom 138	WF	classroom water fountain	N	ECC-138-WF-046	D	8/4/2023		Mandy Carlson	<1.00		NA
	Classroom 138	BF	classroom restroom sink	Y	ECC-138RR-S-047	D	8/4/2023		Mandy Carlson	1.2		NA
	Restroom near Work Room	BF	restroom on right side	Y	ECC-RR-S-048	D	8/4/2023		Mandy Carlson	5.1		Post a "Not for Drinking" Sign or Flush each morning as temporary measure. Take out of service and/or replace. Perform flush (2nd draw) sampling
	Restroom near Work Room	BF	restroom on left side	Y	ECC-RR-S-049	D	8/4/2023		Mandy Carlson	1.2		NA
	Work Room	TF	sink teacher work room	Y	ECC-WR-S-050	D	8/4/2023		Mandy Carlson	2		NA

Red Bold = at or above state action limit  
 ppb = parts per billion  
 < = below laboratory reporting limit