

**MARCELLUS CENTRAL SCHOOL DISTRICT
Lead Monitoring and Remediation Information
As of December 1, 2016**

On September 6, 2016 the Governor signed into law Chapter 296 of the Laws of 2016. This law requires school districts and BOCES to conduct testing of school potable water sources in occupied buildings and to monitor for lead contamination and remediate where necessary. This legislation also requires that we notify the general public of the test results and, when applicable, efforts to remedy sources of water containing lead levels greater than or equal to 15 parts per billion.

In anticipation of this legislation our facilities department arranged for samples to be taken from water fixtures throughout the district in May of 2016. Samples are collected using a two step approach. The “first draw” is taken early in the morning and used to determine if lead exists within the fixture itself. The “30 second flush” requires that fixtures are run for 30 seconds to determine if lead exists in pipes leading to the fixture.

Samples are then analyzed by Life Science Laboratories, Inc., an independent testing facility located in Syracuse. Their analysis appears below. Test results showing “BDL” indicate sample results that were below detection levels. Fixtures with lead content of 15 parts per billion or greater must be remediated or removed. Those fixtures are highlighted and include a description of the remediation approach used.

After receiving clarification regarding the September 6th legislation the district has collected samples from other fixtures which may be used as a potable water source (e.g. custodial closet sinks, shower heads, bathroom sinks). Results from those collected samples appear below. We will update this document to provide sample results as they are received from Life Science Laboratories.

Building_location	Sample Date	Sample Description	Fixture Type	Test Result	Remediation
KCH Room 21	5/12/16	First Draw	Drinking Fountain	2.5	N/A
KCH Room 21	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Room 22	5/12/16	First Draw	Drinking Fountain	4.6	N/A
KCH Room 22	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Room 23	5/12/16	First Draw	Drinking Fountain	3.4	N/A
KCH Room 23	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Room 26	5/12/16	First Draw	Drinking Fountain	5.3	N/A
KCH Room 26	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Room 27	5/12/16	First Draw	Drinking Fountain	3.6	N/A
KCH Room 27	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Hallway Near Room 103	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH Hallway Near Room 103	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Kitchen	5/12/16	First Draw	Kitchen Faucet	2.1	N/A
KCH Kitchen	5/12/16	30 Second Flush	Kitchen Faucet	BDL	N/A
KCH Cafeteria	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH Cafeteria	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Room 16	5/12/16	First Draw	Drinking Fountain	12.0	N/A
KCH Room 16	5/12/16	30 Second Flush	Drinking Fountain	2.4	N/A
KCH Room 15	5/12/16	First Draw	Drinking Fountain	8.8	N/A
KCH Room 15	5/12/16	30 Second Flush	Drinking Fountain	2.4	N/A
KCH Room 14	5/12/16	First Draw	Drinking Fountain	4.1	N/A
KCH Room 14	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH Room 13	5/12/16	First Draw	Drinking Fountain	3.8	N/A
KCH Room 13	5/12/16	30 Second Flush	Drinking Fountain	1.9	N/A
KCH Room 12	5/12/16	First Draw	Drinking Fountain	5.8	N/A
KCH Room 12	5/12/16	30 Second Flush	Drinking Fountain	2.2	N/A
KCH Room 11	5/12/16	First Draw	Drinking Fountain	4.0	N/A

KCH	Room 11	5/12/16	30 Second Flush	Drinking Fountain	2.1	N/A
KCH	Room 10	5/12/16	First Draw	Drinking Fountain	2.7	N/A
KCH	Room 10	5/12/16	30 Second Flush	Drinking Fountain	1.7	N/A
KCH	Room 09	5/12/16	First Draw	Drinking Fountain	2.6	N/A
KCH	Room 09	5/12/16	30 Second Flush	Drinking Fountain	1.4	N/A
KCH	Room 08	5/12/16	First Draw	Drinking Fountain	12.0	N/A
KCH	Room 08	5/12/16	30 Second Flush	Drinking Fountain	1.9	N/A
KCH	Staff Lounge	5/12/16	First Draw	Kitchen Faucet	3.2	N/A
KCH	Staff Lounge	5/12/16	30 Second Flush	Kitchen Faucet	BDL	N/A
KCH	Room 17	5/12/16	First Draw	Drinking Fountain	14.0	N/A
KCH	Room 17	5/12/16	30 Second Flush	Drinking Fountain	6.7	N/A
KCH	Room 6	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH	Room 6	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 5	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH	Room 5	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 3	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH	Room 3	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 1	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH	Room 1	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 2	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH	Room 2	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 4	5/12/16	First Draw	Drinking Fountain	BDL	N/A
KCH	Room 4	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 27	5/12/16	First Draw	Drinking Fountain	9.3	N/A
KCH	Room 27	5/12/16	30 Second Flush	Drinking Fountain	3.4	N/A
KCH	Room 39	5/12/16	First Draw	Drinking Fountain	18.0	Replaced bubbler
KCH	Room 39	5/12/16	30 Second Flush	Drinking Fountain	4.5	
KCH	Room 40	5/12/16	First Draw	Drinking Fountain	5.4	N/A
KCH	Room 40	5/12/16	30 Second Flush	Drinking Fountain	1.7	N/A
KCH	Nurse's Office	5/12/16	First Draw	Sink	BDL	N/A
KCH	Nurse's Office	5/12/16	30 Second Flush	Sink	BDL	N/A
KCH	Room 53	5/12/16	First Draw	Drinking Fountain	9.1	N/A
KCH	Room 53	5/12/16	30 Second Flush	Drinking Fountain	2.1	N/A
KCH	Room 52	5/12/16	First Draw	Drinking Fountain	4.3	N/A
KCH	Room 52	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 51	5/12/16	First Draw	Drinking Fountain	4.1	N/A
KCH	Room 51	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 50	5/12/16	First Draw	Drinking Fountain	13.0	N/A
KCH	Room 50	5/12/16	30 Second Flush	Drinking Fountain	1.9	N/A
KCH	Room 47	5/12/16	First Draw	Drinking Fountain	4.9	N/A
KCH	Room 47	5/12/16	30 Second Flush	Drinking Fountain	2.7	N/A
KCH	Room 46	5/12/16	First Draw	Drinking Fountain	24.0	Replaced bubbler
KCH	Room 46	5/12/16	30 Second Flush	Drinking Fountain	4.7	
KCH	Room 45	5/12/16	First Draw	Drinking Fountain	7.0	N/A
KCH	Room 45	5/12/16	30 Second Flush	Drinking Fountain	1.6	N/A
KCH	Room 44	5/12/16	First Draw	Drinking Fountain	4.5	N/A
KCH	Room 44	5/12/16	30 Second Flush	Drinking Fountain	BDL	N/A
KCH	Room 23	9/28/2016	First Draw	Sink	14.0	N/A
KCH	Room 26	9/28/2016	First Draw	Sink	5.7	N/A
KCH	Room 22	9/28/2016	First Draw	Sink	3.1	N/A
KCH	Room 27	9/28/2016	First Draw	Sink	4.2	N/A
KCH	Room 21	9/28/2016	First Draw	Sink	3.5	N/A
KCH	Room 100	9/28/2016	First Draw	Sink	9.9	N/A
KCH	Room 110	9/28/2016	First Draw	Sink	5.0	N/A
KCH	Room 111	9/28/2016	First Draw	Sink	3.3	N/A
KCH	Room 112	9/28/2016	First Draw	Sink	3.9	N/A
KCH	Room 109	9/28/2016	First Draw	Sink	15.0	Replace faucet

KCH	Room 108	9/28/2016	First Draw	Sink	7.3	N/A
KCH	Room 113	9/28/2016	First Draw	Sink	3.0	N/A
KCH	Room 107	9/28/2016	First Draw	Sink	44.0	Replace faucet
KCH	Room 114	9/28/2016	First Draw	Sink	5.6	N/A
KCH	Room 115	9/28/2016	First Draw	Sink	4.0	N/A
KCH	Room 116	9/28/2016	First Draw	Sink	12.0	N/A
KCH	Room 117	9/28/2016	First Draw	Sink	10.0	N/A
KCH	Back Hall Faculty Bathroom	9/28/2016	First Draw	Sink	3.0	N/A
KCH	Room 6	9/28/2016	First Draw	Sink	4.5	N/A
KCH	Room 5	9/28/2016	First Draw	Sink	BLD	N/A
KCH	Room 4	9/28/2016	First Draw	Sink	1.4	N/A
KCH	Room 5	9/28/2016	First Draw	Sink	1.5	N/A
KCH	Room 6	9/28/2016	First Draw	Sink	5.5	N/A
KCH	Room 3	9/28/2016	First Draw	Sink	1.7	N/A
KCH	Room 3	9/28/2016	First Draw	Sink	1.6	N/A
KCH	Room 4	9/28/2016	First Draw	Sink	4.6	N/A
KCH	Room 2	9/28/2016	First Draw	Sink	2.2	N/A
KCH	Room 2	9/28/2016	First Draw	Sink	1.6	N/A
KCH	Room 1	9/28/2016	First Draw	Sink	4.5	N/A
KCH	Room 1	9/28/2016	First Draw	Sink	1.1	N/A
KCH	Room 37	9/28/2016	First Draw	Sink	7.9	N/A
KCH	Room 38	9/28/2016	First Draw	Sink	4.3	N/A
KCH	Room 39	9/28/2016	First Draw	Sink	14.0	N/A
KCH	Room 40	9/28/2016	First Draw	Sink	10.0	N/A
KCH	Room 41	9/28/2016	First Draw	Sink	2.6	N/A
KCH	Room 41	9/28/2016	First Draw	Sink	BLD	N/A
KCH	Room 40	9/28/2016	First Draw	Sink	2.6	N/A
KCH	Main Office Bathroom	9/28/2016	First Draw	Sink	BLD	N/A
KCH	Room 41	9/28/2016	First Draw	Sink	BLD	N/A
KCH	Room 41	9/28/2016	First Draw	Sink	10.0	N/A
KCH	Main Office Breakroom	9/28/2016	First Draw	Sink	BLD	N/A
KCH	Room 53	9/28/2016	First Draw	Sink	5.3	N/A
KCH	Room 44	9/28/2016	First Draw	Sink	4.8	N/A
KCH	Room 52	9/28/2016	First Draw	Sink	14.0	N/A
KCH	Room 45	9/28/2016	First Draw	Sink	3.1	N/A
KCH	Room 51	9/28/2016	First Draw	Sink	4.7	N/A
KCH	Room 46	9/28/2016	First Draw	Sink	14.0	N/A
KCH	Room 50	9/28/2016	First Draw	Sink	16.0	Replace faucet
KCH	Room 47	9/28/2016	First Draw	Sink	5.9	N/A
KCH	Café Hall Boys Sink	9/28/2016	First Draw	Sink	1.4	N/A
KCH	Café Hall Girls Sink	9/28/2016	First Draw	Sink	4.5	N/A
KCH	Gym Coach's Office	9/28/2016	First Draw	Sink	88.0	Replace faucet
DMS	Kitchen	5/11/16	First Draw	Drinking Fountain	2.5	N/A
DMS	Kitchen	5/11/16	30 Second Flush	Drinking Fountain	1.2	N/A
DMS	Cafeteria	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Cafeteria	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Staff Lounge	5/11/16	First Draw	Drinking Fountain	1.1	N/A
DMS	Staff Lounge	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Staff Lounge	5/11/16	First Draw	Drinking Fountain	1.5	N/A
DMS	Staff Lounge	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Hallway Near Room 165	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Hallway Near Room 165	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Girl's Locker Room	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Girl's Locker Room	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Boy's Locker Room	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Boy's Locker Room	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Main Hall Near Elevator	5/11/16	First Draw	Drinking Fountain	BLD	N/A

DMS	Main Hall Near Elevator	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	District Office Hallway	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	District Office Hallway	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Superintendent's Bathroom	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Superintendent's Bathroom	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	District Office Kitchen	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	District Office Kitchen	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Room 182	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Room 182	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Hallway Near Room 267	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Hallway Near Room 267	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Home & Careers	5/11/16	First Draw	Kitchen Faucet	27.0	Replaced faucet and valve
DMS	Home & Careers	5/11/16	30 Second Flush	Kitchen Faucet	1.8	
DMS	Home & Careers	5/11/16	First Draw	Kitchen Faucet	18.0	Replaced faucet and valve
DMS	Home & Careers	5/11/16	30 Second Flush	Kitchen Faucet	1.9	
DMS	Home & Careers	5/11/16	First Draw	Kitchen Faucet	14.0	N/A
DMS	Home & Careers	5/11/16	30 Second Flush	Kitchen Faucet	1.2	N/A
DMS	Home & Careers	5/11/16	First Draw	Kitchen Faucet	25.0	Replaced faucet and valve
DMS	Home & Careers	5/11/16	30 Second Flush	Kitchen Faucet	BLD	
DMS	Library Hallway	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Library Hallway	5/11/16	30 Second Flush	Drinking Fountain	1.3	N/A
DMS	Library Sink	5/11/16	First Draw	Kitchen Faucet	BLD	N/A
DMS	Library Sink	5/11/16	30 Second Flush	Kitchen Faucet	BLD	N/A
DMS	Hallway Near Room 242	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Hallway Near Room 242	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Room 250	5/11/16	First Draw	Kitchen Faucet	2.0	N/A
DMS	Room 250	5/11/16	30 Second Flush	Kitchen Faucet	BLD	N/A
DMS	Room 82	5/11/16	First Draw	Kitchen Faucet	3.6	N/A
DMS	Room 82	5/11/16	30 Second Flush	Kitchen Faucet	BLD	N/A
DMS	Boy's Old Locker Room	5/11/16	First Draw	Drinking Fountain	BLD	N/A
DMS	Boy's Old Locker Room	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
DMS	Girl's Old Locker Room	5/11/16	First Draw	Drinking Fountain	30.0	Fixture was removed
DMS	Girl's Old Locker Room	5/11/16	30 Second Flush	Drinking Fountain	15.0	
DMS	Old Locker Room Office	5/11/16	First Draw	Kitchen Faucet	20.0	Replaced faucet
DMS	Old Locker Room Office	5/11/16	30 Second Flush	Kitchen Faucet	3.6	
DMS	Old Boys Locker Room	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Old Girls Locker Room Left Sink	9/28/16	First Draw	Faucet	4.3	N/A
DMS	Old Girls Locker Room Right Sink	9/28/16	First Draw	Faucet	3.7	N/A
DMS	4th Girls Bathroom Left Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	4th Girls Bathroom Middle Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	4th Girls Bathroom Right Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	4th Boys Bathroom Left Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	4th Boys Bathroom Middle Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	4th Boys Bathroom Right Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Old Room 164 Sink	9/28/16	First Draw	Faucet	5.8	N/A
DMS	Nurse ADA Sink	9/28/16	First Draw	Faucet	3.5	N/A
DMS	Men's Faculty Left Sink	9/28/16	First Draw	Faucet	2.9	N/A
DMS	Men's Faculty Middle Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Men's Faculty Right Sink	9/28/16	First Draw	Faucet	1.1	N/A
DMS	Art Room Hall Girls Bathroom Lt Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Art Room Hall Girls Bathroom Mid Sink	9/28/16	First Draw	Faucet	1.2	N/A
DMS	Art Room Hall Girls Bathroom Rt Sink	9/28/16	First Draw	Faucet	1.1	N/A
DMS	Room 107 East Sink Middle	9/28/16	First Draw	Faucet	51.0	Replace faucet
DMS	Room 107 East Sink Right	9/28/16	First Draw	Faucet	18.0	Replace faucet
DMS	Room 107 East Sink Left	9/28/16	First Draw	Faucet	17.0	Replace faucet
DMS	Room 107 West Sink Middle	9/28/16	First Draw	Faucet	14.0	N/A
DMS	Room 107 West Sink Right	9/28/16	First Draw	Faucet	16.0	Replace faucet

DMS	Room 107 West Sink Left	9/28/16	First Draw	Faucet	36.0	Replace faucet
DMS	Room 108 Sink	9/28/16	First Draw	Faucet	8.4	N/A
DMS	Women's Faculty Left Sink	9/28/16	First Draw	Faucet	2.1	N/A
DMS	Women's Faculty Middle Sink	9/28/16	First Draw	Faucet	1.2	N/A
DMS	Women's Faculty Right Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 150 Southeast Sink	9/28/16	First Draw	Faucet	7.6	N/A
DMS	Room 150 South Center Sink	9/28/16	First Draw	Faucet	18.0	Replace faucet
DMS	Room 150 Southwest Sink	9/28/16	First Draw	Faucet	13.0	N/A
DMS	Room 150 West Sink South	9/28/16	First Draw	Faucet	63.0	Replace faucet
DMS	Room 150 West Sink North	9/28/16	First Draw	Faucet	88.0	Replace faucet
DMS	Room 150 Northwest Sink	9/28/16	First Draw	Faucet	59.0	Replace faucet
DMS	Room 150 North Center Sink	9/28/16	First Draw	Faucet	17.0	Replace faucet
DMS	Room 150 Northeast Sink	9/28/16	First Draw	Faucet	7.1	N/A
DMS	Room 150 East Sink	9/28/16	First Draw	Faucet	58.0	Replace faucet
DMS	Room 152 Southeast South Sink	9/28/16	First Draw	Faucet	30.0	Replace faucet
DMS	Room 152 Southeast North Sink	9/28/16	First Draw	Faucet	20.0	Replace faucet
DMS	Room 152 South Center South Sink	9/28/16	First Draw	Faucet	14.0	N/A
DMS	Room 152 South Center North Sink	9/28/16	First Draw	Faucet	14.0	N/A
DMS	Room 152 Southwest South Sink	9/28/16	First Draw	Faucet	28.0	Replace faucet
DMS	Room 152 Southwest North Sink	9/28/16	First Draw	Faucet	18.0	Replace faucet
DMS	Room 152 West Sink South Sink	9/28/16	First Draw	Faucet	8.9	N/A
DMS	Room 152 West Sink North Sink	9/28/16	First Draw	Faucet	14.0	N/A
DMS	Room 152 Northwest North Sink	9/28/16	First Draw	Faucet	35.0	Replace faucet
DMS	Room 152 Northwest South Sink	9/28/16	First Draw	Faucet	14.0	N/A
DMS	Room 152 North Center South Sink	9/28/16	First Draw	Faucet	15.0	Replace faucet
DMS	Room 152 North Center North Sink	9/28/16	First Draw	Faucet	13.0	N/A
DMS	Room 152 Northeast South Sink	9/28/16	First Draw	Faucet	14.0	N/A
DMS	Room 152 Northeast North Sink	9/28/16	First Draw	Faucet	16.0	Replace faucet
DMS	Room 152 Teacher's Sink	9/28/16	First Draw	Faucet	9.4	N/A
DMS	Art Hall Boy's Left Sink	9/28/16	First Draw	Faucet	4.2	N/A
DMS	Art Hall Boy's Right Sink	9/28/16	First Draw	Faucet	3.1	N/A
DMS	Room 165 Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 166A Sink	9/28/16	First Draw	Faucet	2.1	N/A
DMS	Room 166 Handwash Sink	9/28/16	First Draw	Faucet	1.0	N/A
DMS	Room 168A Sink	9/28/16	First Draw	Faucet	1.0	N/A
DMS	Room 168 Handwash Sink	9/28/16	First Draw	Faucet	4.3	N/A
DMS	Room 164 Boys Left Sink	9/28/16	First Draw	Faucet	1.0	N/A
DMS	Room 164 Boys Middle Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 164 Boys Right Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 163 Girls Left Sink	9/28/16	First Draw	Faucet	3.1	N/A
DMS	Room 163 Girls Middle Sink	9/28/16	First Draw	Faucet	2.4	N/A
DMS	Room 163 Girls Right Sink	9/28/16	First Draw	Faucet	1.0	N/A
DMS	Room 161 Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 162 Sink	9/28/16	First Draw	Faucet	1.5	N/A
DMS	Room 160 Sink	9/28/16	First Draw	Faucet	1.1	N/A
DMS	Room 250 Sink	9/28/16	First Draw	Faucet	3.5	N/A
DMS	Room 268 Girls Left Sink	9/28/16	First Draw	Faucet	1.5	N/A
DMS	Room 268 Girls Middle Sink	9/28/16	First Draw	Faucet	3.4	N/A
DMS	Room 268 Girls Right Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 266 Boys Left Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 266 Boys Middle Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 266 Boys Rt Sink	9/28/16	First Draw	Faucet	15.0	Replace faucet
DMS	Room 264 Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 262 Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 261 Sink	9/28/16	First Draw	Faucet	1.1	N/A
DMS	Room 263 Sink	9/28/16	First Draw	Faucet	1.5	N/A
DMS	Room 265 Sink	9/28/16	First Draw	Faucet	BDL	N/A

DMS	Room 267 Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Room 269 Sink	9/28/16	First Draw	Faucet	2.4	N/A
DMS	Girls Room Next to 207 Lt Sink	9/28/16	First Draw	Faucet	1.2	N/A
DMS	Girls Room Next to 207 Mid Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Girls Room Next to 207 Rt Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	Library Boys Bathroom Lt Sink	9/28/16	First Draw	Faucet	1.2	N/A
DMS	Library Boys Bathroom Mid Sink	9/28/16	First Draw	Faucet	3.7	N/A
DMS	Library Boys Bathroom Rt Sink	9/28/16	First Draw	Faucet	2.8	N/A
DMS	Library Hall South End Sink	9/28/16	First Draw	Faucet	100.0	Replace faucet
DMS	5th Grade Hall Girls Left Sink	9/28/16	First Draw	Faucet	2.0	N/A
DMS	Room 236 Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	5th Grade Hall Girls Middle Sink	9/28/16	First Draw	Faucet	1.6	N/A
DMS	5th Grade Hall Girls Right Sink	9/28/16	First Draw	Faucet	1.1	N/A
DMS	5th Grade Hall Boys Left Sink	9/28/16	First Draw	Faucet	BDL	N/A
DMS	5th Grade Hall Boys Middle Sink	9/28/16	First Draw	Faucet	1.6	N/A
DMS	5th Grade Hall Boys Right Sink	9/28/16	First Draw	Faucet	1.5	N/A
SHS	Hallway Near Room 261	5/11/16	First Draw	Drinking Fountain	15.0	Replaced fountain
SHS	Hallway Near Room 261	5/11/16	30 Second Flush	Drinking Fountain	12.0	
SHS	Hallway Near Room 104	5/11/16	First Draw	Drinking Fountain	BLD	N/A
SHS	Hallway Near Room 104	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
SHS	LGI/Gymnasium Hallway	5/11/16	First Draw	Drinking Fountain	BLD	N/A
SHS	LGI/Gymnasium Hallway	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
SHS	Auditorium Hallway Left	5/11/16	First Draw	Drinking Fountain	6.4	N/A
SHS	Auditorium Hallway Left	5/11/16	30 Second Flush	Drinking Fountain	6.0	N/A
SHS	Auditorium Hallway Right	5/11/16	First Draw	Drinking Fountain	6.3	N/A
SHS	Auditorium Hallway Right	5/11/16	30 Second Flush	Drinking Fountain	4.0	N/A
SHS	Girl's Locker Room	5/11/16	First Draw	Drinking Fountain	21.0	Replaced bubbler
SHS	Girl's Locker Room	5/11/16	30 Second Flush	Drinking Fountain	4.0	
SHS	Hallway Near Staff Room	5/11/16	First Draw	Drinking Fountain	28.0	Replaced fountain
SHS	Hallway Near Staff Room	5/11/16	30 Second Flush	Drinking Fountain	7.8	
SHS		5/11/16	First Draw	Drinking Fountain	BLD	N/A
SHS		5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
SHS		5/11/16	First Draw	Drinking Fountain	BLD	N/A
SHS		5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
SHS	Cafeteria	5/11/16	First Draw	Drinking Fountain	2.9	N/A
SHS	Cafeteria	5/11/16	30 Second Flush	Drinking Fountain	3.9	N/A
SHS	Kitchen	5/11/16	First Draw	Kitchen Sink	16.0	Replaced faucet
SHS	Kitchen	5/11/16	30 Second Flush	Kitchen Sink	1.0	
SHS	Hallway Near Room 214	5/11/16	First Draw	Drinking Fountain	BLD	N/A
SHS	Hallway Near Room 214	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
SHS	2nd Floor Staff Room	5/11/16	First Draw	Drinking Fountain	BLD	N/A
SHS	2nd Floor Staff Room	5/11/16	30 Second Flush	Drinking Fountain	BLD	N/A
Kasson	Kitchen Sink (North)	8/18/16	First Draw	Sink	11.0	N/A
Kasson	Kitchen Sink (North)	8/18/16	30 Second Flush	Sink	1.1	N/A
Kasson	Kitchen Sink (Middle)	8/18/16	First Draw	Sink	22.0	Replace faucet
Kasson	Kitchen Sink (Middle)	8/18/16	30 Second Flush	Sink	1.7	
Kasson	Kitchen Sink (South)	8/18/16	First Draw	Sink	7.8	N/A
Kasson	Kitchen Sink (South)	8/18/16	30 Second Flush	Sink	1.2	N/A
Kasson	Boy's Locker Room	8/18/16	First Draw	Drinking Fountain	8.7	N/A
Kasson	Boy's Locker Room	8/18/16	30 Second Flush	Drinking Fountain	1.7	N/A
Kasson	Nurse's Office	8/18/16	First Draw	Sink	19.0	Replace faucet
Kasson	Nurse's Office	8/18/16	30 Second Flush	Sink	2.6	
Kasson	Child Care Office	8/18/16	First Draw	Sink	11.0	N/A
Kasson	Child Care Office	8/18/16	30 Second Flush	Sink	1.0	N/A
Kasson	Room 11	8/18/16	First Draw	Drinking Fountain	6.8	N/A
Kasson	Room 11	8/18/16	30 Second Flush	Drinking Fountain	1.7	N/A
Kasson	Room 13	8/18/16	First Draw	Drinking Fountain	9.4	N/A

Kasson Room 13	8/18/16	30 Second Flush	Drinking Fountain	2.1	N/A
Kasson Library	8/18/16	First Draw	Drinking Fountain	21.0	Replace bubbler
Kasson Library	8/18/16	30 Second Flush	Drinking Fountain	1.5	
Kasson Room 14	8/18/16	First Draw	Drinking Fountain	23.0	Replace bubbler
Kasson Room 14	8/18/16	30 Second Flush	Drinking Fountain	3.0	
Kasson Room 15	8/18/16	First Draw	Drinking Fountain	14.0	N/A
Kasson Room 15	8/18/16	30 Second Flush	Drinking Fountain	2.9	N/A
Kasson Room 17	8/18/16	First Draw	Drinking Fountain	22.0	Replace bubbler
Kasson Room 17	8/18/16	30 Second Flush	Drinking Fountain	3.1	
Kasson Room 16	8/18/16	First Draw	Drinking Fountain	16.0	Replace bubbler
Kasson Room 16	8/18/16	30 Second Flush	Drinking Fountain	2.9	
Kasson North Hallway	8/18/16	First Draw	Sink	11.0	N/A
Kasson North Hallway	8/18/16	30 Second Flush	Sink	1.8	N/A
Kasson Old Nurse's Office	8/18/16	First Draw	Sink	14.0	N/A
Kasson Old Nurse's Office	8/18/16	30 Second Flush	Sink	2.5	N/A
Kasson Room 10	8/18/16	First Draw	Drinking Fountain	4.4	N/A
Kasson Room 10	8/18/16	30 Second Flush	Drinking Fountain	BDL	N/A
Kasson Room 7	8/18/16	First Draw	Drinking Fountain	33.0	Replace bubbler
Kasson Room 7	8/18/16	30 Second Flush	Drinking Fountain	1.5	
Kasson Room 8	8/18/16	First Draw	Drinking Fountain	31.0	Replace bubbler
Kasson Room 8	8/18/16	30 Second Flush	Drinking Fountain	2.7	
Kasson Room 6	8/18/16	First Draw	Drinking Fountain	12.0	N/A
Kasson Room 6	8/18/16	30 Second Flush	Drinking Fountain	6.1	N/A
Kasson Room 5	8/18/16	First Draw	Drinking Fountain	29.0	Replace bubbler
Kasson Room 5	8/18/16	30 Second Flush	Drinking Fountain	4.5	
Kasson Room 4	8/18/16	First Draw	Drinking Fountain	13.0	N/A
Kasson Room 4	8/18/16	30 Second Flush	Drinking Fountain	7.7	N/A
Kasson Room 3	8/18/16	First Draw	Drinking Fountain	42.0	Replace bubbler
Kasson Room 3	8/18/16	30 Second Flush	Drinking Fountain	7.4	
Kasson Room 2	8/18/16	First Draw	Drinking Fountain	33.0	Replace bubbler
Kasson Room 2	8/18/16	30 Second Flush	Drinking Fountain	3.9	
Kasson Room 1	8/18/16	First Draw	Drinking Fountain	50.0	Replace bubbler
Kasson Room 1	8/18/16	30 Second Flush	Drinking Fountain	4.9	