

Kssex Hells School District

102 Hawthorne Road

Essex Hells, New Jersey 07021

973-226-0505

www.efsk-6.org

September, 2016

Dear Parents/Guardians,

Due to the concerns raised about lead in drinking water that was found in several school districts around the State, the Essex Fells School District made a decision to test the lead levels in all drinking fountains and water sources in the district this past March.

The district contracted with New Wave Environmental Group to conduct the tests. Samples were collected on March 24th, 2016, in accordance with State sampling guidelines. According to federal regulations, the Maximum Contaminant Level (MCL) is .015. In all, 57 samples were taken with 12 samples exceeding .015, none of which were drinking fountains. Precautions have been taken to address the 12 sample areas.

The full environmental reports can be found on the district website and in the Business Office.

Please feel free to contact me with any questions or concerns.

Thank you,

Michelle V. Gadaleta

Superintendent / Principal



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325111.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-01

SAMPLE LOCATION: RM. 115 #13 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/1/16

4-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1				
				_

1 101 101 101 101 101 101 101 101 101 1				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

wey reen



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325112.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-02

SAMPLE LOCATION: FAC. ROOM BR #2 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
A STATE OF THE STA				
(4)				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325113.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-03

SAMPLE LOCATION: GIRLS' ROOM #3 LFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
	×			

AND DESCRIPTION OF THE PROPERTY OF THE PROPERT				
			7/	-
		The state of the s		
11				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

any Dein 294706

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325114.0

CLIENT# NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-04

SAMPLE LOCATION: BOYS' ROOM #4 LFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.020	mg/l	0.015	4/1/16

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

any Klein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325115.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474 NJ

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: GIRLS' ROOM #3 RGHT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
		The state of the s		
17				
71				
A Control of the Cont	3.			
A STATE OF THE STA				
II.				·.

<= less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325116.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-06

SAMPLE LOCATION: BOYS' ROOM #4 RGHT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:10

RESULT	UNITS	MCL	DATE ANALYZED
<0.001	mg/l	0.015	4/1/16
			_
		P	***
	The second secon		
		<0.001 mg/l	<0.001 mg/l 0.015

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Haney Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325117.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474 NJ

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-07

SAMPLE LOCATION: ROOM 102 #5 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCI.	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16

				, , , , , , , , , , , , , , , , , , ,
12				
	-			
	Y			

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325118.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-08

SAMPLE LOCATION: ROOM 103 #6 RGHT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.007	mg/l	0.015	4/1/16
			-	
				-
6				
	_	**************************************		
			-	

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Haney Dein



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325119.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-09

SAMPLE LOCATION: ROOM 103 #6 CEN - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.016	mg/l	0.015	4/1/16
The state of the s				

				11.11. 21.22.00 (12.11.11.11.11.11.11.11.11.11.11.11.11.1
The state of the s				

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325120.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-10

SAMPLE LOCATION: ROOM 103 #6 LFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:10

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.021	mg/l	0.015	4/1/16
1				
Control of the Contro				
		77		
20				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein





Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325121.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) REPORT OF Harvey Klein, M.S., Laboratory Director **ANALYSIS**

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-11

SAMPLE LOCATION: FAC ROOM BR #1 112 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
and the second s	_			

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325122.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-12

SAMPLE LOCATION: RM 104 #7 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	4/1/16
		3 1		
The state of the s				

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325123.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-13

SAMPLE LOCATION: WF GYM LEF #12 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
× × × × × × × × × × × × × × × × × × ×				
		A CONTRACTOR OF THE CONTRACTOR		
177				
				_
		2		
· · · · · · · · · · · · · · · · · · ·				

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325124.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-14

SAMPLE LOCATION: WF GYM RHGT #12 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
E W				
			·	

			E	

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325125.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

REPORT OF ANALYSIS

TO: New Wave Environmental

P.O. Box 4124

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-15

SAMPLE LOCATION: CUST CLOSET #10 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:15

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/1/16
9 i: 0				
12				
The state of the s				
The second secon				
The second secon		1		
			\(\frac{\partial}{2}	

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966

email: info@gslabs.com Internet: www.gslabs.com REPORT # 360325126.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-16

SAMPLE LOCATION: HANDICAP #8 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/1/16
		-		
		· · · · · · · · · · · · · · · · · · ·	******	
		W. 1811.		

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325127.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-17

SAMPLE LOCATION: BOYS' ROOM #9 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.027	mg/l	0.015	4/1/16
		2		
-				
×				
			38	
				(4)

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325128.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-18

SAMPLE LOCATION: 105 #11 A - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	4/1/16
77				

<= less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325129.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-19

SAMPLE LOCATION: 105 #11 B - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.019	mg/l	0.015	4/1/16
		The state of the s		
Control of the Contro				
		A PLANE OF THE PARTY OF THE PAR		

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Haney Dein

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325130.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-20

SAMPLE LOCATION: 105 #11 C - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.017	mg/l	0.015	4/1/16
		11. 7. 3. S. 11/14. S. 12. S. 12. S. 12. S. 11. S.		
				- L
, , , , , , , , , , , , , , , , , , , ,				
11244				

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325131.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-21

SAMPLE LOCATION: 105 #11 D - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.059	mg/l	0.015	4/1/16
				i i
-				
		And the second s		NAMES OF THE OWNER OF THE OWNER, WHEN THE OWNE

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325132.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-22

SAMPLE LOCATION: 105 #11 E - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.018	mg/l	0.015	
MANUAL CONTRACTOR OF THE STATE	· · · · · · · · · · · · · · · · · · ·		-	

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325133.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-23

SAMPLE LOCATION: 105 #11 F - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.028	mg/l	0.015	4/1/16
y				
The state of the s			-	_
		*		

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325134.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-24

SAMPLE LOCATION: 207 #13 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/1/16
		The second secon	1:	
40.00				1
N II				
	-			
			11	

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325135.0

CLIENT# NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-25

SAMPLE LOCATION: 207 #13 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:20

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/1/16
		The state of the s		
/				
The second secon				

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

tany Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325136.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-26

SAMPLE LOCATION: 206 #12 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

RESULT	UNITS	MCL	DATE ANALYZED
0.001	mg/l	0.015	4/1/16
		,	
		-	
	1		
	0.001	0.001 mg/l	0.001 mg/l 0.015

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Have Dein 294706

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325137.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-27

SAMPLE LOCATION: 206 #12 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/1/16
		A LICE OF THE PARTY OF THE PART		
				-
				-
WATER STATE OF THE				

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Haney Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325138.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-28

SAMPLE LOCATION: 208 #14 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.024	mg/l	0.015	4/1/16
		THE RELATION OF THE PERSON OF		

		President and the second of th		

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325139.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-29

SAMPLE LOCATION: 208 #14 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

RESULT	UNITS	MCL	DATE ANALYZED
<0.001	mg/l	0.015	4/4/16
		<u> </u>	

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

any Deen



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325140.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-30

SAMPLE LOCATION: GIRLS #15 LEFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/4/16
		7.		
	1 -1			
		-		
And and the state of the state				
				_

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325141.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: GIRLS #15 RHGT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	4/4/16
CINA CONTRACTOR CONTRA				
-		A STATE OF THE STA		
		A MILLION AND AND AND AND AND AND AND AND AND AN		
3				
5				

< = less than, not detected.



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

REPORT OF

ANALYSIS

enelac :

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325142.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-32

SAMPLE LOCATION: FAC ROOM #17 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/4/16
		No. Salas N. Carl Salas Sa		
b and the second				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325143.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-33

SAMPLE LOCATION: BOYS' ROOM #16 LFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/4/16
			· · · · · · · · · · · · · · · · · · ·	
Bentus 11 - 11 - 11 - 11 - 11 - 11 - 11 - 11				
Marin				
11				

THE STATE OF THE S				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966

email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325144.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: BOYS' ROOM #16 RHGT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/4/16
A STATE OF THE STA				
	-			
		The second secon		
			- ()	

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325145.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-35

SAMPLE LOCATION: CUSTODIAL #18 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.072	mg/l	0.015	4/4/16
		1		
				····
	-			
Market State of the State of th				
The second secon				
			.,.	
				ACT 1150-1151-1151-1151-1151-1151-1151-1151
			A STATE OF THE STA	

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325146.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-36

SAMPLE LOCATION: 205 #6 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.026	mg/l	0.015	4/4/16
· ·				

		A 141 - 1		
The state of the s				
	**			
20012				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hamey Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325147.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-37

SAMPLE LOCATION: 205 #6 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.008	mg/l	0.015	4/4/16

		420.0 40.0 40.0 40.0 40.0 40.0 40.0 40.0		
		1		
7				

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325148.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-38

SAMPLE LOCATION: 204 #5 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.011	mg/l	0.015	4/4/16
7				
				_
			-	
			-	
			·	
No. 2 To a structure of the structure of				
				-

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325149.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-39

SAMPLE LOCATION: 204 #5 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/4/16
			· · · · · · · · · · · · · · · · · · ·	
				2

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Have Dein

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325150.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-40

SAMPLE LOCATION: 203 #4 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.010	mg/l	0.015	4/5/16
and the second s				
Address of the second s				
25				

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325151.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-41

SAMPLE LOCATION: 203 #4 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:40

RESULT	UNITS	MCL	DATE ANALYZED
<0.001	mg/l	0.015	4/5/16
			- N

	VIII. 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1		

	<0.001	<0.001 mg/l	<0.001 mg/l 0.015

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325152.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-42

SAMPLE LOCATION: NURSE #11 209 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/5/16
				2
	-			
	-			
ř.				
-			***************************************	

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice. Certified by NJ Dept. of Health, NJDEP #20044, NY Dept. of Health #11550 and PADEP #68-03680.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325153.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-43

SAMPLE LOCATION: 202 #3 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	4/5/16

		,		

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Haney Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325154.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-44

SAMPLE LOCATION: 202 #3 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.002	mg/l	0.015	4/5/16

· · · · · · · · · · · · · · · · · · ·				
		-		
		The state of the s		
				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing
410 Hillside Avenue
Hillside, New Jersey 07205



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325155.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director

REPORT OF
ANALYSIS

TO: New Wave Environmental

P.O. Box 4124 143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-45

SAMPLE LOCATION: FAC #10 202 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/5/16
		and the second s		
				-

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

any Rein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325156.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-46

SAMPLE LOCATION: BOYS' ROOM #8 LFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/5/16
The state of the s				
	-			-
The state of the s				
A		*****		
14				
			×	

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325157.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-47

SAMPLE LOCATION: BOYS' ROOM #8 RHGT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/5/16

	_			
25				
(4)				***************************************

				neros de la composición del composición de la composición de la composición de la composición del composición de la composición de la composición de la composición de la composición del composición de la composición de la composición del compos
				3

<= less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325158.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-48

SAMPLE LOCATION: CUSTODIAL #9 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.007	mg/l	0.015	4/5/16

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325159.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-49

SAMPLE LOCATION: GIRLS' ROOM #7 LFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/5/16

7				

				-

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325160.0

CLIENT# NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-50

SAMPLE LOCATION: GIRLS' ROOM #7 RHGT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/5/16
				1
			- 2	
			<u> </u>	
11				
August 1997				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325161.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

REPORT OF ANALYSIS

TO: New Wave Environmental

P.O. Box 4124

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-51

SAMPLE LOCATION: 201 #2 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.014	mg/l	0.015	4/5/16
				10

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

NJ



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325162.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

ATT: Jerry Bello

8

SAMPLE TYPE: WATER, GRAB SAMPLE SAMPLE ID: EF-52

SAMPLE LOCATION: 201 #2 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:50

07474

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	4/5/16
		1G		

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Haney Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325163.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID:

SAMPLE LOCATION: 200 #1 SINK - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:55

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.005	mg/l	0.015	4/5/16
				(4)

				5
))		
			-	

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325164.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

ANALYSIS

TO: New Wave Environmental

P.O. Box 4124

Mathew Klein, M.S., Founder (1916-1996)

Harvey Klein, M.S., Laboratory Director

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-54

SAMPLE LOCATION: 200 #1 WF - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:55

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	4/5/16
AND THE RESIDENCE OF THE PARTY				

/				

< = less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hang Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325165.0

DATE SUBMITTED: 3/25/16

CLIENT # NEW76

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-55

SAMPLE LOCATION: 200 BR #1 LEFT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:55

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.003	mg/l	0.015	4/5/16
<u> </u>				
			-	
Annual of the section of the factor of the section				
and the same of th				
			-	

< = less than, not detected.



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

ANALYSIS

nelac 1

Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325166.0

CLIENT # NEW76 DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

NJ 07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-56

SAMPLE LOCATION: 200 BR #1 RHGT - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:55

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	4/5/16
The second secon				
	-			
		Hoteland Annual		
			~~~	

<= less than, not detected.

MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Hany Dein



Bacteriological and Chemical Testing 410 Hillside Avenue Hillside, New Jersey 07205

REPORT OF

**ANALYSIS** 



Toll Free 800-273-8901 Telephone 908-688-8900 Fax 908-688-8966 email: info@gslabs.com

Internet: www.gslabs.com REPORT # 360325167.0

CLIENT # NEW76

DATE SUBMITTED: 3/25/16

Mathew Klein, M.S., Founder (1916-1996) Harvey Klein, M.S., Laboratory Director

TO: New Wave Environmental

P.O. Box 4124

143 Cheyenne Way

Wayne

07474

ATT: Jerry Bello

SAMPLE TYPE: WATER, GRAB SAMPLE

SAMPLE ID: EF-57

SAMPLE LOCATION: OUTSIDE WF #14 - ESSEX FELLS

DATE SAMPLED: 3/24/16

TIME SAMPLED: 07:55

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.007	mg/l	0.015	4/5/16
		G G		
7.0				
The state of the s				
			Y).	
<u> </u>				
		*		
T				
		-		

< = less than, not detected.