



Longview School District No. 122
2715 Lilac St
Longview, WA 98632
360-575-7019

ADDENDA NO. 01

Project Name: Mark Morris High School Owner Provided Chiller Replacement
Request for Qualifications
Mechanical Design Services
Release Date: February 16, 2024

Date: February 27, 2024

GENERAL INFORMATION / CLARIFICATION:

Item #	Location/Section:	Description
1.01		Will the design team be required to provide a cost estimate for the design? Should a cost estimating consultant be included as part of the design team? Response: No, the design team will not need to give a cost estimate for the cost of construction, but they will be required to give a proposal to do the design work.
1.02		Will structural improvements to the building be required? Response: No structural improvements to the building will be necessary for this project.
1.03		Change of Scope The school district will no longer be purchasing the chiller. The selected firm will be responsible for sizing/specifying the new chiller using SMARDT chillers as the basis of design.