

Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296097	Univent	A / 1st / A101	Univent, 0-5'	TS-A	Barnes & Jones	3590	1/2"	4	80	80	NIS	No Trap Station Components. Valved Out.
296098	Radiator Trap	A / 1st / A101	Radiator Trap Inside Univent, 0-5'	TS-A	Barnes & Jones	3590	1/2"	4	216	209	OK	Thermostatic Radiator Valve. No Trap Station Components.
296099	Univent	A / 1st / A101B	Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	215	198	OK	No Trap Station Components.
296100	Radiator Trap	A / 1st / A101B	Radiator Trap Inside Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
296169	Univent	A / 1st / A102	Univent, 0-5'	TS-A	Barnes & Jones	3590	1/2"	4	216	212	L	No Trap Station Components.
296170	Radiator Trap	A / 1st / A102	Radiator Trap Inside Univent, 0-5'	TS-A	Barnes & Jones	3590	1/2"	4	216	212	OK	Thermostatic Radiator Valve. No Trap Station Components.
296090	Univent	A / 1st / A106	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217	200	OK	No Trap Station Components.
296091	Radiator Trap	A / 1st / A106	Corner Of Rm, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	216	189	OK	DDC Radiator Valve. No Trap Station Components.
296094	Univent	A / 1st / A107	Right Wall Near Closet, 0-5'	TS-A	Spirax Sarco	N/A	1/2"	4	NA	NA	NA	No Trap Station Components. Cover Is In Wall. Will Need To Cut Wall.
296087	Univent	A / 1st / A109	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217	199	OK	No Trap Station Components.
296088	Radiator Trap	A / 1st / A109	Right Corner, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	216	212	L	DDC Radiator Valve. No Trap Station Components.
296085	Univent	A / 1st / A111	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	178	OK	No Trap Station Components.
296086	Radiator Trap	A / 1st / A111	Univent, 0-5'	TS-A	Barnes & Jones	3GH	1/2"	4	212	198	OK	DDC Radiator Valve. No Trap Station Components.
296083	Univent	A / 1st / A112	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	200	OK	No Trap Station Components.
296084	Radiator Trap	A / 1st / A112	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	3GH	1/2"	4	217	194	OK	DDC Radiator Valve. No Trap Station Components.
296081	Univent	A / 1st / A113	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	215	B	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296082	Radiator Trap	A / 1st / A113	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	3GH	1/2"	4	216 212	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
296078	Univent	A / 1st / A115	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 198	OK	No Trap Station Components.
296077	Univent	A / 1st / A116	Univent, 0-5'	TS-A	Barnes & Jones	122A	1/2"	4	221 218	<b>L</b>	No Trap Station Components.
296092	Univent	A / 1st / A117C	Kitchen Table Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out.
296093	Radiator Trap	A / 1st / A117C	Corner Radiator, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296311	Radiator Trap	A / 1st / A118	Right Wall, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	217 189	OK	DDC Radiator Valve. No Trap Station Components.
296310	Radiator Trap	A / 1st / A119	Back Wall, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	213 214	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296308	Radiator Trap	A / 1st / A120	On Wall, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	214 184	OK	DDC Radiator Valve. No Trap Station Components.
296306	Radiator Trap	A / 1st / A121	On Wall, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	218 214	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
296304	Radiator Trap	A / 1st / A122	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	212 178	OK	DDC Radiator Valve. No Trap Station Components.
296305	Radiator Trap	A / 1st / A122	Left Radiator, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	220 188	OK	DDC Radiator Valve. No Trap Station Components.
296316	Univent	A / 1st / A128	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 189	OK	No Trap Station Components.
296317	Radiator Trap	A / 1st / A128	Radiator In Corner, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	217 189	OK	DDC Radiator Valve. No Trap Station Components.
296314	Univent	A / 1st / A129	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	220 217	<b>L</b>	No Trap Station Components.
296315	Radiator Trap	A / 1st / A129	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	214 212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296312	Univent	A / 1st / A132	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 187	OK	No Trap Station Components.
296313	Radiator Trap	A / 1st / A132	Against Wall, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.
296095	Radiator Trap	A / 1st / Girls Bathroom	On Wall, 0-5'	TS-S	Barnes & Jones	122	1/2"	4	216 212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296096	Radiator Trap	A / 1st / Hallway	Across From A102, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out. DDC Valve Broken Off
296301	Radiator Trap	A / 1st / Hallway	Beginning Of A Bldg Right Side Of Lockers, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	217 198	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296302	Radiator Trap	A / 1st / Hallway	Beginning Of A Bldg Left Side Of Lockers, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	220 186	OK	DDC Radiator Valve. No Trap Station Components.
296307	Drip Leg	A / 1st / Hallway	Opposite Rm A121, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	NA NA	RIP	. Valved Out, Disconnected From System.
296303	Radiator Trap	A / 1st / Men's Bathroom	On Wall, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296309	Radiator Trap	A / 1st / Office Right Of A-116	Right Wall, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296079	Radiator Trap	A / 1st / A115	Right Corner, 0-5'	TS-A	Barnes & Jones	3GH	1/2"	4	216 212	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
296337	Radiator Trap	A / 2nd / A201	Back Right Corner By Water Cooler, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.
296336	Radiator Trap	A / 2nd / A201A	Left Corner Of Rm, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	221 198	OK	DDC Radiator Valve. No Trap Station Components.
296338	Radiator Trap	A / 2nd / A202A	Back Corner, 0-5'	TS-A	N/A	N/A	1/2"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Mounted Desk In Way.
296339	Radiator Trap	A / 2nd / A203	Back Wall, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	80 80	NIS	DDC Radiator Valve. Inlet Isolation. Valved Out.
296340	Univent	A / 2nd / A206	Univent, 0-5'	FT	Barnes & Jones	FT2015-A	3/4"	4	216 200	OK	No Trap Station Components.
296341	Radiator Trap	A / 2nd / A206	Corner Of Rm, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	215 213	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
296342	Univent	A / 2nd / A207	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 206	OK	No Trap Station Components.
296343	Radiator Trap	A / 2nd / A207	Right Wall Radiator, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	221 189	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296344	Radiator Trap	A / 2nd / A208	Left Back Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	215 212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296345	Univent	A / 2nd / A208	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	4	215 200	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296346	Univent	A / 2nd / A211	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217	184	OK	No Trap Station Components.
296347	Radiator Trap	A / 2nd / A211	Right Radiator, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	217	208	OK	DDC Radiator Valve. No Trap Station Components.
296348	Radiator Trap	A / 2nd / A212	Left Radiator, 0-5'	TS-A	Spirax Sarco	125	1/2"	4	216	212	L	DDC Radiator Valve. No Trap Station Components.
296349	Univent	A / 2nd / A212	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215	198	OK	No Trap Station Components.
296352	Univent	A / 2nd / A213	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	214	177	OK	No Trap Station Components.
296353	Radiator Trap	A / 2nd / A213	Right Radiator In Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	214	178	OK	DDC Radiator Valve. No Trap Station Components.
296364	Univent	A / 2nd / A214	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	176	OK	No Trap Station Components.
296355	Radiator Trap	A / 2nd / A214	Radiator Back Wall, 0-5'	TS-A	N/A	N/A	1/2"	4	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. Desk Mounted.
296356	Univent	A / 2nd / A215	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	195	OK	No Trap Station Components.
296357	Radiator Trap	A / 2nd / A215	Radiator In Right Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	213	212	L	DDC Radiator Valve. No Trap Station Components.
296358	Radiator Trap	A / 2nd / A215	Univent Left Side, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	215	178	OK	DDC Radiator Valve. No Trap Station Components.
296611	Univent	A / 2nd / A215	Univent Right Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215	199	OK	No Trap Station Components.
296350	Radiator Trap	A / 2nd / A217B	Right Corner Radiator Under Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	80	80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296351	Univent	A / 2nd / A217B	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	201	OK	No Trap Station Components.
296327	AHU	A / 2nd / A218	Steam Coil In Corner Under Panel, 0-5'	TS-A	Spirax Sarco	125	1/2"	4	216	189	OK	No Trap Station Components.
296328	Radiator Trap	A / 2nd / A218	Radiator In Right Corner Behind Cabinets, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. Loaded Cabinets In Way.
296325	AHU	A / 2nd / A219	Steam Coil In Corner Under Panel, 0-5'	TS-A	Spirax Sarco	125A	1/2"	4	214	212	L	Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296326	Radiator Trap	A / 2nd / A219	Radiator In Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	217 200	OK	DDC Radiator Valve. No Trap Station Components.
296323	AHU	A / 2nd / A220	Steam Coil In Corner Under Panel, 0-5'	TS-A	Spirax Sarco	125	1/2"	4	216 197	OK	No Trap Station Components.
296321	AHU	A / 2nd / A221	Steam Coil In Corner Under Panel, 0-5'	TS-A	Spirax Sarco	125	1/2"	4	216 187	OK	No Trap Station Components.
296322	Radiator Trap	A / 2nd / A221	Radiator Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	215 189	OK	DDC Radiator Valve. No Trap Station Components.
296319	AHU	A / 2nd / A222	Steam Coil Under Panel, 0-5'	TS-A	Spirax Sarco	125A	1/2"	4	215 212	L	No Trap Station Components.
296320	Radiator Trap	A / 2nd / A222	Left Radiator In Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	217 189	OK	DDC Radiator Valve. No Trap Station Components.
296324	Radiator Trap	A / 2nd / A226A	On Wall, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	220 219	B	DDC Radiator Valve. No Trap Station Components.
296331	Univent	A / 2nd / A228	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 198	OK	No Trap Station Components.
296332	Radiator Trap	A / 2nd / A228	Radiator In Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	216 213	B	DDC Radiator Valve. No Trap Station Components.
296333	Univent	A / 2nd / A229	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 199	OK	No Trap Station Components.
296334	Radiator Trap	A / 2nd / A229	Radiator In Right Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	215 213	L	DDC Radiator Valve. No Trap Station Components.
296329	Univent	A / 2nd / A232	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 186	OK	No Trap Station Components.
296330	Radiator Trap	A / 2nd / A232	Radiator In Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	4	214 176	OK	DDC Radiator Valve. No Trap Station Components.
296335	Radiator Trap	A / 2nd / Hallway	Across From A201, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296318	Radiator Trap	A / 2nd / Women's Bathroom	On Wall, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	217 212	L	DDC Radiator Valve. No Trap Station Components.
296080	Univent	A / Basement / 1st	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	214 212	L	No Trap Station Components.
296076	Radiator Trap	A / Basement / Entrance 4	Radiator On Wall, 5-10'	TS-A	Nicholson	N/A	1"	4	212 187	OK	DDC Radiator Valve. No Trap Station Components.
296359	Radiator Trap	A / Ground / A007	Radiator Back Wall001, 0-5'	TS-A	Barnes & Jones	122	1/2"	4	216 198	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296360	Reheat Coil	A / Ground / A007	Reheat Coil Up Above, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	80 80	NIS	No Trap Station Components. Valved Out.
296050	Drip Leg	A / Ground / A016	Against Back Wall, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	80 80	NIS	Inlet Isolation, Strainer, Outlet Isolation. Valved Out.
296055	Drip Leg	A / Ground / B Rm Boiler Rm	Steam Tunnel In Corner, 0-5'	FT	Barnes & Jones	N/A	3/4"	4	NA NA	NA	No Trap Station Components. Confined Space.
296034	Drip Leg	A / Ground / Boiler Rm	Right Upon Entrance In Corner, 10-15'	TS-A	Barnes & Jones	122	1/2"	2	NA NA	RIP	Valved Out, Disconnected From System.
296035	Drip Leg	A / Ground / Boiler Rm	Right Upon Entrance At Corner, Above 15'	FT	Spirax Sarco	FTI15	3/4"	2	80 80	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296036	Drip Leg	A / Ground / Boiler Rm	Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	80 80	NIS	Strainer, Blowdown. Valved Out.
296037	Drip Leg	A / Ground / Boiler Rm	Boiler 1, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	80 80	NIS	Strainer, Blowdown. Valved Out, Disconnected From System.
296038	Drip Leg	A / Ground / Boiler Rm	1st Trap Off Steam Main Left Wall, 10-15'	FT	Barnes & Jones	FT2015-6	1 1/2"	4	218 194	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296039	Drip Leg	A / Ground / Boiler Rm	2nd Trap Off Steam Main Left Wall, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	218 80	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296040	Drip Leg	A / Ground / Boiler Rm	3rd Trap Off Steam Main Left Wall, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 212	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296041	Drip Leg	A / Ground / Boiler Rm	4th Trap Off Steam Main Left Wall, 10-15'	FT	Barnes & Jones	FT2015-6	1 1/2"	4	218 214	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296042	Drip Leg	A / Ground / Boiler Rm (Rm Before Rm That Houses Boilers)	By Stairs Leading Down To Boilers, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296043	Drip Leg	A / Ground / Boiler Rm (Rm Before Rm That Houses Boilers)	By Exit Door, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296044	Drip Leg	A / Ground / Boiler Rm (Rm Before Rm That Houses Boilers)	On Top Of Unit, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 199	OK	Inlet Isolation, Strainer, Outlet Isolation.
296045	Drip Leg	A / Ground / C-146	Entrance, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 215	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296046	Drip Leg	A / Ground / C-146	Left Above Header, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 200	B	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296047	Drip Leg	A / Ground / C-146	Left Side Next To Header, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 189	OK	Inlet Isolation, Strainer, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296048	Drip Leg	A / Ground / C-146	Left Corner Above Steam Tunnel, 5-10'	FT	Barnes & Jones	FTI2015-5	1 1/4"	4	214	189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296049	Drip Leg	A / Ground / C-146	Left Corner On Wall, 5-10'	FT	Barnes & Jones	FTI2015-4	1"	4	218	198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296054	Unit Heater	A / Ground / Hallway	Outside A006, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	80	80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
296051	Drip Leg	A / Ground / Unmarked Rm Right Of A015	Back Wall, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	NA	NA	RIP	Valved Out, Disconnected From System.
300654	Drip Leg	B / Basement / NE Tunnel	25 Ft In, 0-5'	FT	Nicholson	SERIESG6G	3/4"	3	76	76	P	Inlet Isolation, Strainer, Outlet Isolation. Cap Leaking Steam And Condensate.
300655	Drip Leg	B / Basement / NE Tunnel	At 1st Corner, 0-5'	FT	Nicholson	8G	1 1/4"	3	214	207	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Inlet Isolation Leaking Steam And Condensate.
300656	Drip Leg	B / Basement / NE Tunnel	Around 1st Corner, 0-5'	FT	Nicholson	7G	1"	3	216	206	L	Inlet Isolation, Strainer, Outlet Isolation. Inlet Isolation Leaking Steam And Condensate.
300657	Drip Leg	B / Basement / NE Tunnel	At T, 0-5'	FT	Nicholson	8G	1 1/4"	3	217	210	L	Inlet Isolation, Strainer, Outlet Isolation.
300641	Drip Leg	B / Basement / Boiler Rm (Northwest Tunnel)	First Trap Around Corner, 5-10'	FT	Nicholson	7G	1"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300642	Drip Leg	B / Basement / Boiler Rm (Northwest Tunnel)	End Of Corridor Left Once In More Open Space, 5-10'	TS-A	Barnes & Jones	134	3/4"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300643	Drip Leg	B / Basement / Boiler Rm (Northwest Tunnel)	End Of Tunnel Into Large Open Space Middle Of Rm, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300632	Drip Leg	B / Basement / Boiler Rm (Southeast Tunnel)	Towards End Of First Passageway On Wall, 0-5'	FT	Nicholson	8G	1 1/4"	3	215	212	L	Inlet Isolation, Strainer, Outlet Isolation. Inlet Union Leaking Steam.
300633	Drip Leg	B / Basement / Boiler Rm (Southeast Tunnel)	Around First Corner On Wall, 0-5'	FT	Nicholson	8G	1 1/4"	3	215	215	B	Inlet Isolation, Strainer, Outlet Isolation.
300634	Drip Leg	B / Basement / Boiler Rm (Southeast Tunnel)	Direct Middle Of Tunnel After Left Turn By Two Access Areas, 0-5'	FT	Nicholson	8G	1 1/4"	3	216	212	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300653	Reheat Coil	B / Basement / Boiler Rm (Southwest Tunnel)	At Unit In Back, 0-5'	FT	Nicholson	6G	3/4"	3	80 80	NIS	Inlet Isolation, Strainer, Outlet Isolation. Valved Out.
300636	Drip Leg	B / Basement / Boiler Rm (Southwest Tunnel)	At AHU Unit, 5-10'	TS-A	Mepco	1E	1/2"	3	80 80	NIS	No Trap Station Components. Valved Out.
300637	Reheat Coil	B / Basement / Boiler Rm (Southwest Tunnel)	Under Unit, 5-10'	FT	Nicholson	6G	3/4"	3	216 198	OK	Inlet Isolation, Strainer, Outlet Isolation.
300638	Drip Leg	B / Basement / Boiler Rm (Southwest Tunnel)	At Unit, 5-10'	TS-A	Mepco	1E	1/2"	3	216 198	OK	No Trap Station Components.
300639	Drip Leg	B / Basement / Boiler Rm (Southwest Tunnel)	Straight Back Behind Unit, 5-10'	TS-A	Spirax Sarco	RTA125	3/4"	3	216 193	OK	No Trap Station Components.
300640	Drip Leg	B / Basement / Boiler Rm (Southwest Tunnel)	Straight Back At Corner Turning Right, 5-10'	FT	Nicholson	6G	3/4"	3	NA NA	RIP	Valved Out, Disconnected From System.
300644	Drip Leg	B / Basement / C001C Access Panel (Small Tunnel To Left)	Right Around First Corner, 5-10'	TS-S	N/A	N/A	3/4"	3	215 215	L	No Trap Station Components.
300658	Drip Leg	C / Basement / C001-C	1st Trap, 0-5'	FT	Barnes & Jones	FT2015-5	1 1/4"	3	215 193	OK	Inlet Isolation, Strainer.
300659	Drip Leg	C / Basement / C001-C	2nd Trap, 0-5'	FT	Barnes & Jones	FTI2015-8	2"	3	84 84	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation Leaking Condensate.
300660	Drip Leg	C / Basement / C001-C	In Space Left Of 2nd Trap, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	219 173	OK	Inlet Isolation, Strainer, Outlet Isolation.
296821	Unit Heater	C / 1st / 2nd Garage	Outside Office, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	217 189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296822	Radiator Trap	C / 1st / 2nd Garage	Empty Office In Second Garage, 0-5'	TS-A	Barnes & Jones	3507	3/4"	4	215 194	OK	DDC Radiator Valve. No Trap Station Components.
296750	Radiator Trap	C / 1st / C001	Storage Closet In Back, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	212 176	OK	Manual Radiator Valve. No Trap Station Components.
296751	Univent	C / 1st / C001	Left Univent, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	214 177	OK	No Trap Station Components.
296752	Univent	C / 1st / C001	Right Univent, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	215 187	OK	No Trap Station Components.
296748	Univent	C / 1st / C001A	Univent, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	216 187	OK	No Trap Station Components.
296749	Radiator Trap	C / 1st / C001B	Radiator Back Wall, 0-5'	TS-A	Barnes & Jones	3507	1/2"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296753	Radiator Trap	C / 1st / C002	Radiator By Exit Door, 0-5'	TS-A	Barnes & Jones	3507	1/2"	4	215 178	OK	DDC Radiator Valve. Outlet Isolation.
300671	Reheat Coil	C / 1st / C002A	First Heating Coil, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	217 198	OK	Strainer.
300672	Reheat Coil	C / 1st / C002A	2nd Reheat Coil, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	214 187	OK	Strainer.
300673	Drip Leg	C / 1st / C002A	Drip, 5-10'	TS-A	Barnes & Jones	1721	1/2"	3	215 176	OK	No Trap Station Components.
296754	Unit Heater	C / 1st / C002C	AHU Behind Wood Storage, 0-5'	TS-A	Barnes & Jones	122	1/2"	4	212 188	OK	No Trap Station Components.
296755	Radiator Trap	C / 1st / C003	On Wall, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	215 167	OK	Thermostatic Radiator Valve. No Trap Station Components.
296746	Univent	C / 1st / C007	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	214 186	OK	No Trap Station Components.
296747	Radiator Trap	C / 1st / C007	Radiator Right, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.
296744	Univent	C / 1st / C008	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215 178	OK	No Trap Station Components.
296745	Radiator Trap	C / 1st / C008	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.
296756	Univent	C / 1st / C009	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out, Disconnected From System, Could Not Turn On.
296757	Radiator Trap	C / 1st / C009	Radiator Right, 0-5'	TS-A	N/A	N/A	1/2"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Blocked By Cabinets.
296737	Univent	C / 1st / C010	Univent, 0-5'	FT	Hoffman	FT015H	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out, Disconnected From System, Could Not Turn On.
296738	Radiator Trap	C / 1st / C010	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	216 80	P	Thermostatic Radiator Valve. No Trap Station Components.
296741	Univent	C / 1st / C011	Univent, 0-5'	TS-S	Barnes & Jones	2819	1/2"	4	216 198	OK	No Trap Station Components.
296743	Radiator Trap	C / 1st / C011	Radiator Right Corner, 0-5'	TS-A	N/A	N/A	1/2"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Blocked.
296739	Univent	C / 1st / C014	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	220 198	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296740	Radiator Trap	C / 1st / C014	Radiator Left, 0-5'	TS-A	Barnes & Jones	1949	1/2"	4	217 80	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
296758	Univent	C / 1st / C022	Univent, 0-5'	TS-A	Barnes & Jones	1929	3/4"	4	214 214	<b>L</b>	No Trap Station Components.
296759	Radiator Trap	C / 1st / C022	Back Corner, 0-5'	TS-A	Barnes & Jones	12819	1/2"	4	220 218	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296760	Radiator Trap	C / 1st / C022	Next To Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	221 189	OK	DDC Radiator Valve. No Trap Station Components.
296818	Radiator Trap	C / 1st / C030	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	221 199	OK	DDC Radiator Valve. No Trap Station Components.
296736	Univent	C / 1st / C-12	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215 212	<b>L</b>	No Trap Station Components.
296735	Univent	C / 1st / C-15	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	221 197	OK	No Trap Station Components.
296734	Radiator Trap	C / 1st / C-15B	Radiator Left Corner, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	220 187	OK	DDC Radiator Valve. No Trap Station Components.
296819	Unit Heater	C / 1st / C-24	Back Wall Unit Heater, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
296820	Unit Heater	C / 1st / Garage	Unit Heater Outside Maintenance Mechanic Shop, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296817	Radiator Trap	C / 1st / Hallway	Bottom Of Stairs Before Going To A Bldg, 0-5'	TS-A	Barnes & Jones	122	1/2"	4	215 177	OK	DDC Radiator Valve. No Trap Station Components.
296823	Unit Heater	C / 1st / Telephone Rm	Right Rm In Hallway (Weightlifting), 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
296824	Unit Heater	C / 1st / Telephone Rm	Left Hand Side Rm Before Tunnel, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
296791	Radiator Trap	C / 2nd / C-101A	Under AC Unit, 0-5'	TS-A	Hoffman	17C	1/2"	4	215 201	OK	DDC Radiator Valve. No Trap Station Components.
296792	Radiator Trap	C / 2nd / C-101B	Under AC Unit, 0-5'	TS-A	Hoffman	17C	1/2"	4	217 178	OK	DDC Radiator Valve. No Trap Station Components.
296793	Radiator Trap	C / 2nd / C-101C	Under Ac, 0-5'	TS-A	Hoffman	17C	1/2"	4	214 187	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296789	Univent	C / 2nd / C-102	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	220 212	L	No Trap Station Components.
296790	Radiator Trap	C / 2nd / C-102	Radiator Left, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	221 214	L	DDC Radiator Valve. No Trap Station Components.
296781	Univent	C / 2nd / C-103	Univent Left Side, 0-5'	TS-S	Barnes & Jones	2819	1/2"	4	216 178	OK	No Trap Station Components.
296782	Radiator Trap	C / 2nd / C-103	Univent Right Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 200	OK	DDC Radiator Valve. No Trap Station Components.
296787	Univent	C / 2nd / C-104	Univent Left Side, 0-5'	TS-S	Barnes & Jones	3507	1/2"	4	214 175	OK	No Trap Station Components.
296788	Radiator Trap	C / 2nd / C-104	Univent Right Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215 187	OK	DDC Radiator Valve. No Trap Station Components.
296785	Univent	C / 2nd / C-105	Univent, 0-5'	FT	Barnes & Jones	FT-2015-3	3/4"	4	216 187	OK	No Trap Station Components.
296786	Radiator Trap	C / 2nd / C-105	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	220 178	OK	DDC Radiator Valve. No Trap Station Components.
296779	Univent	C / 2nd / C-106	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	218 198	OK	No Trap Station Components.
296780	Radiator Trap	C / 2nd / C-106	Radiator Right, 0-5'	TS-A	Barnes & Jones	1929	3/4"	4	212 187	OK	DDC Radiator Valve. No Trap Station Components.
296774	Univent	C / 2nd / C-107	Univent Right Corner, 0-5'	TS-A	Barnes & Jones	3507	1/2"	4	217 190	OK	No Trap Station Components.
296775	Univent	C / 2nd / C-107	Univent Left Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	214 178	OK	No Trap Station Components.
296776	Radiator Trap	C / 2nd / C-107	Radiator Left Corner, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	217 190	OK	DDC Radiator Valve. No Trap Station Components.
296777	Univent	C / 2nd / C-108	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215 198	OK	No Trap Station Components.
296778	Radiator Trap	C / 2nd / C-108	Radiator Left Corner, 0-5'	TS-A	Barnes & Jones	3146	1/2"	4	216 189	OK	DDC Radiator Valve. No Trap Station Components.
296771	Univent	C / 2nd / C-110	Univent Left Side, 0-5'	TS-S	Barnes & Jones	3507	1/2"	4	214 212	L	No Trap Station Components.
296772	Radiator Trap	C / 2nd / C-110	Univent Right Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	218 193	OK	DDC Radiator Valve. No Trap Station Components.
296773	Univent	C / 2nd / C-111	Univent, 0-5'	FT	Hoffman	FT015H	3/4"	4	220 197	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296767	Univent	C / 2nd / C112	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out.
296768	Radiator Trap	C / 2nd / C116	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	2819	1/2"	4	217 189	OK	DDC Radiator Valve. No Trap Station Components.
296766	Univent	C / 2nd / C117	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	215 120	<b>P</b>	No Trap Station Components.
296765	Univent	C / 2nd / C119	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out.
296764	Radiator Trap	C / 2nd / C120	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296762	Univent	C / 2nd / C121	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out.
296763	Radiator Trap	C / 2nd / C121	Inside Univent, 0-5'	TS-A	Barnes & Jones	5000	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296761	Radiator Trap	C / 2nd / C-12B	Radiator On Wall, 0-5'	TS-A	Spirax Sarco	125	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296813	Univent	C / 2nd / C141A	Univent, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	218 198	OK	Inlet Isolation.
296814	Radiator Trap	C / 2nd / C141A	Radiator Left Of Univent, 0-5'	TS-S	Barnes & Jones	1990	3/4"	4	215 177	OK	DDC Radiator Valve. No Trap Station Components.
295812	Radiator Trap	C / 2nd / C144	Radiator Back Wall, 0-5'	TS-S	Barnes & Jones	1990	3/4"	4	214 167	OK	DDC Radiator Valve. No Trap Station Components.
296811	Univent	C / 2nd / C144	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	215 199	OK	Inlet Isolation.
296809	Univent	C / 2nd / C145	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out.
296810	Radiator Trap	C / 2nd / C145	Radiator Right Of Univent, 0-5'	TS-S	Hoffman	085C	3/4"	4	215 177	OK	DDC Radiator Valve. No Trap Station Components.
296807	Univent	C / 2nd / C146	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	220 198	OK	No Trap Station Components.
296808	Radiator Trap	C / 2nd / C146	Radiator Left Of Univent, 0-5'	TS-S	Barnes & Jones	3500	3/4"	4	215 198	OK	DDC Radiator Valve. Outlet Isolation.
296804	Univent	C / 2nd / C147A	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	213 178	OK	No Trap Station Components.
296805	Radiator Trap	C / 2nd / C147A	Radiator Left Of Univent, 0-5'	TS-S	Barnes & Jones	1990	3/4"	4	214 187	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296806	Radiator Trap	C / 2nd / C147A	Radiator Left Of Univent, 0-5'	TS-S	Hoffman	085N	3/4"	4	212 176	OK	DDC Radiator Valve. No Trap Station Components.
296803	Radiator Trap	C / 2nd / C147B	Radiator On Wall, 0-5'	TS-S	Barnes & Jones	1950	3/4"	4	213 200	OK	Manual Radiator Valve. Inlet Isolation, Outlet Isolation.
296799	Radiator Trap	C / 2nd / C-148	On Wall Under Window, 0-5'	TS-A	Barnes & Jones	122	1/2"	4	212 212	L	Manual Radiator Valve. No Trap Station Components.
296797	Univent	C / 2nd / C-150	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	215 189	OK	No Trap Station Components.
296798	Radiator Trap	C / 2nd / C-150	Radiator Left Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	4	216 90	P	DDC Radiator Valve. No Trap Station Components.
296794	Univent	C / 2nd / C-151	Left Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	218 192	OK	No Trap Station Components.
296795	Univent	C / 2nd / C-151	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	214 177	OK	No Trap Station Components.
296796	Radiator Trap	C / 2nd / C-151	Radiator Right Wall, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	221 187	OK	DDC Radiator Valve. No Trap Station Components.
296769	Radiator Trap	C / 2nd / Hallway	Across From Rm C117, 0-5'	TS-S	Barnes & Jones	3507	1/2"	4	215 187	OK	DDC Radiator Valve. No Trap Station Components.
296770	Radiator Trap	C / 2nd / Hallway	Across From C120, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296800	Radiator Trap	C / 2nd / Hallway	Radiator Across From C147, 0-5'	TS-S	Barnes & Jones	3507	1/2"	4	215 179	OK	DDC Radiator Valve. No Trap Station Components.
296801	Radiator Trap	C / 2nd / Hallway	Across From C146, 0-5'	TS-S	Hoffman	17C	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296802	Radiator Trap	C / 2nd / Hallway	Across From C145 By Doors, 0-5'	TS-S	Barnes & Jones	3507	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296815	Radiator Trap	C / 2nd / Hallway	Across From Main Office By North House (Entrance To A Bldg), 0-5'	TS-S	Barnes & Jones	3507	3/4"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296816	Radiator Trap	C / 2nd / Hallway	Top Of Stairs Before Entrance To A Bldg, 0-5'	TS-S	Barnes & Jones	122	1/2"	4	216 198	OK	DDC Radiator Valve. No Trap Station Components.
296724	Univent	C / 1st / C-16	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	214 176	OK	No Trap Station Components.
296725	Radiator Trap	C / 1st / C-16	Inside Univent, 0-5'	TS-A	Hoffman	8C	1/2"	4	216 186	OK	DDC Radiator Valve. No Trap Station Components.
296727	Radiator Trap	C / 1st / C-16	Radiator Right Corner, 0-5'	TS-S	Hoffman	8C	1/2"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296726	Radiator Trap	C / 1st / C-17	Radiator Right Corner, 0-5'	TS-S	Barnes & Jones	134	3/4"	4	220 198	OK	DDC Radiator Valve. No Trap Station Components.
296728	Univent	C / 1st / C-17	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 183	OK	No Trap Station Components.
296729	Univent	C / 1st / C-18	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 198	L	No Trap Station Components.
296730	Radiator Trap	C / 1st / C-18	Inside Univent, 0-5'	TS-S	Spirax Sarco	125	1/2"	4	219 199	OK	DDC Radiator Valve. No Trap Station Components.
296731	Radiator Trap	C / 1st / C-18	Radiator In Right, 0-5'	TS-A	Barnes & Jones	5000	1/2"	4	215 187	OK	DDC Radiator Valve. No Trap Station Components.
296732	Radiator Trap	C / 1st / C-20	On Wall, 0-5'	TS-A	Erwell	MOD-A-30	1/2"	4	218 198	OK	Manual Radiator Valve. No Trap Station Components. Manual Valve Radiator Valve Leaking By
296733	Radiator Trap	C / 1st / Hallway	Outside C022, 0-5'	TS-S	Barnes & Jones	5000	1/2"	4	214 212	L	DDC Radiator Valve. No Trap Station Components.
296053	Drip Leg	C / Ground / C031	Above Switchboard, 10-15'	FT	Barnes & Jones	FTI2015	3/4"	4	218 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296052	Drip Leg	C / Ground / Hallway	Outside C031, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296395	Radiator Trap	D / 1st / D108	Radiator Right Of Univent, 0-5'	TS-A	Hoffman	8C	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296396	Univent	D / 1st / D108	Univent, 0-5'	FT	Hoffman	FT015H	3/4"	4	80 80	NIS	No Trap Station Components. Valved Out.
296397	Radiator Trap	D / 1st / D108	Left Of Univent, 0-5'	TS-A	Hoffman	17C	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296394	Radiator Trap	D / 1st / D108A	Radiator In Corner Behind Piano, 5-10'	TS-A	N/A	N/A	1/2"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Large Piano Blocking It.
296399	Radiator Trap	D / 1st / D110	Middle Of Back Wall, 0-5'	TS-S	Barnes & Jones	5000	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296398	Radiator Trap	D / 1st / D110A	In Corner, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	218 194	OK	DDC Radiator Valve. No Trap Station Components.
296400	Radiator Trap	D / 1st / D110B	Radiator Right Wall, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	216 195	OK	DDC Radiator Valve. No Trap Station Components.
296401	Radiator Trap	D / 1st / D114	Left Back Corner, 0-5'	TS-S	Barnes & Jones	5000	1/2"	4	216 188	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296402	Radiator Trap	D / 1st / D114	Corner Opposite Entrance, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	220 198	OK	DDC Radiator Valve. No Trap Station Components.
296405	Radiator Trap	D / 1st / D116	Corner Radiator, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	220 218	L	DDC Radiator Valve. No Trap Station Components.
296406	Radiator Trap	D / 1st / D116B	Right Corner Of Rm, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	214 189	OK	Thermostatic Radiator Valve. No Trap Station Components.
296409	Radiator Trap	D / 1st / D117	Radiator Behind Storage, 0-5'	TS-A	N/A	N/A	1/2"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Storage Blocking Radiator.
296407	Radiator Trap	D / 1st / D117A	Right Corner, 0-5'	TS-A	Barnes & Jones	1929	1/2"	4	215 193	OK	DDC Radiator Valve. No Trap Station Components.
296404	Radiator Trap	D / 1st / Hallway	Outside D116C, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 200	OK	DDC Radiator Valve. No Trap Station Components.
296408	Radiator Trap	D / 1st / Hallway	Outside D117A, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	L	DDC Radiator Valve. No Trap Station Components.
296410	Radiator Trap	D / 1st / Hallway	Outside D117, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	L	DDC Radiator Valve. No Trap Station Components.
296403	Radiator Trap	D / 1st / Stairwell Outside D114	On Platform, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	214 176	OK	Manual Radiator Valve. No Trap Station Components.
296336	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Along Right Wall Second Drip After Electrical Boxes, 10-15'	TS-A	Barnes & Jones	1929	3/4"	4	217 198	OK	No Trap Station Components.
296379	AHU	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Left Corner, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	217 188	OK	No Trap Station Components.
296380	AHU	D / Ground / Caged Rm Across From D005(Other AHU Rm)	In Corner Behind Condensate Pit, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
296381	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Corner Behind Condensate Pump, 5-10'	FT	Spirax Sarco	FT15	3/4"	4	218 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296382	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Corner Behind Condensate Pump, 5-10'	FT	Spirax Sarco	FT15	3/4"	4	214 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Condensate pump Leaking Steam And Condensate.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296383	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Upon Entrance Second Drip Along Right Wall, 10-15'	TS-A	Barnes & Jones	1929	3/4"	4	216 219	L	No Trap Station Components.
296384	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Upon Entrance Third Drip Along Right Wall, 10-15'	TS-A	Barnes & Jones	1929	3/4"	4	216 212	L	No Trap Station Components.
296385	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Along Right Wall Next To Electrical Box, 10-15'	TS-A	Barnes & Jones	1929	3/4"	4	216 212	L	No Trap Station Components.
296387	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Along Right Wall Third Drip After Electrical Boxes, 10-15'	TS-A	Barnes & Jones	1929	3/4"	4	217 187	OK	No Trap Station Components.
296388	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	In Corner By AHU2, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	220 195	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296389	AHU	D / Ground / Caged Rm Across From D005(Other AHU Rm)	AHU-2 Top, 5-10'	FT	Spirax Sarco	FT15	1 1/4"	4	216 199	OK	Strainer, Blowdown.
296390	AHU	D / Ground / Caged Rm Across From D005(Other AHU Rm)	AHU-2 Middle Trap, 5-10'	FT	Spirax Sarco	FT15	1 1/4"	4	80 80	NIS	Strainer, Blowdown. Valved Out.
296391	AHU	D / Ground / Caged Rm Across From D005(Other AHU Rm)	AHU-2 Bottom Trap, 5-10'	FT	Spirax Sarco	FT15	1 1/4"	4	80 80	NIS	Strainer, Blowdown. Valved Out.
296392	Unit Heater	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Unit Heater In Front Of AHU-2, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296393	Unit Heater	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Unit Heater On Top Of AHU -2, 5-10'	FT	Spirax Sarco	FT15	3/4"	4	220 191	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296370	Drip Leg	D / Ground / D005 (AHU)	Unit 2D, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	217 199	OK	Inlet Isolation.
296371	AHU	D / Ground / D005 (AHU)	Unit 2D In Back, 0-5'	FT	Barnes & Jones	FTI2015-3	3/4"	4	217 189	OK	Inlet Isolation, Strainer, Outlet Isolation.
296372	AHU	D / Ground / D005 (AHU)	Unit 1D, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 214	L	Inlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296373	AHU	D / Ground / D005 (AHU)	Unit 1D In Back, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	185	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296374	AHU	D / Ground / D005 (AHU)	Above AHU For Gym, 10-15'	FT	N/A	69	3/4"	4	197	167	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296375	Reheat Coil	D / Ground / D005 (AHU)	Above AHU For Gym, 10-15'	TS-A	Barnes & Jones	1721	1/2"	4	216	189	OK	No Trap Station Components.
296376	Unit Heater	D / Ground / D005 (AHU)	Unit Heater In Corner, 10-15'	FT	Barnes & Jones	FT2015-4	1"	4	216	198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296377	Drip Leg	D / Ground / D005 (AHU)	In Corner By Unit 2D, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216	197	OK	Inlet Isolation, Outlet Isolation.
296378	Drip Leg	D / Ground / D005 (AHU)	In Corner Under Ductwork, 5-10'	FT	Barnes & Jones	FT2015-5	1 1/4"	4	217	213	L	Inlet Isolation, Strainer, Outlet Isolation.
296262	Drip Leg	D / Ground / Large Rm Across From D001	PRV Station On Wall, 5-10'	TS-A	Barnes & Jones	2163	1"	4	220	195	OK	No Trap Station Components.
296361	Drip Leg	D / Ground / Large Rm Across From D001	Little Rm Off Entrance, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	220	198	OK	Inlet Isolation, Strainer, Outlet Isolation.
296363	Drip Leg	D / Ground / Large Rm Across From D001	Second Drip On PRV Station, 5-10'	TS-A	Barnes & Jones	2163	1"	4	216	176	OK	No Trap Station Components.
296364	Drip Leg	D / Ground / Large Rm Across From D001	End Of PRV Station, 0-5'	FT	Barnes & Jones	FT2015-8	2"	4	215	187	OK	Inlet Isolation, Strainer, Outlet Isolation.
296365	Heat Exchanger	D / Ground / Large Rm Across From D001	First HEX On Left Side, 5-10'	FT	Barnes & Jones	FT2015-8	2"	4	212	212	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296366	Heat Exchanger	D / Ground / Large Rm Across From D001	Second HEX On Left Side, 5-10'	FT	Barnes & Jones	FT2015-8	2"	4	145	120	OK	Inlet Isolation, Strainer, Outlet Isolation.
296367	Drip Leg	D / Ground / Large Rm Across From D001	Crawlspace Leading Back In Little Offshoot Ten Yards Back From HEX, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	215	213	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Outlet Union Leaking Steam And Condensate.
296368	Drip Leg	D / Ground / Large Rm Across From D001	Crawl Space In Back All The Way Towards End By Condensate Pump, 5-10'	FT	Barnes & Jones	FT2015-8	2"	4	218	190	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296369	Drip Leg	D / Ground / Large Rm Across From D001 (Can Access From Rm C001-C Access Panel)	In Crawlspace Space All The Way In Back To The Left Of The Condensate Pit. In Cutout In Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	4	216	212	B	No Trap Station Components. Nipple Leaking Condensate.
300650	Drip Leg	E / Basement / Far Back Tunnel Left Branch	Along Right Wall, 0-5'	TS-S	Barnes & Jones	5007	3/4"	3	79	78	P	Inlet Isolation, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300662	Radiator Trap	E / Basement / Far Back Tunnel Left Branch	After 300653, 0-5'	TS-A	Barnes & Jones	5007	3/4"	3	210 176	OK	DDC Radiator Valve. Inlet Isolation, Outlet Isolation.
300663	Drip Leg	E / Basement / Far Back Tunnel Left Branch	Along Right Wall, 0-5'	TS-A	Barnes & Jones	5007	3/4"	3	78 78	NIS	Inlet Isolation, Outlet Isolation. Not Calling.
300664	Drip Leg	E / Basement / Far Back Tunnel Left Branch	Last Trap On Right Wall, 0-5'	TS-S	Barnes & Jones	5007	3/4"	3	79 79	NIS	Inlet Isolation, Outlet Isolation. Not Calling.
296701	Radiator Trap	E / 1st / Basement	Radiator Exit 24, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.
296492	Radiator Trap	E / 1st / Hallway To Pool	Across From Stairwell To Boys Locker Rm1, 0-5'	TS-A	Barnes & Jones	122	1/2"	4	217 187	OK	DDC Radiator Valve. No Trap Station Components.
296493	Radiator Trap	E / 1st / Hallway To Pool	Across From Stairwell Down To Girls Locker Rm, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	200 80	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
296494	Radiator Trap	E / 1st / Hallway To Pool	East Side 1st Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	217 215	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296495	Radiator Trap	E / 1st / Hallway To Pool	East Side 2nd Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296496	Radiator Trap	E / 1st / Hallway To Pool	East Side 3rd Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	218 198	OK	DDC Radiator Valve. No Trap Station Components.
296497	Radiator Trap	E / 1st / Hallway To Pool	East Side Last Radiator Before Pool Entrance, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296498	Radiator Trap	E / 1st / Hallway To Pool	West Side 1st Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
296499	Radiator Trap	E / 1st / Hallway To Pool	West Side Last Radiator Before Pool Entrance, 0-5'	TS-A	Barnes & Jones	122A	1/2"	4	216 178	OK	DDC Radiator Valve. No Trap Station Components.
296500	Radiator Trap	E / 1st / Hallway To Pool	Between Stairwells To Both Boys And Girls Locker Rm, 0-5'	TS-A	N/A	N/A	1"	4	220 214	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
296706	Drip Leg	E / 1st / Large MER By North Gym	Outside By Ice Machine, 0-5'	FT	Barnes & Jones	FT12015-3	3/4"	4	NA NA	RIP	Valved Out, Disconnected From System.
296707	Drip Leg	E / 1st / Large MER By North Gym	Under Header In Back, 0-5'	FT	Barnes & Jones	FT2015-3	1 1/4"	4	212 98	<b>P</b>	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296708	Drip Leg	E / 1st / Large MER By North Gym	Back Corridor Above Header, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 212	<b>L</b>	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296705	Radiator Trap	E / 1st / Stairwell	Above Exit 22, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296482	Univent	E / 2nd / E-207	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	216 197	OK	No Trap Station Components.
296483	Radiator Trap	E / 2nd / E-207	Radiator Right Corner, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	216 187	OK	DDC Radiator Valve. No Trap Station Components.
296484	Univent	E / 2nd / E-215	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 198	OK	No Trap Station Components.
296485	Radiator Trap	E / 2nd / E-215	Radiator Right Corner, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	217 198	OK	DDC Radiator Valve. No Trap Station Components.
296486	Univent	E / 2nd / E-216 (Planet Fitness Gym)	Left Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	NA NA	RIP	Valved Out, Disconnected From System.
296487	Univent	E / 2nd / E-216 (Planet Fitness Gym)	Univent Middle, 0-5'	TS-A	Barnes & Jones	134A	3/4"	4	215 198	OK	No Trap Station Components.
296488	Radiator Trap	E / 2nd / E-216 (Planet Fitness Gym)	Radiator In Between Middle And Right Univent, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	216 189	OK	DDC Radiator Valve. No Trap Station Components.
296489	Univent	E / 2nd / E-216 (Planet Fitness Gym)	Right Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	215 187	OK	No Trap Station Components.
296490	Radiator Trap	E / 2nd / E-216 (Planet Fitness Gym)	Right Corner Radiator, 0-5'	TS-S	Barnes & Jones	5007	1/2"	4	214 212	L	DDC Radiator Valve. No Trap Station Components.
296491	Univent	E / 2nd / E-218	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	4	217 188	OK	No Trap Station Components.
300647	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	Directly Across From Tunnel Entrance, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	217 198	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Inlet Union Leaking Steam.
300648	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	First Trap Starting Left Branch, 5-10'	TS-S	Barnes & Jones	134	3/4"	3	215 192	OK	Outlet Isolation.
300649	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	2nd Trap On Left Against Wall, 5-10'	TS-S	Spirax Sarco	RTA125	3/4"	3	80 80	NIS	Outlet Isolation. Valved Out.
300651	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	4th Trap To The Left, 5-10'	TS-A	Barnes & Jones	5000	1/2"	3	215 194	OK	No Trap Station Components.
300652	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	All The Way Left Against Back Wall, 5-10'	TS-A	Hoffman	8C	3/4"	3	216 199	OK	Outlet Isolation. Elbow Leaking Steam.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300653	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	All The Way Left Against Back Wall, 5-10'	TS-S	Tunstall	TA	3/4"	3	216	178	OK	Outlet Isolation.
300665	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	End Of Left Branch. Drip In Corner, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	216	213	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Strainer Installed Backwards.
300666	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	Across From 300649, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	80	80	NIS	No Trap Station Components. Valved Out.
296703	Radiator Trap	E / Basement / E-2	Against Wall, 0-5'	TS-A	Barnes & Jones	122	1/2"	4	216	188	OK	Manual Radiator Valve. No Trap Station Components.
296702	Radiator Trap	E / Basement / E-3	On Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	215	213	L	DDC Radiator Valve. No Trap Station Components.
296704	Radiator Trap	E / Basement / Exit 22	On Platform, 0-5'	TS-A	Barnes & Jones	1721	1/2"	4	215	201	OK	DDC Radiator Valve. No Trap Station Components.
296709	Drip Leg	E / Basement / AHU Rm Downstairs From Exit 33	Left Corner, 5-10'	TS-A	Barnes & Jones	134	3/4"	4	216	189	OK	No Trap Station Components.
296710	AHU	E / Basement / AHU Rm Downstairs From Exit 33	Left Corner, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	216	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296711	AHU	E / Basement / AHU Rm Downstairs From Exit 33	Left Corner, 5-10'	FT	Watts	WFT-15	1/2"	4	217	196	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
300645	Radiator Trap	E / Basement (Hallway With Locker Rms) / E-7	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220	216	L	DDC Radiator Valve. No Trap Station Components.
300646	Radiator Trap	E / Basement (Hallway With Locker Rms) / E-7	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	217	222	L	DDC Radiator Valve. No Trap Station Components.
296718	Drip Leg	E / 2nd / E-210	South Wall Unit, 10-15'	FT	Barnes & Jones	FT2014-3	3/4"	4	216	187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296719	Unit Heater	E / 2nd / E-210	South Wall Unit Heater, 10-15'	FT	Spirax Sarco	FT15	3/4"	4	220	198	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296720	Drip Leg	E / 2nd / E-210	North Unit Heater, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296721	Unit Heater	E / 2nd / E-210	North Unit Heater, 10-15'	FT	Spirax Sarco	FTI15	3/4"	4	212	186	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296722	Unit Heater	E / 2nd / E-210	Northwest Unit Heater, 10-15'	FT	Spirax Sarco	FTI15	3/4"	4	215	185	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296723	Unit Heater	E / 2nd / E-210	Southeast Unit Heater, 10-15'	FT	Spirax Sarco	FT15	3/4"	4	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
29640	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Southeast Corner, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	215 178	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296420	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Northwest Corner, 5-10'	TS-A	Barnes & Jones	5007	1/2"	4	218 212	L	No Trap Station Components.
296421	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Northwest Corner, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	216 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296422	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Northeast Corner, 5-10'	TS-A	Barnes & Jones	5007	1/2"	4	216 193	OK	No Trap Station Components.
296423	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU 2E Right Side, 0-5'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 193	OK	Inlet Isolation, Strainer, Outlet Isolation.
296424	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-2E Left Side, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	215 188	OK	No Trap Station Components.
296425	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-2E Left Side, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	215 212	L	No Trap Station Components.
296426	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-2E Left Side, 5-10'	FT	Mepco	42-515	1 1/4"	4	220 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296427	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-2E Left Side, 5-10'	FT	Mepco	42-715	1 1/2"	4	217 198	OK	Inlet Isolation, Strainer, Outlet Isolation.
296428	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-4E Right Side, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296429	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-4E Left Side, 5-10'	TS-A	Barnes & Jones	3500	1/2"	4	216 185	OK	No Trap Station Components.
296430	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-4E Left Side, 5-10'	TS-A	Barnes & Jones	3500	1/2"	4	220 184	OK	No Trap Station Components.
296431	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-4E Left Side, 5-10'	FT	Mepco	42-515	1 1/4"	4	215 199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296432	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-4E Left Side, 5-10'	FT	Mepco	42-715 INLINE	1 1/2"	4	200 90	P	Strainer, Blowdown, Outlet Isolation Stuck Closed.
296433	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-3E Right Side, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 195	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296434	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-3E Left Side, 5-10'	TS-A	Hoffman	17C	1/2"	4	220 217	B	No Trap Station Components.
296435	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-3E Left Side, 5-10'	TS-A	Barnes & Jones	3500	1/2"	4	215 176	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296436	AHU	E / Mezzanine (Locker Rm AHUs) / E-219A	AHU-3E Left Side, 5-10'	FT	Mepco	42-715	1 1/2"	4	216 188	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296437	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Southwest Corner, 10-15'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 176	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296438	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Southwest Corner, 5-10'	TS-A	Barnes & Jones	5007	1/2"	4	214 174	OK	No Trap Station Components.
296439	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Southwest Corner, 5-10'	FT	Barnes & Jones	FT2015-4	1"	4	216 199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296441	Drip Leg	E / Mezzanine (Locker Rm AHUs) / E-219A	Southeast Corner, 5-10'	TS-A	Barnes & Jones	1949	1/2"	4	221 187	OK	No Trap Station Components.
296460	AHU	E / Roof / North Gym AHU Northeast Entrance	First AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 197	OK	No Trap Station Components.
296461	AHU	E / Roof / North Gym AHU Northeast Entrance	First AHU On Catwalk, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	217 193	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296462	AHU	E / Roof / North Gym AHU Northeast Entrance	2nd AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 187	OK	No Trap Station Components. Union Leaking Condensate.
296463	AHU	E / Roof / North Gym AHU Northeast Entrance	2nd AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	217 189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296464	AHU	E / Roof / North Gym AHU Northeast Entrance	Third AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	L	No Trap Station Components.
296465	AHU	E / Roof / North Gym AHU Northeast Entrance	Third AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 198	OK	Inlet Isolation, Strainer, Outlet Isolation.
296466	AHU	E / Roof / North Gym AHU Northeast Entrance	4th AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	215 193	OK	No Trap Station Components.
296467	AHU	E / Roof / North Gym AHU Northeast Entrance	4th AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	214 187	OK	Strainer, Blowdown, Outlet Isolation.
296468	AHU	E / Roof / North Gym AHU Northeast Entrance	Fifth AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 194	OK	No Trap Station Components.
296469	AHU	E / Roof / North Gym AHU Northeast Entrance	Third AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 198	OK	Strainer, Blowdown, Outlet Isolation.
296470	AHU	E / Roof / North Gym AHU Northeast Entrance	Last AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	3/4"	4	215 213	L	No Trap Station Components.
296471	AHU	E / Roof / North Gym AHU Northeast Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	220 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296472	Drip Leg	E / Roof / North Gym AHU Northeast Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-5	1 1/4"	4	216 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296473	AHU	E / Roof / North Gym AHU Northwest Entrance	First AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	220 80	<b>P</b>	No Trap Station Components.
296474	AHU	E / Roof / North Gym AHU Northwest Entrance	First AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI-2015-3	3/4"	4	215 80	<b>P</b>	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296475	AHU	E / Roof / North Gym AHU Northwest Entrance	2nd AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 187	OK	No Trap Station Components.
296476	AHU	E / Roof / North Gym AHU Northwest Entrance	2nd AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	217 176	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296477	AHU	E / Roof / North Gym AHU Northwest Entrance	Third AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 197	OK	No Trap Station Components.
296478	AHU	E / Roof / North Gym AHU Northwest Entrance	Third AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	215 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296479	AHU	E / Roof / North Gym AHU Northwest Entrance	Last AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	3/8"	4	216 197	OK	No Trap Station Components.
296480	AHU	E / Roof / North Gym AHU Northwest Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	213 188	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296481	Drip Leg	E / Roof / North Gym AHU Northwest Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-5	1 1/4"	4	218 201	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296451	AHU	E / Roof / South Gym AHU Southeast Entrance	First AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	217 180	OK	No Trap Station Components.
296452	AHU	E / Roof / South Gym AHU Southeast Entrance	First AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	214 193	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296453	AHU	E / Roof / South Gym AHU Southeast Entrance	2nd AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	221 187	OK	No Trap Station Components.
296454	AHU	E / Roof / South Gym AHU Southeast Entrance	2nd AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296455	AHU	E / Roof / South Gym AHU Southeast Entrance	Third AHU On Entrance, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	214 199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296456	AHU	E / Roof / South Gym AHU Southeast Entrance	Third AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	217 212	<b>L</b>	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296457	AHU	E / Roof / South Gym AHU Southeast Entrance	Last AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 200	OK	No Trap Station Components.
296458	AHU	E / Roof / South Gym AHU Southeast Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	216 197	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296459	Drip Leg	E / Roof / South Gym AHU Southeast Entrance	Last AHU, 5-10'	FT	Barnes & Jones	FTI2015-5	1 1/4"	4	216 197	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
296442	AHU	E / Roof / South Gym AHU Southwest Entrance	First AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	215 187	OK	No Trap Station Components.
296443	AHU	E / Roof / South Gym AHU Southwest Entrance	First AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	220 189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296444	AHU	E / Roof / South Gym AHU Southwest Entrance	2nd AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 197	L	No Trap Station Components.
296445	AHU	E / Roof / South Gym AHU Southwest Entrance	2nd AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	217 194	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296446	AHU	E / Roof / South Gym AHU Southwest Entrance	3rd AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	216 212	L	No Trap Station Components.
296447	AHU	E / Roof / South Gym AHU Southwest Entrance	Third AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	214 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296448	AHU	E / Roof / South Gym AHU Southwest Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	4	214 199	OK	Strainer, Blowdown, Outlet Isolation.
296449	AHU	E / Roof / South Gym AHU Southwest Entrance	Last AHU On Catwalk, 5-10'	TS-A	Barnes & Jones	1721	1/2"	4	215 212	L	No Trap Station Components.
296450	Drip Leg	E / Roof / South Gym AHU Southwest Entrance	Last AHU On Catwalk, 5-10'	FT	Barnes & Jones	FTI2015-5	1 1/4"	4	216 177	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296715	Radiator Trap	E Athletics / 2nd / First Office On Left	Back Corner, 5-10'	TS-A	N/A	N/A	3/4"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Cabinets Blocking.
296716	Radiator Trap	E Athletics / 2nd / Second Office On Left	At Wall, 5-10'	TS-A	Barnes & Jones	122	1/2"	4	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
296717	Radiator Trap	E Athletics / 2nd / Second Office On Left	At Wall, 5-10'	TS-A	N/A	N/A	1/2"	4	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Cabinets Blocking.
300661	Drip Leg	E/F / Basement / Tunnel Off Condensate Pump-2nd Chamber	At 2nd Chamber Hole, 0-5'	FT	Barnes & Jones	FT2015-8	2"	3	217 184	OK	Inlet Isolation, Strainer, Blowdown, Check Valve, Outlet Isolation.
296056	Drip Leg	Pool Bldg / Basement / Boiler Rm	By Condensate Pump, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	4	217 197	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296062	Drip Leg	Pool Bldg / Basement / Bottom Of Stairs	Other Side Of Structure, 5-10'	FT	Mepco	MLFTI15-6	1 1/2"	4	216 80	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296068	Drip Leg	Pool Bldg / Basement / Bottom Of Stairs	Bottom Of Mezzanine, 5-10'	FT	Mepco	MLFTI15-6	1 1/2"	4	215 198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296059	Drip Leg	Pool Bldg / Basement / Bottom Of Stairs	Corner Below Stairs, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	218 212	L	Inlet Isolation, Strainer, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296060	Drip Leg	Pool Bldg / Basement / Bottom Of Stairs	Corner Below Stairs, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	218	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296061	Drip Leg	Pool Bldg / Basement / Bottom Of Stairs	Corner Of Stairs, 5-10'	FT	Barnes & Jones	FT2015-8	2"	4	216	187	OK	Inlet Isolation, Strainer, Outlet Isolation.
296063	Drip Leg	Pool Bldg / Basement / Dirt Pit	Middle Of Pit Against Wall, 10-15'	TS-A	Barnes & Jones	134A	3/4"	4	212	212	L	No Trap Station Components.
296064	Drip Leg	Pool Bldg / Basement / Dirt Pit	By Corridor To Rm Outside Boiler Rm, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	218	213	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296065	Drip Leg	Pool Bldg / Basement / Dirt Pit	Middle Of Pit, 10-15'	TS-A	Barnes & Jones	134A	3/4"	4	216	211	B	No Trap Station Components.
296066	Drip Leg	Pool Bldg / Basement / Dirt Pit	Towards Entrance To Pit, 10-15'	TS-A	Barnes & Jones	134A	3/4"	4	216	212	L	No Trap Station Components.
296067	Drip Leg	Pool Bldg / Basement / Dirt Pit	First Radiator Drip On Entrance, 10-15'	TS-A	Barnes & Jones	122A	1/2"	4	218	218	B	No Trap Station Components.
296069	Drip Leg	Pool Bldg / Basement / Mezzanine In Basement Pool Rm	Left Side, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	216	187	OK	Inlet Isolation, Strainer, Outlet Isolation.
296070	Drip Leg	Pool Bldg / Basement / Mezzanine In Basement Pool Rm	Right Side, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	4	215	203	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296072	Drip Leg	Pool Bldg / Basement / Mezzanine In Far Room	Right Side, 5-10'	TS-A	Barnes & Jones	134A	3/4"	4	80	80	NIS	No Trap Station Components. Valved Out.
296074	Drip Leg	Pool Bldg / Basement / Outside Boiler Rm	Above Double Red Doors, 10-15'	TS-A	Barnes & Jones	134A	3/4"	4	80	80	NIS	No Trap Station Components. Valved Out.
296075	Drip Leg	Pool Bldg / Basement / Outside Boiler Rm	Above Electrical Panels, 10-15'	TS-A	Barnes & Jones	134A	3/4"	4	80	80	NIS	No Trap Station Components. Valved Out.
296057	Unit Heater	Pool Bldg / Basement / Outside Boiler Rm	Opposite Wooden Stairs, 10-15'	FT	Spirax Sarco	FT15	3/4"	4	80	80	NIS	Inlet Isolation, Strainer, Outlet Isolation. Valved Out.
296058	Drip Leg	Pool Bldg / Basement / Outside Boiler Rm	By Red Double Doors, 5-10'	FT	Barnes & Jones	FT2015-8	2"	4	NA	NA	RIP	Valved Out, Disconnected From System.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296169	Univent	A / 1st / A102	Univent, 0-5'	Barnes & Jones	3590	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296088	Radiator Trap	A / 1st / A109	Right Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296081	Univent	A / 1st / A113	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	B	Repair Kit, Difficult Access
296082	Radiator Trap	A / 1st / A113	Radiator On Wall, 0-5'	Barnes & Jones	3GH	Thermostatic Angle	4	1/2"	NPT	B	Repair Kit, No Issues
296077	Univent	A / 1st / A116	Univent, 0-5'	Barnes & Jones	122A	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296310	Radiator Trap	A / 1st / A119	Back Wall, 0-5'	Barnes & Jones	5007	Thermostatic Straight	4	1/2"	NPT	L	Repair Kit, No Issues
296306	Radiator Trap	A / 1st / A121	On Wall, 0-5'	Barnes & Jones	5007	Thermostatic Straight	4	1/2"	NPT	B	Repair Kit, No Issues
296314	Univent	A / 1st / A129	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, Difficult Access
296315	Radiator Trap	A / 1st / A129	Radiator On Wall, 0-5'	Barnes & Jones	2819	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296095	Radiator Trap	A / 1st / Girls Bathroom	On Wall, 0-5'	Barnes & Jones	122	Thermostatic Straight	4	1/2"	NPT	L	Repair Kit, Difficult Access
296301	Radiator Trap	A / 1st / Hallway	Beginning Of A Bldg Right Side Of Lockers, 0-5'	Barnes & Jones	2819	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296079	Radiator Trap	A / 1st / A115	Right Corner, 0-5'	Barnes & Jones	3GH	Thermostatic Angle	4	1/2"	NPT	B	Repair Kit, Difficult Access
296341	Radiator Trap	A / 2nd / A206	Corner Of Rm, 0-5'	Barnes & Jones	5007	Thermostatic Angle	4	1/2"	NPT	B	Repair Kit, Difficult Access
296343	Radiator Trap	A / 2nd / A207	Right Wall Radiator, 0-5'	Barnes & Jones	5007	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296344	Radiator Trap	A / 2nd / A208	Left Back Corner, 0-5'	Barnes & Jones	5007	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296348	Radiator Trap	A / 2nd / A212	Left Radiator, 0-5'	Spirax Sarco	125	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296357	Radiator Trap	A / 2nd / A215	Radiator In Right Corner, 0-5'	Barnes & Jones	5007	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296325	AHU	A / 2nd / A219	Steam Coil In Corner Under Panel, 0-5'	Spirax Sarco	125A	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, System Shutdown Required
296319	AHU	A / 2nd / A222	Steam Coil Under Panel, 0-5'	Spirax Sarco	125A	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296324	Radiator Trap	A / 2nd / A226A	On Wall, 0-5'	Barnes & Jones	134A	Thermostatic Angle	4	3/4"	NPT	B	Repair Kit, No Issues
296332	Radiator Trap	A / 2nd / A228	Radiator In Corner, 0-5'	Barnes & Jones	5007	Thermostatic Angle	4	1/2"	NPT	B	Repair Kit, No Issues
296334	Radiator Trap	A / 2nd / A229	Radiator In Right Corner, 0-5'	Barnes & Jones	5007	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296318	Radiator Trap	A / 2nd / Women's Bathroom	On Wall, 0-5'	Barnes & Jones	5007	Thermostatic Straight	4	1/2"	NPT	L	Repair Kit, No Issues
296080	Univent	A / Basement / 1st	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, Difficult Access
296039	Drip Leg	A / Ground / Boiler Rm	2nd Trap Off Steam Main Left Wall, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	P	Full Trap, No Issues
296040	Drip Leg	A / Ground / Boiler Rm	3rd Trap Off Steam Main Left Wall, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, No Issues
296041	Drip Leg	A / Ground / Boiler Rm	4th T Trap Off Steam Main Left Wall, 10-15'	Barnes & Jones	FT2015-6	Float & Thermostatic	4	1 1/2"	NPT	L	Repair Kit, No Issues
296045	Drip Leg	A / Ground / C-146	Entrance, 5-10'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, No Issues
296046	Drip Leg	A / Ground / C-146	Left Above Header, 10-15'	Barnes & Jones	FTI2015-3	Float & Thermostatic	4	3/4"	NPT	B	Repair Kit, No Issues
300654	Drip Leg	B / Basement / NE Tunnel	25 Ft In, 0-5'	Nicholson	SERIESG6G	Float & Thermostatic	3	3/4"	NPT	P	Full Trap, No Issues
300655	Drip Leg	B / Basement / NE Tunnel	At 1st Corner, 0-5'	Nicholson	8G	Float & Thermostatic	3	1 1/4"	NPT	L	Full Trap, No Issues
300656	Drip Leg	B / Basement / NE Tunnel	Around 1st Corner, 0-5'	Nicholson	7G	Float & Thermostatic	3	1"	NPT	L	Full Trap, No Issues
300657	Drip Leg	B / Basement / NE Tunnel	At T, 0-5'	Nicholson	8G	Float & Thermostatic	3	1 1/4"	NPT	L	Full Trap, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300632	Drip Leg	B / Basement / Boiler Rm (Southeast Tunnel)	Towards End Of First Passageway On Wall, 0-5'	Nicholson	8G	Float & Thermostatic	3	1 1/4"	NPT	L	Full Trap, Permit Required Confined Space, Difficult Access, System Shutdown Required
300633	Drip Leg	B / Basement / Boiler Rm (Southeast Tunnel)	Around First Corner On Wall, 0-5'	Nicholson	8G	Float & Thermostatic	3	1 1/4"	NPT	B	Full Trap, Permit Required Confined Space, Difficult Access, System Shutdown Required
300634	Drip Leg	B / Basement / Boiler Rm (Southeast Tunnel)	Direct Middle Of Tunnel After Left Turn By Two Access Areas, 0-5'	Nicholson	8G	Float & Thermostatic	3	1 1/4"	NPT	L	Full Trap, Permit Required Confined Space, Difficult Access, System Shutdown Required
300659	Drip Leg	C / Basement / C001-C	2nd Trap, 0-5'	Barnes & Jones	FTI2015-8	Float & Thermostatic	3	2"	NPT	P	Repair Kit, No Issues
296738	Radiator Trap	C / 1st / C010	Radiator Right Corner, 0-5'	Barnes & Jones	134	Thermostatic Angle	4	3/4"	NPT	P	Repair Kit, No Issues
296740	Radiator Trap	C / 1st / C014	Radiator Left, 0-5'	Barnes & Jones	1949	Thermostatic Angle	4	1/2"	NPT	P	Repair Kit, No Issues
296758	Univent	C / 1st / C022	Univent, 0-5'	Barnes & Jones	1929	Thermostatic Angle	4	3/4"	NPT	L	Repair Kit, No Issues
296759	Radiator Trap	C / 1st / C022	Back Corner, 0-5'	Barnes & Jones	12819	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296736	Univent	C / 1st / C-12	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, Difficult Access
296789	Univent	C / 2nd / C-102	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, Difficult Access
296790	Radiator Trap	C / 2nd / C-102	Radiator Left, 0-5'	Barnes & Jones	2819	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296771	Univent	C / 2nd / C-110	Univent Left Side, 0-5'	Barnes & Jones	3507	Thermostatic Straight	4	1/2"	NPT	L	Repair Kit, Difficult Access
296766	Univent	C / 2nd / C117	Univent, 0-5'	Barnes & Jones	134	Thermostatic Angle	4	3/4"	NPT	P	Repair Kit, No Issues
296799	Radiator Trap	C / 2nd / C-148	On Wall Under Window, 0-5'	Barnes & Jones	122	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296798	Radiator Trap	C / 2nd / C-150	Radiator Left Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	4	3/4"	NPT	P	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296729	Univent	C / 1st / C-18	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, No Issues
296733	Radiator Trap	C / 1st / Hallway	Outside C022, 0-5'	Barnes & Jones	5000	Thermostatic Straight	4	1/2"	NPT	L	Repair Kit, No Issues
296405	Radiator Trap	D / 1st / D116	Corner Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296408	Radiator Trap	D / 1st / Hallway	Outside D117A, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296410	Radiator Trap	D / 1st / Hallway	Outside D117, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
296383	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Upon Entrance Second Drip Along Right Wall, 10-15'	Barnes & Jones	1929	Thermostatic Angle	4	3/4"	NPT	L	Repair Kit, No Issues, System Shutdown Required
296384	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Upon Entrance Third Drip Along Right Wall, 10-15'	Barnes & Jones	1929	Thermostatic Angle	4	3/4"	NPT	L	Repair Kit, System Shutdown Required
296385	Drip Leg	D / Ground / Caged Rm Across From D005(Other AHU Rm)	Along Right Wall Next To Electrical Box, 10-15'	Barnes & Jones	1929	Thermostatic Angle	4	3/4"	NPT	L	Repair Kit, System Shutdown Required
296372	AHU	D / Ground / D005 (AHU)	Unit 1D, 5-10'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, System Shutdown Required
296378	Drip Leg	D / Ground / D005 (AHU)	In Corner Under Ductwork, 5-10'	Barnes & Jones	FT2015-5	Float & Thermostatic	4	1 1/4"	NPT	L	Full Trap, No Issues
296365	Heat Exchanger	D / Ground / Large Rm Across From D001	First HEX On Left Side, 5-10'	Barnes & Jones	FT2015-8	Float & Thermostatic	4	2"	NPT	L	Full Trap, Difficult Access
296367	Drip Leg	D / Ground / Large Rm Across From D001	Crawlspace Leading Back In Little Offshoot Ten Yards Back From HEX, 5-10'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, No Issues
296369	Drip Leg	D / Ground / Large Rm Across From D001 (Can Access From Rm C001-C Access Panel)	In Crawlspace Space All The Way In Back To The Left Of The Condensate Pit. In Cutout In Wall, 0-5'	Barnes & Jones	1929	Thermostatic Angle	4	3/4"	NPT	B	Full Trap, Permit Required Confined Space, Welder Required
300650	Drip Leg	E / Basement / Far Back Tunnel Left Branch	Along Right Wall, 0-5'	Barnes & Jones	5007	Thermostatic Straight	3	3/4"	NPT	P	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296493	Radiator Trap	E / 1st / Hallway To Pool	Across From Stairwell Down To Girls Locker Rm, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	P	Repair Kit, Difficult Access
296494	Radiator Trap	E / 1st / Hallway To Pool	East Side 1st Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296495	Radiator Trap	E / 1st / Hallway To Pool	East Side 2nd Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296498	Radiator Trap	E / 1st / Hallway To Pool	West Side 1st Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296500	Radiator Trap	E / 1st / Hallway To Pool	Between Stairwells To Both Boys And Girls Locker Rm, 0-5'	N/A	N/A	Thermostatic Angle	4	1"	NPT	B	Full Trap, Difficult Access
296707	Drip Leg	E / 1st / Large MER By North Gym	Under Header In Back, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	1 1/4"	NPT	P	Full Trap, Unlabeled Asbestos (PACM)
296708	Drip Leg	E / 1st / Large MER By North Gym	Back Corridor Above Header, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	4	3/4"	NPT	L	Repair Kit, No Issues, Unlabeled Asbestos (PACM)
296705	Radiator Trap	E / 1st / Stairwell	Above Exit 22, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, Difficult Access
296490	Radiator Trap	E / 2nd / E-216 (Planet Fitness Gym)	Right Corner Radiator, 0-5'	Barnes & Jones	5007	Thermostatic Straight	4	1/2"	NPT	L	Repair Kit, No Issues
300647	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	Directly Across From Tunnel Entrance, 5-10'	Barnes & Jones	FTI2015-3	Float & Thermostatic	3	3/4"	NPT	L	Full Trap, Non-Permit Confined Space, System Shutdown Required
300665	Drip Leg	E / Basement / Condensate Tank Rm (Far Back Tunnel Left Branch)	End Of Left Branch. Drip In Corner, 5-10'	Barnes & Jones	FTI2015-3	Float & Thermostatic	3	3/4"	NPT	L	Full Trap, Non-Permit Confined Space
296702	Radiator Trap	E / Basement / E-3	On Wall, 0-5'	Barnes & Jones	1721	Thermostatic Angle	4	1/2"	NPT	L	Repair Kit, No Issues
300645	Radiator Trap	E / Basement (Hallway With Locker Rms) / E-7	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
300646	Radiator Trap	E / Basement (Hallway With Locker Rms) / E-7	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
280545	Radiator Trap	Main / 1st / 100	Left Radiator, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	212 176	OK	Thermostatic Radiator Valve. No Trap Station Components.
280546	Radiator Trap	Main / 1st / 100	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	80 80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
280547	Radiator Trap	Main / 1st / 100	Last Radiator, 0-5'	TS-A	Hoffman	17C	1/2"	3	214 167	OK	Thermostatic Radiator Valve. No Trap Station Components.
280557	Radiator Trap	Main / 1st / 101	Left Radiator Under Window, 0-5'	TS-A	Barnes & Jones	3500	1/2"	3	212 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280558	Radiator Trap	Main / 1st / 101	Right Radiator Under Window, 0-5'	TS-A	Barnes & Jones	3500	1/2"	3	213 190	OK	Thermostatic Radiator Valve. No Trap Station Components.
280548	Radiator Trap	Main / 1st / 102	Opposite Entrance, 0-5'	TS-A	N/A	N/A	3/4"	3	NA NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Bolted Furniture In Way.
280549	Radiator Trap	Main / 1st / 102	Superintendent's Office Right Side, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	217 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280550	Radiator Trap	Main / 1st / 102	Superintendent's Office Back Wall, 0-5'	TS-A	Hoffman	17C	1/2"	3	80 80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
280559	Radiator Trap	Main / 1st / 103	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215 176	OK	Thermostatic Radiator Valve. No Trap Station Components.
280560	Radiator Trap	Main / 1st / 105	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214 212	L	Thermostatic Radiator Valve. No Trap Station Components.
280561	Radiator Trap	Main / 1st / 106	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	213 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
280562	Radiator Trap	Main / 1st / 107	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	3500	1/2"	3	214 168	OK	Thermostatic Radiator Valve. No Trap Station Components.
280537	Univent	Main / 1st / 108	Univent. Trap Behind Bookcase, 5-10'	TS-A	Spirax Sarco	H	1/2"	3	214 198	L	No Trap Station Components.
280538	Radiator Trap	Main / 1st / 108	Opposite Door, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215 213	L	Thermostatic Radiator Valve. No Trap Station Components.
280539	Radiator Trap	Main / 1st / 108	Radiator In Right Office, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	213 186	OK	Thermostatic Radiator Valve. No Trap Station Components.
280540	Drip Leg	Main / 1st / 108	Right Office Front Of Radiator, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	212 195	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
280564	Univent	Main / 1st / 111	Univent On Wall, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	215 179	OK	Inlet Isolation.
280563	Radiator Trap	Main / 1st / 111A	Small Office Left Upon Entrance, 0-5'	TS-A	Barnes & Jones	3500	1/2"	3	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
280536	Radiator Trap	Main / 1st / Hallway	Outside 108, 5-10'	TS-A	Barnes & Jones	1764	1/2"	3	214 98	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components.
280542	Radiator Trap	Main / 1st / Hallway	Down The Hall From 108, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	NA NA	RIP	Thermostatic Radiator Valve. Valved Out.
280551	Radiator Trap	Main / 1st / Main Entrance West Side	In Wall, 0-5'	TS-A	N/A	N/A	1/2"	3	NA NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Access Panel Required To Access Trap.
280552	Radiator Trap	Main / 1st / Main Entrance West Side	Inside Corner Wall, 0-5'	TS-A	N/A	N/A	1/2"	3	NA NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Access Panel Required.
280553	Radiator Trap	Main / 1st / Men's Bathroom Outside 100	Under Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	214 212	<b>L</b>	Thermostatic Radiator Valve. No Trap Station Components.
280543	Radiator Trap	Main / 1st / Office Between 102 And 108	Radiator Left Side, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	214 212	<b>L</b>	Thermostatic Radiator Valve. No Trap Station Components.
280544	Radiator Trap	Main / 1st / Office Between 102 And 108	Radiator Right Side, 0-5'	TS-A	Barnes & Jones	1764	3/4"	3	214 177	OK	Thermostatic Radiator Valve. No Trap Station Components.
280565	Radiator Trap	Main / 1st / Stairwell	Platform Top Of Red Stairs Before Balcony, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	216 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280541	Radiator Trap	Main / 1st / Storage Closet Outside 108	Back Wall, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	224 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
280554	Radiator Trap	Main / 1st / Visitor's Entrance	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	214 180	OK	Thermostatic Radiator Valve. No Trap Station Components.
280555	Radiator Trap	Main / 1st / Visitor's Entrance	Under Window Behind Desk, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	212 178	OK	Thermostatic Radiator Valve. No Trap Station Components.
280556	Radiator Trap	Main / 1st / Women's Bathroom Past Visitor's Entrance	Above Toilet, 5-10'	TS-A	Barnes & Jones	1746	1/2"	3	214 176	OK	Thermostatic Radiator Valve. No Trap Station Components.
280582	Radiator Trap	Main / 2nd / 200	Radiator Corner Wall, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214 212	<b>L</b>	Thermostatic Radiator Valve. No Trap Station Components.
280579	Radiator Trap	Main / 2nd / 201	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	212 198	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
280575	Radiator Trap	Main / 2nd / 203	Radiator Back Right, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Wooden Frame Built Around No Access Panel.
280576	Radiator Trap	Main / 2nd / 203	Left Corner Access Panel, 0-5'	TS-A	Warren Webster	712H	1/2"	3	215	167	OK	Thermostatic Radiator Valve. No Trap Station Components.
280586	Radiator Trap	Main / 2nd / 204	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	214	201	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Open
280574	Radiator Trap	Main / 2nd / 205	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	3164	1/2"	3	213	190	OK	Thermostatic Radiator Valve. No Trap Station Components.
280573	Radiator Trap	Main / 2nd / 207	Radiator Under Window, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Blocked By Large Cabinet.
280566	Radiator Trap	Main / 2nd / 209	Left Wall, 0-5'	TS-A	N/A	N/A	1/2"	3	213	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280567	Radiator Trap	Main / 2nd / 209	Radiator Under Back Window, 0-5'	TS-A	N/A	N/A	1/2"	3	213	212	L	Thermostatic Radiator Valve. No Trap Station Components.
280568	Radiator Trap	Main / 2nd / 209 (Assistant Superintendent's Office)	Left Wall, 0-5'	TS-A	Barnes & Jones	3164	1/2"	3	214	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280569	Radiator Trap	Main / 2nd / 209 (Assistant Superintendent's Office)	Back Wall, 0-5'	TS-A	Barnes & Jones	3164	1/2"	3	214	194	OK	Thermostatic Radiator Valve. No Trap Station Components.
280570	Radiator Trap	Main / 2nd / 211	Radiator Under Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	214	187	OK	Thermostatic Radiator Valve. No Trap Station Components.
280571	Radiator Trap	Main / 2nd / 211	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	213	200	OK	Thermostatic Radiator Valve. No Trap Station Components.
280572	Radiator Trap	Main / 2nd / 211	Radiator Under Left Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215	176	OK	Thermostatic Radiator Valve. No Trap Station Components.
280590	Radiator Trap	Main / 2nd / 214	Behind Entrance Door, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215	200	OK	Thermostatic Radiator Valve. No Trap Station Components.
280591	Radiator Trap	Main / 2nd / 214	Back Corner, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	216	212	L	Manual Radiator Valve. No Trap Station Components.
280594	Radiator Trap	Main / 2nd / 216	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214	187	OK	Thermostatic Radiator Valve. No Trap Station Components.
280593	Radiator Trap	Main / 2nd / 218	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	213	212	L	Thermostatic Radiator Valve. No Trap Station Components.
280595	Radiator Trap	Main / 2nd / 224	Radiator Under Left Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214	194	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
280596	Radiator Trap	Main / 2nd / 224	Radiator Across From Door, 0-5'	TS-A	Barnes & Jones	3164	1/2"	3	215 193	OK	Thermostatic Radiator Valve. No Trap Station Components.
280597	Radiator Trap	Main / 2nd / 224	Radiator In Corner Of Office, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214 188	OK	Thermostatic Radiator Valve. No Trap Station Components.
280578	Radiator Trap	Main / 2nd / Bathroom Across From 203	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1972	1/2"	3	215 178	OK	Thermostatic Radiator Valve. No Trap Station Components.
280589	Radiator Trap	Main / 2nd / Bathroom Next To 210	Radiator By Sink, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	212 196	OK	Thermostatic Radiator Valve. No Trap Station Components.
280580	Radiator Trap	Main / 2nd / Conference Rm Across From 200	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	70 80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
280581	Radiator Trap	Main / 2nd / Conference Rm Across From 200	Radiator In Bathroom, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215 179	OK	Thermostatic Radiator Valve. No Trap Station Components.
280853	Radiator Trap	Main / 2nd / Office Across From 204 (Bottom Of Stairs To Third Floor)	Right Wall, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	80 80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
280854	Radiator Trap	Main / 2nd / Office Across From 204 (Bottom Of Stairs To Third Floor)	Through Side Door Under Window In Small Office, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	212 97	P	Thermostatic Radiator Valve. No Trap Station Components.
280587	Radiator Trap	Main / 2nd / Office Across From 210 Left	Radiator In Corner, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
280588	Radiator Trap	Main / 2nd / Office Across From 210 Right	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	217 97	P	Thermostatic Radiator Valve. No Trap Station Components.
280585	Radiator Trap	Main / 2nd / Office Behind 210	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	213 178	OK	Thermostatic Radiator Valve. No Trap Station Components.
280577	Radiator Trap	Main / 2nd / Rm Across From 203	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	214 199	OK	Thermostatic Radiator Valve. No Trap Station Components.
280592	Radiator Trap	Main / 2nd / Stairwell Platform Next To 218	Radiator On Wall, 5-10'	TS-A	Barnes & Jones	1764	1/2"	3	224 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
269206	Radiator Trap	Main / 3rd / 300	Under Window, 0-5'	TS-A	Barnes & Jones	1972	1/2"	3	214 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
269207	Radiator Trap	Main / 3rd / 302	Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	80 80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out, Not Used, In Computer Temp Sensitive Room.
259205	Radiator Trap	Main / 3rd / 303	Under Window, 0-5'	TS-A	Barnes & Jones	1972	1/2"	3	215 198	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
269209	Radiator Trap	Main / 3rd / 306	Under Corner Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215 212	L	Thermostatic Radiator Valve. No Trap Station Components.
259204	Radiator Trap	Main / 3rd / 307	Under Window, 0-5'	TS-A	Warren Webster	02H	1/2"	3	214 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
269210	Radiator Trap	Main / 3rd / 308	Under Window, 0-5'	TS-A	Hoffman	17C	1/2"	3	212 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
269203	Radiator Trap	Main / 3rd / 309	Under Window, 0-5'	TS-A	Warren Webster	N/A	1/2"	3	214 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
269212	Radiator Trap	Main / 3rd / 312	Opposite Door, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	213 186	OK	Thermostatic Radiator Valve. No Trap Station Components.
269213	Radiator Trap	Main / 3rd / 314	Opposite Door, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	214 188	OK	Thermostatic Radiator Valve. No Trap Station Components.
269214	Radiator Trap	Main / 3rd / 316	By Entrance, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	217 185	OK	Thermostatic Radiator Valve. No Trap Station Components.
269211	Radiator Trap	Main / 3rd / Hallway	Across From 312, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215 178	OK	Thermostatic Radiator Valve. No Trap Station Components.
269202	Radiator Trap	Main / 3rd / Office Of Testing And Federal Grants	Under Emergency Rescue Window, 0-5'	TS-A	N/A	N/A	1/2"	3	212 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
269201	Radiator Trap	Main / 3rd / Office Of Testing And Federal Grant's Most Southern Rm	Back Right Radiator, 0-5'	TS-A	N/A	N/A	1/2"	3	215 212	L	Thermostatic Radiator Valve. No Trap Station Components.
269208	Radiator Trap	Main / 3rd / Old Bathroom Next To 306	Under Window, 0-5'	TS-A	Barnes & Jones	1764	1/2"	3	215 176	OK	Thermostatic Radiator Valve. No Trap Station Components.
280514	Drip Leg	Main / Basement / Break Rm	Radiator Closest To Back Wall, 5-10'	TS-A	Barnes & Jones	122	1/2"	3	213 212	L	No Trap Station Components.
280515	Radiator Trap	Main / Basement / Break Rm	Radiator Closest To Back Wall, 5-10'	TS-S	N/A	N/A	1/2"	3	215 180	OK	Thermostatic Radiator Valve. No Trap Station Components.
280516	Drip Leg	Main / Basement / Break Rm	Radiator Furthest From Back Wall, 5-10'	TS-A	Barnes & Jones	122	1/2"	3	215 178	OK	No Trap Station Components.
280517	Radiator Trap	Main / Basement / Break Rm	Radiator Furthest From Back Wall, 5-10'	TS-S	Spirax Sarco	N/A	1/2"	3	214 213	L	Thermostatic Radiator Valve. No Trap Station Components.
280518	Drip Leg	Main / Basement / Break Rm	Front Of Boiler 1, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	215 213	L	Inlet Isolation, Strainer, Blowdown.
280519	Drip Leg	Main / Basement / Break Rm	Front Of Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	215 200	OK	Inlet Isolation, Strainer, Outlet Isolation.
280520	Drip Leg	Main / Basement / Break Rm	Left Of Boiler 1, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	213 187	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
280521	Drip Leg	Main / Basement / Break Rm	Left Of Boiler 1 On Wall, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	3	215	198	OK	Inlet Isolation, Strainer, Outlet Isolation.
280522	Drip Leg	Main / Basement / Break Rm	Right Of Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	199	OK	Inlet Isolation, Strainer, Outlet Isolation. Outlet Isolation Leaking Condensate.
280523	Drip Leg	Main / Basement / Break Rm	Right Of Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	3	215	178	OK	Inlet Isolation, Strainer, Outlet Isolation.
280524	Drip Leg	Main / Basement / Break Rm	Crawlspace In Back Of Boiler Rm, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	NA	NA	NA	Inlet Isolation, Strainer, Outlet Isolation. Confined Space.
280511	Radiator Trap	Main / Basement / Girl's Bathroom In Front Of Boiler Rm Entrance	Radiator Back Wall, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	213	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280505	Drip Leg	Main / Basement / Hallway Leading To Boiler Rm	Radiator Behind Door Opposite Exit Door By Rm 20, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	198	OK	Inlet Isolation, Strainer.
280506	Radiator Trap	Main / Basement / Hallway Leading To Boiler Rm	Radiator Behind Door Opposite Exit Door By Rm 20, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	212	190	OK	Thermostatic Radiator Valve. No Trap Station Components.
280507	Radiator Trap	Main / Basement / Hallway Leading To Boiler Rm	Radiator Opposite Women's Bathroom, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	224	90	P	Thermostatic Radiator Valve. No Trap Station Components.
280508	Drip Leg	Main / Basement / Hallway Leading To Boiler Rm	Radiator Across From Girl's Bathroom, 5-10'	TS-A	Barnes & Jones	3500	1/2"	3	213	198	OK	No Trap Station Components.
280509	Drip Leg	Main / Basement / Hallway Leading To Boiler Rm	Radiator Across From Girl's Bathroom, 5-10'	TS-A	Barnes & Jones	3500	3/4"	3	213	187	OK	No Trap Station Components.
280525	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	East Corner, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	214	167	OK	Thermostatic Radiator Valve. No Trap Station Components.
280526	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	Middle Column Southeast, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	213	176	OK	Thermostatic Radiator Valve. No Trap Station Components.
280527	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	Southeast Corner In Back, 5-10'	TS-A	Barnes & Jones	5000	1/2"	3	214	180	OK	Thermostatic Radiator Valve. No Trap Station Components.
280528	Drip Leg	Main / Basement / Meeting Rm Across From Red Staircase	Southeast Corner Radiator Inside Casing, 5-10'	TS-A	Hoffman	8C	3/4"	3	213	176	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
280529	Drip Leg	Main / Basement / Meeting Rm Across From Red Staircase	Northwest Corner Radiator, 5-10'	TS-A	Warren Webster	712	1/2"	3	NA	NA	RIP	. Disconnected From System.
280530	Drip Leg	Main / Basement / Meeting Rm Across From Red Staircase	Northwest Corner Radiator, 5-10'	FT	Spirax Sarco	FTL-00	1 1/2"	3	214	198	OK	No Trap Station Components.
280531	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	Northwest Radiator, 5-10'	TS-A	Spirax Sarco	H	1/2"	3	213	90	P	Thermostatic Radiator Valve. No Trap Station Components.
280532	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	Northwest Wall Middle Column, 5-10'	TS-A	Barnes & Jones	1721	1/2"	3	213	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
280533	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	West Corner, 5-10'	TS-A	Barnes & Jones	1721	1/2"	3	213	190	OK	Thermostatic Radiator Valve. No Trap Station Components.
280512	Drip Leg	Main / Basement / Men's Bathroom In Front Of Boiler Rm Entrance	Radiator In Stall, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	214	189	L	No Trap Station Components.
280513	Radiator Trap	Main / Basement / Men's Bathroom In Front Of Boiler Rm Entrance	Radiator In Stall, 5-10'	TS-A	Barnes & Jones	3146	1/2"	3	214	177	OK	Thermostatic Radiator Valve. No Trap Station Components.
280510	Drip Leg	Main / Basement / Office End Of Hall From Boiler Rm Entrance	On Wall, 5-10'	TS-A	Barnes & Jones	1764	1/2"	3	214	212	L	No Trap Station Components.
280534	Radiator Trap	Main / Basement / Restroom Next To Red Staircase	Radiator In Stall, 5-10'	TS-S	Spirax Sarco	N/A	1/2"	3	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
280535	Drip Leg	Main / Basement / Restroom Next To Red Staircase	Radiator In Stall, 5-10'	TS-A	Barnes & Jones	1764	1/2"	3	214	213	L	No Trap Station Components.
280501	Radiator Trap	Main / Basement / Rm 20 Storage Area	Radiator Under Window Left Wall, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	215	200	L	Thermostatic Radiator Valve. No Trap Station Components.
280502	Drip Leg	Main / Basement / Rm 20 Storage Area	Corner Behind Radiator, 5-10'	TS-A	Barnes & Jones	5000	1/2"	3	213	198	OK	Inlet Isolation.
280504	Drip Leg	Main / Basement / Rm 20 Storage Area	Corner Behind Radiator, 5-10'	TS-A	Barnes & Jones	122	1/2"	3	213	213	L	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Leaking and Plugged Traps

Table 2: Leaking and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
280560	Radiator Trap	Main / 1st / 105	Radiator Under Window, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access
280537	Univent	Main / 1st / 108	Univent. Trap Behind Bookcase, 5-10'	Spirax Sarco	H	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Behind Bookcase
280538	Radiator Trap	Main / 1st / 108	Opposite Door, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
280536	Radiator Trap	Main / 1st / Hallway	Outside 108, 5-10'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, System Shutdown Required
280553	Radiator Trap	Main / 1st / Men's Bathroom Outside 100	Under Window, 0-5'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, System Shutdown Required
280543	Radiator Trap	Main / 1st / Office Between 102 And 108	Radiator Left Side, 0-5'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
280582	Radiator Trap	Main / 2nd / 200	Radiator Corner Wall, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
280567	Radiator Trap	Main / 2nd / 209	Radiator Under Back Window, 0-5'	N/A	N/A	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access
280591	Radiator Trap	Main / 2nd / 214	Back Corner, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
280593	Radiator Trap	Main / 2nd / 218	Radiator On Wall, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
280854	Radiator Trap	Main / 2nd / Office Across From 204 (Bottom Of Stairs To Third Floor)	Through Side Door Under Window In Small Office, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
280588	Radiator Trap	Main / 2nd / Office Across From 210 Right	Radiator Under Window, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
269209	Radiator Trap	Main / 3rd / 306	Under Corner Window, 0-5'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access
269201	Radiator Trap	Main / 3rd / Office Of Testing And Federal Grant's Most Southern Rm	Back Right Radiator, 0-5'	N/A	N/A	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, Wood Frame Would Need To Be Cut.
280514	Drip Leg	Main / Basement / Break Rm	Radiator Closest To Back Wall, 5-10'	Barnes & Jones	122	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, System Shutdown Required
280517	Radiator Trap	Main / Basement / Break Rm	Radiator Furthest From Back Wall, 5-10'	Spirax Sarco	N/A	Thermostatic Straight	3	1/2"	NPT	L	Full Trap, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Leaking and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
280518	Drip Leg	Main / Basement / Break Rm	Front Of Boiler 1, 5-10'	Barnes & Jones	FT2015-4	Float & Thermostatic	3	1"	NPT	L	Repair Kit, System Shutdown Required, No Outlet Valve
280507	Radiator Trap	Main / Basement / Hallway Leading To Boiler Rm	Radiator Opposite Women's Bathroom, 5-10'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
280531	Radiator Trap	Main / Basement / Meeting Rm Across From Red Staircase	Northwest Radiator, 5-10'	Spirax Sarco	H	Thermostatic Angle	3	1/2"	NPT	P	Full Trap, Extremely Difficult Access. Buried In A Wall Blocked By A Radiator. Will Need To Cut Wall To Create Space To Turn Wrench.
280512	Drip Leg	Main / Basement / Men's Bathroom In Front Of Boiler Rm Entrance	Radiator In Stall, 5-10'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, System Shutdown Required
280510	Drip Leg	Main / Basement / Office End Of Hall From Boiler Rm Entrance	On Wall, 5-10'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, System Shutdown Required
280535	Drip Leg	Main / Basement / Restroom Next To Red Staircase	Radiator In Stall, 5-10'	Barnes & Jones	1764	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, System Shutdown Required, Trap Piped Backwards
280501	Radiator Trap	Main / Basement / Rm 20 Storage Area	Radiator Under Window Left Wall, 0-5'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
280504	Drip Leg	Main / Basement / Rm 20 Storage Area	Corner Behind Radiator, 5-10'	Barnes & Jones	122	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, System Shutdown Required

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300101	Univent	Main / 1st / 101	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	210	189	OK	No Trap Station Components.
300102	Radiator Trap	Main / 1st / 101	Below AC, 0-5'	TS-A	N/A	NA	3/4"	3	215	209	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
300111	Radiator Trap	Main / 1st / 101	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	213	167	OK	Thermostatic Radiator Valve. No Trap Station Components.
300112	Radiator Trap	Main / 1st / 101	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	214	194	OK	DDC Radiator Valve. No Trap Station Components.
300113	Univent	Main / 1st / 101	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	196	OK	No Trap Station Components.
300103	Univent	Main / 1st / 102	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	212	176	OK	No Trap Station Components.
300104	Radiator Trap	Main / 1st / 102	Radiator Trap, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. Suspected Leak. Access Panel Required
300105	Univent	Main / 1st / 104	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	218	198	OK	No Trap Station Components.
300106	Radiator Trap	Main / 1st / 104	Radiator Left Of Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	216	198	OK	DDC Radiator Valve. No Trap Station Components.
300107	Radiator Trap	Main / 1st / 104	In Storage Closet, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	Thermostatic Radiator Valve. No Trap Station Components. No Access.
300114	Radiator Trap	Main / 1st / 105	Closet, 0-5'	TS-A	N/A	NA	1/2"	3	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. Buried.
300115	Radiator Trap	Main / 1st / 105	Left Radiator, 0-5'	TS-A	Warren Webster	513	3/4"	3	74	76	<b>P</b>	DDC Radiator Valve. No Trap Station Components. DDC Valve Stuck Closed
300116	Radiator Trap	Main / 1st / 105	Right Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	213	186	OK	DDC Radiator Valve. No Trap Station Components.
300108	Univent	Main / 1st / 106	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	219	214	<b>L</b>	No Trap Station Components.
300109	Radiator Trap	Main / 1st / 106	Radiator Trap In Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	215	185	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300110	Radiator Trap	Main / 1st / 106	Storage Unit, 0-5'	FT	N/A	N/A	3/4"	3	NA	NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Storage Closet Full.
300128	Radiator Trap	Main / 1st / 107A	Radiator On Wall, 5-10'	TS-A	N/A	N/A	3/4"	3	216	200	OK	DDC Radiator Valve. No Trap Station Components.
300129	Drip Leg	Main / 1st / 107A	Drip Against Back Wall, 10-15'	TS-A	Warren Webster	513	3/4"	3	217	165	OK	No Trap Station Components.
300130	Drip Leg	Main / 1st / 107A Storage Closet	Drip In Corner, 10-15'	TS-A	N/A	M/A	3/4"	3	NA	NA	NA	No Trap Station Components. Storage Area Filled.
300131	Radiator Trap	Main / 1st / 107A Storage Closet	Radiator On Wall, 5-10'	TS-A	Warren Webster	512	1/2"	3	224	176	OK	DDC Radiator Valve. No Trap Station Components.
300123	Radiator Trap	Main / 1st / 107B	Left Of Door, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	197	OK	DDC Radiator Valve. No Trap Station Components.
300124	Radiator Trap	Main / 1st / 107B	2nd Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	213	187	OK	DDC Radiator Valve. No Trap Station Components.
300125	Radiator Trap	Main / 1st / 107B	3rd Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	110	89	P	DDC Radiator Valve. No Trap Station Components.
300126	Drip Leg	Main / 1st / 107B	Back Left Corner, 5-10'	TS-A	Warren Webster	723	3/4"	3	214	207	L	No Trap Station Components.
300127	Radiator Trap	Main / 1st / 107B	Back Wall, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	78	76	P	DDC Radiator Valve. No Trap Station Components.
300120	Radiator Trap	Main / 1st / 109A	Radiator On Wall, 5-10'	TS-A	Warren Webster	512	1/2"	3	215	186	OK	DDC Radiator Valve. No Trap Station Components.
300121	Drip Leg	Main / 1st / 109A	Drip In Corner, 10-15'	TS-A	Warren Webster	723	3/4"	3	216	196	OK	No Trap Station Components.
300140	Radiator Trap	Main / 1st / 112	Right Wall, 0-5'	TS-A	Warren Webster	512	1/2"	3	213	187	OK	DDC Radiator Valve. No Trap Station Components.
300141	Radiator Trap	Main / 1st / 112	2nd Radiator On Right, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	211	B	DDC Radiator Valve. No Trap Station Components.
300142	Radiator Trap	Main / 1st / 112A	Below Window, 0-5'	TS-A	Hoffman	17C	1/2"	3	216	191	OK	DDC Radiator Valve. No Trap Station Components.
300144	Radiator Trap	Main / 1st / 114	Below Right Window, 0-5'	TS-A	Warren Webster	513	3/4"	3	216	209	L	DDC Radiator Valve. No Trap Station Components.
300145	Radiator Trap	Main / 1st / 114 Closet	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	78	78	P	DDC Radiator Valve. No Trap Station Components. DDC Valve Stuck Closed

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300146	Radiator Trap	Main / 1st / 114 Closet	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	189	OK	DDC Radiator Valve. No Trap Station Components.
300143	Radiator Trap	Main / 1st / 114B	Left Corner, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	215	208	L	DDC Radiator Valve. No Trap Station Components.
300210	Radiator Trap	Main / 1st / 115	Back Right Corner, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	83	83	P	Manual Radiator Valve. No Trap Station Components.
300211	Radiator Trap	Main / 1st / 115	Above Double Doors, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	83	83	P	Manual Radiator Valve. No Trap Station Components. Manual Valve Stuck Open
300212	Radiator Trap	Main / 1st / 115	Left Of Double Doors, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	215	208	L	Manual Radiator Valve. No Trap Station Components.
300213	Radiator Trap	Main / 1st / 115	Above Fire Extinguisher, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	NA	NA	RIP	Manual Radiator Valve. Valved Out, Not Used.
300214	Radiator Trap	Main / 1st / 115	Across From Fire Extinguisher, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	214	186	OK	Manual Radiator Valve. Inlet Isolation.
300215	Radiator Trap	Main / 1st / 115	Across From Double Doors, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	214	207	L	Manual Radiator Valve. Inlet Isolation Leaking Condensate. Manual Valve Leaking From Valve Body
300216	Radiator Trap	Main / 1st / 115	Across From Double Doors, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	215	207	L	Manual Radiator Valve. Inlet Isolation.
300217	Radiator Trap	Main / 1st / 115	Above Eyewash, Above Ceiling	TS-A	Warren Webster	512	1/2"	3	NA	NA	RIP	Thermostatic Radiator Valve. Not Calling, Not Used.
300218	Radiator Trap	Main / 1st / 115	Far Right Corner, Above Ceiling	TS-A	Warren Webster	513	3/4"	3	214	212	B	Manual Radiator Valve. Inlet Isolation.
300155	Radiator Trap	Main / 1st / 119 Custodial Lounge	In Bathroom, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	100	P	Thermostatic Radiator Valve. No Trap Station Components.
300156	Radiator Trap	Main / 1st / 119 Custodial Lounge	Under Right Window, 0-5'	TS-A	Warren Webster	513	3/4"	3	214	98	P	DDC Radiator Valve. No Trap Station Components.
300157	Radiator Trap	Main / 1st / 119 Custodial Lounge	Under Left Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	212	L	DDC Radiator Valve. No Trap Station Components.
300160	Radiator Trap	Main / 1st / 120 Storage Rm	Right Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	212	L	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Open
300161	Radiator Trap	Main / 1st / 120 Storage Rm	Left Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	198	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300162	Radiator Trap	Main / 1st / 120 Storage Rm	Bathroom Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 185	P	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
300167	Radiator Trap	Main / 1st / 121	Storage Rm Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
300168	Univent	Main / 1st / 121	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214 177	OK	No Trap Station Components.
300169	Univent	Main / 1st / 122	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214 174	OK	No Trap Station Components.
300170	Radiator Trap	Main / 1st / 122	Univent Back Right, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	76 89	P	DDC Radiator Valve. No Trap Station Components.
300171	Radiator Trap	Main / 1st / 122	Closet, 0-5'	TS-A	N/A	NA	1/2"	3	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Buried Beneath Toys.
300175	Radiator Trap	Main / 1st / 123	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	214 207	L	DDC Radiator Valve. No Trap Station Components.
300176	Univent	Main / 1st / 123	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215 189	OK	No Trap Station Components.
300177	Radiator Trap	Main / 1st / 123	Bathroom, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 181	OK	Thermostatic Radiator Valve. No Trap Station Components.
300172	Univent	Main / 1st / 124	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214 199	OK	No Trap Station Components.
300173	Radiator Trap	Main / 1st / 124	Univent Back Right Corner, 0-5'	TS-A	Watts	1G	1/2"	3	216 179	OK	Thermostatic Radiator Valve. No Trap Station Components.
300174	Radiator Trap	Main / 1st / 124	Closet, 0-5'	TS-A	N/A	NA	1/2"	3	NA NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Buried.
269300	Drip Leg	Main / 1st / 3 Next To Cafeteria	Right Corner, 0-5'	FT	Spirax Sarco	FT15	3/4"	3	215 178	OK	Inlet Isolation, Strainer, Blowdown.
300132	Drip Leg	Main / 1st / Bathroom Across From 109	Radiator On Wall, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 89	P	No Trap Station Components.
300134	Radiator Trap	Main / 1st / Cabinet/Storage Area Next To 109	Radiator Across From Entrance, 10-15'	TS-A	Warren Webster	512	1/2"	3	216 198	OK	DDC Radiator Valve. No Trap Station Components.
300135	Radiator Trap	Main / 1st / Cabinet/Storage Area Next To 109	Radiator Back Wall, 5-10'	TS-A	Barnes & Jones	134	3/4"	3	NA NA	RIP	No Radiator Valve. Disconnected From System.
300136	Reheat Coil	Main / 1st / Cabinet/Storage Area Next To 109	Against Back Wall, 5-10'	FT	Hoffman	FT015-H	3/4"	3	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
300137	Drip Leg	Main / 1st / Cabinet/Storage Area Next To 109	Middle Of Back Wall, 10-15'	TS-A	Warren Webster	513	3/4"	3	80 80	NIS	No Trap Station Components. Valved Out.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300138	Drip Leg	Main / 1st / Cabinet/Storage Area Next To 109	Right Corner Below Ductwork, 10-15'	TS-A	Warren Webster	533	3/4"	3	80	80	NIS	Outlet Isolation. Valved Out.
300147	Reheat Coil	Main / 1st / Cafeteria	Left Wall, 10-15'	TS-A	Warren Webster	N05	1"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300148	Reheat Coil	Main / 1st / Cafeteria	Left Wall, 10-15'	TS-A	Warren Webster	N05	1"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300149	Drip Leg	Main / 1st / Cafeteria	Back Left Corner, 10-15'	TS-A	Warren Webster	788	3/4"	3	215	199	OK	No Trap Station Components.
300150	Reheat Coil	Main / 1st / Cafeteria	Back Left Corner, 10-15'	TS-A	Warren Webster	544	1"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300151	Reheat Coil	Main / 1st / Cafeteria	Back Left Corner, 10-15'	TS-A	Warren Webster	544	1"	3	NA	NA	RIP	Valved Out, Disconnected From System.
300152	Radiator Trap	Main / 1st / Cafeteria	Radiator Above Middle Window, 10-15'	TS-A	Warren Webster	514	3/4"	3	216	192	OK	DDC Radiator Valve. No Trap Station Components.
300153	Radiator Trap	Main / 1st / Cafeteria	Radiator Right Corner, 5-10'	TS-RH	Warren Webster	513RB	1/2"	3	214	176	OK	DDC Radiator Valve. No Trap Station Components.
300154	Drip Leg	Main / 1st / Cafeteria	Next To Radiator In Right Corner, 10-15'	TS-A	Warren Webster	513	3/4"	3	213	179	OK	No Trap Station Components.
300164	Radiator Trap	Main / 1st / Girl's Bathroom Across From Cafeteria	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	78	76	P	DDC Radiator Valve. No Trap Station Components.
300118	Radiator Trap	Main / 1st / Hallway	Radiator Across From 109A, 0-5'	TS-A	Warren Webster	512	1/2"	3	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
300119	Radiator Trap	Main / 1st / Hallway	Next To 109A, 5-10'	TS-A	Warren Webster	512	1/2"	3	215	193	OK	Thermostatic Radiator Valve. No Trap Station Components.
300117	Drip Leg	Main / 1st / Hallway	Outside 109A, 10-15'	FT	Spirax Sarco	FT15	1"	3	213	208	L	Inlet Isolation, Strainer, Outlet Isolation.
300122	Radiator Trap	Main / 1st / Hallway	Outside 107B, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	208	L	Manual Radiator Valve. No Trap Station Components. Manual Valve Stuck Open
300133	Radiator Trap	Main / 1st / Hallway	Across From Large Storage, 0-5'	TS-V	N/A	NO TRAP	1/2"	3	78	78	P	No Radiator Valve. No Trap Station Components.
300134	Radiator Trap	Main / 1st / Hallway	Outside Elevator, 0-5'	TS-S	Mepco	1E	1/2"	3	214	208	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Radiator Valve Leaking By
300163	Radiator Trap	Main / 1st / Hallway	Across From Cafeteria, 0-5'	TS-S	N/A	NO TRAP	3/4"	3	213	213	L	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300209	Radiator Trap	Main / 1st / Machine Shop	Back Right Corner, 10-15'	TS-A	Warren Webster	513	3/4"	3	214 179	OK	DDC Radiator Valve. No Trap Station Components.
300219	Drip Leg	Main / 1st / Pantry	Back Wall, 5-10'	TS-A	Warren Webster	533	3/4"	3	156 164	P	No Trap Station Components.
300220	Radiator Trap	Main / 1st / Pantry	Back Left Corner, 5-10'	TS-A	Warren Webster	513	3/4"	3	82 82	P	DDC Radiator Valve. No Trap Station Components.
300221	Drip Leg	Main / 1st / Pantry	Around Corner From Door, 5-10'	FT	Spirax Sarco	FT15	3/4"	3	215 182	OK	Inlet Isolation, Strainer, Blowdown.
300178	Radiator Trap	Main / 1st / Stairwell 1	Outside 124, 0-5'	TS-A	Warren Webster	513	3/4"	3	216 212	B	Manual Radiator Valve. No Trap Station Components. Manual Valve Stuck Open
300179	Radiator Trap	Main / 1st / Stairwell 1	Lower Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 211	B	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Open
300180	Radiator Trap	Main / 1st / Stairwell 1	At Exit, 0-5'	TS-A	Warren Webster	512	1/2"	3	81 81	P	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
300165	Radiator Trap	Main / 1st / Stairwell 2	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	78 78	P	Thermostatic Radiator Valve. No Trap Station Components.
300166	Radiator Trap	Main / 1st / Stairwell 2	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	77 78	P	Thermostatic Radiator Valve. No Trap Station Components.
300181	Radiator Trap	Main / 1st / Stairwell 4	At Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 207	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Radiator Valve Leaking By
300158	Radiator Trap	Main / 1st / Vestibule Outside Custodial Lounge	Right Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	213 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
300159	Radiator Trap	Main / 1st / Vestibule Outside Custodial Lounge	Left Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 193	OK	Thermostatic Radiator Valve. No Trap Station Components.
300182	Radiator Trap	Main / 2nd / 201	Radiator, 0-5'	TS-A	N/A	NA	3/4"	3	NA NA	NA	Thermostatic Radiator Valve. No Trap Station Components. Cannot Remove Cover.
300183	Univent	Main / 2nd / 202A	Left Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215 207	L	No Trap Station Components.
300184	Univent	Main / 2nd / 202A	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214 178	OK	No Trap Station Components.
300191	Radiator Trap	Main / 2nd / 203	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	84 83	P	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300192	Radiator Trap	Main / 2nd / 203	Left Radiator, 0-5'	TS-A	Warren Webster	513	3/4"	3	217 209	L	DDC Radiator Valve. No Trap Station Components.
300193	Radiator Trap	Main / 2nd / 203	Right Radiator, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	215 183	OK	DDC Radiator Valve. No Trap Station Components.
300185	Univent	Main / 2nd / 204	Univent, 0-5'	FT	Spirax Sarco	FTI-15	3/4"	3	216 194	OK	Outlet Isolation.
300186	Radiator Trap	Main / 2nd / 204	Radiator, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	214 187	OK	DDC Radiator Valve. No Trap Station Components.
300187	Radiator Trap	Main / 2nd / 204	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	81 81	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling.
300195	Radiator Trap	Main / 2nd / 205	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	213 178	OK	DDC Radiator Valve. No Trap Station Components.
300196	Radiator Trap	Main / 2nd / 205	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 209	L	DDC Radiator Valve. No Trap Station Components.
300194	Radiator Trap	Main / 2nd / 205C	Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	NA NA	RIP	DDC Radiator Valve. Valved Out, Not Used.
300197	Radiator Trap	Main / 2nd / 205D	Below Window, Above 15'	TS-A	Warren Webster	512	1/2"	3	216 207	L	DDC Radiator Valve. No Trap Station Components.
300188	Univent	Main / 2nd / 206	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215 186	OK	No Trap Station Components.
300189	Radiator Trap	Main / 2nd / 206	Radiator, 0-5'	TS-A	Hoffman	17C	1/2"	3	215 188	OK	DDC Radiator Valve. No Trap Station Components.
300190	Radiator Trap	Main / 2nd / 206	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	83 81	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling.
300201	Radiator Trap	Main / 2nd / 215	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 192	OK	DDC Radiator Valve. No Trap Station Components.
300202	Radiator Trap	Main / 2nd / 215	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 191	OK	DDC Radiator Valve. No Trap Station Components.
300227	Radiator Trap	Main / 2nd / 216	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 207	L	DDC Radiator Valve. No Trap Station Components.
300232	Radiator Trap	Main / 2nd / 216 Bathroom	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 179	OK	DDC Radiator Valve. No Trap Station Components.
300224	Radiator Trap	Main / 2nd / 216A	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 192	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300225	Radiator Trap	Main / 2nd / 216A	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	91 90	P	DDC Radiator Valve. No Trap Station Components.
300229	Radiator Trap	Main / 2nd / 216B	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	218 211	B	DDC Radiator Valve. No Trap Station Components.
300230	Radiator Trap	Main / 2nd / 216B	Middle Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 188	OK	DDC Radiator Valve. No Trap Station Components.
300231	Radiator Trap	Main / 2nd / 216B	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 207	L	DDC Radiator Valve. No Trap Station Components.
300228	Radiator Trap	Main / 2nd / 216C	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 183	OK	Manual Radiator Valve. No Trap Station Components. Manual Valve Radiator Valve Leaking By
300226	Radiator Trap	Main / 2nd / 216D	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 178	OK	DDC Radiator Valve. No Trap Station Components.
300206	Radiator Trap	Main / 2nd / 217	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 196	OK	DDC Radiator Valve. No Trap Station Components.
300207	Radiator Trap	Main / 2nd / 217	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	87 87	P	DDC Radiator Valve. No Trap Station Components.
300208	Radiator Trap	Main / 2nd / 217	Bathroom, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 199	OK	DDC Radiator Valve. No Trap Station Components.
300203	Radiator Trap	Main / 2nd / 218	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 189	OK	DDC Radiator Valve. No Trap Station Components.
300243	Univent	Main / 2nd / 223	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214 207	L	Inlet Isolation, Outlet Isolation.
300244	Radiator Trap	Main / 2nd / 223	Radiator, 0-5'	TS-S	Barnes & Jones	134	3/4"	3	214 185	OK	DDC Radiator Valve. No Trap Station Components.
300245	Radiator Trap	Main / 2nd / 223	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	89 89	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling.
300240	Univent	Main / 2nd / 224	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213 177	OK	No Trap Station Components.
300241	Radiator Trap	Main / 2nd / 224	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	214 179	OK	DDC Radiator Valve. No Trap Station Components.
300242	Radiator Trap	Main / 2nd / 224	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 207	L	Thermostatic Radiator Valve. No Trap Station Components.
300249	Radiator Trap	Main / 2nd / 225	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	215 208	L	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300250	Radiator Trap	Main / 2nd / 225	Radiator, 0-5'	TS-S	Barnes & Jones	134	3/4"	3	89	89	P	DDC Radiator Valve. No Trap Station Components. DDC Valve Stuck Closed
300251	Univent	Main / 2nd / 225	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	207	L	Inlet Isolation, Outlet Isolation.
300248	Radiator Trap	Main / 2nd / 226	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	215	197	OK	DDC Radiator Valve. No Trap Station Components.
300246	Univent	Main / 2nd / 226	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	185	OK	Inlet Isolation, Outlet Isolation.
300247	Radiator Trap	Main / 2nd / 226	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	217	207	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Leaking From Valve Body
300239	Radiator Trap	Main / 2nd / Boy's Bathroom Next To 224	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	191	OK	DDC Radiator Valve. No Trap Station Components.
300198	Radiator Trap	Main / 2nd / Girl's Bathroom Across From Library	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	192	OK	DDC Radiator Valve. No Trap Station Components.
300223	Radiator Trap	Main / 2nd / Hallway	Outside Elevator, 0-5'	TS-S	Barnes & Jones	122	1/2"	3	215	211	B	Thermostatic Radiator Valve. No Trap Station Components.
300233	Radiator Trap	Main / 2nd / Hallway	Across From Auditorium, 0-5'	TS-A	Warren Webster	513	3/4"	3	215	196	OK	Manual Radiator Valve. No Trap Station Components.
300252	Radiator Trap	Main / 2nd / Hallway	Outside 225, 0-5'	TS-A	Warren Webster	713	3/4"	3	215	197	OK	Manual Radiator Valve. No Trap Station Components. Manual Valve Broken Off
300222	AHU	Main / 2nd / Library	Between 215 And 214, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	214	174	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
300236	Radiator Trap	Main / 2nd / Stage	Right Radiator, 0-5'	TS-A	Warren Webster	513	3/4"	3	210	174	OK	DDC Radiator Valve. No Trap Station Components.
300234	AHU	Main / 2nd / Stage	Left AHU, 0-5'	FT	Hoffman	FT015-H5	1 1/4"	3	190	176	OK	Strainer, Blowdown, Outlet Isolation.
300235	Radiator Trap	Main / 2nd / Stage	Left Radiator, 0-5'	TS-A	Warren Webster	513	3/4"	3	85	85	P	DDC Radiator Valve. No Trap Station Components.
300237	AHU	Main / 2nd / Stage	Right AHU, 10-15'	FT	Hoffman	FT015-H5	1 1/4"	3	213	178	OK	Strainer, Blowdown, Outlet Isolation.
300253	Radiator Trap	Main / 2nd / Stairwell 1	Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	89	89	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300238	Radiator Trap	Main / 2nd / Stairwell 2	Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	81	81	P	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
300199	Radiator Trap	Main / 2nd / Stairwell 3	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	81	81	P	Thermostatic Radiator Valve. No Trap Station Components.
300200	Radiator Trap	Main / 2nd / Stairwell 3	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	87	84	P	Thermostatic Radiator Valve. No Trap Station Components.
300204	Radiator Trap	Main / 2nd / Stairwell Behind Library	At Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	89	86	P	Thermostatic Radiator Valve. No Trap Station Components.
300205	Radiator Trap	Main / 2nd / Stairwell Behind Library	At Dead End Stairs, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	193	OK	Manual Radiator Valve. No Trap Station Components. Manual Valve Stuck Open
300262	Radiator Trap	Main / 3rd / 301	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	90	90	P	Thermostatic Radiator Valve. No Trap Station Components.
300263	Radiator Trap	Main / 3rd / 301	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	215	181	OK	DDC Radiator Valve. No Trap Station Components.
300264	Univent	Main / 3rd / 301	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	197	OK	Inlet Isolation, Outlet Isolation.
300256	Univent	Main / 3rd / 304	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	193	OK	Inlet Isolation, Outlet Isolation.
300257	Radiator Trap	Main / 3rd / 304	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	213	176	OK	DDC Radiator Valve. No Trap Station Components.
300258	Radiator Trap	Main / 3rd / 304	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	88	88	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
300265	Univent	Main / 3rd / 305	Left Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	85	85	NIS	Inlet Isolation, Outlet Isolation. Not Calling.
300266	Radiator Trap	Main / 3rd / 305	Radiator, 0-5'	TS-A	Warren Webster	523	3/4"	3	216	195	OK	DDC Radiator Valve. No Trap Station Components.
300267	Univent	Main / 3rd / 305	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	NIS	Inlet Isolation, Outlet Isolation. Valved Out.
300259	Radiator Trap	Main / 3rd / 306A	Beneath Cover, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	216	178	OK	DDC Radiator Valve. No Trap Station Components.
300260	Univent	Main / 3rd / 306B	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	178	OK	No Trap Station Components.
300261	Radiator Trap	Main / 3rd / 306B	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	91	91	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300269	Univent	Main / 3rd / 307	1st Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	189	OK	Inlet Isolation, Outlet Isolation.
300270	Radiator Trap	Main / 3rd / 307	1st Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	217	185	OK	DDC Radiator Valve. No Trap Station Components.
300271	Radiator Trap	Main / 3rd / 307	2nd Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	217	202	OK	DDC Radiator Valve. No Trap Station Components.
300272	Radiator Trap	Main / 3rd / 307	3rd Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	189	OK	DDC Radiator Valve. No Trap Station Components.
300273	Radiator Trap	Main / 3rd / 307	4th Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	193	OK	DDC Radiator Valve. No Trap Station Components.
300274	Radiator Trap	Main / 3rd / 307	5th Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	200	OK	DDC Radiator Valve. No Trap Station Components.
300275	Univent	Main / 3rd / 307	2nd Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	178	OK	Inlet Isolation, Outlet Isolation.
300280	Radiator Trap	Main / 3rd / 312	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	189	OK	DDC Radiator Valve. No Trap Station Components.
300278	Radiator Trap	Main / 3rd / 312A	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	211	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
300279	Radiator Trap	Main / 3rd / 312A	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	179	OK	DDC Radiator Valve. No Trap Station Components.
300277	Radiator Trap	Main / 3rd / 312B	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	207	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
300284	Radiator Trap	Main / 3rd / 312C	Middle Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	82	82	<b>P</b>	DDC Radiator Valve. No Trap Station Components. DDC Valve Stuck Closed
300285	Radiator Trap	Main / 3rd / 312C	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	85	85	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components.
300281	Radiator Trap	Main / 3rd / 312D	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	199	OK	Thermostatic Radiator Valve. No Trap Station Components.
300282	Radiator Trap	Main / 3rd / 312D	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	192	OK	Thermostatic Radiator Valve. No Trap Station Components.
300287	Radiator Trap	Main / 3rd / 313	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	193	OK	DDC Radiator Valve. No Trap Station Components.
300288	Radiator Trap	Main / 3rd / 313	Middle Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	209	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
300289	Radiator Trap	Main / 3rd / 313	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	189	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300292	Univent	Main / 3rd / 322	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	81	81	NIS	Inlet Isolation, Outlet Isolation. Valved Out.
300293	Radiator Trap	Main / 3rd / 322	Radiator Access Panels, 0-5'	TS-A	N/A	NA	3/4"	3	89	89	P	DDC Radiator Valve. No Trap Station Components.
300294	Radiator Trap	Main / 3rd / 322	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	208	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Broken Off
300295	Radiator Trap	Main / 3rd / 323	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	215	178	OK	Thermostatic Radiator Valve. No Trap Station Components.
300296	Radiator Trap	Main / 3rd / 323	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	214	182	OK	DDC Radiator Valve. No Trap Station Components.
300297	Univent	Main / 3rd / 323	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	185	OK	Inlet Isolation, Outlet Isolation.
300298	Radiator Trap	Main / 3rd / 324	Below Window, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	200	187	OK	DDC Radiator Valve. No Trap Station Components.
300301	Radiator Trap	Main / 3rd / 325	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	193	OK	Thermostatic Radiator Valve. No Trap Station Components.
300302	Radiator Trap	Main / 3rd / 325	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	214	188	OK	DDC Radiator Valve. No Trap Station Components.
300303	Univent	Main / 3rd / 325	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	210	191	OK	Inlet Isolation, Outlet Isolation.
300299	Radiator Trap	Main / 3rd / 326	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	89	88	P	DDC Radiator Valve. No Trap Station Components.
300300	Radiator Trap	Main / 3rd / 326	Closet, 0-5'	TS-A	Warren Webster	512	1/2"	3	216	209	L	Thermostatic Radiator Valve. No Trap Station Components.
300291	Radiator Trap	Main / 3rd / Girl's Bathroom Next To 322	Below Window, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	182	OK	DDC Radiator Valve. No Trap Station Components.
300255	Radiator Trap	Main / 3rd / Hallway	Outside 304, 0-5'	TS-A	Warren Webster	512	1/2"	3	89	89	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling. Thermostatic Valve Stuck Closed
300276	Radiator Trap	Main / 3rd / Hallway	Outside Elevator, 0-5'	TS-S	Barnes & Jones	122	1/2"	3	215	207	L	Thermostatic Radiator Valve. No Trap Station Components.
300286	Radiator Trap	Main / 3rd / Hallway	Next To 312, 0-5'	TS-A	Warren Webster	523	3/4"	3	NA	NA	RIP	Thermostatic Radiator Valve. Valved Out.
300304	Radiator Trap	Main / 3rd / Hallway	Outside 325, 0-5'	TS-A	Warren Webster	513	3/4"	3	81	81	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling. Thermostatic Valve Stuck Closed

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
300305	Radiator Trap	Main / 3rd / Stairwell 1	Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 199	OK	Thermostatic Radiator Valve. No Trap Station Components.
300290	Radiator Trap	Main / 3rd / Stairwell 2	Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	82 82	P	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Radiator Valve Leaking By
300268	Radiator Trap	Main / 3rd / Stairwell 3	Landing 300268, 0-5'	TS-A	Warren Webster	512	1/2"	3	85 85	P	Thermostatic Radiator Valve. No Trap Station Components.
300254	Radiator Trap	Main / 3rd / Stairwell 4	Landing, 0-5'	TS-A	Warren Webster	512	1/2"	3	86 86	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling.
300309	Drip Leg	Main / 4th / Gym	Left End, 10-15'	FT	Spirax Sarco	FT15	3/4"	3	215 188	OK	Inlet Isolation, Strainer, Blowdown.
300310	AHU	Main / 4th / Gym Storage	Left AHU, 10-15'	FT	Spirax Sarco	FT15	1"	3	210 174	OK	Strainer, Blowdown.
300311	Drip Leg	Main / 4th / Gym Storage	Left Radiator AHU, 10-15'	FT	Spirax Sarco	FT15	3/4"	3	215 176	OK	Inlet Isolation, Strainer, Blowdown.
300313	AHU	Main / 4th / Gym Storage	Right AHU, 10-15'	FT	Spirax Sarco	FT15	1"	3	211 176	OK	Strainer.
300312	Radiator Trap	Main / 4th / Stairwell 2	Skylight, 10-15'	TS-A	Warren Webster	523	3/4"	3	214 198	OK	Manual Radiator Valve. Inlet Isolation.
300314	Radiator Trap	Main / 4th / Stairwell 2	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	213 194	OK	Thermostatic Radiator Valve. No Trap Station Components.
300315	Radiator Trap	Main / 4th / Stairwell 2	Right Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	87 97	P	Thermostatic Radiator Valve. No Trap Station Components.
300306	Radiator Trap	Main / 4th / Stairwell 3	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	214 199	OK	Thermostatic Radiator Valve. No Trap Station Components.
300307	Radiator Trap	Main / 4th / Stairwell 3	Left Radiator, 0-5'	TS-A	Warren Webster	512	1/2"	3	216 199	OK	Thermostatic Radiator Valve. No Trap Station Components.
300308	Radiator Trap	Main / 4th / Stairwell 3	Skylight, 10-15'	TS-A	Warren Webster	513	3/4"	3	88 88	NIS	Manual Radiator Valve. Inlet Isolation. Valved Out.
269288	Drip Leg	Main / Basement / Boiler Rm C	Against Back Wall Next To Access Door, 10-15'	TS-A	Warren Webster	533	3/4"	3	216 197	OK	No Trap Station Components.
269289	Drip Leg	Main / Basement / Boiler Rm C	Below Main Header Against Wall, 10-15'	FT	Hoffman	FT56	1 1/4"	3	215 98	P	Inlet Isolation, Strainer.
269283	Drip Leg	Main / Basement / Boiler Rm D	Left Of Boiler 2, 5-10'	FT	Hoffman	FT55	3/4"	3	80 80	NIS	Inlet Isolation, Strainer. Valved Out.
269284	Drip Leg	Main / Basement / Boiler Rm D	Left Of Boiler 1, 5-10'	FT	Hoffman	FT55	3/4"	3	80 80	NIS	Inlet Isolation, Strainer. Valved Out.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
269285	Drip Leg	Main / Basement / Boiler Rm D	Front Of Boiler, 5-10'	FT	Hoffman	FT55	3/4"	3	216	213	L	Inlet Isolation, Strainer, Outlet Isolation.
269292	Univent	Main / Basement / Classroom A	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	186	OK	No Trap Station Components.
269293	Radiator Trap	Main / Basement / Classroom A	Radiator, 0-5'	TS-A	Hoffman	8C	3/4"	3	214	167	OK	DDC Radiator Valve. No Trap Station Components.
269291	Radiator Trap	Main / Basement / Classroom B	Radiator Left Window, 0-5'	TS-A	Hoffman	8C	3/4"	3	213	194	OK	DDC Radiator Valve. No Trap Station Components.
269291	Univent	Main / Basement / Classroom B	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	200	120	P	No Trap Station Components.
269296	Radiator Trap	Main / Basement / Hallway	Radiator Outside Classroom A, 5-10'	TS-A	Warren Webster	513	3/4"	3	216	189	OK	Manual Radiator Valve. No Trap Station Components.
269297	Drip Leg	Main / Basement / Hallway	Outside Classroom A, 10-15'	TS-A	Warren Webster	513	3/4"	3	214	187	OK	No Trap Station Components.
269298	Radiator Trap	Main / Basement / Stairwell By Exit 13	Platform Left Side, 0-5'	TS-A	Warren Webster	512	1/2"	3	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
269299	Radiator Trap	Main / Basement / Stairwell By Exit 13	Platform Right Side, 0-5'	TS-A	Warren Webster	512	1/2"	3	214	132	P	Thermostatic Radiator Valve. No Trap Station Components.
269294	Drip Leg	Main / Basement / Storage Rm Next To Classroom A	Back Corner, 5-10'	FT	Warren Webster	N/A	1 1/4"	3	216	212	L	Inlet Isolation.
269295	Radiator Trap	Main / Basement / Storage Rm Next To Classroom A	Radiator Ceiling, 5-10'	TS-A	Warren Webster	513	1/2"	3	NA	NA	RIP	No Radiator Valve. Disconnected From System.
269287	Drip Leg	Main / Basement / Storage Rm Off Boiler Rm C	Under Header Against Wall, 10-15'	FT	Hoffman	CT56	1 1/4"	3	215	177	OK	Inlet Isolation, Strainer.
300316	Drip Leg	Main / Basement / Carpenter Shop	Back Corner, 10-15'	FT	Spirax Sarco	FT15	1 1/4"	3	215	196	OK	Inlet Isolation, Strainer.
300317	Univent	Main / Basement / Carpenter Shop	Univent, 10-15'	FT	Spirax Sarco	FT14	3/4"	3	214	199	OK	Outlet Isolation.
300283	Univent	Main / Basement / Garage Storage	Univent, 0-5'	FT	Hoffman	55	2"	3	214	181	OK	Strainer.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300102	Radiator Trap	Main / 1st / 101	Below AC, 0-5'	N/A	NA	Thermostatic Angle	3	3/4"	NPT	<b>B</b>	Full Trap, Difficult Access, Scheduling Issues, Will Need To Cut Access Panel. Model Unknown. Can Hear Blowing From 10' Out.
300115	Radiator Trap	Main / 1st / 105	Left Radiator, 0-5'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300108	Univent	Main / 1st / 106	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access
300125	Radiator Trap	Main / 1st / 107B	3rd Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Difficult Access, Scheduling Issues
300126	Drip Leg	Main / 1st / 107B	Back Left Corner, 5-10'	Warren Webster	723	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues, System Shutdown Required
300127	Radiator Trap	Main / 1st / 107B	Back Wall, 0-5'	Barnes & Jones	122	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300141	Radiator Trap	Main / 1st / 112	2nd Radiator On Right, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>B</b>	Repair Kit, No Issues
300144	Radiator Trap	Main / 1st / 114	Below Right Window, 0-5'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues
300145	Radiator Trap	Main / 1st / 114 Closet	Left Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300143	Radiator Trap	Main / 1st / 114B	Left Corner, 0-5'	Barnes & Jones	134	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues
300210	Radiator Trap	Main / 1st / 115	Back Right Corner, Above Ceiling	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300211	Radiator Trap	Main / 1st / 115	Above Double Doors, Above Ceiling	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300212	Radiator Trap	Main / 1st / 115	Left Of Double Doors, Above Ceiling	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues
300215	Radiator Trap	Main / 1st / 115	Across From Double Doors, Above Ceiling	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues
300216	Radiator Trap	Main / 1st / 115	Across From Double Doors, Above Ceiling	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300218	Radiator Trap	Main / 1st / 115	Far Right Corner, Above Ceiling	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>B</b>	Repair Kit, Difficult Access, Scheduling Issues
300155	Radiator Trap	Main / 1st / 119 Custodial Lounge	In Bathroom, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, No Issues
300156	Radiator Trap	Main / 1st / 119 Custodial Lounge	Under Right Window, 0-5'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, No Issues
300157	Radiator Trap	Main / 1st / 119 Custodial Lounge	Under Left Window, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Full Trap, Difficult Access
300160	Radiator Trap	Main / 1st / 120 Storage Rm	Right Window, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access, Radiator Valve Is An Old Pneumatic Valve.
300162	Radiator Trap	Main / 1st / 120 Storage Rm	Bathroom Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Difficult Access
300170	Radiator Trap	Main / 1st / 122	Univent Back Right, 0-5'	Barnes & Jones	134	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, Difficult Access
300175	Radiator Trap	Main / 1st / 123	Radiator, 0-5'	Barnes & Jones	134	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, No Issues
300132	Drip Leg	Main / 1st / Bathroom Across From 109	Radiator On Wall, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Difficult Access, Will Have To Dismantle Wood Frame Around
300164	Radiator Trap	Main / 1st / Girl's Bathroom Across From Cafeteria	Below Window, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300117	Drip Leg	Main / 1st / Hallway	Outside 109A, 10-15'	Spirax Sarco	FT15	Float & Thermostatic	3	1"	NPT	<b>L</b>	Repair Kit, No Issues
300122	Radiator Trap	Main / 1st / Hallway	Outside 107B, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access
300133	Radiator Trap	Main / 1st / Hallway	Across From Large Storage, 0-5'	N/A	NOTRAP	Thermostatic Vertical	3	1/2"	NPT	<b>P</b>	Full Trap, Difficult Access
300134	Radiator Trap	Main / 1st / Hallway	Outside Elevator, 0-5'	Mepco	1E	Thermostatic Straight	3	1/2"	NPT	<b>L</b>	Repair Kit, No Issues
300163	Radiator Trap	Main / 1st / Hallway	Across From Cafeteria, 0-5'	N/A	NOTRAP	Thermostatic Straight	3	3/4"	NPT	<b>L</b>	Full Trap, No Issues
300219	Drip Leg	Main / 1st / Pantry	Back Wall, 5-10'	Warren Webster	533	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, System Shutdown Required
300220	Radiator Trap	Main / 1st / Pantry	Back Left Corner, 5-10'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300178	Radiator Trap	Main / 1st / Stairwell 1	Outside 124, 0-5'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>B</b>	Repair Kit, Difficult Access
300179	Radiator Trap	Main / 1st / Stairwell 1	Lower Landing, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>B</b>	Repair Kit, No Issues
300180	Radiator Trap	Main / 1st / Stairwell 1	At Exit, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, No Issues
300165	Radiator Trap	Main / 1st / Stairwell 2	Left Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, No Issues
300166	Radiator Trap	Main / 1st / Stairwell 2	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, No Issues
300181	Radiator Trap	Main / 1st / Stairwell 4	At Landing, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, No Issues
300183	Univent	Main / 2nd / 202A	Left Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	<b>L</b>	Repair Kit, Scheduling Issues
300191	Radiator Trap	Main / 2nd / 203	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, No Issues
300192	Radiator Trap	Main / 2nd / 203	Left Radiator, 0-5'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, Scheduling Issues
300196	Radiator Trap	Main / 2nd / 205	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Scheduling Issues
300197	Radiator Trap	Main / 2nd / 205D	Below Window, Above 15'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues
300227	Radiator Trap	Main / 2nd / 216	Below Window, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Scheduling Issues
300225	Radiator Trap	Main / 2nd / 216A	Left Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, Scheduling Issues
300229	Radiator Trap	Main / 2nd / 216B	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>B</b>	Repair Kit, Scheduling Issues
300231	Radiator Trap	Main / 2nd / 216B	Left Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Scheduling Issues
300207	Radiator Trap	Main / 2nd / 217	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>P</b>	Repair Kit, No Issues
300243	Univent	Main / 2nd / 223	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, Scheduling Issues
300242	Radiator Trap	Main / 2nd / 224	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300249	Radiator Trap	Main / 2nd / 225	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Scheduling Issues
300250	Radiator Trap	Main / 2nd / 225	Radiator, 0-5'	Barnes & Jones	134	Thermostatic Straight	3	3/4"	NPT	P	Full Trap, Difficult Access, Scheduling Issues
300251	Univent	Main / 2nd / 225	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, Scheduling Issues
300247	Radiator Trap	Main / 2nd / 226	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Scheduling Issues
300223	Radiator Trap	Main / 2nd / Hallway	Outside Elevator, 0-5'	Barnes & Jones	122	Thermostatic Straight	3	1/2"	NPT	B	Repair Kit, No Issues
300235	Radiator Trap	Main / 2nd / Stage	Left Radiator, 0-5'	Warren Webster	513	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, No Issues
300238	Radiator Trap	Main / 2nd / Stairwell 2	Landing, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300199	Radiator Trap	Main / 2nd / Stairwell 3	Left Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300200	Radiator Trap	Main / 2nd / Stairwell 3	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300204	Radiator Trap	Main / 2nd / Stairwell Behind Library	At Landing, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300262	Radiator Trap	Main / 3rd / 301	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Scheduling Issues
300278	Radiator Trap	Main / 3rd / 312A	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	B	Repair Kit, Scheduling Issues
300277	Radiator Trap	Main / 3rd / 312B	Below Window, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Scheduling Issues
300284	Radiator Trap	Main / 3rd / 312C	Middle Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Scheduling Issues
300285	Radiator Trap	Main / 3rd / 312C	Left Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Scheduling Issues
300288	Radiator Trap	Main / 3rd / 313	Middle Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Scheduling Issues
300293	Radiator Trap	Main / 3rd / 322	Radiator Access Panels, 0-5'	N/A	NA	Thermostatic Angle	3	3/4"	NPT	P	Full Trap, Difficult Access
300294	Radiator Trap	Main / 3rd / 322	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300299	Radiator Trap	Main / 3rd / 326	Radiator, 0-5'	Barnes & Jones	134	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, Scheduling Issues
300300	Radiator Trap	Main / 3rd / 326	Closet, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
300276	Radiator Trap	Main / 3rd / Hallway	Outside Elevator, 0-5'	Barnes & Jones	122	Thermostatic Straight	3	1/2"	NPT	L	Repair Kit, No Issues
300290	Radiator Trap	Main / 3rd / Stairwell 2	Landing, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300268	Radiator Trap	Main / 3rd / Stairwell 3	Landing 300268, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300315	Radiator Trap	Main / 4th / Stairwell 2	Right Radiator, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
269289	Drip Leg	Main / Basement / Boiler Rm C	Below Main Header Against Wall, 10-15'	Hoffman	FT56	Float & Thermostatic	3	1 1/4"	NPT	P	Repair Kit, System Shutdown Required
269285	Drip Leg	Main / Basement / Boiler Rm D	Front Of Boiler, 5-10'	Hoffman	FT55	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, No Issues
269291	Univent	Main / Basement / Classroom B	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Full Trap. Inside Univent So Very Difficult Access.
269299	Radiator Trap	Main / Basement / Stairwell By Exit 13	Platform Right Side, 0-5'	Warren Webster	512	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
269294	Drip Leg	Main / Basement / Storage Rm Next To Classroom A	Back Corner, 5-10'	Warren Webster	N/A	Float & Thermostatic	3	1 1/4"	NPT	L	Full Trap, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
298020	Univent	Main / 1st / 104	Center Window, 0-5'	TS-A	Mepco	2E	3/4"	3	200	190	OK	No Trap Station Components.
298021	Radiator Trap	Main / 1st / 104	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	220	200	OK	DDC Radiator Valve. No Trap Station Components.
298022	Radiator Trap	Main / 1st / 104	Left Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	225	207	OK	Thermostatic Radiator Valve. No Trap Station Components.
298018	Univent	Main / 1st / 105	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	189	180	OK	No Trap Station Components.
298019	Radiator Trap	Main / 1st / 105	Right Window, 0-5'	TS-A	Barnes & Jones	5007	3/4"	3	200	200	L	DDC Radiator Valve. No Trap Station Components.
298023	Radiator Trap	Main / 1st / 106	Left Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	200	180	OK	DDC Radiator Valve. No Trap Station Components.
298024	Radiator Trap	Main / 1st / 106	Middle Window, 0-5'	TS-A	Mepco	2E	3/4"	3	200	187	OK	DDC Radiator Valve. No Trap Station Components.
298025	Univent	Main / 1st / 106	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	200	190	OK	No Trap Station Components.
298016	Univent	Main / 1st / 107	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	190	180	OK	No Trap Station Components.
298017	Radiator Trap	Main / 1st / 107	Next To Univent, 0-5'	TS-A	Barnes & Jones	5007	3/4"	3	187	180	OK	DDC Radiator Valve. No Trap Station Components.
298026	Radiator Trap	Main / 1st / 108	Left Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	NA	NA	RIP	Thermostatic Radiator Valve. Valved Out, Disconnected From System.
298027	Univent	Main / 1st / 108	Middle Window, 0-5'	TS-A	Mepco	2E	3/4"	3	170	165	OK	No Trap Station Components.
298028	Radiator Trap	Main / 1st / 108	Right Of Univent, 0-5'	TS-A	Mepco	2E	3/4"	3	220	200	OK	DDC Radiator Valve. No Trap Station Components.
298029	Radiator Trap	Main / 1st / 108	Right Most Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	190	180	OK	DDC Radiator Valve. No Trap Station Components.
298031	Radiator Trap	Main / 1st / 108	Left Of Univent, 0-5'	TS-A	Mepco	2E	3/4"	3	212	180	OK	DDC Radiator Valve. No Trap Station Components.
298014	Univent	Main / 1st / 109	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	180	177	OK	No Trap Station Components.
298015	Radiator Trap	Main / 1st / 109	Right Corner, 0-5'	TS-A	Mepco	2E	3/4"	3	200	200	L	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298030	Radiator Trap	Main / 1st / 110	Left Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	212 200	OK	DDC Radiator Valve. No Trap Station Components.
298032	Univent	Main / 1st / 110	Univent, 0-5'	TS-A	Mepco	2E	3/4"	3	180 170	OK	No Trap Station Components.
298033	Radiator Trap	Main / 1st / 110	Right Corner, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	NA NA	RIP	Thermostatic Radiator Valve. Valved Out, Disconnected From System.
298012	Univent	Main / 1st / 111	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	220 190	OK	No Trap Station Components.
298013	Radiator Trap	Main / 1st / 111	Middle Window, 0-5'	TS-S	Barnes & Jones	5007	3/4"	3	220 212	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
298010	Univent	Main / 1st / 113	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	206 198	OK	No Trap Station Components.
298011	Radiator Trap	Main / 1st / 113	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	70 70	NIS	DDC Radiator Valve. No Trap Station Components. Not Calling, No Power To Unit.
298054	Radiator Trap	Main / 1st / 119	Middle Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	103 102	<b>P</b>	Pneumatic Radiator Valve. No Trap Station Components.
298056	Radiator Trap	Main / 1st / 123	Left Of Univent, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	218 213	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
298057	Univent	Main / 1st / 123	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	200 180	OK	No Trap Station Components.
298058	Univent	Main / 1st / 124	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	207 190	OK	No Trap Station Components.
298059	Radiator Trap	Main / 1st / 124	Right Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	215 190	OK	DDC Radiator Valve. No Trap Station Components.
298060	Radiator Trap	Main / 1st / 125	Next To Univent, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	220 190	OK	DDC Radiator Valve. No Trap Station Components.
298061	Univent	Main / 1st / 125	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	200 180	OK	No Trap Station Components.
298062	Univent	Main / 1st / 126	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	180 167	OK	No Trap Station Components.
298063	Radiator Trap	Main / 1st / 126	Next To Univent, 0-5'	TS-A	Hoffman	8C	3/4"	3	200 176	OK	DDC Radiator Valve. No Trap Station Components.
298064	Univent	Main / 1st / 127	Right Window, 0-5'	TS-A	Mepco	2E	3/4"	3	220 200	OK	No Trap Station Components.
298065	Radiator Trap	Main / 1st / 127	Next To Univent, 0-5'	TS-A	Mepco	2E	3/4"	3	210 190	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298066	Univent	Main / 1st / 128	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	210 187	OK	No Trap Station Components.
298067	Radiator Trap	Main / 1st / 128	Next To Univent, 0-5'	TS-A	Hoffman	8C	3/4"	3	210 190	OK	DDC Radiator Valve. No Trap Station Components.
298050	Univent	Main / 1st / 133	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	187 170	OK	No Trap Station Components.
298051	Radiator Trap	Main / 1st / 133	Right Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	180 176	OK	DDC Radiator Valve. No Trap Station Components.
298052	Radiator Trap	Main / 1st / 133	Right Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	180 177	OK	DDC Radiator Valve. No Trap Station Components.
298047	Radiator Trap	Main / 1st / 134	Left Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	200 189	OK	DDC Radiator Valve. No Trap Station Components.
298048	Radiator Trap	Main / 1st / 134	Left Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	190 178	OK	DDC Radiator Valve. No Trap Station Components.
298049	Univent	Main / 1st / 134	Right Window, 0-5'	TS-A	Hoffman	8C	3/4"	3	180 170	OK	No Trap Station Components.
298044	Univent	Main / 1st / 137	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	170 166	OK	No Trap Station Components.
298045	Radiator Trap	Main / 1st / 137	Right Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	208 198	OK	DDC Radiator Valve. No Trap Station Components.
298046	Univent	Main / 1st / 137	Right Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	200 189	OK	No Trap Station Components.
298040	Radiator Trap	Main / 1st / 138A/B	Left Corner, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	218 200	OK	DDC Radiator Valve. No Trap Station Components. DDC Valve Leaking From Valve Body
298041	Univent	Main / 1st / 138A/B	Left Univent, 0-5'	TS-A	Mepco	2E	3/4"	3	181 177	OK	No Trap Station Components.
298042	Radiator Trap	Main / 1st / 138A/B	Between Univent, 0-5'	TS-A	Barnes & Jones	NA	3/4"	3	220 200	OK	DDC Radiator Valve. No Trap Station Components.
298043	Univent	Main / 1st / 138A/B	Right Univent, 0-5'	TS-A	Mepco	2E	3/4"	3	170 167	OK	No Trap Station Components.
298037	Radiator Trap	Main / 1st / 139	Left Window, 0-5'	VIB	Barnes & Jones	5007	1/2"	3	198 188	OK	DDC Radiator Valve. No Trap Station Components.
298038	Radiator Trap	Main / 1st / 139	Left Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	178 170	OK	DDC Radiator Valve. No Trap Station Components.
298039	Univent	Main / 1st / 139	Right Window, 0-5'	TS-A	Hoffman	8C	3/4"	3	170 160	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298034	Univent	Main / 1st / 140	Left Window, 0-5'	TS-A	Mepco	2E	3/4"	3	180 176	OK	No Trap Station Components.
298035	Radiator Trap	Main / 1st / 140	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	212 190	OK	DDC Radiator Valve. No Trap Station Components.
298036	Radiator Trap	Main / 1st / 140	Right Window, 0-5'	TS-A	Hoffman	17C	1/2"	3	180 170	OK	DDC Radiator Valve. No Trap Station Components.
298001	Drip Leg	Main / 1st / Boiler	Boiler 1, Front, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	3	212 169	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
298002	Drip Leg	Main / 1st / Boiler	Boiler 1, Right Side, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	185 175	OK	Inlet Isolation.
298003	Drip Leg	Main / 1st / Boiler	Boiler 2, Left Side, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	112 160	NIS	Inlet Isolation. Not Calling, Process Not Running.
298004	Drip Leg	Main / 1st / Boiler	Boiler 2, Front, 5-10'	FT	Armstrong	FT2015-6	1 1/2"	3	226 289	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
298005	Drip Leg	Main / 1st / Boiler	Boiler 2, Behind, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	218 180	OK	Inlet Isolation, Strainer, Blowdown, Check Valve.
298006	Drip Leg	Main / 1st / Boiler	Boiler 2, Behind, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	225 189	OK	Inlet Isolation, Strainer, Blowdown, Check Valve.
298007	Heat Exchanger	Main / 1st / Boiler	HEX Station, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	3	122 121	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
298008	Drip Leg	Main / 1st / Boiler	Domestic Water Heater, Behind, Left Trap, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	140 100	P	Inlet Isolation, Strainer, Outlet Isolation.
298009	Drip Leg	Main / 1st / Boiler	Domestic Water Heater, Behind, Right Trap, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	225 196	OK	Inlet Isolation, Strainer, Outlet Isolation.
298055	Radiator Trap	Main / 1st / Boy's Bathroom Across 119	Back Wall, 0-5'	TS-A	Mepco	2E	3/4"	3	215 180	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
298074	Radiator Trap	Main / 1st / E.S.O.L.	Under Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	210 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
298075	Radiator Trap	Main / 1st / Entrance 1	Left Side Looking Out, 0-5'	TS-A	Barnes & Jones	3500	1/2"	3	190 178	OK	Pneumatic Radiator Valve. No Trap Station Components.
298073	Radiator Trap	Main / 1st / Entrance 14	Vestibule, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	200 190	OK	Thermostatic Radiator Valve. No Trap Station Components.
298076	Radiator Trap	Main / 1st / Entrance 2	Right Side Looking Out, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	210 198	OK	Pneumatic Radiator Valve. No Trap Station Components.
298077	Radiator Trap	Main / 1st / Entrance 2	Left Side Looking Out, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	76 78	P	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
298078	Radiator Trap	Main / 1st / Entrance 2	Next To Entrance Under Window, 0-5'	TS-A	Barnes & Jones	3148	1/2"	3	213	180	OK	Pneumatic Radiator Valve. No Trap Station Components.
298079	Drip Leg	Main / 1st / Entrance 2	Tunnel Entrance, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	200	180	OK	Inlet Isolation, Strainer, Blowdown.
298068	Radiator Trap	Main / 1st / Faculty Rm	Under Window, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	200	187	OK	DDC Radiator Valve. No Trap Station Components.
198071	AHU	Main / 1st / Faculty Rm Hallway	Above Ceiling, Across From Custodial Office, 5-10'	FT	Hoffman	FT015H	3/4"	3	70	70	NIS	Inlet Isolation, Strainer, Outlet Isolation. Not Calling.
298069	AHU	Main / 1st / Faculty Rm Hallway	Above Ceiling, In Front Of Storage Closet, 5-10'	FT	Watts	WFT-15	3/4"	3	168	155	OK	Inlet Isolation, Strainer, Outlet Isolation.
298070	Drip Leg	Main / 1st / Faculty Rm Hallway	Above Ceiling, In Front Of Storage Closet, 5-10'	FT	Hoffman	FT015H-4	1"	3	210	200	OK	Inlet Isolation, Strainer, Outlet Isolation.
298072	AHU	Main / 1st / Faculty Rm Hallway	Above Ceiling, Across Faculty Rm, 5-10'	FT	Hoffman	FT015H	3/4"	3	170	155	OK	Inlet Isolation, Strainer, Outlet Isolation.
298053	Radiator Trap	Main / 1st / Girls' Bathroom Across Rm 119	Back Wall, 0-5'	TS-A	Mepco	2E	3/4"	3	219	186	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
298081	Radiator Trap	Main / 1st / Hallway Wall	Next To Rm 115, 0-5'	TS-A	Barnes & Jones	5007	1/2"	3	190	170	OK	Pneumatic Radiator Valve. No Trap Station Components.
298082	Drip Leg	Main / Basement / Mech Rm	Entrance, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	220	200	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
298083	Drip Leg	Main / Basement / Mech Rm	Diagonal From Entrance, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	210	190	OK	Inlet Isolation, Strainer, Outlet Isolation.
298084	Drip Leg	Main / Basement / Mech Rm	Behind Air Compressor, 5-10'	TS-A	Barnes & Jones	5007	3/4"	3	190	170	OK	No Trap Station Components.
298085	Drip Leg	Main / Basement / Mech Rm	Behind Air Compressor, 5-10'	TS-A	Barnes & Jones	5007	3/4"	3	192	180	OK	No Trap Station Components.
298086	Drip Leg	Main / Basement / Mech Rm	Behind Air Compressor, 5-10'	TS-A	Barnes & Jones	5007	3/4"	3	90	90	NIS	No Trap Station Components. Not Running.
298087	Drip Leg	Main / Basement / Mech Rm	Behind Air Compressor, 5-10'	TS-A	Barnes & Jones	5007	3/4"	3	197	188	OK	No Trap Station Components.
298088	Drip Leg	Main / Basement / Mech Rm	Back Left Corner, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	220	190	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
298019	Radiator Trap	Main / 1st / 105	Right Window, 0-5'	Barnes & Jones	5007	Thermostatic Angle	3	3/4"	NPT	L	Full Trap, Difficult Access, May Need Access Panel
298015	Radiator Trap	Main / 1st / 109	Right Corner, 0-5'	Mepco	2E	Thermostatic Angle	3	3/4"	NPT	L	Full Trap, No Issues
298013	Radiator Trap	Main / 1st / 111	Middle Window, 0-5'	Barnes & Jones	5007	Thermostatic Straight	3	3/4"	NPT	B	Full Trap, Difficult Access, May Need Access Panel
298054	Radiator Trap	Main / 1st / 119	Middle Window, 0-5'	Barnes & Jones	5007	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
298056	Radiator Trap	Main / 1st / 123	Left Of Univent, 0-5'	Barnes & Jones	5007	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, Very Tight Space
298008	Drip Leg	Main / 1st / Boiler	Domestic Water Heater, Behind, Left Trap, 0-5'	Barnes & Jones	FT2015-4	Float & Thermostatic	3	1"	NPT	P	Repair Kit, No Issues
298077	Radiator Trap	Main / 1st / Entrance 2	Left Side Looking Out, 0-5'	Barnes & Jones	5007	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298108	Radiator Trap	Main / 2nd / 104	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220 198	OK	Pneumatic Radiator Valve. No Trap Station Components.
298109	Radiator Trap	Main / 2nd / 104	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	217 200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298110	Radiator Trap	Main / 2nd / 105	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220 200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298111	Radiator Trap	Main / 2nd / 105	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	225 218	<b>B</b>	Pneumatic Radiator Valve. No Trap Station Components.
298112	Radiator Trap	Main / 2nd / 105	Right Radiator, 0-5'	TS-A	Barnes & Jones	3174	1/2"	3	220 206	OK	Pneumatic Radiator Valve. No Trap Station Components.
298105	Radiator Trap	Main / 2nd / 106	Left Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	70 70	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling.
298106	Radiator Trap	Main / 2nd / 106	Middle Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220 216	<b>B</b>	Pneumatic Radiator Valve. No Trap Station Components.
298107	Radiator Trap	Main / 2nd / 106	Right Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220 215	<b>L</b>	Pneumatic Radiator Valve. No Trap Station Components.
298119	Radiator Trap	Main / 2nd / 107, Conference Rm	Middle Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220 203	OK	Pneumatic Radiator Valve. No Trap Station Components.
298120	Radiator Trap	Main / 2nd / 107, Social Worker Office	Under Window, 0-5'	TS-S	Barnes & Jones	1950	1/2"	3	214 199	OK	Pneumatic Radiator Valve. No Trap Station Components.
298104	Radiator Trap	Main / 2nd / 109	Left Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	215 200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298117	Radiator Trap	Main / 2nd / 114	Left Radiator, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	220 200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298118	Radiator Trap	Main / 2nd / 114	Right Radiator, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	70 70	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Used, Disconnected From System.
298097	Radiator Trap	Main / 2nd / 118	Left Window, 0-5'	TS-A	Barnes & Jones	4172	1/2"	3	225 217	<b>B</b>	Thermostatic Radiator Valve. No Trap Station Components.
298098	Radiator Trap	Main / 2nd / 118	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	215 197	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298095	Radiator Trap	Main / 2nd / 119	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	200 190	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
298096	Radiator Trap	Main / 2nd / 119	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	215 206	OK	Thermostatic Radiator Valve. No Trap Station Components.
298093	Radiator Trap	Main / 2nd / 120	Right Window, 0-5'	TS-A	Barnes & Jones	1972	1/2"	3	212 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
298094	Radiator Trap	Main / 2nd / 120	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	67 67	P	Thermostatic Radiator Valve. No Trap Station Components.
298091	Radiator Trap	Main / 2nd / 121	Right Window, 0-5'	TS-A	Barnes & Jones	4172	1/2"	3	200 187	OK	Thermostatic Radiator Valve. No Trap Station Components.
298092	Radiator Trap	Main / 2nd / 121	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	68 68	P	Thermostatic Radiator Valve. No Trap Station Components.
293556	Radiator Trap	Main / 2nd / 122	Left Radiator, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	218 195	OK	Thermostatic Radiator Valve. No Trap Station Components.
293557	Radiator Trap	Main / 2nd / 122	Middle Radiator, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	222 206	OK	Thermostatic Radiator Valve. No Trap Station Components.
293558	Radiator Trap	Main / 2nd / 122	Right Radiator, 0-5'	TS-A	Barnes & Jones	4172	1/2"	3	215 197	OK	Thermostatic Radiator Valve. No Trap Station Components.
298089	Radiator Trap	Main / 2nd / 123	Center Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	215 200	OK	Thermostatic Radiator Valve. No Trap Station Components.
298090	Radiator Trap	Main / 2nd / 123	Right Window, 0-5'	TS-A	Barnes & Jones	4172	1/2"	3	70 70	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling. Thermostatic Valve Stuck Closed
298103	Radiator Trap	Main / 2nd / Boy's Bathroom Across From 108	Under Window, 0-5'	TS-A	Hoffman	17C	1/2"	3	215 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
298116	Radiator Trap	Main / 2nd / Girl's Bathroom Across From Rm 114	Under Window, 0-5'	TS-A	Mepco	17C	1/2"	3	219 192	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
298099	Radiator Trap	Main / 2nd / Hallway	Next To Rm 122, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	220 200	OK	Manual Radiator Valve. No Trap Station Components.
298100	Radiator Trap	Main / 2nd / Main Entrance Vestibule	Left Radiator, Looking Out, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	220 214	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Broken Off

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298101	Radiator Trap	Main / 2nd / Main Entrance Vestibule	Right Radiator, Looking Out, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	109 106	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Broken Off
298102	Radiator Trap	Main / 2nd / Main Office	Right Window, 0-5'	TS-S	Barnes & Jones	5007	1/2"	3	220 200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298121	Radiator Trap	Main / 2nd / Nurse's Office	Under Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	224 113	<b>L</b>	Thermostatic Radiator Valve. No Trap Station Components.
298142	Radiator Trap	Main / 3rd / 202	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	200 197	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Leaking From Valve Body
298143	Radiator Trap	Main / 3rd / 202	Middle Radiator, 0-5'	TS-A	Barnes & Jones	4172	1/2"	3	218 214	<b>L</b>	Pneumatic Radiator Valve. No Trap Station Components.
298144	Radiator Trap	Main / 3rd / 202	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	225 204	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Leaking From Valve Body
298145	Radiator Trap	Main / 3rd / 204	Middle Window, Left Trap, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	219 213	<b>L</b>	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Leaking From Valve Body
298146	Radiator Trap	Main / 3rd / 204	Middle Window, Right Trap, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	223 205	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Leaking From Valve Body
298147	Radiator Trap	Main / 3rd / 205	Middle Window, Left Trap, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	222 204	OK	Thermostatic Radiator Valve. No Trap Station Components.
298148	Radiator Trap	Main / 3rd / 205	Middle Window, Right Trap, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	83 83	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components.
298149	Radiator Trap	Main / 3rd / 206	Middle Window, Left Trap, 0-5'	TS-A	Barnes & Jones	NA	1/2"	3	220 206	OK	Pneumatic Radiator Valve. No Trap Station Components.
298150	Radiator Trap	Main / 3rd / 206	Middle Window, Right Trap, 0-5'	TS-A	Hoffman	17C	1/2"	3	222 214	<b>L</b>	Pneumatic Radiator Valve. No Trap Station Components.
298151	Radiator Trap	Main / 3rd / 207	Middle Window, Left Trap, 0-5'	TS-A	Barnes & Jones	NA	1/2"	3	220 203	OK	Thermostatic Radiator Valve. No Trap Station Components.
298152	Radiator Trap	Main / 3rd / 207	Middle Window, Right Trap, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	222 206	OK	Thermostatic Radiator Valve. No Trap Station Components.
298153	Radiator Trap	Main / 3rd / 209	Right Window, 0-5'	TS-A	Barnes & Jones	NA	1/2"	3	224 198	OK	Pneumatic Radiator Valve. No Trap Station Components.
298154	Radiator Trap	Main / 3rd / 211	Left Window, 0-5'	TS-A	Barnes & Jones	NA	1/2"	3	217 196	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
298124	Radiator Trap	Main / 3rd / 214	Left Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	220	198	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
298125	Radiator Trap	Main / 3rd / 214	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	76	76	P	Thermostatic Radiator Valve. No Trap Station Components.
298126	Radiator Trap	Main / 3rd / 214	Right Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	76	76	P	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Closed
298127	Radiator Trap	Main / 3rd / 215	Left Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	210	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
298128	Radiator Trap	Main / 3rd / 215	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	218	196	OK	Pneumatic Radiator Valve. No Trap Station Components.
298129	Radiator Trap	Main / 3rd / 215	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	218	199	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Broken Off
298130	Radiator Trap	Main / 3rd / 216	Left Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	220	203	OK	Pneumatic Radiator Valve. No Trap Station Components.
298131	Radiator Trap	Main / 3rd / 216	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	230	215	B	Pneumatic Radiator Valve. No Trap Station Components.
298132	Radiator Trap	Main / 3rd / 216	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	78	78	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling, No Power To Unit. Pneumatic Valve Stuck Closed
298133	Radiator Trap	Main / 3rd / 217	Left Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	225	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298134	Radiator Trap	Main / 3rd / 217	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	225	204	OK	Pneumatic Radiator Valve. No Trap Station Components.
298135	Radiator Trap	Main / 3rd / 217	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	226	207	OK	Pneumatic Radiator Valve. No Trap Station Components.
298136	Radiator Trap	Main / 3rd / 218	Left Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	223	205	OK	Pneumatic Radiator Valve. No Trap Station Components.
298137	Radiator Trap	Main / 3rd / 218	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	225	204	OK	Pneumatic Radiator Valve. No Trap Station Components.
298138	Radiator Trap	Main / 3rd / 218	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	220	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298139	Radiator Trap	Main / 3rd / 219	Left Window, 0-5'	TS-A	Barnes & Jones	1950	1/2"	3	226	204	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
298140	Radiator Trap	Main / 3rd / 219	Middle Window, 0-5'	TS-A	Barnes & Jones	1950	3/4"	3	225 206	OK	Pneumatic Radiator Valve. No Trap Station Components.
298141	Radiator Trap	Main / 3rd / 219	Right Window, 0-5'	TS-A	Barnes & Jones	3146	3/4"	3	75 75	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling, Not Used, Disconnected From System. Pneumatic Valve Stuck Closed
298123	Radiator Trap	Main / 3rd / Boy's Bathroom Across From Rm 208	Under Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	74 74	<b>P</b>	Manual Radiator Valve. No Trap Station Components.
298122	Radiator Trap	Main / 3rd / Girl's Bathroom Across From Rm 212	Under Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	226 205	OK	Manual Radiator Valve. No Trap Station Components.
298155	Radiator Trap	Main / 3rd / Teacher's Bathroom	Radiator, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	226 216	<b>L</b>	Manual Radiator Valve. No Trap Station Components. Manual Valve Radiator Valve Leaking By
293545	Drip Leg	Main / Ground / 19, Boy's Bathroom	Radiator, 0-5'	TS-A	Spirax Sarco	H	1/2"	3	225 216	<b>L</b>	No Trap Station Components.
293546	Radiator Trap	Main / Ground / 19, Boy's Bathroom	Radiator, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	220 204	OK	Thermostatic Radiator Valve. No Trap Station Components. Radiator Coil is Leaking Steam.
298114	Unit Heater	Main / Ground / 24	Left Corner, 5-10'	TS-A	Barnes & Jones	1966	3/4"	3	225 204	OK	Inlet Isolation.
298115	Unit Heater	Main / Ground / 24	Right Corner, 5-10'	TS-A	Barnes & Jones	1966	3/4"	3	225 205	OK	Inlet Isolation.
293547	Radiator Trap	Main / Ground / 28	Left Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	220 203	OK	Pneumatic Radiator Valve. No Trap Station Components.
293548	Radiator Trap	Main / Ground / 29	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	200 196	OK	Pneumatic Radiator Valve. No Trap Station Components.
293549	Radiator Trap	Main / Ground / 29	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	200 197	OK	Pneumatic Radiator Valve. No Trap Station Components.
293552	Radiator Trap	Main / Ground / 30	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	222 206	OK	Pneumatic Radiator Valve. No Trap Station Components.
293550	Radiator Trap	Main / Ground / 31	Right Window, Right Trap, 0-5'	TS-A	Barnes & Jones	122A	1/2"	3	220 215	<b>L</b>	Pneumatic Radiator Valve. No Trap Station Components.
293551	Radiator Trap	Main / Ground / 31	Right Window, Left Trap, 0-5'	TS-A	Barnes & Jones	122A	1/2"	3	216 200	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
293553	Radiator Trap	Main / Ground / 33	Right Window, Left Trap, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	220 200	OK	Pneumatic Radiator Valve. No Trap Station Components.
293554	Radiator Trap	Main / Ground / 33	Right Window, Right Trap, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	218 204	OK	Pneumatic Radiator Valve. No Trap Station Components.
293555	Radiator Trap	Main / Ground / 34	Right Window, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	212 198	OK	Pneumatic Radiator Valve. No Trap Station Components.
293536	Drip Leg	Main / Ground / Boiler Rm	Left HEX, 5-10'	FT	Barnes & Jones	FT2015-5	1 1/4"	3	220 204	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
293537	Heat Exchanger	Main / Ground / Boiler Rm	Left HEX, 0-5'	FT	Barnes & Jones	FT2015-8	2"	3	180 168	OK	Inlet Isolation, Strainer.
293538	Drip Leg	Main / Ground / Boiler Rm	Right HEX, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	220 200	OK	Inlet Isolation, Strainer, Outlet Isolation.
293539	Heat Exchanger	Main / Ground / Boiler Rm	Right HEX, 0-5'	FT	Barnes & Jones	T-44	1 1/2"	3	86 86	NIS	Inlet Isolation, Strainer, Outlet Isolation. Not Calling, Not Running.
293540	Drip Leg	Main / Ground / Boiler Rm	Between Boilers, Front, 5-10'	FT	Barnes & Jones	T-44	1 1/2"	3	220 200	OK	Inlet Isolation, Strainer, Outlet Isolation.
293541	Drip Leg	Main / Ground / Boiler Rm	Boiler 1, Right Side, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	225 207	OK	Inlet Isolation.
293542	Drip Leg	Main / Ground / Boiler Rm	Boiler 2, Left Side, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	99 117	NIS	Inlet Isolation. Not Calling, Not Running.
293543	Drip Leg	Main / Ground / Boiler Rm	Boiler 2, Right Side, 5-10'	FT	Barnes & Jones	T-44	1 1/2"	3	220 207	OK	Inlet Isolation, Strainer, Outlet Isolation.
293544	Drip Leg	Main / Ground / Boiler Rm	Boiler 2, Right Side, 10-15'	FT	Barnes & Jones	FT2015-4	1"	3	220 205	OK	Inlet Isolation, Strainer, Outlet Isolation.
298113	Radiator Trap	Main / Ground / Girl's Bathroom Across Rm 22	Under Window, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	220 200	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Leaking From Valve Body

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Blowing, Leaking, and Plugged Traps

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
298111	Radiator Trap	Main / 2nd / 105	Middle Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	B	Full Trap, No Issues
298106	Radiator Trap	Main / 2nd / 106	Middle Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	B	Repair Kit, No Issues
298107	Radiator Trap	Main / 2nd / 106	Right Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
298097	Radiator Trap	Main / 2nd / 118	Left Window, 0-5'	Barnes & Jones	4172	Thermostatic Angle	3	1/2"	NPT	B	Repair Kit, No Issues
298094	Radiator Trap	Main / 2nd / 120	Middle Window, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
298092	Radiator Trap	Main / 2nd / 121	Middle Window, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
298100	Radiator Trap	Main / 2nd / Main Entrance Vestibule	Left Radiator, Looking Out, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
298101	Radiator Trap	Main / 2nd / Main Entrance Vestibule	Right Radiator, Looking Out, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
298121	Radiator Trap	Main / 2nd / Nurse's Office	Under Window, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, No Issues
298143	Radiator Trap	Main / 3rd / 202	Middle Radiator, 0-5'	Barnes & Jones	4172	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
298145	Radiator Trap	Main / 3rd / 204	Middle Window, Left Trap, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
298148	Radiator Trap	Main / 3rd / 205	Middle Window, Right Trap, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Full Trap, No Issues
298150	Radiator Trap	Main / 3rd / 206	Middle Window, Right Trap, 0-5'	Hoffman	17C	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
298125	Radiator Trap	Main / 3rd / 214	Middle Window, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
298126	Radiator Trap	Main / 3rd / 214	Right Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Full Trap, No Issues
298131	Radiator Trap	Main / 3rd / 216	Middle Window, 0-5'	Barnes & Jones	1950	Thermostatic Angle	3	1/2"	NPT	B	Full Trap, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
298123	Radiator Trap	Main / 3rd / Boy's Bathroom Across From Rm 208	Under Window, 0-5'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	P	Full Trap, No Issues
298155	Radiator Trap	Main / 3rd / Teacher's Bathroom	Radiator, 0-5'	Barnes & Jones	3146	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, No Issues
293545	Drip Leg	Main / Ground / 19, Boy's Bathroom	Radiator, 0-5'	Spirax Sarco	H	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
293550	Radiator Trap	Main / Ground / 31	Right Window, Right Trap, 0-5'	Barnes & Jones	122A	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
255920	Radiator Trap	Main / 1st / 101A	Radiator Under Window, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. No Access Panel In Cabinets.
255921	Radiator Trap	Main / 1st / 101A	Bathroom Off Principals Office, 0-5'	TS-A	Hoffman	17C	1/2"	3	215	190	OK	Pneumatic Radiator Valve. No Trap Station Components.
255919	Radiator Trap	Main / 1st / 101B	Below Window, 0-5'	TS-A	Hoffman	17C	1/2"	3	213	208	L	Pneumatic Radiator Valve. No Trap Station Components.
255918	Radiator Trap	Main / 1st / 101C	Left Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	209	L	Pneumatic Radiator Valve. No Trap Station Components.
255917	Radiator Trap	Main / 1st / 101D	Between Windows, 0-5'	TS-A	Hoffman	17C	1/2"	3	214	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
255916	Radiator Trap	Main / 1st / 101E	Below Window, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	194	OK	Pneumatic Radiator Valve. No Trap Station Components.
255915	Radiator Trap	Main / 1st / 101F	Left Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
255914	Radiator Trap	Main / 1st / 101G	Below Window, 0-5'	TS-A	Barnes & Jones	2819	1/2"	3	214	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
296970	Univent	Main / 1st / 102	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	NIS	No Trap Station Components. Valved Out.
296962	Univent	Main / 1st / 104	Left Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	198	OK	No Trap Station Components.
296963	Radiator Trap	Main / 1st / 104	Radiator In Between Univents, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	217	212	L	Pneumatic Radiator Valve. No Trap Station Components.
296964	Univent	Main / 1st / 104	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	190	OK	Inlet Isolation, Outlet Isolation.
296934	Univent	Main / 1st / 105	Univent. Right, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	215	176	OK	No Trap Station Components.
296935	Drip Leg	Main / 1st / 105	Above Ceiling Right Univent, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	215	199	OK	No Trap Station Components.
296937	Radiator Trap	Main / 1st / 105	Radiator. Left Corner. Last Cabinet Access, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
296938	Radiator Trap	Main / 1st / 105	Radiator Third Cabinet Access From Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	217	212	L	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296936	Radiator Trap	Main / 1st / 105A	On Wall, 0-5'	TS-A	Barnes & Jones	2819	1/2"	3	217	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
296939	Radiator Trap	Main / 1st / 106	Radiator Left Of Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
296940	Univent	Main / 1st / 106	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	184	OK	No Trap Station Components.
296961	Radiator Trap	Main / 1st / 106	Small Rm Branched Off 106, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	178	OK	Pneumatic Radiator Valve. No Trap Station Components.
255911	Radiator Trap	Main / 1st / 112	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	200	98	P	Pneumatic Radiator Valve. No Trap Station Components.
255912	Univent	Main / 1st / 112	Right Side Univent, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	202	80	P	No Trap Station Components.
255913	Drip Leg	Main / 1st / 112	Right Side Univent, Above Ceiling	FT	Barnes & Jones	FT2015-2	3/4"	3	213	188	OK	Outlet Isolation.
254904	Radiator Trap	Main / 1st / 114	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
255905	Drip Leg	Main / 1st / 114	Univent Right Side, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	215	186	OK	No Trap Station Components.
255906	Univent	Main / 1st / 114	Right Side Univent, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	213	180	OK	No Trap Station Components.
255910	Radiator Trap	Main / 1st / 115	Through Cupboard, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	210	188	OK	Pneumatic Radiator Valve. No Trap Station Components.
255799	Drip Leg	Main / 1st / 116	Right Side Univent, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	212	178	OK	No Trap Station Components.
255800	Univent	Main / 1st / 116	Right Side Univent, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	213	192	OK	No Trap Station Components.
255901	Radiator Trap	Main / 1st / 116	Right Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
255907	Drip Leg	Main / 1st / 117	Right Side Univent, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	215	189	OK	Outlet Isolation.
255908	Univent	Main / 1st / 117	Univent Left Side, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	212	192	OK	No Trap Station Components.
255909	Radiator Trap	Main / 1st / 117	2nd Window From Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	211	195	OK	Pneumatic Radiator Valve. No Trap Station Components.
255902	Radiator Trap	Main / 1st / 119	Through Cupboard, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	188	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
255903	Univent	Main / 1st / 119	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	179	OK	Outlet Isolation.
255797	Univent	Main / 1st / 121	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	208	L	Outlet Isolation. Steam Trap Mounted Incorrectly.
255798	Radiator Trap	Main / 1st / 121	Panel Left Of Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	181	OK	Pneumatic Radiator Valve. No Trap Station Components.
255796	Radiator Trap	Main / 1st / 123	Below Ac, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	81	81	P	Pneumatic Radiator Valve. No Trap Station Components.
255794	Univent	Main / 1st / 125	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	184	OK	Outlet Isolation.
255795	Radiator Trap	Main / 1st / 125	Panel Next To Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
255775	Univent	Main / 1st / 126	Left Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	190	OK	No Trap Station Components.
255776	Radiator Trap	Main / 1st / 126	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	207	L	Pneumatic Radiator Valve. No Trap Station Components.
255777	Univent	Main / 1st / 126	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	P	Outlet Isolation.
255778	Radiator Trap	Main / 1st / 126	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	210	165	OK	Pneumatic Radiator Valve. No Trap Station Components.
255768	Radiator Trap	Main / 1st / 128	Radiator Left Corner Of Rm, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	180	OK	Pneumatic Radiator Valve. No Trap Station Components.
255769	Univent	Main / 1st / 128	Left Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	191	OK	No Trap Station Components.
255770	Radiator Trap	Main / 1st / 128	Left Of Right Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	197	OK	Pneumatic Radiator Valve. No Trap Station Components.
255771	Univent	Main / 1st / 128	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	212	L	No Trap Station Components.
255772	Radiator Trap	Main / 1st / 128	Right Of Right Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	188	OK	Pneumatic Radiator Valve. No Trap Station Components.
255773	Radiator Trap	Main / 1st / 128 Side Rm	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
255766	Univent	Main / 1st / 130	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	187	OK	No Trap Station Components.
255767	Radiator Trap	Main / 1st / 130	Radiator Right Of Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	200	120	P	Manual Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255763	Univent	Main / 1st / 137	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	191	OK	Outlet Isolation.
255764	Radiator Trap	Main / 1st / 137	Panel Next To Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	210	184	OK	Pneumatic Radiator Valve. No Trap Station Components.
255760	Univent	Main / 1st / 139	Univent, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	198	OK	No Trap Station Components.
255761	Radiator Trap	Main / 1st / 139	Radiator Left Of Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	187	OK	Pneumatic Radiator Valve. No Trap Station Components.
255758	Univent	Main / 1st / 141	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	203	OK	Outlet Isolation.
255759	Radiator Trap	Main / 1st / 141	Panel Next To Univent, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	82	82	P	Pneumatic Radiator Valve. No Trap Station Components.
255755	Univent	Main / 1st / 143	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	NIS	Outlet Isolation. Valved Out.
255756	Radiator Trap	Main / 1st / 143	Left Of Univent, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
255754	Radiator Trap	Main / 1st / 145	Back Wall, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	214	188	OK	Pneumatic Radiator Valve. No Trap Station Components.
29700	Radiator Trap	Main / 1st / 147	Left Radiator, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	218	200	OK	Thermostatic Radiator Valve. No Trap Station Components.
298158	Radiator Trap	Main / 1st / 147	Right Radiator, 0-5'	TS-A	Barnes & Jones	1998	1/2"	3	220	200	OK	Thermostatic Radiator Valve. No Trap Station Components.
296998	Radiator Trap	Main / 1st / 149	Right Radiator, 0-5'	TS-A	Barnes & Jones	NA	1/2"	3	218	196	OK	Pneumatic Radiator Valve. No Trap Station Components.
296999	Radiator Trap	Main / 1st / 149	Right Radiator, 0-5'	TS-A	Barnes & Jones	NA	1/2"	3	217	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
296993	Radiator Trap	Main / 1st / 151	Back Of Space, 5-10'	TS-A	Barnes & Jones	1721	3/4"	3	218	213	L	Pneumatic Radiator Valve. No Trap Station Components.
296973	Univent	Main / 1st / 152	Beck Of Space, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	210	192	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296974	Radiator Trap	Main / 1st / 152	Back Wall, 0-5'	TS-S	Barnes & Jones	5000	3/4"	3	220	215	L	DDC Radiator Valve. Inlet Isolation. DDC Valve Broken Off
298975	Drip Leg	Main / 1st / 152	Back Wall Above Lockers, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	219	206	OK	No Trap Station Components.
296976	Univent	Main / 1st / 152B	Back Of Space, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	218	205	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296977	Radiator Trap	Main / 1st / 152B	Back Wall, 0-5'	TS-S	Barnes & Jones	5000	3/4"	3	213	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
296978	Univent	Main / 1st / 153A	Back Of Space, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	70	70	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Not Calling, No Power To Unit.
296980	Radiator Trap	Main / 1st / 153A	Bathroom, Left Side Of Radiator, 0-5'	TS-S	Barnes & Jones	5000	3/4"	3	218	215	L	DDC Radiator Valve. No Trap Station Components. DDC Valve Broken Off
296992	Drip Leg	Main / 1st / 153A	Bathroom, Right Side Of Radiator, 0-5'	TS-S	Barnes & Jones	5000	3/4"	3	222	214	L	No Trap Station Components.
297979	Radiator Trap	Main / 1st / 153A	Back Wall, 0-5'	TS-S	Barnes & Jones	5000	3/4"	3	217	207	OK	DDC Radiator Valve. No Trap Station Components.
296994	Radiator Trap	Main / 1st / 153C	Back Wall, Left Side Of Radiator, 0-5'	TS-S	Barnes & Jones	5007	3/4"	3	212	195	OK	DDC Radiator Valve. No Trap Station Components. DDC Valve Broken Off
296995	Drip Leg	Main / 1st / 153C	Back Wall, Right Side Of Radiator, 0-5'	TS-S	Barnes & Jones	5007	3/4"	3	222	217	L	No Trap Station Components.
296996	Drip Leg	Main / 1st / 153C	Bathroom, Left Side Of Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	170	150	P	No Trap Station Components.
296997	Radiator Trap	Main / 1st / 153C	Bathroom, Right Side Of Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	210	197	OK	DDC Radiator Valve. No Trap Station Components. DDC Valve Broken Off
296968	Radiator Trap	Main / 1st / 155A	Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	210	197	OK	Pneumatic Radiator Valve. No Trap Station Components.
296967	Radiator Trap	Main / 1st / 155B	Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	193	180	OK	Pneumatic Radiator Valve. No Trap Station Components.
296984	Radiator Trap	Main / 1st / 157	157E Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	205	OK	Pneumatic Radiator Valve. No Trap Station Components.
296985	Radiator Trap	Main / 1st / 157	157C Left Side, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	206	OK	Pneumatic Radiator Valve. No Trap Station Components.
296986	Radiator Trap	Main / 1st / 157	157C, Middle Of Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	197	OK	Pneumatic Radiator Valve. No Trap Station Components.
296987	Univent	Main / 1st / 157	Hallway Above Second Light Fixture, 5-10'	FT	Spirax Sarco	FT-14	3/4"	3	70	70	NIS	Inlet Isolation. Valved Out, Bad Heating Coil.
296988	Drip Leg	Main / 1st / 157	157B, Right Corner Second Tile From Window, 5-10'	FT	Spirax Sarco	FT-14	3/4"	3	220	200	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296989	Univent	Main / 1st / 157	157B, Far Side Of Univent About Ceiling, 5-10'	FT	Spirax Sarco	FT-14	3/4"	3	208	190	OK	Outlet Isolation.
255924	Univent	Main / 1st / 159 Nurses Office	Left Side Univent, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	214	198	OK	No Trap Station Components.
255925	Drip Leg	Main / 1st / 159 Nurses Office	Left Side Univent, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	213	190	OK	No Trap Station Components.
255926	Radiator Trap	Main / 1st / 159 Nurses Office	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	212	175	OK	Pneumatic Radiator Valve. No Trap Station Components.
255927	Radiator Trap	Main / 1st / 159B Nurses Office	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
300622	Radiator Trap	Main / 1st / Auditorium	Last Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Manual Radiator Valve. No Trap Station Components. Carpenter Required.
300623	Radiator Trap	Main / 1st / Auditorium	6th Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Carpenter Required.
300624	Radiator Trap	Main / 1st / Auditorium	5th Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Carpenter Required.
300625	Radiator Trap	Main / 1st / Auditorium	4th Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Carpenter Required.
300626	Radiator Trap	Main / 1st / Auditorium	3rd From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Carpenter Required.
300627	Radiator Trap	Main / 1st / Auditorium	2nd Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Carpenter Requires.
300628	Radiator Trap	Main / 1st / Auditorium	1st Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Carpenter Required.
255793	Radiator Trap	Main / 1st / Boys Bathroom Across From Cafeteria	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	78	78	P	Pneumatic Radiator Valve. No Trap Station Components.
255967	Drip Leg	Main / 1st / Boys Bathroom Gym	Left Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	213	209	L	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255968	Radiator Trap	Main / 1st / Boys Bathroom Gym	Left Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	210	<b>B</b>	Pneumatic Radiator Valve. No Trap Station Components.
296691	Radiator Trap	Main / 1st / Boys Bathroom Next To Stairwell 2	Under Window, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	70	70	NIS	DDC Radiator Valve. No Trap Station Components. Not Calling. Not Used, No Power To Unit.
255779	Radiator Trap	Main / 1st / Cafeteria	Dining Rm North Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	180	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Broken Off
255780	Radiator Trap	Main / 1st / Cafeteria	Dining Rm West Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	212	187	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Broken Off
255781	Radiator Trap	Main / 1st / Cafeteria	1st On West Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	180	OK	DDC Radiator Valve. No Trap Station Components.
255782	Radiator Trap	Main / 1st / Cafeteria	2nd On West Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	187	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
255783	Univent	Main / 1st / Cafeteria	Univent Right Side, 0-5'	TS-A	Spirax Sarco	125	3/4"	3	213	198	OK	No Trap Station Components.
255784	Radiator Trap	Main / 1st / Cafeteria	South Wall Radiator On West End, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	178	OK	DDC Radiator Valve. No Trap Station Components.
255785	Radiator Trap	Main / 1st / Cafeteria	South Wall Middle Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	212	198	OK	DDC Radiator Valve. No Trap Station Components.
255786	Radiator Trap	Main / 1st / Cafeteria	South Wall East Most Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	212	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
255787	Univent	Main / 1st / Cafeteria	South Wall Univent, 0-5'	TS-A	Spirax Sarco	125	3/4"	3	214	179	OK	No Trap Station Components.
255788	Drip Leg	Main / 1st / Cafeteria/Kitchen	West Side Under Skylight, 10-15'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	No Trap Station Components. Valved Out.
255789n	Radiator Trap	Main / 1st / Cafeteria/Kitchen	Radiator Behind Sink, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
255790	Drip Leg	Main / 1st / Cafeteria/Kitchen	Below Right Skylight, 10-15'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	No Trap Station Components. Valved Out.
255791	Drip Leg	Main / 1st / Cafeteria/Kitchen	Drip In Corner Next To Row Of Three Sinks, 10-15'	TS-A	Barnes & Jones	1929	3/4"	3	214	190	OK	No Trap Station Components.
300613	Drip Leg	Main / 1st / Crawlspace Below 100D	Below Entry, 0-5'	FT	Barnes & Jones	FT2015-5	1 1/4"	3	215	207	<b>L</b>	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255922	Radiator Trap	Main / 1st / Entrance Corridor	Outside Auditorium Right Side, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	212	L	Pneumatic Radiator Valve. No Trap Station Components.
255923	Radiator Trap	Main / 1st / Entrance Corridor	Before Auditorium Entrance Left Side, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
298159	Radiator Trap	Main / 1st / Girls Bathroom Across From 162	Under Window, 0-5'	TS-A	Spirax Sarco	RTA125	3/4"	3	70	70	NIS	DDC Radiator Valve. No Trap Station Components. Not Calling.
255957	Drip Leg	Main / 1st / Girls Bathroom Gyms	Right Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	207	L	No Trap Station Components.
255958	Radiator Trap	Main / 1st / Girls Bathroom Gyms	Right Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
296932	Radiator Trap	Main / 1st / Girls Restroom Across From 107	On Wall, 0-5'	TS-A	Spirax Sarco	A125	3/4"	3	80	80	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out.
255959	Radiator Trap	Main / 1st / Gym Entrance	Left Radiator, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	2	213	206	L	Pneumatic Radiator Valve. No Trap Station Components.
255960	Drip Leg	Main / 1st / Gym Entrance	Left Radiator, 0-5'	TS-S	Barnes & Jones	3146	3/4"	2	213	208	L	No Trap Station Components.
255961	Radiator Trap	Main / 1st / Gym Entrance	Right Radiator, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	2	213		OK	Pneumatic Radiator Valve. No Trap Station Components.
255962	Drip Leg	Main / 1st / Gym Entrance	Right Radiator, 0-5'	TS-S	Barnes & Jones	3146	3/4"	2	213	210	B	No Trap Station Components.
255963	Drip Leg	Main / 1st / Gym Entrance	Above Right Radiator, 5-10'	FT	Barnes & Jones	FT2015-4	1"	2	213	180	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
255954	Drip Leg	Main / 1st / Gym Stairwell	In Front Of Women's Bathroom, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	167	OK	No Trap Station Components.
255955	Radiator Trap	Main / 1st / Gym Stairwell	In Front Of Women's Bathroom, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	P	Pneumatic Radiator Valve. No Trap Station Components.
255956	Drip Leg	Main / 1st / Gym Stairwell	In Front Of Women's Bathroom, 5-10'	FT	Barnes & Jones	FT-2015	3/4"	2	213	187	OK	No Trap Station Components.
255964	Drip Leg	Main / 1st / Gym Stairwell	Outside Bathroom, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	216	208	L	No Trap Station Components.
255965	Radiator Trap	Main / 1st / Gym Stairwell	Outside Bathroom, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
255966	Drip Leg	Main / 1st / Gym Stairwell	Outside Bathroom, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	207	L	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296933	Radiator Trap	Main / 1st / Hallway	Outside Rm 105, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
296965	Radiator Trap	Main / 1st / Hallway	Across From 113, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
296966	Radiator Trap	Main / 1st / Hallway	Across From Rm 119, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
296969	Radiator Trap	Main / 1st / Hallway	Across From 104, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	193	OK	Pneumatic Radiator Valve. No Trap Station Components.
255762	Radiator Trap	Main / 1st / Hallway	Outside 137, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	83	82	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling, No Power To Unit.
255774	Radiator Trap	Main / 1st / Hallway	Outside Cafeteria, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	77	77	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling, Pulled Air Off Valve Doesn't Operate. Pneumatic Valve Stuck Closed
298160	Radiator Trap	Main / 1st / Hallway Across From Rm 147	Back Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	60	70	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling.
296982	Radiator Trap	Main / 1st / Main Entrance Vestibule	Left Radiator While Looking Out, 5-10'	TS-A	Barnes & Jones	NA	3/4"	3	220	216	B	Pneumatic Radiator Valve. No Trap Station Components.
296983	Radiator Trap	Main / 1st / Main Entrance Vestibule	Right Radiator While Looking Out, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
296930	Univent	Main / 1st / Rm 107	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	219	180	OK	No Trap Station Components.
296931	Radiator Trap	Main / 1st / Rm 107	Radiator Left Of Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
296927	Unit Heater	Main / 1st / Rm 109	Above Ceiling Right Of Univent, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	212	190	OK	No Trap Station Components.
296928	Drip Leg	Main / 1st / Rm 109	Univent Left Side, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	212	189	OK	No Trap Station Components.
296929	Radiator Trap	Main / 1st / Rm 109	Radiator Back Right Corner Through Second To Last Cabinet, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	167	OK	Pneumatic Radiator Valve. No Trap Station Components.
296926	Radiator Trap	Main / 1st / Rm 113	On Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
296914	Radiator Trap	Main / 1st / South Gym	East Side 1st, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	188	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296915	Radiator Trap	Main / 1st / South Gym	East Side 2nd, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220	216	L	Pneumatic Radiator Valve. No Trap Station Components.
296916	Radiator Trap	Main / 1st / South Gym	East Side 3rd, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	200	80	P	Pneumatic Radiator Valve. No Trap Station Components.
296917	Radiator Trap	Main / 1st / South Gym	East Side 4th, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out.
296918	Radiator Trap	Main / 1st / South Gym	East Side 5th, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	177	OK	Pneumatic Radiator Valve. No Trap Station Components.
296919	Radiator Trap	Main / 1st / South Gym	East Side 6th (On End), 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out.
296920	Radiator Trap	Main / 1st / South Gym	West Side 1st, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
296921	Radiator Trap	Main / 1st / South Gym	West Side 2nd, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220	213	L	Pneumatic Radiator Valve. No Trap Station Components.
296922	Radiator Trap	Main / 1st / South Gym	West Side 3rd, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
296923	Radiator Trap	Main / 1st / South Gym	West Side 4th, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	194	OK	Pneumatic Radiator Valve. No Trap Station Components.
296924	Radiator Trap	Main / 1st / South Gym	West Side 5th, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	218	193	OK	Pneumatic Radiator Valve. No Trap Station Components.
296925	Radiator Trap	Main / 1st / South Gym	West Side 6th (On End), 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	193	OK	Pneumatic Radiator Valve. No Trap Station Components.
296990	Univent	Main / 1st / Stairwell 2	Exit Doors, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	217	206	OK	No Trap Station Components.
255757	Univent	Main / 1st / Stairwell 3	Vestibule, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	208	L	No Trap Station Components.
255765	Univent	Main / 1st / Stairwell 4	Vestibule, 5-10'	TS-S	Barnes & Jones	5000	3/4"	3	211	185	OK	No Trap Station Components.
255792	Univent	Main / 1st / Stairwell 5	Vestibule, 0-5'	TS-S	Barnes & Jones	5000	3/4"	3	213	211	B	No Trap Station Components.
296971	Radiator Trap	Main / 1st / Stairwell Next To 102	Bottom Platform, 0-5'	FT	Barnes & Jones	FTI2015-3	3/4"	3	216	212	L	Pneumatic Radiator Valve. No Trap Station Components.
296972	Radiator Trap	Main / 1st / Stairwell Next To 102	Platform Leading Up To 2nd Floor, Above 15'	TS-A	Barnes & Jones	5000	1/2"	3	216	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
296913	Univent	Main / 1st / Basement Stairwell / Exit 3	Platform Before Entrance, 5-10'	TS-S	Barnes & Jones	5007	3/4"	3	215	177	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300047	Univent	Main / 2nd / 201	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	78	78	P	Outlet Isolation. Steam Trap Mounted Incorrectly.
300048	Radiator Trap	Main / 2nd / 201	Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300044	Radiator Trap	Main / 2nd / 202	Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	211	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300045	Univent	Main / 2nd / 202	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	76	76	P	Outlet Isolation.
300042	Univent	Main / 2nd / 203	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	199	OK	Outlet Isolation.
300043	Radiator Trap	Main / 2nd / 203	Radiator, 0-5'	TS-A	Armstrong	15	1/2"	3	213	178	OK	Pneumatic Radiator Valve. No Trap Station Components.
300040	Radiator Trap	Main / 2nd / 204	Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	213	179	OK	Pneumatic Radiator Valve. No Trap Station Components.
300041	Univent	Main / 2nd / 204	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	77	77	P	Outlet Isolation.
300035	Univent	Main / 2nd / 205	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	179	OK	Outlet Isolation.
300036	Radiator Trap	Main / 2nd / 205	Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	85	85	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling.
300037	Drip Leg	Main / 2nd / 206	Between 2nd And 3rd Lights From Door, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	76	76	NIS	No Trap Station Components. Valved Out.
300038	Air Handling Unit	Main / 2nd / 206	Between 2nd And 3rd Lights From Door, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	76	76	NIS	No Trap Station Components. Valved Out.
300039	Radiator Trap	Main / 2nd / 206	Radiator, 0-5'	TS-A	Armstrong	NA	1/2"	3	214	183	OK	Pneumatic Radiator Valve. No Trap Station Components.
300032	Univent	Main / 2nd / 207	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	187	OK	Outlet Isolation.
300033	Radiator Trap	Main / 2nd / 207	Radiator, 0-5'	TS-S	Barnes & Jones	4285	3/4"	3	213	206	L	Pneumatic Radiator Valve. No Trap Station Components.
300029	Univent	Main / 2nd / 209	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	194	OK	Outlet Isolation.
300030	Radiator Trap	Main / 2nd / 209	Radiator, 0-5'	TS-A	Barnes & Jones	4285	3/4"	3	214	208	L	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300027	Air Handling Unit	Main / 2nd / 211	HV-1, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	76	76	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
300028	Drip Leg	Main / 2nd / 211	AHU, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	215	184	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
300021	Radiator Trap	Main / 2nd / 212	Left Radiator, 0-5'	TS-LH	Barnes & Jones	1721	1/2"	3	215	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300022	Univent	Main / 2nd / 212	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	191	OK	No Trap Station Components.
300024	Radiator Trap	Main / 2nd / 213	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	200	OK	Pneumatic Radiator Valve. No Trap Station Components.
300025	Univent	Main / 2nd / 213	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	201	OK	Outlet Isolation.
300026	Radiator Trap	Main / 2nd / 213	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	202	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Radiator Valve Leaking By
300019	Univent	Main / 2nd / 214	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	195	OK	No Trap Station Components.
300020	Radiator Trap	Main / 2nd / 214	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300017	Univent	Main / 2nd / 215	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	198	OK	Outlet Isolation.
300018	Radiator Trap	Main / 2nd / 215	Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	213	196	OK	Pneumatic Radiator Valve. No Trap Station Components.
300014	Univent	Main / 2nd / 216	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	200	OK	Outlet Isolation.
300015	Radiator Trap	Main / 2nd / 216	Right Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300011	Univent	Main / 2nd / 217	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	167	OK	Outlet Isolation.
300012	Radiator Trap	Main / 2nd / 217	Right Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	214	208	L	Pneumatic Radiator Valve. No Trap Station Components.
300013	Radiator Trap	Main / 2nd / 217	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300010	Radiator Trap	Main / 2nd / 223	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	173	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300008	Univent	Main / 2nd / 225	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	85	84	P	Outlet Isolation.
300009	Radiator Trap	Main / 2nd / 225	Below Left Window, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	79	79	P	Pneumatic Radiator Valve. No Trap Station Components.
255997	Univent	Main / 2nd / 226	Left Univent, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	207	L	No Trap Station Components.
255998	Radiator Trap	Main / 2nd / 226	Left Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	211	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
255999	Univent	Main / 2nd / 226	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	77	78	NIS	Outlet Isolation. Not Calling.
256000	Radiator Trap	Main / 2nd / 226	Right Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	210	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300004	Radiator Trap	Main / 2nd / 227	Right Side Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	212	B	Pneumatic Radiator Valve. No Trap Station Components.
300005	Drip Leg	Main / 2nd / 227	Right Side Univent, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	2	215	212	B	Outlet Isolation.
300006	Univent	Main / 2nd / 227	Univent, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	75	76	P	No Trap Station Components.
300001	Drip Leg	Main / 2nd / 229	Next To Projector, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	78	78	P	No Trap Station Components.
300002	Univent	Main / 2nd / 229	Inside Univent, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	76	76	P	No Trap Station Components.
300003	Radiator Trap	Main / 2nd / 229	Below Window, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	213	191	OK	Pneumatic Radiator Valve. No Trap Station Components.
255987	Univent	Main / 2nd / 230	Right Side Of Left Univent, 0-5'	TS-S	Barnes & Jones	4285	3/4"	2	212	185	OK	No Trap Station Components.
255988	Radiator Trap	Main / 2nd / 230	Left Side Of Radiator, In Access Panel, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	210	L	Pneumatic Radiator Valve. No Trap Station Components.
255989	Univent	Main / 2nd / 230	Right Side Of Right Univent, 0-5'	TS-S	Barnes & Jones	4285	3/4"	2	212	210	L	No Trap Station Components.
255990	Radiator Trap	Main / 2nd / 230A	Left Side Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
255994	Univent	Main / 2nd / 231	Left Side Univent, 0-5'	FT	Barnes & Jones	FT2015	3/4"	2	212	183	OK	Outlet Isolation.
255995	Radiator Trap	Main / 2nd / 231	Right Side Of Radiator, In Access Panel, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	183	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255993	Radiator Trap	Main / 2nd / 233	Right Side Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
255985	Univent	Main / 2nd / 237	Right Side Univent, 0-5'	FT	Hoffman	FT015H	3/4"	2	80	80	NIS	No Trap Station Components. Not Calling.
255986	Radiator Trap	Main / 2nd / 237	Right Side Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. In Radiator Cabinet With No Access Panel.
255982	Univent	Main / 2nd / 239	Right Side Univent, 0-5'	FT	Hoffman	FT015H	3/4"	2	216	187	OK	Outlet Isolation.
255983	Radiator Trap	Main / 2nd / 239	Right Side Of Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	177	OK	Pneumatic Radiator Valve. No Trap Station Components.
255980	Univent	Main / 2nd / 241	Univent Right Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	179	OK	Outlet Isolation.
255981	Radiator Trap	Main / 2nd / 241	Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	214	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
155978	Univent	Main / 2nd / 243	Univent Right Side, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	199	OK	Outlet Isolation. Steam Trap Not Level.
255979	Radiator Trap	Main / 2nd / 243	Right Panel, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	208	L	Pneumatic Radiator Valve. No Trap Station Components.
255977	Radiator Trap	Main / 2nd / 245	Right Corner, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
255972	Drip Leg	Main / 2nd / 247	In Front Of Door, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	215	194	OK	No Trap Station Components.
255973	Univent	Main / 2nd / 247	In Front Of Door, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	210	188	OK	No Trap Station Components.
255974	Radiator Trap	Main / 2nd / 247	Left Corner, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	210	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
255928	Drip Leg	Main / 2nd / 249	HV-3, 0-5'	FT	Barnes & Jones	FT6	1"	3	215	208	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
255929	Air Handling Unit	Main / 2nd / 249	HV-3, 0-5'	FT	Barnes & Jones	FT6	1"	3	210	191	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
255930	Air Handling Unit	Main / 2nd / 253	Backside HV-2, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	213	171	OK	Inlet Isolation, Outlet Isolation.
300065	Drip Leg	Main / 2nd / 255	Left Of Univent, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	215	173	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300066	Univent	Main / 2nd / 255	In Front Of Door, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	214	184	OK	No Trap Station Components.
300067	Radiator Trap	Main / 2nd / 255	Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	184	OK	Pneumatic Radiator Valve. No Trap Station Components.
300061	Radiator Trap	Main / 2nd / 259	Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Buried Behind Paperwork And Removal Of Panels. Pneumatic Valve Stuck Closed
300053	Air Handling Unit	Main / 2nd / 260	Left AHU, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	76	76	NIS	Outlet Isolation. Valved Out, Not Calling.
300054	Air Handling Unit	Main / 2nd / 260	Right AHU, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	74	74	NIS	Outlet Isolation. Valved Out, Not Calling.
300051	Air Handling Unit	Main / 2nd / 264	Left AHU, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	192	174	OK	Outlet Isolation.
300052	Air Handling Unit	Main / 2nd / 264	Right AHU, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	199	173	OK	Outlet Isolation.
300049	Radiator Trap	Main / 2nd / 265	Right Radiator, 0-5'	TS-A	Spirax Sarco	T25	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300050	Radiator Trap	Main / 2nd / 265	Left Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	78	78	P	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Closed
300007	Radiator Trap	Main / 2nd / Boys Bathroom, West Hallway	Left Of Sinks, 0-5'	TS-A	Spirax Sarco	RTA125	1/2"	2	NA	NA	NA	No Radiator Valve. No Trap Station Components. Cannot Remove Cover.
300031	Radiator Trap	Main / 2nd / Girls Bathroom Across From 207	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	213	179	OK	Pneumatic Radiator Valve. No Trap Station Components.
255976	Radiator Trap	Main / 2nd / Girls Bathroom Next To 247	Below Window, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	214	177	OK	DDC Radiator Valve. No Trap Station Components.
255931	Radiator Trap	Main / 2nd / Gym	First Radiator On Right, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255932	Radiator Trap	Main / 2nd / Gym	Second Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255933	Radiator Trap	Main / 2nd / Gym	Third Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255934	Radiator Trap	Main / 2nd / Gym	Fourth Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255935	Radiator Trap	Main / 2nd / Gym	Fifth Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255936	Radiator Trap	Main / 2nd / Gym	Sixth Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255937	Radiator Trap	Main / 2nd / Gym	Seventh Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255938	Radiator Trap	Main / 2nd / Gym	Eighth Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	RIP	No Radiator Valve. Disconnected From System.
255939	Radiator Trap	Main / 2nd / Gym	Eighth Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	85	85	P	No Radiator Valve. No Trap Station Components.
255940	Radiator Trap	Main / 2nd / Gym	Seventh Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	210	L	No Radiator Valve. No Trap Station Components.
255941	Radiator Trap	Main / 2nd / Gym	Sixth Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	210	B	No Radiator Valve. No Trap Station Components.
255942	Radiator Trap	Main / 2nd / Gym	Fifth Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	217	212	B	No Radiator Valve. No Trap Station Components.
255943	Radiator Trap	Main / 2nd / Gym	Fourth Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	212	L	No Radiator Valve. No Trap Station Components.
255944	Radiator Trap	Main / 2nd / Gym	Third Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	217	212	B	No Radiator Valve. No Trap Station Components.
255945	Radiator Trap	Main / 2nd / Gym	Second Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	180	OK	No Radiator Valve. No Trap Station Components.
255946	Radiator Trap	Main / 2nd / Gym	First Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	171	OK	No Radiator Valve. No Trap Station Components.
255947	Radiator Trap	Main / 2nd / Gym Stairwell	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	210	L	Pneumatic Radiator Valve. No Trap Station Components.
255970	Air Handling Unit	Main / 2nd / Gym Storage 251	HV-4, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	176	OK	Inlet Isolation, Outlet Isolation.
255971	Radiator Trap	Main / 2nd / Gym Storage 251A	Below Right Window, 0-5'	TS-A	N/A	NA	1/2"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Buried.
255969	Radiator Trap	Main / 2nd / Gym Storage 251B	Back Wall, 0-5'	TS-A	N/A	NA	1/2"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Buried.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
255975	Radiator Trap	Main / 2nd / Hallway	Across From 247, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling. Pneumatic Valve Stuck Closed
255984	Radiator Trap	Main / 2nd / Hallway	Outside 237, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	210	L	Pneumatic Radiator Valve. No Trap Station Components.
255996	Radiator Trap	Main / 2nd / Hallway	Outside 231, 0-5'	TS-A	Spirax Sarco	RTA-125	1/2"	3	78	78	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling. Pneumatic Valve Broken Off
300016	Radiator Trap	Main / 2nd / Hallway	Across From 215, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	73	73	P	Pneumatic Radiator Valve. No Trap Station Components.
300023	Radiator Trap	Main / 2nd / Hallway	Outside 212, 0-5'	TS-S	Barnes & Jones	3500	1/2"	3	76	76	P	Pneumatic Radiator Valve. No Trap Station Components.
300034	Radiator Trap	Main / 2nd / Hallway	Outside 207, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	76	75	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling. Pneumatic Valve Stuck Closed
300046	Radiator Trap	Main / 2nd / Hallway	Outside 201, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	76	76	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling.
300062	Univent	Main / 2nd / 257	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	195	OK	Outlet Isolation.
300063	Radiator Trap	Main / 2nd / 257	Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	213	193	OK	Pneumatic Radiator Valve. No Trap Station Components.
300055	Radiator Trap	Main / 2nd / 261	1st Radiator On Right, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	76	76	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling. Pneumatic Valve Stuck Closed
300056	Radiator Trap	Main / 2nd / 261	2nd Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	76	75	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling. Pneumatic Valve Stuck Closed
300057	Radiator Trap	Main / 2nd / 261	3rd Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300058	Radiator Trap	Main / 2nd / 261	4th Radiator, 0-5'	TS-A	Hoffman	17C	1/2"	3	213	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300059	Vacuum Breaker	Main / 2nd / 261	5th Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	208	L	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300060	Radiator Trap	Main / 2nd / 261	6th Radiator, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300064	Radiator Trap	Main / 2nd / Boys Bathroom Next To 255	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	213	176	OK	DDC Radiator Valve. No Trap Station Components. DDC Valve Broken Off
300068	Radiator Trap	Main / 2nd / Hallway	Across From 253, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	76	76	P	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Closed
302141	Univent	Main / 3rd / 309	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	198	OK	No Trap Station Components.
302142	Radiator Trap	Main / 3rd / 309	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
302139	Radiator Trap	Main / 3rd / 311	Radiator (Trap Suspected Under Counter Top By Oven), 0-5'	FT	N/A	N/A	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. No Access Panel And Going To Be Hard To Create One.
302140	Univent	Main / 3rd / 311	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	217	194	OK	Outlet Isolation.
302136	Univent	Main / 3rd / 312	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	178	OK	No Trap Station Components.
302137	Radiator Trap	Main / 3rd / 312	Radiator Under Window Left Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
302132	Drip Leg	Main / 3rd / 313	Left Side Of Univent, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	215	213	L	Inlet Isolation.
302133	Univent	Main / 3rd / 313	Inside Univent, Above Ceiling	FT	Spirax Sarco	FT14	3/4"	3	216	187	OK	No Trap Station Components.
302134	Radiator Trap	Main / 3rd / 313	Radiator Under Window Left Corner, 0-5'	TS-A	N/A	N/A	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. No Access Panel.
302135	Radiator Trap	Main / 3rd / 313	Radiator Under Window Right Corner, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. No Access Panel.
302129	Drip Leg	Main / 3rd / 314	Middle Of Rm, Above Ceiling	FT	Barnes & Jones	FT2015-5	1 1/4"	3	214	160	OK	Inlet Isolation.
302130	Reheat Coil	Main / 3rd / 314	Middle Of Rm, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	215	180	OK	Inlet Isolation, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
302131	Radiator Trap	Main / 3rd / 314	Radiator Under Window Right Corner, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. No Access Panel. Can't Reach From Up Top.
302126	Radiator Trap	Main / 3rd / 315	Left Radiator Access Panel In Cabinets, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	212	L	Pneumatic Radiator Valve. No Trap Station Components.
302125	Univent	Main / 3rd / 315	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	193	OK	No Trap Station Components.
302127	Radiator Trap	Main / 3rd / 315	Right Radiator. Access Panel In Cabinets, 0-5'	TS-A	Barnes & Jones	122A	1/2"	3	215	212	L	Pneumatic Radiator Valve. No Trap Station Components.
302121	Reheat Coil	Main / 3rd / 316	Middle Of Rm, Above Ceiling	FT	Barnes & Jones	FTI2015-3	3/4"	3	214	176	OK	Inlet Isolation, Strainer.
302122	Drip Leg	Main / 3rd / 316	Towards Right Wall, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	215	187	OK	Outlet Isolation.
302123	Radiator Trap	Main / 3rd / 316	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	214	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
302124	Reheat Coil	Main / 3rd / 316	Against Right Wall, Above Ceiling	FT	Barnes & Jones	FTI2015-3	3/4"	3	80	80	NIS	Outlet Isolation. Not Calling.
302119	Univent	Main / 3rd / 317	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	176	OK	No Trap Station Components.
302120	Radiator Trap	Main / 3rd / 317	Radiator Left Corner, 0-5'	TS-A	N/A	N/A	3/4"	3	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Access Panel Not In Correct Place.
302118	Radiator Trap	Main / 3rd / 323	Under Window. Access Panel Right Cabinet, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	186	OK	Pneumatic Radiator Valve. No Trap Station Components.
302113	Radiator Trap	Main / 3rd / 324 Teachers Rm	Radiator Back Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
302116	Univent	Main / 3rd / 325	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	176	OK	No Trap Station Components.
302117	Radiator Trap	Main / 3rd / 325	Radiator Under Window Access Panel Left Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	212	L	Pneumatic Radiator Valve. No Trap Station Components.
302105	Univent	Main / 3rd / 326	Left Univent, 0-5'	TS-A	N/A	N/A	1/2"	3	NA	NA	NA	No Trap Station Components. Trap Piped Behind Univent.
302106	Radiator Trap	Main / 3rd / 326	Radiator Between Univents Access Panel In Cabinet, 0-5'	TS-A	Barnes & Jones	1721	3/4"	3	215	212	L	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
302107	Univent	Main / 3rd / 326	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	NIS	No Trap Station Components. Not Calling.
302112	Radiator Trap	Main / 3rd / 327	Radiator Under Window Access Panel Right Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	193	OK	Pneumatic Radiator Valve. No Trap Station Components.
302109	Univent	Main / 3rd / 329	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	225	176	OK	No Trap Station Components.
302110	Radiator Trap	Main / 3rd / 329	Middle Radiator Access Panel Left Of Univent, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	195	OK	Pneumatic Radiator Valve. No Trap Station Components.
302111	Radiator Trap	Main / 3rd / 329	Left Radiator Access Panel In Cabinet, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	197	OK	Pneumatic Radiator Valve. No Trap Station Components.
302101	Air Vent	Main / 3rd / 330	Left Univent. Access Panel In Cabinet, 0-5'	TS-S	Barnes & Jones	1785	3/4"	3	214	197	OK	No Trap Station Components.
302102	Radiator Trap	Main / 3rd / 330	Between Univents. Access Panel I'M Cabinet, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	212	L	Pneumatic Radiator Valve. No Trap Station Components.
302103	Univent	Main / 3rd / 330	Right Univent. Access Panel In Cabinet, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	177	OK	No Trap Station Components.
302114	Radiator Trap	Main / 3rd / Boys Bathroom Next To 324	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA125	3/4"	3	80	80	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out.
255948	Radiator Trap	Main / 3rd / Gym Stairwell	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	P	Pneumatic Radiator Valve. No Trap Station Components.
255952	Radiator Trap	Main / 3rd / Gym Stairwell	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	89	89	P	Pneumatic Radiator Valve. No Trap Station Components.
301128	Radiator Trap	Main / 3rd / Hallway	Radiator Across From 315, 0-5'	TS-S	Barnes & Jones	1721	1/2"	3	214	192	OK	Pneumatic Radiator Valve. No Trap Station Components.
302108	Radiator Trap	Main / 3rd / Hallway	Radiator Across From 326, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
302138	Radiator Trap	Main / 3rd / Hallway	Across From 311, 0-5'	TS-S	Barnes & Jones	1721	1/2"	3	80	80	NIS	Pneumatic Radiator Valve. No Trap Station Components. Not Calling.
302104	Radiator Trap	Main / 3rd / Space Between 330 And 326	Under Window, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
302115	Radiator Trap	Main / 3rd / Stairwell 5	Platform Before 3rd Floor, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	187	OK	Pneumatic Radiator Valve. No Trap Station Components.
302143	Radiator Trap	Main / 3rd / Stairwell 6	Platform Before Third Floor Under Window, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	192	OK	Pneumatic Radiator Valve. No Trap Station Components.
255949	Radiator Trap	Main / 3rd / Upper Bleachers	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	185	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255950	Radiator Trap	Main / 3rd / Upper Bleachers	Center Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	180	OK	Thermostatic Radiator Valve. No Trap Station Components.
255951	Radiator Trap	Main / 3rd / Upper Bleachers	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	180	OK	Thermostatic Radiator Valve. No Trap Station Components.
300346	Air Handling Unit	Main / 3rd / 300	AHU Coil, 0-5'	FT	Barnes & Jones	44T	1 1/2"	3	163	160	OK	Inlet Isolation, Strainer, Outlet Isolation.
300347	Drip Leg	Main / 3rd / 300	AHU Coil, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	173	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
300228	Univent	Main / 3rd / 301	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	174	OK	No Trap Station Components.
300329	Radiator Trap	Main / 3rd / 301	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	181	OK	Pneumatic Radiator Valve. No Trap Station Components.
300331	Radiator Trap	Main / 3rd / 302	Radiator, 0-5'	TS-A	Barnes & Jones	2819	1/2"	3	215	185	OK	Pneumatic Radiator Valve. No Trap Station Components.
300332	Univent	Main / 3rd / 302	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	217	199	OK	No Trap Station Components.
300326	Univent	Main / 3rd / 303	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	225	171	OK	No Trap Station Components.
300327	Radiator Trap	Main / 3rd / 303	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	217	178	OK	Pneumatic Radiator Valve. No Trap Station Components.
300324	Radiator Trap	Main / 3rd / 304	Radiator, 0-5'	TS-A	Watts	1G ONBODY	1/2"	3	215	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300325	Univent	Main / 3rd / 304	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	NA	NA	RIP	Disconnected From System.
300319	Univent	Main / 3rd / 305	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	178	OK	No Trap Station Components.
300320	Radiator Trap	Main / 3rd / 305	Radiator, 0-5'	TS-A	Watts	1G ONBODY	1/2"	3	216	211	B	Pneumatic Radiator Valve. No Trap Station Components.
300321	Univent	Main / 3rd / 306	Left Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	216	189	OK	Inlet Isolation.
300322	Radiator Trap	Main / 3rd / 306	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	216	210	L	Pneumatic Radiator Valve. No Trap Station Components.
300323	Univent	Main / 3rd / 306	Right Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	92	92	P	No Trap Station Components.
300097	Univent	Main / 3rd / 307	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	171	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300098	Radiator Trap	Main / 3rd / 307	Radiator, 0-5'	TS-A	Barnes & Jones	3146	1/2"	3	215	179	OK	Pneumatic Radiator Valve. No Trap Station Components.
300096	Radiator Trap	Main / 3rd / 331	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	213	179	OK	Pneumatic Radiator Valve. No Trap Station Components.
300094	Univent	Main / 3rd / 333	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	209	167	OK	Outlet Isolation.
300095	Radiator Trap	Main / 3rd / 333	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	213	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
300091	Univent	Main / 3rd / 337	Univent, 0-5'	FT	Hoffman	FT015-H3	3/4"	3	76	76	P	Inlet Isolation, Outlet Isolation.
300092	Radiator Trap	Main / 3rd / 337	Radiator, 0-5'	TS-A	Hoffman	8C	3/4"	3	213	178	OK	Pneumatic Radiator Valve. No Trap Station Components.
300088	Univent	Main / 3rd / 339	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	214	186	OK	No Trap Station Components.
300089	Radiator Trap	Main / 3rd / 339	Radiator, 0-5'	TS-A	Barnes & Jones	3146	3/4"	3	208	174	OK	Pneumatic Radiator Valve. No Trap Station Components. Steam Trap Leaking Condensate.
300086	Univent	Main / 3rd / 341	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	81	81	NIS	No Trap Station Components. Valved Out, Not Calling.
300087	Radiator Trap	Main / 3rd / 341	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	181	OK	Pneumatic Radiator Valve. No Trap Station Components.
300083	Univent	Main / 3rd / 343	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	210	178	OK	No Trap Station Components.
300084	Radiator Trap	Main / 3rd / 343	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	178	OK	Pneumatic Radiator Valve. No Trap Station Components.
300082	Radiator Trap	Main / 3rd / 345	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	194	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Radiator Valve Leaking By
300077	Univent	Main / 3rd / 347	In Front Of Door, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	213	173	OK	No Trap Station Components.
300078	Drip Leg	Main / 3rd / 347	In Front Of Tall Cabinet, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	3	214	196	OK	No Trap Station Components.
300079	Radiator Trap	Main / 3rd / 347	Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	213	197	OK	Pneumatic Radiator Valve. No Trap Station Components.
300073	Drip Leg	Main / 3rd / 355	In Front Of Door, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	214	176	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300074	Univent	Main / 3rd / 355	In Front Of Door, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	76	84	P	No Trap Station Components.
300075	Radiator Trap	Main / 3rd / 355	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	207	L	Pneumatic Radiator Valve. No Trap Station Components. Elbow Leaking Condensate.
300070	Univent	Main / 3rd / 357	Univent, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	3	76	76	NIS	Outlet Isolation. Valved Out, Not Calling.
300071	Radiator Trap	Main / 3rd / 357	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	191	OK	Pneumatic Radiator Valve. No Trap Station Components.
300345	Radiator Trap	Main / 3rd / 359	Below Window, 0-5'	TS-A	Barnes & Jones	134	3/4"	3	214	197	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Radiator Valve Leaking By
300341	Radiator Trap	Main / 3rd / 361	Right Skylight, 10-15'	TS-A	Warren Webster	513	3/4"	3	195	167	OK	Pneumatic Radiator Valve. No Trap Station Components.
300342	Radiator Trap	Main / 3rd / 361	Left Skylight, 10-15'	TS-A	Barnes & Jones	134	3/4"	3	202	164	OK	Pneumatic Radiator Valve. No Trap Station Components.
300343	Radiator Trap	Main / 3rd / 361	Right Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	215	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300344	Radiator Trap	Main / 3rd / 361	Left Radiator, 0-5'	TS-A	N/A	NA	1/2"	3	215	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
300336	Radiator Trap	Main / 3rd / 363	Right Skylight, 10-15'	TS-A	Warren Webster	513	3/4"	3	200	172	OK	Pneumatic Radiator Valve. No Trap Station Components.
300337	Radiator Trap	Main / 3rd / 363	Left Skylight, 10-15'	TS-A	Warren Webster	NA	1"	3	200	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300338	Radiator Trap	Main / 3rd / 363	Right Radiator, 0-5'	TS-A	Barnes & Jones	2819	1/2"	3	215	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300339	Radiator Trap	Main / 3rd / 363	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	207	L	Pneumatic Radiator Valve. No Trap Station Components.
300340	Radiator Trap	Main / 3rd / 363	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	187	OK	Pneumatic Radiator Valve. No Trap Station Components.
300333	Radiator Trap	Main / 3rd / 365	Skylight, 10-15'	TS-A	Barnes & Jones	1721	1/2"	3	217	191	OK	Pneumatic Radiator Valve. No Trap Station Components.
300334	Radiator Trap	Main / 3rd / 365	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	216	208	L	Pneumatic Radiator Valve. No Trap Station Components.
300099	Radiator Trap	Main / 3rd / Bathroom Across From 307	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	215	190	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
300072	Radiator Trap	Main / 3rd / Boys Bathroom Next To 355	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	214	174	OK	DDC Radiator Valve. No Trap Station Components.
300081	Radiator Trap	Main / 3rd / Girls Bathroom Next To 347	Back Wall, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	3	213	181	OK	DDC Radiator Valve. No Trap Station Components.
300076	Radiator Trap	Main / 3rd / Hallway	Across From 355, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	76	76	P	Pneumatic Radiator Valve. No Trap Station Components.
300080	Radiator Trap	Main / 3rd / Hallway	Across From 347, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	76	76	NIS	Pneumatic Radiator Valve. No Trap Station Components. Valved Out, Not Calling.
300090	Radiator Trap	Main / 3rd / Hallway	Outside 337, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	79	76	P	Pneumatic Radiator Valve. No Trap Station Components.
300318	Radiator Trap	Main / 3rd / Hallway	Next To 305A, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	NA	NA	RIP	Pneumatic Radiator Valve. Valved Out, Not Used.
300330	Radiator Trap	Main / 3rd / Hallway	Outside 301, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	NA	NA	RIP	Pneumatic Radiator Valve. Valved Out, Not Calling.
300069	Radiator Trap	Main / 3rd / Stairwell	Outside 357, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	188	OK	Pneumatic Radiator Valve. No Trap Station Components.
300085	Radiator Trap	Main / 3rd / Stairwell	Next To 343, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	213	184	OK	Pneumatic Radiator Valve. No Trap Station Components.
300093	Radiator Trap	Main / 3rd / Stairwell	Outside 337, 0-5'	TS-A	Barnes & Jones	5000	1/2"	3	213	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
300335	Radiator Trap	Main / 3rd / Stairwell	Across From 365, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	194	OK	Pneumatic Radiator Valve. No Trap Station Components.
296849	Drip Leg	Main / Basement / Back Entrance (Cage Rm)	Above Exit Door, 10-15'	TS-A	Barnes & Jones	1929	3/4"	3	215	212	L	No Trap Station Components.
296850	Drip Leg	Main / Basement / Back Entrance (Cage Rm)	Above First Window, 10-15'	TS-A	Barnes & Jones	1929	3/4"	3	218	193	OK	No Trap Station Components.
296851	Radiator Trap	Main / Basement / Back Entrance (Cage Rm)	Radiator Up Above, 10-15'	TS-A	Barnes & Jones	1929	3/4"	3	217	189	L	Pneumatic Radiator Valve. No Trap Station Components.
296852	Drip Leg	Main / Basement / Back Entrance (Cage Rm)	End Of Cage, 10-15'	TS-A	Barnes & Jones	1929	3/4"	3	217	212	L	No Trap Station Components.
296853	Drip Leg	Main / Basement / Back Entrance (Cage Rm)	End Of Cage, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	178	OK	No Trap Station Components.
296609	Drip Leg	Main / Basement / Basement Underground Hallway	Back Part On Right Side Near Storage Area, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	220	180	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296901	Drip Leg	Main / Basement / Basement Underground Hallway	Corner Opposite Entrance, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	217	180	OK	No Trap Station Components.
296902	Drip Leg	Main / Basement / Basement Underground Hallway	In Caged Rm First On Right M0, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	217	216	L	No Trap Station Components.
296903	Drip Leg	Main / Basement / Basement Underground Hallway	In Caged Rm 2nd On Right, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	216	187	OK	No Trap Station Components.
296904	Drip Leg	Main / Basement / Basement Underground Hallway	In Caged Rm Third On Right, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	217	199	OK	No Trap Station Components.
296905	Drip Leg	Main / Basement / Basement Underground Hallway	In Caged Rm Fourth On Right, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	216	212	L	No Trap Station Components.
296907	Drip Leg	Main / Basement / Basement Underground Hallway	Back Part On Right Side Near Storage Area, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	214	178	OK	No Trap Station Components.
296908	Drip Leg	Main / Basement / Basement Underground Hallway	Towards End Of Tunnel On Right Wall Before It Opens Up, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	214	189	OK	No Trap Station Components.
296909	Drip Leg	Main / Basement / Basement Underground Hallway	Towards End In First Carved Our Area, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	216	178	L	No Trap Station Components.
296910	Drip Leg	Main / Basement / Basement Underground Hallway	At Very End In Corner, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	217	180	OK	No Trap Station Components. Nipple Leaking Condensate.
296911	Drip Leg	Main / Basement / Basement Underground Hallway	At Very End In Corner, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	214	186	OK	No Trap Station Components.
296912	Drip Leg	Main / Basement / Basement Underground Hallway	At Very End In Corner, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	214	194	OK	No Trap Station Components.
296826	Drip Leg	Main / Basement / Boiler Rm	Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	189	OK	Inlet Isolation.
296827	Drip Leg	Main / Basement / Boiler Rm	Boiler 1, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	213	187	OK	Inlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296828	Drip Leg	Main / Basement / Boiler Rm	Above Entrance, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296829	Drip Leg	Main / Basement / Boiler Rm	Above Boiler 2 Panel, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	3	180	100	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296830	Drip Leg	Main / Basement / Boiler Rm	Above Electrical Panel In Corner, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	3	200	90	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296831	Drip Leg	Main / Basement / Boiler Rm	Above Electrical Panel In Corner, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	3	160	89	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296846	Drip Leg	Main / Basement / Break Rm	Drip Against Wall, 5-10'	TS-A	Barnes & Jones	1929	1/2"	3	216	193	OK	No Trap Station Components.
296847	Drip Leg	Main / Basement / Break Rm	Radiator On Wall Right Side, 0-5'	TS-A	Barnes & Jones	3494	1/2"	3	217	212	L	No Trap Station Components.
296848	Radiator Trap	Main / Basement / Break Rm	Radiator On Wall Left Side, 0-5'	TS-A	Spirax Sarco	H	1/2"	3	216	189	OK	Pneumatic Radiator Valve. No Trap Station Components.
300616	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	End Of Tunnel Near Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	218	215	L	No Trap Station Components.
300617	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	2nd Trap Towards Right End Of Tunnel, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	197	OK	No Trap Station Components.
300618	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	Opposite Entrance Of Tunnel, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	212	L	No Trap Station Components. Inlet Union Leaking Steam.
300619	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	Left Of Tunnel In Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	212	L	No Trap Station Components.
300620	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	Left In Tunnel Last Trap In Left Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	216	198	OK	No Trap Station Components.
296881	Drip Leg	Main / Basement / Data Closet 2E	Back Left Corner, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	215	192	OK	No Trap Station Components.
296882	Drip Leg	Main / Basement / Data Closet 2E	Back Left Corner, 5-10'	FT	Barnes & Jones	FT2015-4	1"	2	214	187	OK	Blowdown.
296883	Drip Leg	Main / Basement / Data Closet 2E	Back Left Corner, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	212	210	L	No Trap Station Components.
296844	Drip Leg	Main / Basement / Head Custodian Office	Left Side Of Radiator, 0-5'	TS-A	Spirax Sarco	H	1/2"	2	213	210	B	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296845	Radiator Trap	Main / Basement / Head Custodian Office	Radiator In Corner, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	220	193	OK	Pneumatic Radiator Valve. No Trap Station Components.
296869	Drip Leg	Main / Basement / Library	Left Side Of Radiator On Left Side Of Rm, Bottom Shelf Of Tall Bookcase Behind Cutout In Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	180	OK	No Trap Station Components.
296870	Radiator Trap	Main / Basement / Library	Right Side Of Radiator On Left Wall Behind Shelf In Cut Out, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	181	OK	Pneumatic Radiator Valve. No Trap Station Components.
296871	Radiator Trap	Main / Basement / Library	Left Side Of Radiator On Right Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	174	OK	Pneumatic Radiator Valve. No Trap Station Components.
296872	Drip Leg	Main / Basement / Library	Right Side Of Radiator On Right Wall, Bottom Shelf Of Tall Bookcase Behind Cutout, 0-5'	TS-A	Barnes & Jones	1G	3/4"	2	213	181	OK	No Trap Station Components.
296873	Drip Leg	Main / Basement / Library	In Between Left Wall And Left Support Column, Above Ceiling	FT	Barnes & Jones	FT15	3/4"	2	215	182	OK	Inlet Isolation, Outlet Isolation.
296874	Drip Leg	Main / Basement / Library	Right Of Left Support Column, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	2	213	212	L	Inlet Isolation, Outlet Isolation.
296875	Drip Leg	Main / Basement / Library	In Between Bookshelf On Right Side Of Rm And Right Support Column, Above Ceiling, Above Ceiling	FT	Hoffman	FT015H	3/4"	2	215	187	OK	Inlet Isolation, Outlet Isolation.
296876	Drip Leg	Main / Basement / Library	In Back Rm Of Library, Right Side Of Radiator On Left Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	185	OK	No Trap Station Components.
296877	Radiator Trap	Main / Basement / Library	Back Rm In Library, Left Side Of Radiator On Left Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	NA	NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Cannot Access Trap No Access Panel.
296878	Drip Leg	Main / Basement / Library	Back Rm In Library Left Side Of Radiator On Right Wall In Access Panel, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	183	OK	No Trap Station Components.
296879	Radiator Trap	Main / Basement / Library	Back Rm In Library, Right Side Of Radiator On Right Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	178	OK	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296832	Drip Leg	Main / Basement / MER Next To Boiler Rm	Above Ductwork, Above 15'	FT	Barnes & Jones	FT2015-4	1"	3	217	189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Strainer Plugged.
296833	Drip Leg	Main / Basement / MER Next To Boiler Rm	Above Ductwork Against Wall, Above 15'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296835	Drip Leg	Main / Basement / MER Next To Boiler Rm	Next To Ductwork, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296836	Drip Leg	Main / Basement / MER Next To Boiler Rm	Next To Ductwork, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	3	220	198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296837	Drip Leg	Main / Basement / MER Next To Boiler Rm	In Front Of Oil Tank, Above 15'	FT	Barnes & Jones	FT2015-3	3/4"	2	80	80	NIS	Inlet Isolation, Strainer, Outlet Isolation. Valved Out.
296838	Drip Leg	Main / Basement / MER Next To Boiler Rm	In Front Of Oil Tank, Above 15'	FT	Barnes & Jones	FT2015-3	3/4"	2	215	188	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296839	Drip Leg	Main / Basement / MER Next To Boiler Rm	Opposite End If Ductwork On Wall, Above 15'	FT	Barnes & Jones	FT2015-4	1"	3	116	90	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296840	Drip Leg	Main / Basement / MER Next To Boiler Rm	Opposite End Of Ductwork Above Electrical Lines, Above 15'	FT	Barnes & Jones	FT2015-3	3/4"	3	180	130	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296841	Drip Leg	Main / Basement / MER Next To Boiler Rm	Opposite Ductwork On Wall, 10-15'	FT	Barnes & Jones	FT2015-4	1"	3	220	90	P	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Dirt Leg Plugged.
296842	Drip Leg	Main / Basement / MER Next To Boiler Rm	In Caged Area, Right Wall, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	212	200	L	No Trap Station Components.
296859	Drip Leg	Main / Basement / North Crawlspace	In Front Of Entry, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	178	OK	No Trap Station Components.
296860	Drip Leg	Main / Basement / North Crawlspace	Halfway Down Tunnel, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	180	OK	No Trap Station Components.
296893	Drip Leg	Main / Basement / Rm 7	Univent Right Hand Side, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	217	188	OK	No Trap Station Components.
296894	Univent	Main / Basement / Rm 7	Univent Left Side, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	216	189	OK	No Trap Station Components.
296895	Drip Leg	Main / Basement / Rm 7	Drip Above Radiator Near Left Corner, Above Ceiling	TS-A	N/A	N/A	1/2"	3	215	176	OK	No Trap Station Components.
296896	Radiator Trap	Main / Basement / Rm 7	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	1929	1/2"	3	216	192	OK	Pneumatic Radiator Valve. No Trap Station Components.
296897	Drip Leg	Main / Basement / Rm 7	Radiator Left Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	199	OK	No Trap Station Components.
296854	Univent	Main / Basement / Rm 9	Heater In Ceiling (Middle Of Rm), Above Ceiling	FT	Barnes & Jones	FTI2015-3	3/4"	3	80	80	NIS	No Trap Station Components. Valved Out.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296855	Unit Heater	Main / Basement / Rm 9	Heater In Ceiling (Middle Of Rm), Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	80	80	NIS	No Trap Station Components. Valved Out.
296891	Radiator Trap	Main / Basement / Rm 9A	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	216	198	OK	Pneumatic Radiator Valve. No Trap Station Components.
296892	Drip Leg	Main / Basement / Rm 9A	Radiator Back Left, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	212	189	OK	No Trap Station Components.
296889	Drip Leg	Main / Basement / Rm 9B	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	216	212	L	No Trap Station Components.
296890	Radiator Trap	Main / Basement / Rm 9B	In Storage Closet, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	216	178	OK	Pneumatic Radiator Valve. No Trap Station Components.
296887	Drip Leg	Main / Basement / Rm 9C	Back Wall Right, 0-5'	TS-A	Barnes & Jones	122	1/2"	3	221	198	L	No Trap Station Components.
296888	Radiator Trap	Main / Basement / Rm 9C	Back Wall Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	220	187	OK	Pneumatic Radiator Valve. No Trap Station Components.
296856	Unit Heater	Main / Basement / Rm 9D	Unit Heater In Ceiling, Above Ceiling	TS-S	Barnes & Jones	134	3/4"	3	216	199	OK	No Trap Station Components.
296857	Unit Heater	Main / Basement / Rm 9D	Unit Heater Above Ceiling, Above Ceiling	FT	Barnes & Jones	FT2015-3	3/4"	3	217	199	OK	No Trap Station Components.
296858	Drip Leg	Main / Basement / Rm 9D	Above Ceiling In Left Corner, Above Ceiling	TS-A	Barnes & Jones	1929	1/2"	3	217	190	OK	No Trap Station Components.
296885	Drip Leg	Main / Basement / Rm 9D	Radiator Right Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	220	215	L	No Trap Station Components.
296886	Radiator Trap	Main / Basement / Rm 9D	Radiator Front Left Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	216	188	OK	Pneumatic Radiator Valve. No Trap Station Components.
296843	Drip Leg	Main / Basement / Stairwell From Boiler Rm	Above Platform, 10-15'	TS-A	Barnes & Jones	122	1/2"	3	220	216	L	No Trap Station Components.
296884	Drip Leg	Main / Basement / Storage Rm 1	Straight Ahead From Entrance, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	215	186	OK	No Trap Station Components.
296861	Drip Leg	Main / Basement / West Hallway	Right Of North Crawlspace Entry, 0-5'	FT	Barnes & Jones	FT2015-4	1"	2	215	186	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296862	Drip Leg	Main / Basement / West Hallway Rm 10B	Rm To The Left, Access Panel In Back Right Corner, 0-5'	FT	Hoffman	FT015H	1 1/4"	2	212	188	OK	No Trap Station Components.
296863	Drip Leg	Main / Basement / West Hallway Rm 10B	Storage Closet, Back Left Wall Above Ceiling, Above Ceiling	FT	Barnes & Jones	51T	3/4"	2	217	210	L	Inlet Isolation, Strainer, Blowdown.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296864	Drip Leg	Main / Basement / West Hallway Rm 10B	In Storage Closet, Above Ceiling Middle Of Room Ppl, Above Ceiling	TS-A	Barnes & Jones	134	3/4"	2	212	210	L	No Trap Station Components.
296865	Radiator Trap	Main / Basement / West Hallway Rm 10B	Storage Closet, Left Side Of Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	180	OK	No Radiator Valve. No Trap Station Components.
296867	Drip Leg	Main / Basement / West Hallway Rm 6	Right Side Of Radiator, 0-5'	TS-A	Barnes & Jones	122	1/2"	2	212	212	L	No Trap Station Components.
296868	Radiator Trap	Main / Basement / West Hallway Rm 6	Left Side Of Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	181	OK	Pneumatic Radiator Valve. No Trap Station Components.
296866	Radiator Trap	Main / Basement / West Hallway Rm 8	In Second Set Of Cabinet Doors From Right Side Of Counter, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	176	OK	Pneumatic Radiator Valve. No Trap Station Components.
296880	Univent	Main / Basement / West Hallway Rm 8	Tile Directly Left Of Second Light From The Right Wall, Row Of Lights Closest To Windows, Above Ceiling	FT	Barnes & Jones	FT2015	3/4"	2	214	187	OK	No Trap Station Components.
296957	Drip Leg	Main / Basement / 1A	Right Inside Corner Above Ceiling Tiles, 5-10'	TS-A	Barnes & Jones	134	3/4"	3	218	210	OK	No Trap Station Components.
296958	Drip Leg	Main / Basement / 1A	Middle Of Rm, Front Of Univent Above Ceiling, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	217	199	OK	No Trap Station Components.
296959	Univent	Main / Basement / 1A	Behind Univent Above Ceiling, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	210	291	OK	No Trap Station Components.
296960	Univent	Main / Basement / 1B	Middle Of Rm, Front Of Univent Above Ceiling, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	213	206	OK	No Trap Station Components.
296981	Drip Leg	Main / Basement / 1B	Middle Of Rm, Front Of Univent Above Ceiling, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	200	OK	No Trap Station Components.
296950	Drip Leg	Main / Basement / 3, Hallway	Above Entrance, 5-10'	FT	Barnes & Jones	FT2015-4	1"	3	217	198	OK	Inlet Isolation, Strainer, Blowdown.
296951	Drip Leg	Main / Basement / 3, Music Rm	Right Wall Above Exit, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	218	200	OK	Inlet Isolation, Check Valve, Outlet Isolation.
296952	Univent	Main / Basement / 3, Music Rm	Left Cross Corner, Behind Univent, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	186	178	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
296953	Drip Leg	Main / Basement / 3, Music Rm	Left Cross Corner, Behind Univent, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	215	197	OK	No Trap Station Components.
296954	Drip Leg	Main / Basement / 3, Music Rm	Left Cross Corner, Above Exit, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	220	205	OK	Check Valve.
296955	Univent	Main / Basement / 3, Music Rm	Left Corner, Behind Univent, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	189	175	OK	No Trap Station Components.
296956	Drip Leg	Main / Basement / 3, Music Rm	Left Corner, Behind Univent, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	218	195	OK	No Trap Station Components.
196943	Univent	Main / Basement / 5	Univent, Right, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	187	180	OK	No Trap Station Components.
296941	Drip Leg	Main / Basement / 5	Closet, Right Corner, 5-10'	FT	Barnes & Jones	FT-6	3/4"	3	219	190	OK	No Trap Station Components.
296942	Drip Leg	Main / Basement / 5	Univent, Right, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	220	196	OK	No Trap Station Components.
296944	Univent	Main / Basement / 5	Univent, Left, 5-10'	FT	Barnes & Jones	FTI2015-3	3/4"	3	197	186	OK	Check Valve.
296945	Drip Leg	Main / Basement / 5	Univent, Left, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	216	198	OK	No Trap Station Components.
296946	Drip Leg	Main / Basement / 5	Univent, Left, Behind, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	218	208	OK	No Trap Station Components.
296947	Drip Leg	Main / Basement / 5	Univent, Left, Behind And Above Light, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	114	115	P	No Trap Station Components.
296948	Drip Leg	Main / Basement / 5	Left Cross Corner Above Exit, 5-10'	TS-A	Barnes & Jones	1929	3/4"	3	215	205	OK	No Trap Station Components.
296949	Drip Leg	Main / Basement / 5A, Storage Rm	Left Cross Corner, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	3	218	198	OK	Inlet Isolation, Outlet Isolation.
300100	Radiator Trap	Main / Basement / B6 Bathroom	Center Of Rm, 5-10'	TS-A	Barnes & Jones	1721	1/2"	3	NA	NA	RIP	Pneumatic Radiator Valve. Valved Out.
300601	Drip Leg	Main / Basement / Crawlspace	Across From Stairwell 3, 0-5'	FT	Barnes & Jones	FT2015-4	1"	3	220	207	L	Inlet Isolation, Strainer.
300602	Drip Leg	Main / Basement / Crawlspace	80Ft In, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	213	167	OK	No Trap Station Components.
300603	Drip Leg	Main / Basement / Crawlspace	Branch Left After 80 Ft, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	75	85	P	No Trap Station Components.
300604	Drip Leg	Main / Basement / Crawlspace	80 Ft Left Branch, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	218	207	L	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
300605	Drip Leg	Main / Basement / Crawlspace	80Ft Left Branch Round Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	No Trap Station Components. Debris. Steam Trap Leaking Steam And Condensate.
300606	Drip Leg	Main / Basement / Crawlspace	80Ft Left Branch Around Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	NA	NA	NA	No Trap Station Components. Debris.
300607	Drip Leg	Main / Basement / Crawlspace Below 157D	Left, 0-5'	FT	Barnes & Jones	FT2015-5	1 1/4"	3	215	197	OK	No Trap Station Components. Outlet Union Leaking Steam And Condensate.
300608	Drip Leg	Main / Basement / Crawlspace Below 157D	Left, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	210	199	OK	No Trap Station Components.
300609	Drip Leg	Main / Basement / Crawlspace Below 157D	Far Left, 0-5'	TS-A	Barnes & Jones	1928	3/4"	3	216	189	OK	No Trap Station Components.
300610	Drip Leg	Main / Basement / Crawlspace Below 157D	Back Right, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	221	208	L	No Trap Station Components.
300611	Drip Leg	Main / Basement / Crawlspace Below 157D	Right 25 Ft, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	185	OK	No Trap Station Components.
300612	Drip Leg	Main / Basement / Crawlspace Below 157D	Right 30 Ft, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	218	211	B	No Trap Station Components. Inlet Isolation Leaking Condensate.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
255919	Radiator Trap	Main / 1st / 101B	Below Window, 0-5'	Hoffman	17C	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, Scheduling Issues, Copper Pipes. File Cabinet In The Way
255918	Radiator Trap	Main / 1st / 101C	Left Corner, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Scheduling Issues
296963	Radiator Trap	Main / 1st / 104	Radiator In Between Univents, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Behind Cabinet.
296938	Radiator Trap	Main / 1st / 105	Radiator Third Cabinet Access From Right, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Behind Cabinet
255911	Radiator Trap	Main / 1st / 112	Radiator Under Window, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, Extremely Difficult Access Behind Cabinet In Room
255912	Univent	Main / 1st / 112	Right Side Univent, Above Ceiling	Barnes & Jones	134	Thermostatic Straight	3	3/4"	NPT	P	Repair Kit, No Issues
255797	Univent	Main / 1st / 121	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, Difficult Access, Need To Adjust Position
255796	Radiator Trap	Main / 1st / 123	Below Ac, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Scheduling Issues
255776	Radiator Trap	Main / 1st / 126	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues, Copper Tubing
255777	Univent	Main / 1st / 126	Right Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues, Might Need To Pull Trap To Repair
255771	Univent	Main / 1st / 128	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, No Issues
255767	Radiator Trap	Main / 1st / 130	Radiator Right Of Univent, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Through Far-Right Cabinet Access
255759	Radiator Trap	Main / 1st / 141	Panel Next To Univent, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues, Need To Remove Panels. Copper Pipes
296993	Radiator Trap	Main / 1st / 151	Back Of Space, 5-10'	Barnes & Jones	1721	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296974	Radiator Trap	Main / 1st / 152	Back Wall, 0-5'	Barnes & Jones	5000	Thermostatic Straight	3	3/4"	NPT	L	Repair Kit, No Issues
296980	Radiator Trap	Main / 1st / 153A	Bathroom, Left Side Of Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Straight	3	3/4"	NPT	L	Repair Kit, Difficult Access
296992	Drip Leg	Main / 1st / 153A	Bathroom, Right Side Of Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Straight	3	3/4"	NPT	L	Repair Kit, No Issues
296995	Drip Leg	Main / 1st / 153C	Back Wall, Right Side Of Radiator, 0-5'	Barnes & Jones	5007	Thermostatic Straight	3	3/4"	NPT	L	Repair Kit, No Issues
296996	Drip Leg	Main / 1st / 153C	Bathroom, Left Side Of Radiator, 0-5'	Barnes & Jones	134	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, No Issues
255793	Radiator Trap	Main / 1st / Boys Bathroom Across From Cafeteria	Back Wall, 0-5'	Spirax Sarco	RTA-125	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, Scheduling Issues
255967	Drip Leg	Main / 1st / Boys Bathroom Gym	Left Wall, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, No Issues
255968	Radiator Trap	Main / 1st / Boys Bathroom Gym	Left Wall, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	B	Repair Kit, No Issues
255782	Radiator Trap	Main / 1st / Cafeteria	2nd On West Wall, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, No Issues
255786	Radiator Trap	Main / 1st / Cafeteria	South Wall East Most Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, No Issues
300613	Drip Leg	Main / 1st / Crawlspace Below 100D	Below Entry, 0-5'	Barnes & Jones	FT2015-5	Float & Thermostatic	3	1 1/4"	NPT	L	Repair Kit,
255922	Radiator Trap	Main / 1st / Entrance Corridor	Outside Auditorium Right Side, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access
255957	Drip Leg	Main / 1st / Girls Bathroom Gyms	Right Wall, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, No Issues
255958	Radiator Trap	Main / 1st / Girls Bathroom Gyms	Right Wall, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues, Copper Tubing
255959	Radiator Trap	Main / 1st / Gym Entrance	Left Radiator, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	2	3/4"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves
255960	Drip Leg	Main / 1st / Gym Entrance	Left Radiator, 0-5'	Barnes & Jones	3146	Thermostatic Straight	2	3/4"	NPT	L	Repair Kit, System Shutdown Required
255962	Drip Leg	Main / 1st / Gym Entrance	Right Radiator, 0-5'	Barnes & Jones	3146	Thermostatic Straight	2	3/4"	NPT	B	Repair Kit, System Shutdown Required, No Isolation Valves
255955	Radiator Trap	Main / 1st / Gym Stairwell	In Front Of Women's Bathroom, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, System Shutdown Required, No Isolation Valve

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
255964	Drip Leg	Main / 1st / Gym Stairwell	Outside Bathroom, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, No Issues
255965	Radiator Trap	Main / 1st / Gym Stairwell	Outside Bathroom, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
255966	Drip Leg	Main / 1st / Gym Stairwell	Outside Bathroom, 5-10'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
296982	Radiator Trap	Main / 1st / Main Entrance Vestibule	Left Radiator While Looking Out, 5-10'	Barnes & Jones	NA	Thermostatic Angle	3	3/4"	NPT	B	Full Trap, No Issues
296915	Radiator Trap	Main / 1st / South Gym	East Side 2nd, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, System Shutdown Required
296916	Radiator Trap	Main / 1st / South Gym	East Side 3rd, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, System Shutdown Required
296921	Radiator Trap	Main / 1st / South Gym	West Side 2nd, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, System Shutdown Required
255757	Univent	Main / 1st / Stairwell 3	Vestibule, 5-10'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, No Issues
255792	Univent	Main / 1st / Stairwell 5	Vestibule, 0-5'	Barnes & Jones	5000	Thermostatic Straight	3	3/4"	NPT	B	Repair Kit, No Issues
296971	Radiator Trap	Main / 1st / Stairwell Next To 102	Bottom Platform, 0-5'	Barnes & Jones	FTI2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
300047	Univent	Main / 2nd / 201	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300048	Radiator Trap	Main / 2nd / 201	Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
300045	Univent	Main / 2nd / 202	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300041	Univent	Main / 2nd / 204	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Full Trap, Difficult Access, Scheduling Issues
300033	Radiator Trap	Main / 2nd / 207	Radiator, 0-5'	Barnes & Jones	4285	Thermostatic Straight	3	3/4"	NPT	L	Repair Kit, Difficult Access
300030	Radiator Trap	Main / 2nd / 209	Radiator, 0-5'	Barnes & Jones	4285	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
300027	Air Handling Unit	Main / 2nd / 211	HV-1, 0-5'	Barnes & Jones	FT2015-4	Float & Thermostatic	3	1"	NPT	P	Repair Kit, No Issues
300020	Radiator Trap	Main / 2nd / 214	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300015	Radiator Trap	Main / 2nd / 216	Right Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
300012	Radiator Trap	Main / 2nd / 217	Right Radiator, 0-5'	N/A	NA	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, Will Have To Make Access Hatch
300013	Radiator Trap	Main / 2nd / 217	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access
300008	Univent	Main / 2nd / 225	Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300009	Radiator Trap	Main / 2nd / 225	Below Left Window, 0-5'	Barnes & Jones	122	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Scheduling Issues
255997	Univent	Main / 2nd / 226	Left Univent, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, Difficult Access, Copper
300004	Radiator Trap	Main / 2nd / 227	Right Side Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Difficult Access, System Shutdown Required, Need To Make Access Panel To Do Repair
300005	Drip Leg	Main / 2nd / 227	Right Side Univent, Above Ceiling	Barnes & Jones	FT2015-3	Float & Thermostatic	2	3/4"	NPT	B	Repair Kit, System Shutdown Required, No Inlet Isolation
300006	Univent	Main / 2nd / 227	Univent, Above Ceiling	Spirax Sarco	FT14	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300001	Drip Leg	Main / 2nd / 229	Next To Projector, Above Ceiling	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Scheduling Issues
300002	Univent	Main / 2nd / 229	Inside Univent, Above Ceiling	Spirax Sarco	FT14	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
255988	Radiator Trap	Main / 2nd / 230	Left Side Of Radiator, In Access Panel, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves
255989	Univent	Main / 2nd / 230	Right Side Of Right Univent, 0-5'	Barnes & Jones	4285	Thermostatic Straight	2	3/4"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves
255979	Radiator Trap	Main / 2nd / 243	Right Panel, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
255977	Radiator Trap	Main / 2nd / 245	Right Corner, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
255928	Drip Leg	Main / 2nd / 249	HV-3, 0-5'	Barnes & Jones	FT6	Float & Thermostatic	3	1"	NPT	L	Repair Kit, No Issues
300049	Radiator Trap	Main / 2nd / 265	Right Radiator, 0-5'	Spirax Sarco	T25	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
300050	Radiator Trap	Main / 2nd / 265	Left Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
255939	Radiator Trap	Main / 2nd / Gym	Eighth Radiator On Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, System Shutdown Required, No Isolation Valves
255940	Radiator Trap	Main / 2nd / Gym	Seventh Radiator On Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves
255941	Radiator Trap	Main / 2nd / Gym	Sixth Radiator On Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, System Shutdown Required, No Isolation Valves
255942	Radiator Trap	Main / 2nd / Gym	Fifth Radiator On Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Full Trap, System Shutdown Required, No Isolation Valves
255943	Radiator Trap	Main / 2nd / Gym	Fourth Radiator On Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves
255944	Radiator Trap	Main / 2nd / Gym	Third Radiator On Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, System Shutdown Required, No Isolation Valves
255947	Radiator Trap	Main / 2nd / Gym Stairwell	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves
255984	Radiator Trap	Main / 2nd / Hallway	Outside 237, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
300016	Radiator Trap	Main / 2nd / Hallway	Across From 215, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300023	Radiator Trap	Main / 2nd / Hallway	Outside 212, 0-5'	Barnes & Jones	3500	Thermostatic Straight	3	1/2"	NPT	P	Repair Kit, No Issues
300059	Vacuum Breaker	Main / 2nd / 261	5th Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
300060	Radiator Trap	Main / 2nd / 261	6th Radiator, 0-5'	Barnes & Jones	5000	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, No Issues
300068	Radiator Trap	Main / 2nd / Hallway	Across From 253, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
302132	Drip Leg	Main / 3rd / 313	Left Side Of Univent, Above Ceiling	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	L	Repair Kit, No Issues
302126	Radiator Trap	Main / 3rd / 315	Left Radiator Access Panel In Cabinets, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, May Need To Cut Larger Access Panel. Hard To Turn Wrenches For A Full Change Out
302127	Radiator Trap	Main / 3rd / 315	Right Radiator. Access Panel In Cabinets, 0-5'	Barnes & Jones	122A	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Through Access Panel

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
302117	Radiator Trap	Main / 3rd / 325	Radiator Under Window Access Panel Left Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, Difficult Access, Inside Access Panel Not A Lot Of Room
302106	Radiator Trap	Main / 3rd / 326	Radiator Between Univents Access Panel In Cabinet, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	3/4"	NPT	L	Full Trap, Difficult Access, Requires 3/4 Thermostatics Angle Trap. Difficult Access Small Wrenches To Remove
302102	Radiator Trap	Main / 3rd / 330	Between Univents. Access Panel I'M Cabinet, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Full Trap, Difficult Access
255948	Radiator Trap	Main / 3rd / Gym Stairwell	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, System Shutdown Required, No Isolation Valves
255952	Radiator Trap	Main / 3rd / Gym Stairwell	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, System Shutdown Required, No Isolation Valves
300324	Radiator Trap	Main / 3rd / 304	Radiator, 0-5'	Watts	1G ONBODY	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, Scheduling Issues
300320	Radiator Trap	Main / 3rd / 305	Radiator, 0-5'	Watts	1G ONBODY	Thermostatic Angle	3	1/2"	NPT	B	Full Trap, Difficult Access, Scheduling Issues
300322	Radiator Trap	Main / 3rd / 306	Radiator, 0-5'	Barnes & Jones	134	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, Difficult Access
300323	Univent	Main / 3rd / 306	Right Univent, 0-5'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300091	Univent	Main / 3rd / 337	Univent, 0-5'	Hoffman	FT015-H3	Float & Thermostatic	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300074	Univent	Main / 3rd / 355	In Front Of Door, Above Ceiling	Barnes & Jones	134	Thermostatic Straight	3	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
300075	Radiator Trap	Main / 3rd / 355	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
300343	Radiator Trap	Main / 3rd / 361	Right Radiator, 0-5'	N/A	NA	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, Difficult Access, Scheduling Issues
300339	Radiator Trap	Main / 3rd / 363	Middle Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
300334	Radiator Trap	Main / 3rd / 365	Below Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	L	Repair Kit, Scheduling Issues
300076	Radiator Trap	Main / 3rd / Hallway	Across From 355, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues
300090	Radiator Trap	Main / 3rd / Hallway	Outside 337, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296849	Drip Leg	Main / Basement / Back Entrance (Cage Rm)	Above Exit Door, 10-15'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
296851	Radiator Trap	Main / Basement / Back Entrance (Cage Rm)	Radiator Up Above, 10-15'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, No Issues
296852	Drip Leg	Main / Basement / Back Entrance (Cage Rm)	End Of Cage, 10-15'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
296902	Drip Leg	Main / Basement / Basement Underground Hallway	In Caged Rm First On Right M0, 5-10'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
296905	Drip Leg	Main / Basement / Basement Underground Hallway	In Caged Rm Fourth On Right, 5-10'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
296909	Drip Leg	Main / Basement / Basement Underground Hallway	Towards End In First Carved Our Area, 5-10'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
296828	Drip Leg	Main / Basement / Boiler Rm	Above Entrance, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Full Trap, Difficult Access, System Shutdown Required
296829	Drip Leg	Main / Basement / Boiler Rm	Above Boiler 2 Panel, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Full Trap, Difficult Access, System Shutdown Required
296830	Drip Leg	Main / Basement / Boiler Rm	Above Electrical Panel In Corner, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Full Trap, Difficult Access, System Shutdown Required
296831	Drip Leg	Main / Basement / Boiler Rm	Above Electrical Panel In Corner, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	P	Full Trap, Difficult Access, System Shutdown Required
296847	Drip Leg	Main / Basement / Break Rm	Radiator On Wall Right Side, 0-5'	Barnes & Jones	3494	Thermostatic Angle	3	1/2"	NPT	L	Full Trap, No Issues
300616	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	End Of Tunnel Near Wall, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, Permit Required Confined Space, Difficult Access
300618	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	Opposite Entrance Of Tunnel, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Full Trap, Permit Required Confined Space, Difficult Access
300619	Drip Leg	Main / Basement / Confined Space Tunnel In Rm 12B	Left Of Tunnel In Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, Permit Required Confined Space, Difficult Access
296883	Drip Leg	Main / Basement / Data Closet 2E	Back Left Corner, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, System Shutdown Required, No Isolation Valves

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
296844	Drip Leg	Main / Basement / Head Custodian Office	Left Side Of Radiator, 0-5'	Spirax Sarco	H	Thermostatic Angle	2	1/2"	NPT	<b>B</b>	Repair Kit, System Shutdown Required, No Iso Valves
296874	Drip Leg	Main / Basement / Library	Right Of Left Support Column, Above Ceiling	Barnes & Jones	FT2015-3	Float & Thermostatic	2	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access
296839	Drip Leg	Main / Basement / Mer Next To Boiler Rm	Opposite End If Ductwork On Wall, Above 15'	Barnes & Jones	FT2015-4	Float & Thermostatic	3	1"	NPT	<b>P</b>	Full Trap, Lift Required, Difficult Access, System Shutdown Required
296840	Drip Leg	Main / Basement / Mer Next To Boiler Rm	Opposite End Of Ductwork Above Electrical Lines, Above 15'	Barnes & Jones	FT2015-3	Float & Thermostatic	3	3/4"	NPT	<b>P</b>	Full Trap, Lift Required, Difficult Access, System Shutdown Required
296841	Drip Leg	Main / Basement / Mer Next To Boiler Rm	Opposite Ductwork On Wall, 10-15'	Barnes & Jones	FT2015-4	Float & Thermostatic	3	1"	NPT	<b>P</b>	Full Trap, Lift Required, Difficult Access, System Shutdown Required
296842	Drip Leg	Main / Basement / Mer Next To Boiler Rm	In Caged Area, Right Wall, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	<b>L</b>	Repair Kit, System Shutdown Required, No Isolation Valves
296889	Drip Leg	Main / Basement / Rm 9B	Radiator Right Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, System Shutdown Required
296887	Drip Leg	Main / Basement / Rm 9C	Back Wall Right, 0-5'	Barnes & Jones	122	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access, System Shutdown Required
296885	Drip Leg	Main / Basement / Rm 9D	Radiator Right Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	<b>L</b>	Repair Kit, System Shutdown Required
296843	Drip Leg	Main / Basement / Stairwell From Boiler Rm	Above Platform, 10-15'	Barnes & Jones	122	Thermostatic Angle	3	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access
296863	Drip Leg	Main / Basement / West Hallway Rm 10B	Storage Closet, Back Left Wall Above Ceiling, Above Ceiling	Barnes & Jones	51T	Float & Thermostatic	2	3/4"	NPT	<b>L</b>	Full Trap, System Shutdown Required, No Outlet Isolation
296864	Drip Leg	Main / Basement / West Hallway Rm 10B	In Storage Closet, Above Ceiling Middle Of Roo. Ppl, Above Ceiling	Barnes & Jones	134	Thermostatic Angle	2	3/4"	NPT	<b>L</b>	Repair Kit, Difficult Access, System Shutdown Required, No Isolation Valves
296867	Drip Leg	Main / Basement / West Hallway Rm 6	Right Side Of Radiator, 0-5'	Barnes & Jones	122	Thermostatic Angle	2	1/2"	NPT	<b>L</b>	Repair Kit, Difficult Access, System Shutdown Required, Behind Radiator Cover Hard To Get Access
296947	Drip Leg	Main / Basement / 5	Univent, Left, Behind And Above Light, 5-10'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	<b>P</b>	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
277851	Univent	Eastview / 1st / 101	Univent On Left, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	214	199	OK	Strainer, Blowdown.
277852	Radiator Trap	Eastview / 1st / 101	Radiator Left Side, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	215	187	OK	DDC Radiator Valve. No Trap Station Components.
277853	Univent	Eastview / 1st / 101	Univent In Right Corner, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	80	80	NIS	Inlet Isolation, Outlet Isolation. Valved Out.
277848	Univent	Eastview / 1st / 102	Left Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	213	195	OK	Inlet Isolation, Outlet Isolation.
277849	Univent	Eastview / 1st / 102	Right Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	83	83	NIS	Inlet Isolation, Outlet Isolation. Not Calling.
277850	Radiator Trap	Eastview / 1st / 102	Right Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	210	178	OK	DDC Radiator Valve. No Trap Station Components.
277857	Univent	Eastview / 1st / 103	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	80	80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out, Not Responding In System.
277856	Univent	Eastview / 1st / 104	Below Window, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	211	190	OK	Inlet Isolation, Outlet Isolation.
277861	Univent	Eastview / 1st / 107	Univent, 0-5'	TS-A	Spirax Sarco	125	3/4"	2	213	192	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
277862	Radiator Trap	Eastview / 1st / 107	Radiator Next To Univent, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	212	L	DDC Radiator Valve. No Trap Station Components.
277864	Radiator Trap	Eastview / 1st / 108A	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	172	1/2"	2	214	178	OK	DDC Radiator Valve. No Trap Station Components.
277863	Radiator Trap	Eastview / 1st / 108B	On Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	184	OK	DDC Radiator Valve. No Trap Station Components.
277865	Radiator Trap	Eastview / 1st / 108C	On Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	199	OK	DDC Radiator Valve. No Trap Station Components.
277868	Radiator Trap	Eastview / 1st / 110	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	80	80	P	DDC Radiator Valve. No Trap Station Components.
277869	Univent	Eastview / 1st / 110	Univent, 0-5'	TS-A	Spirax Sarco	125	3/4"	2	213	192	OK	No Trap Station Components.
277870	Univent	Eastview / 1st / 111	Univent Left Access, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	210	187	OK	Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
277871	Radiator Trap	Eastview / 1st / 111	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	211	188	OK	DDC Radiator Valve. No Trap Station Components.
277872	Radiator Trap	Eastview / 1st / 111	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	194	OK	DDC Radiator Valve. No Trap Station Components.
277887	Reheat Coil	Eastview / 1st / 113	Heating Coil Above Ceiling In Front Of White Board, Above Ceiling	TS-A	Spirax Sarco	A125	3/4"	2	214	188	OK	No Trap Station Components.
277875	Univent	Eastview / 1st / 114	Univent, 0-5'	TS-A	Hoffman	8C	3/4"	2	213	198	OK	Strainer, Blowdown.
296621	Radiator Trap	Eastview / 1st / 115	Entrance To Auditorium Vestibule Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	189	OK	Thermostatic Radiator Valve. No Trap Station Components.
296622	Radiator Trap	Eastview / 1st / 115	Entrance To Auditorium Vestibule Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	176	OK	Thermostatic Radiator Valve. No Trap Station Components.
296627	Radiator Trap	Eastview / 1st / 115D	Front Of Entrance, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	100	P	Thermostatic Radiator Valve. No Trap Station Components.
296628	Radiator Trap	Eastview / 1st / 115D	Back Wall Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	182	OK	Thermostatic Radiator Valve. No Trap Station Components.
296629	Radiator Trap	Eastview / 1st / 115E	Back Wall Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	216	90	P	Thermostatic Radiator Valve. No Trap Station Components.
296630	Radiator Trap	Eastview / 1st / 115E	Opposite Entrance, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	199	OK	Thermostatic Radiator Valve. No Trap Station Components.
277882	Univent	Eastview / 1st / 117	Univent, 0-5'	TS-A	Spirax Sarco	A125	3/4"	2	213	196	OK	Strainer, Blowdown, Outlet Isolation.
277883	Radiator Trap	Eastview / 1st / 117B (Exam Rm Of Nurses)	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	187	OK	Manual Radiator Valve. No Trap Station Components.
277884	Univent	Eastview / 1st / 118	Right Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	212	190	OK	Inlet Isolation, Outlet Isolation.
277885	Radiator Trap	Eastview / 1st / 118	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	184	OK	DDC Radiator Valve. No Trap Station Components. Steam Trap Leaking Condensate.
277886	Univent	Eastview / 1st / 118	Left Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	1/2"	2	212	179	OK	Inlet Isolation, Outlet Isolation.
277889	Radiator Trap	Eastview / 1st / 119	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	188	OK	DDC Radiator Valve. No Trap Station Components.
277890	Univent	Eastview / 1st / 119	Univent, 0-5'	TS-A	Mepco	2E	3/4"	2	215	198	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
277891	Radiator Trap	Eastview / 1st / 121	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	212	L	DDC Radiator Valve. No Trap Station Components.
277892	Univent	Eastview / 1st / 121	Univent, 0-5'	TS-S	N/A	?	3/4"	2	214	193	OK	No Trap Station Components.
277895	Radiator Trap	Eastview / 1st / 123	Radiator Above Sink, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
277896	Radiator Trap	Eastview / 1st / 123	Radiator Above Oven, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
277897	Radiator Trap	Eastview / 1st / 123	Radiator Above Windows, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
277898	Radiator Trap	Eastview / 1st / 123	Back Bathroom, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
296671	Univent	Eastview / 1st / 124	Next To Entrance, 0-5'	FT	Barnes & Jones	FT2015-3	3/4"	2	212	188	OK	Strainer.
296672	Radiator Trap	Eastview / 1st / 124	Radiator Back Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	180	OK	Thermostatic Radiator Valve. No Trap Station Components.
296673	Radiator Trap	Eastview / 1st / 124	Radiator Back Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
277900	Radiator Trap	Eastview / 1st / 124A	Radiator Above Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	188	OK	Thermostatic Radiator Valve. No Trap Station Components.
296684	Drip Leg	Eastview / 1st / 127. Mac Lab	Drip Against Entrance Wall, 10-15'	TS-A	Barnes & Jones	4326	1"	2	214	187	OK	No Trap Station Components.
296686	Unit Heater	Eastview / 1st / 127. Mac Lab	Back Unit Heater, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	2	215	170	OK	Strainer, Outlet Isolation.
296687	Radiator Trap	Eastview / 1st / 127. Mac Lab	Back Corner Radiator, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	213	170	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Broken Off
296885	Unit Heater	Eastview / 1st / 127. Mac Lab	Forward Unit Heater, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	2	215	180	OK	Strainer, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296888	Heat Exchanger	Eastview / 1st / 127. Mac Lab	HEX Above Exit Door, 10-15'	FT	Barnes & Jones	FT2015-4	1"	2	211	171	OK	No Trap Station Components.
296889	Radiator Trap	Eastview / 1st / 127. Mac Lab	Radiator Across From Entrance, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
296674	Radiator Trap	Eastview / 1st / 128	Radiator Up Above Between Windows, 5-10'	TS-A	Barnes & Jones	1998	3/4"	2	214	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
296675	Drip Leg	Eastview / 1st / 128	Right Wall Near Closet, 5-10'	TS-A	Warren Webster	N05	1 1/4"	2	216	193	OK	No Trap Station Components.
296676	Drip Leg	Eastview / 1st / 128	In Front Of Entrance, 10-15'	FT	Hoffman	FT15	1"	2	216	180	OK	Inlet Isolation, Strainer, Outlet Isolation.
296690	Radiator Trap	Eastview / 1st / 130	In Front Of Roll Up Door, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	213	189	OK	DDC Radiator Valve. No Trap Station Components.
296678	Univent	Eastview / 1st / 131	Univent Above Sink, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	2	215	177	OK	Strainer.
296679	Radiator Trap	Eastview / 1st / 131	Radiator Trap Above Sink, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	214	212	L	Manual Radiator Valve. No Trap Station Components.
296680	Radiator Trap	Eastview / 1st / 131	Radiator Opposite Entrance, 10-15'	TS-A	Barnes & Jones	1929	3/4"	2	216	187	OK	DDC Radiator Valve. No Trap Station Components.
296777	Drip Leg	Eastview / 1st / 131	Drip Behind Sink, 10-15'	TS-A	Barnes & Jones	1721	1"	2	216	195	OK	No Trap Station Components.
296682	Unit Heater	Eastview / 1st / 135	Unit Heater In Back Corner, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	220	168	OK	Inlet Isolation, Outlet Isolation.
296881	Radiator Trap	Eastview / 1st / 135	Radiator Trap Against Right Window, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	214	185	OK	DDC Radiator Valve. No Trap Station Components.
296883	Radiator Trap	Eastview / 1st / 135	Radiator Against Back Windows, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	216	197	L	DDC Radiator Valve. No Trap Station Components.
296613	Radiator Trap	Eastview / 1st / Auditorium	North Wall 1st Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	180	OK	Thermostatic Radiator Valve. No Trap Station Components.
296614	Radiator Trap	Eastview / 1st / Auditorium	North Side 2nd Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	200	100	P	Thermostatic Radiator Valve. No Trap Station Components.
296615	Radiator Trap	Eastview / 1st / Auditorium	North Side Last Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	177	OK	Thermostatic Radiator Valve. No Trap Station Components.
296616	Radiator Trap	Eastview / 1st / Auditorium	North Side Wall Opposite Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
296617	Radiator Trap	Eastview / 1st / Auditorium	South Wall Opposite Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	160	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296618	Radiator Trap	Eastview / 1st / Auditorium	South Wall Third Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	215	212	L	Thermostatic Radiator Valve. No Trap Station Components.
296619	Radiator Trap	Eastview / 1st / Auditorium	South Wall First Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
296620	Radiator Trap	Eastview / 1st / Auditorium	South Wall 2nd Radiator From Stage, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	165	OK	Thermostatic Radiator Valve. No Trap Station Components.
291968	Radiator Trap	Eastview / 1st / Boys Bathroom Across From 130	Above Back Window, Above Ceiling	TS-A	Spirax Sarco	125	3/4"	3	215	189	OK	DDC Radiator Valve. No Trap Station Components.
291969	Radiator Trap	Eastview / 1st / Boys Bathroom Across From 130	Above Middle Urinal, Above Ceiling	TS-A	Barnes & Jones	1721	1/2"	3	214	190	OK	DDC Radiator Valve. No Trap Station Components.
277858	Radiator Trap	Eastview / 1st / Boys Bathroom Next To 104	Last Stall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	211	184	OK	DDC Radiator Valve. No Trap Station Components.
296639	Radiator Trap	Eastview / 1st / Entrance 1 Vestibule	Right Side Upon Enterint, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	202	OK	Thermostatic Radiator Valve. No Trap Station Components.
296640	Radiator Trap	Eastview / 1st / Entrance 1 Vestibule	Left Side Upon Entering, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	224	187	OK	Thermostatic Radiator Valve. No Trap Station Components.
296641	Radiator Trap	Eastview / 1st / Entrance 3 Vestibule	Radiator Opposite Entrance, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
296642	Radiator Trap	Eastview / 1st / Entrance 3 Vestibule	Right Side Upon Entrance, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	212	L	Thermostatic Radiator Valve. No Trap Station Components.
296643	Radiator Trap	Eastview / 1st / Entrance 3 Vestibule	Left Side Upon Entrance, 0-5'	TS-A	Barnes & Jones	1731	1/2"	2	213	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
291971	Radiator Trap	Eastview / 1st / Girls Bathroom Next To 100E	Above Window Ceiling Tile, Above Ceiling	TS-A	Barnes & Jones	125	3/4"	3	215	180	OK	DDC Radiator Valve. No Trap Station Components.
277887	Radiator Trap	Eastview / 1st / Hallway	Across From 121, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	210	173	OK	Thermostatic Radiator Valve. No Trap Station Components.
277854	Radiator Trap	Eastview / 1st / Hallway	Outside 101, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	210	182	OK	Thermostatic Radiator Valve. No Trap Station Components.
277855	Radiator Trap	Eastview / 1st / Hallway	Stairwell By 101, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	96	132	P	Thermostatic Radiator Valve. No Trap Station Components.
277859	Radiator Trap	Eastview / 1st / Hallway	Across From It 100A, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	206	164	OK	Thermostatic Radiator Valve. No Trap Station Components.
277867	Radiator Trap	Eastview / 1st / Hallway	Across From 110, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	200	172	OK	Thermostatic Radiator Valve. No Trap Station Components.
277873	Radiator Trap	Eastview / 1st / Hallway	Outside 112, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	210	172	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
277899	Radiator Trap	Eastview / 1st / Hallway	Outside 124, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	210	177	OK	Thermostatic Radiator Valve. No Trap Station Components.
296644	Radiator Trap	Eastview / 1st / Hallway	Stairwell By 107, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	187	164	OK	Thermostatic Radiator Valve. No Trap Station Components.
296623	Radiator Trap	Eastview / 1st / Main Entrance To Auditorium	Left Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	199	OK	Thermostatic Radiator Valve. No Trap Station Components.
296624	Radiator Trap	Eastview / 1st / Main Entrance To Auditorium	Middle Right Column, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	189	OK	Thermostatic Radiator Valve. No Trap Station Components.
296625	Radiator Trap	Eastview / 1st / Main Entrance To Auditorium	Middle Left Column, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	188	OK	Thermostatic Radiator Valve. No Trap Station Components.
296626	Radiator Trap	Eastview / 1st / Main Entrance To Auditorium	Left Side, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	190	OK	Thermostatic Radiator Valve. No Trap Station Components.
277879	Radiator Trap	Eastview / 1st / Main Office 116	Back Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	178	OK	DDC Radiator Valve. No Trap Station Components.
277876	Radiator Trap	Eastview / 1st / Main Office 116A	Radiator On Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	178	OK	DDC Radiator Valve. No Trap Station Components.
277877	Radiator Trap	Eastview / 1st / Main Office 116A	Radiator On Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	187	OK	DDC Radiator Valve. No Trap Station Components.
277878	Radiator Trap	Eastview / 1st / Main Office 116E	On Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	192	OK	DDC Radiator Valve. No Trap Station Components.
277881	Radiator Trap	Eastview / 1st / Main Office 116J	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	293	OK	DDC Radiator Valve. No Trap Station Components.
277880	Radiator Trap	Eastview / 1st / Main Office Copy Rm	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	193	OK	DDC Radiator Valve. No Trap Station Components.
291970	Radiator Trap	Eastview / 1st / Rm123 Bathroom	Above Radiator Ceiling Tiles, Above Ceiling	TS-A	Spirax Sarco	125	1/2"	3	215	197	OK	DDC Radiator Valve. No Trap Station Components.
296698	Univent	Eastview / 2nd / 201 Boys Locker	Back Wall, Above Ceiling	TS-S	Hoffman	8C	3/4"	2	211	182	OK	Outlet Isolation.
296697	Univent	Eastview / 2nd / 202 Girls Locker	Back Wall, 5-10'	TS-S	Spirax Sarco	RTH-125	3/4"	2	210	174	OK	No Trap Station Components.
296691	Radiator Trap	Eastview / 2nd / 203	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	209	<b>B</b>	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296692	Univent	Eastview / 2nd / 203	Univent, 0-5'	TS-S	Armstrong	20	3/4"	2	84	84	P	No Trap Station Components.
296693	Radiator Trap	Eastview / 2nd / 203	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	215	208	B	DDC Radiator Valve. No Trap Station Components.
296694	Radiator Trap	Eastview / 2nd / 203	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	210	B	DDC Radiator Valve. No Trap Station Components.
296695	Radiator Trap	Eastview / 2nd / 204	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	78	78	P	DDC Radiator Valve. No Trap Station Components.
296696	Univent	Eastview / 2nd / 204	Univent, 0-5'	TS-S	Mepco	2E	3/4"	2	213	200	OK	No Trap Station Components.
291803	Univent	Eastview / 2nd / 205	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	211	191	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296699	Radiator Trap	Eastview / 2nd / 206A Gym Office	Below Window, 0-5'	TS-S	N/A	NA	1/2"	2	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. No Trap Found.
296700	Radiator Trap	Eastview / 2nd / 206B Gym Storage	Below Window, 0-5'	TS-S	N/A	NA	1/2"	2	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. Unable To Find Trap.
291804	Univent	Eastview / 2nd / 207	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	213	184	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291805	Radiator Trap	Eastview / 2nd / 207	Radiator, 0-5'	TS-A	Barnes & Jones	1998	1/2"	2	215	208	L	DDC Radiator Valve. No Trap Station Components.
291806	Univent	Eastview / 2nd / 209	Univent, 0-5'	TS-S	Armstrong	TS-3	3/4"	2	210	178	OK	No Trap Station Components.
291807	Radiator Trap	Eastview / 2nd / 209	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	173	OK	DDC Radiator Valve. No Trap Station Components.
291810	Univent	Eastview / 2nd / 211	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	84	84	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. See Pics .Steam Trap Leaking Steam And Condensate.
291811	Radiator Trap	Eastview / 2nd / 211	Right Radiator, 0-5'	TS-A	Hoffman	8C	3/4"	2	213	186	OK	DDC Radiator Valve. No Trap Station Components.
291812	Radiator Trap	Eastview / 2nd / 211	Left Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	198	OK	DDC Radiator Valve. No Trap Station Components.
291813	Univent	Eastview / 2nd / 212	Univent, 0-5'	TS-S	Mepco	2E	3/4"	2	213	189	OK	No Trap Station Components.
291814	Radiator Trap	Eastview / 2nd / 212	Radiator, 0-5'	TS-A	Barnes & Jones	134	3/4"	2	213	207	L	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291817	Univent	Eastview / 2nd / 213	Univent, 0-5'	TS-S	Mepco	2E	3/4"	2	211	173	OK	No Trap Station Components.
291818	Radiator Trap	Eastview / 2nd / 213	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	185	OK	DDC Radiator Valve. No Trap Station Components.
291815	Univent	Eastview / 2nd / 214	Univent, 0-5'	TS-S	Illinois	3GH	3/4"	2	211	179	OK	No Trap Station Components.
291816	Radiator Trap	Eastview / 2nd / 214	Radiator, 0-5'	TS-S	Watts	3GH	3/4"	2	130	94	P	DDC Radiator Valve. No Trap Station Components.
291820	Univent	Eastview / 2nd / 215	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	198	164	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291821	Radiator Trap	Eastview / 2nd / 215	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	179	OK	DDC Radiator Valve. No Trap Station Components.
291822	Univent	Eastview / 2nd / 217 Library	Left Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	212	189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Univent coil Leaking Steam And Condensate.
291823	Radiator Trap	Eastview / 2nd / 217 Library	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	87	87	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling.
291824	Univent	Eastview / 2nd / 217 Library	Right Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	211	178	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291825	Radiator Trap	Eastview / 2nd / 217 Library Office	Below Window, 0-5'	TS-A	Hoffman	17C	1/2"	2	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. File Cabinet.
291826	Univent	Eastview / 2nd / 218	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	214	207	L	No Trap Station Components.
291831	Radiator Trap	Eastview / 2nd / 219	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	209	B	DDC Radiator Valve. No Trap Station Components.
291832	Radiator Trap	Eastview / 2nd / 219	Right Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	193	OK	Thermostatic Radiator Valve. No Trap Station Components.
291833	Univent	Eastview / 2nd / 219	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	210	177	OK	No Trap Station Components.
291828	Univent	Eastview / 2nd / 220	Univent, 0-5'	TS-S	Illinois	3GH	3/4"	2	211	184	OK	No Trap Station Components. Steam Trap Leaking Condensate.
291829	Radiator Trap	Eastview / 2nd / 220	Right Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	207	L	DDC Radiator Valve. No Trap Station Components.
292830	Radiator Trap	Eastview / 2nd / 220	Left Radiator, 0-5'	TS-A	Barnes & Jones	122	1/2"	2	211	188	OK	Manual Radiator Valve. No Trap Station Components. Manual Valve Radiator Valve Leaking By

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
291839	Radiator Trap	Eastview / 2nd / 221	Radiator, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	211	179	OK	DDC Radiator Valve. No Trap Station Components.
291840	Univent	Eastview / 2nd / 221	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	176	OK	No Trap Station Components.
291837	Radiator Trap	Eastview / 2nd / 221B	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	211	199	OK	Thermostatic Radiator Valve. No Trap Station Components.
291834	Univent	Eastview / 2nd / 222	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	88	88	P	No Trap Station Components.
291835	Radiator Trap	Eastview / 2nd / 222	Right Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	198	OK	DDC Radiator Valve. No Trap Station Components.
291836	Radiator Trap	Eastview / 2nd / 222	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	206	L	Manual Radiator Valve. No Trap Station Components. Manual Valve Radiator Valve Leaking By
291841	Radiator Trap	Eastview / 2nd / 223	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	210	176	OK	Thermostatic Radiator Valve. No Trap Station Components.
291842	Radiator Trap	Eastview / 2nd / 223	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	183	OK	Thermostatic Radiator Valve. No Trap Station Components.
291843	Radiator Trap	Eastview / 2nd / 223	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	81	81	P	Thermostatic Radiator Valve. No Trap Station Components.
291845	Radiator Trap	Eastview / 2nd / 224	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	194	OK	DDC Radiator Valve. No Trap Station Components.
291846	Radiator Trap	Eastview / 2nd / 224	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	212	192	OK	DDC Radiator Valve. No Trap Station Components.
291847	Radiator Trap	Eastview / 2nd / 224	Closet, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	208	L	Manual Radiator Valve. No Trap Station Components. Manual Valve Radiator Valve Leaking By
291850	Radiator Trap	Eastview / 2nd / 225	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	216	198	OK	DDC Radiator Valve. No Trap Station Components.
291851	Radiator Trap	Eastview / 2nd / 225	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	216	209	B	DDC Radiator Valve. No Trap Station Components.
291848	Radiator Trap	Eastview / 2nd / 226	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	208	B	DDC Radiator Valve. No Trap Station Components.
291853	Radiator Trap	Eastview / 2nd / 227B	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	206	L	DDC Radiator Valve. No Trap Station Components.
291852	Radiator Trap	Eastview / 2nd / 228	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	192	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291854	Radiator Trap	Eastview / 2nd / 229	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	216	209	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
291859	Radiator Trap	Eastview / 2nd / 230	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	207	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
291860	Radiator Trap	Eastview / 2nd / 230	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	199	OK	DDC Radiator Valve. No Trap Station Components.
291861	Radiator Trap	Eastview / 2nd / 230	Right Radiator, 0-5'	TS-A	Hoffman	17C	1/2"	2	92	89	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
291855	Radiator Trap	Eastview / 2nd / 231	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	89	82	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
291856	Radiator Trap	Eastview / 2nd / 231	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	207	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
291863	Radiator Trap	Eastview / 2nd / 233	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	184	OK	DDC Radiator Valve. No Trap Station Components.
291864	Radiator Trap	Eastview / 2nd / 234	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	207	<b>L</b>	DDC Radiator Valve. No Trap Station Components.
291865	Radiator Trap	Eastview / 2nd / 235	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	196	OK	DDC Radiator Valve. No Trap Station Components.
291866	Radiator Trap	Eastview / 2nd / 235	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	198	OK	DDC Radiator Valve. No Trap Station Components.
291867	Radiator Trap	Eastview / 2nd / 235	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	186	OK	DDC Radiator Valve. No Trap Station Components.
291270	Radiator Trap	Eastview / 2nd / 236	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	209	<b>B</b>	DDC Radiator Valve. No Trap Station Components.
291871	Radiator Trap	Eastview / 2nd / 236	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	193	OK	DDC Radiator Valve. No Trap Station Components.
291872	Radiator Trap	Eastview / 2nd / 236	Left Radiator, 0-5'	TS-A	Barnes & Jones	1998	1/2"	2	213	198	OK	DDC Radiator Valve. No Trap Station Components.
291967	Radiator Trap	Eastview / 2nd / Boys Bathroom Across From 230	Above Back Ceiling Tile, Above Ceiling	TS-A	N/A	N/A	3/4"	3	NA	NA	NA	DDC Radiator Valve. No Trap Station Components. They Built A Wall Around .
291808	Radiator Trap	Eastview / 2nd / Girls Bathroom Across From Gym	Below Window, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	190	OK	DDC Radiator Valve. Inlet Isolation.
291801	Radiator Trap	Eastview / 2nd / Hallway	Across From 203, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	200	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Open

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291802	Radiator Trap	Eastview / 2nd / Hallway	Across From 207, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	78	78	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling.
291809	Radiator Trap	Eastview / 2nd / Hallway	Across From 211, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	211	186	OK	Thermostatic Radiator Valve. No Trap Station Components.
291819	Radiator Trap	Eastview / 2nd / Hallway	Outside 215, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	211	189	OK	Thermostatic Radiator Valve. No Trap Station Components.
291827	Radiator Trap	Eastview / 2nd / Hallway	Outside 218, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	84	84	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
291838	Radiator Trap	Eastview / 2nd / Hallway	Across From 221, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	78	78	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling. Thermostatic Valve Stuck Closed
291844	Radiator Trap	Eastview / 2nd / Hallway	Stairwell By 224, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	134	83	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components.
291857	Radiator Trap	Eastview / 2nd / Hallway	Across From 229 Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	189	OK	Thermostatic Radiator Valve. No Trap Station Components.
291858	Radiator Trap	Eastview / 2nd / Hallway	Across From 229 Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	91	89	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components.
291868	Radiator Trap	Eastview / 2nd / Hallway	Stairwell F Left, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	195	OK	Thermostatic Radiator Valve. No Trap Station Components.
291869	Radiator Trap	Eastview / 2nd / Hallway	Stairwell F Right, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	207	<b>L</b>	Thermostatic Radiator Valve. No Trap Station Components.
291874	Radiator Trap	Eastview / 3rd / 301	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	99	98	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out, Not Calling. Inlet Isolation Leaking Condensate. Manual Valve Stuck Closed
291875	Radiator Trap	Eastview / 3rd / 301	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	194	OK	DDC Radiator Valve. No Trap Station Components.
291876	Univent	Eastview / 3rd / 301	Univent, 0-5'	FT	Spirax Sarco	FT15	1"	2	214	191	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291877	Radiator Trap	Eastview / 3rd / 301	Opposite Wall Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	96	96	NIS	DDC Radiator Valve. No Trap Station Components. Not Calling.
291879	Radiator Trap	Eastview / 3rd / 302	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	186	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291880	Univent	Eastview / 3rd / 302	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	210	179	OK	Outlet Isolation.
291881	Radiator Trap	Eastview / 3rd / 302	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	89	89	P	DDC Radiator Valve. No Trap Station Components.
291878	Univent	Eastview / 3rd / 303	Left Of Univent, 0-5'	FT	Spirax Sarco	FT15	1"	2	213	200	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291883	Univent	Eastview / 3rd / 304	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	213	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291884	Radiator Trap	Eastview / 3rd / 304	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	210	B	DDC Radiator Valve. No Trap Station Components.
291885	Univent	Eastview / 3rd / 305	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	214	198	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291886	Univent	Eastview / 3rd / 306	Univent, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	210	179	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291887	Radiator Trap	Eastview / 3rd / 306	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	209	B	DDC Radiator Valve. No Trap Station Components.
291888	Drip Leg	Eastview / 3rd / 307 Bathroom	Below Window, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	214	188	OK	No Trap Station Components.
291889	Radiator Trap	Eastview / 3rd / 307 Bathroom	Radiator, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	184	OK	DDC Radiator Valve. No Trap Station Components.
291892	Radiator Trap	Eastview / 3rd / 309	Radiator, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	215	181	OK	DDC Radiator Valve. No Trap Station Components.
291893	Univent	Eastview / 3rd / 309	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	191	OK	Inlet Isolation, Strainer, Outlet Isolation.
291896	Radiator Trap	Eastview / 3rd / 310	Radiator, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	177	OK	DDC Radiator Valve. No Trap Station Components.
291895	Univent	Eastview / 3rd / 310	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	199	OK	Inlet Isolation, Outlet Isolation.
291899	Univent	Eastview / 3rd / 312	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	210	178	OK	Inlet Isolation, Outlet Isolation.
291898	Univent	Eastview / 3rd / 313	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	189	OK	Inlet Isolation, Outlet Isolation.
291901	Radiator Trap	Eastview / 3rd / 314	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	182	OK	DDC Radiator Valve. No Trap Station Components.
291902	Univent	Eastview / 3rd / 314	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	186	OK	Inlet Isolation, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291900	Univent	Eastview / 3rd / 315	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	183	OK	Inlet Isolation, Outlet Isolation.
291962	Radiator Trap	Eastview / 3rd / 315	Above Entrance, Above Ceiling	TS-A	Barnes & Jones	125	3/4"	3	215	187	OK	DDC Radiator Valve. No Trap Station Components.
291963	Radiator Trap	Eastview / 3rd / 315	Above Ceiling Tile Between Two Entrances, Above Ceiling	TS-A	Spirax Sarco	125	3/4"	3	200	89	P	DDC Radiator Valve. No Trap Station Components.
291964	Radiator Trap	Eastview / 3rd / 315	Back Corner Left Of Univent, Above Ceiling	TS-A	Spirax Sarco	125	3/4"	3	80	80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
291903	Radiator Trap	Eastview / 3rd / 316	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	188	OK	DDC Radiator Valve. No Trap Station Components.
291904	Univent	Eastview / 3rd / 316	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	214	178	OK	Inlet Isolation, Outlet Isolation.
291907	Univent	Eastview / 3rd / 317	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	211	176	OK	Inlet Isolation, Outlet Isolation.
291908	Univent	Eastview / 3rd / 318	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	184	OK	Inlet Isolation, Outlet Isolation.
291891	Radiator Trap	Eastview / 3rd / Girls Bathroom By 308	Below Window, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	194	OK	DDC Radiator Valve. No Trap Station Components.
291873	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Outside 302, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	94	89	P	Thermostatic Radiator Valve. No Trap Station Components.
291882	Radiator Trap	Eastview / 3rd / Hallway	Outside 303, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	188	OK	Thermostatic Radiator Valve. No Trap Station Components.
291890	Radiator Trap	Eastview / 3rd / Hallway	Across From 308, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	179	OK	Thermostatic Radiator Valve. No Trap Station Components.
291897	Radiator Trap	Eastview / 3rd / Hallway	Across From 312, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	214	193	OK	Thermostatic Radiator Valve. No Trap Station Components.
291905	Radiator Trap	Eastview / 3rd / Hallway	Outside 316, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	188	OK	Thermostatic Radiator Valve. No Trap Station Components.
291906	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Across From 316, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	87	86	P	Thermostatic Radiator Valve. No Trap Station Components.
291909	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Across From 319, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	206	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Leaking From Valve Body

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
292894	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Outside 309, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	91	91	<b>P</b>	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Stuck Closed
291949	Radiator Trap	Eastview / 4th / Cafeteria	1st Radiator West Side, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	212	189	OK	DDC Radiator Valve. No Trap Station Components.
291950	Radiator Trap	Eastview / 4th / Cafeteria	West Side 2nd Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	212	188	OK	DDC Radiator Valve. No Trap Station Components.
291951	Radiator Trap	Eastview / 4th / Cafeteria	Back Wall Southwest Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	213	199	OK	DDC Radiator Valve. No Trap Station Components.
291952	Radiator Trap	Eastview / 4th / Cafeteria	Second Radiator From Southwest Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	214	188	OK	DDC Radiator Valve. No Trap Station Components.
291953	Radiator Trap	Eastview / 4th / Cafeteria	3rd Radiator From Southwest Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	80	80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
291954	Radiator Trap	Eastview / 4th / Cafeteria	4th Radiator From Southwest Corner (Middle Of Wall), 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	214	199	NIS	DDC Radiator Valve. No Trap Station Components. Not Calling.
291955	Radiator Trap	Eastview / 4th / Cafeteria	2nd Radiator From Southeast Corner, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	180	80	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
291956	Radiator Trap	Eastview / 4th / Cafeteria	South Wall In Corner Southeast Corner, 0-5'	TS-A	Barnes & Jones	1929	3/4"	3	215	189	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
291957	Radiator Trap	Eastview / 4th / Cafeteria	2nd Radiator Against Southeast Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	215	180	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
291958	Radiator Trap	Eastview / 4th / Cafeteria	1st Radiator Against Southeast Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	3	160	80	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
291959	Drip Leg	Eastview / 4th / Cafeteria/Kitchen	Above Deep Sink, 10-15'	TS-A	Barnes & Jones	1721	1/2"	3	214	198	OK	No Trap Station Components.
291960	Radiator Trap	Eastview / 4th / Southeast Stairwell	On Platform, 10-15'	TS-A	Barnes & Jones	1721	3/4"	3	200	90	<b>P</b>	DDC Radiator Valve. No Trap Station Components.
27768	Air Handling Unit	Eastview / Basement / Boiler Rm	Small Condensate Pump Next To AHU, 0-5'	FT	Spirax Sarco	FT15	1 1/4"	2	80	80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
27769	Drip Leg	Eastview / Basement / Boiler Rm	Small Condensate Pump Next To AHU, 0-5'	FT	Spirax Sarco	FT15	3/4"	2	214	189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
277761	Drip Leg	Eastview / Basement / Boiler Rm	Next To Boiler 1, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	2	213	200	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
277763	Drip Leg	Eastview / Basement / Boiler Rm	Above Boiler 1 Under Steam Header, 10-15'	FT	Barnes & Jones	FT2015-4	1"	2	NA	NA	NA	Inlet Isolation, Strainer, Blowdown. Will Require Staging To Access .

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
277764	Drip Leg	Eastview / Basement / Boiler Rm	Above Boiler 2 Under Steam Main, Above 15'	FT	Barnes & Jones	FT2015-4	1"	2	NA	NA	NA	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Will Require Staging To Access.
277765	Drip Leg	Eastview / Basement / Boiler Rm	Front Of Boiler 2 Next To Exit Staircase, Above 15'	TS-A	Barnes & Jones	1998	3/4"	2	212	187	OK	No Trap Station Components.
277767	Drip Leg	Eastview / Basement / Boiler Rm	Above AHU, Above 15'	TS-A	Barnes & Jones	1998	3/4"	2	215	189	OK	No Trap Station Components.
296608	Drip Leg	Eastview / Basement / Boiler Rm	By Large Condensate Tank In Front Of Spiral Staircase, Above 15'	TS-A	N/A	NA	1"	2	138	90	P	No Trap Station Components. Dirt Leg Plugged.
296609	Drip Leg	Eastview / Basement / Boiler Rm	Above Large Condensate Tank, Above 15'	TS-A	N/A	N/A	3/4"	2	NA	NA	NA	No Trap Station Components. Will Require Staging To Access.
296610	Drip Leg	Eastview / Basement / Girls Rm Below Auditorium Stairs	In Right Corner Above Stalls, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	213	213	L	No Trap Station Components.
296612	Radiator Trap	Eastview / Basement / Girls Rm Below Auditorium Stairs	Radiator Up Above, 5-10'	TS-A	Barnes & Jones	1712	1/2"	2	220	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
277779	Drip Leg	Eastview / Basement / Staff Break Rm	Back Corner Behind Cabinets, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	215	198	OK	No Trap Station Components.
27778	Drip Leg	Eastview / Basement / Staff Break Rm	Back Corner Behind Cabinets, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	214	212	L	No Trap Station Components.
277781	Drip Leg	Eastview / Basement / Staff Break Rm	Front Right Corner Above Flammable Storage, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	214	192	OK	No Trap Station Components.
277790	Drip Leg	Eastview / Basement / Staff Break Rm	By Middle Window, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	215	194	OK	No Trap Station Components.
277791	Drip Leg	Eastview / Basement / Storage Rm 020	Front Left Corner, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	216	187	OK	No Trap Station Components.
277792	Drip Leg	Eastview / Basement / Storage Rm 020	By Wood Door In Back Corner, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	214	193	OK	No Trap Station Components.
277793	Radiator Trap	Eastview / Basement / Storage Rm 020	Left Radiator Up Above, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
277794	Drip Leg	Eastview / Basement / Storage Rm 020	Drip Against Back Wall, 10-15'	TS-A	Barnes & Jones	1929	3/4"	2	214	198	OK	No Trap Station Components.
277795	Radiator Trap	Eastview / Basement / Storage Rm 020	Right Radiator Up Above, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	215	198	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
277796	Drip Leg	Eastview / Basement / Storage Rm 020	Back Right Corner Opposite Wooden Door, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	215	176	OK	No Trap Station Components.
277797	Drip Leg	Eastview / Basement / Storage Rm 020	Back Right Corner Opposite Wooden Door, 10-15'	TS-A	Spirax Sarco	A125	3/4"	2	215	187	OK	Outlet Isolation.
277798	Drip Leg	Eastview / Basement / Storage Rm 020	Back Right Corner Opposite Wooden Door, 10-15'	TS-A	Barnes & Jones	1721	1/2"	2	216	198	OK	No Trap Station Components.
296655	Radiator Trap	Eastview / Basement / 007 Weight Rm	In Front Of Lockers, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	211	171	OK	Thermostatic Radiator Valve. No Trap Station Components.
296656	Drip Leg	Eastview / Basement / 007 Weight Rm	Left Of Lockers, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	213	209	B	No Trap Station Components.
296657	Drip Leg	Eastview / Basement / 007 Weight Rm	In Front Of Fire Pull, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	211	200	OK	No Trap Station Components. Outlet Union Leaking Condensate.
296658	Radiator Trap	Eastview / Basement / 007 Weight Rm	Center Of Rm, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	95	175	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling. Thermostatic Valve Stuck Closed
296659	Radiator Trap	Eastview / Basement / 007 Weight Rm	Right Far Wall, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	84	84	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling.
296660	Drip Leg	Eastview / Basement / 007 Weight Rm	Right Of Emergency Window, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	210	197	OK	No Trap Station Components.
296661	Drip Leg	Eastview / Basement / 007 Weight Rm	In Front Of Emergency Window, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	213	209	B	No Trap Station Components.
296662	Drip Leg	Eastview / Basement / 007 Weight Rm	Left Corner, 5-10'	TS-A	Barnes & Jones	147	1"	2	213	202	OK	No Trap Station Components.
296663	Radiator Trap	Eastview / Basement / 007 Weight Rm	Left Corner, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	199	161	OK	Thermostatic Radiator Valve. No Trap Station Components.
296664	Radiator Trap	Eastview / Basement / 007 Weight Rm Exit	In Front Of Exit, 5-10'	TS-A	Barnes & Jones	122	1/2"	2	211	178	OK	Thermostatic Radiator Valve. No Trap Station Components.
296665	Drip Leg	Eastview / Basement / 007 Weight Rm Storage	Right Corner, 5-10'	TS-A	Barnes & Jones	134	3/4"	2	213	208	L	No Trap Station Components.
296666	Radiator Trap	Eastview / Basement / 007 Weight Rm Storage	Back Wall, 5-10'	TS-A	Barnes & Jones	122	1/2"	2	211	169	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296667	Drip Leg	Eastview / Basement / 007 Weight Rm Storage	Back Wall, 5-10'	TS-A	Barnes & Jones	133	3/4"	2	213	194	OK	No Trap Station Components.
296668	Radiator Trap	Eastview / Basement / 007 Weight Rm Storage	Left Wall, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	210	173	OK	Thermostatic Radiator Valve. No Trap Station Components.
277783	Drip Leg	Eastview / Basement / 017	Right Wall, 5-10'	TS-A	Barnes & Jones	134	3/4"	2	212	200	OK	No Trap Station Components.
277786	Radiator Trap	Eastview / Basement / Bathroom	Left Of Door, 5-10'	TS-S	Barnes & Jones	5000	1/2"	2	80	80	P	Thermostatic Radiator Valve. No Trap Station Components.
277787	Drip Leg	Eastview / Basement / Bathroom	Above Sink, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	212	199	OK	No Trap Station Components.
277762	Drip Leg	Eastview / Basement / Boiler Rm	Right Of Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	2	215	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
277766	Drip Leg	Eastview / Basement / Boiler Rm	In Front Of Boiler 1, Above 15'	TS-A	Barnes & Jones	1998	3/4"	2	212	190	OK	No Trap Station Components.
277770	Drip Leg	Eastview / Basement / Boiler Rm	Above AHU, Above 15'	TS-A	Barnes & Jones	134	3/4"	2	213	193	OK	No Trap Station Components.
296653	Radiator Trap	Eastview / Basement / Gym Boys Bathroom	In Front Of Urinals, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	210	168	OK	Thermostatic Radiator Valve. No Trap Station Components.
296654	Drip Leg	Eastview / Basement / Gym Boys Bathroom	In Front Of Stalls, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	140	132	P	No Trap Station Components.
296651	Drip Leg	Eastview / Basement / Gym Girls Bathroom	Above Single Stall, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	213	200	OK	No Trap Station Components.
296652	Radiator Trap	Eastview / Basement / Gym Girls Bathroom	In Front Of Single Stall, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	211	182	OK	Thermostatic Radiator Valve. No Trap Station Components.
296648	Drip Leg	Eastview / Basement / Gym Office	Above Entry, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	212	208	L	No Trap Station Components.
296649	Radiator Trap	Eastview / Basement / Gym Office	In Front Of Bathroom Door, 5-10'	TS-A	Barnes & Jones	1821	1/2"	2	100	100	P	Thermostatic Radiator Valve. No Trap Station Components.
296650	Radiator Trap	Eastview / Basement / Gym Office	Bathroom, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	212	189	OK	Thermostatic Radiator Valve. No Trap Station Components.
277799	Radiator Trap	Eastview / Basement / Hallway	In Front Of Exit, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	212	186	OK	Thermostatic Radiator Valve. No Trap Station Components.
277782	Radiator Trap	Eastview / Basement / Light Bulb Rm	Center Of Rm, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	210	167	OK	Thermostatic Radiator Valve. No Trap Station Components.
277784	Radiator Trap	Eastview / Basement / Rm Outside Light Bulbs	Center Of Rm, 5-10'	TS-S	Barnes & Jones	5000	1/2"	2	212	171	OK	Thermostatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296645	Drip Leg	Eastview / Basement / Stair A	Above Left Radiator, 5-10'	FT	Barnes & Jones	FT2015-4	1"	2	213	195	OK	No Trap Station Components.
296646	Radiator Trap	Eastview / Basement / Stair A	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	184	OK	Thermostatic Radiator Valve. No Trap Station Components.
296647	Radiator Trap	Eastview / Basement / Stair A	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	207	L	Thermostatic Radiator Valve. No Trap Station Components.
296669	Radiator Trap	Eastview / Basement / Stair B	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	191	OK	Thermostatic Radiator Valve. No Trap Station Components.
296670	Radiator Trap	Eastview / Basement / Stair B	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	110	173	P	Thermostatic Radiator Valve. No Trap Station Components.
277790	Drip Leg	Eastview / Basement / Storage Below Stage	In Front Of Door To Stage, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	212	199	OK	No Trap Station Components.
277789	Radiator Trap	Eastview / Basement / Storage Below Stage	Center Of Rm, 5-10'	TS-A	Barnes & Jones	1721	1/2"	2	209	163	OK	Thermostatic Radiator Valve. No Trap Station Components.
277788	Drip Leg	Eastview / Basement / Storage Next To Light Bulb	Right Wall, 5-10'	TS-A	Barnes & Jones	1929	3/4"	2	212	202	OK	No Trap Station Components.
277771	Unit Heater	Eastview / Basement / Tank Rm	Above Tank, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	2	213	198	OK	Inlet Isolation, Strainer, Outlet Isolation.
277772	Drip Leg	Eastview / Basement / Tank Rm	FWD Left Of Tank, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	2	215	208	L	Inlet Isolation, Strainer, Outlet Isolation.
277773	Unit Heater	Eastview / Basement / Tank Rm	Above FWD End Of Tank, 10-15'	FT	Barnes & Jones	FT2015-3	3/4"	2	212	200	OK	Inlet Isolation, Strainer, Outlet Isolation.
277774	Drip Leg	Eastview / Basement / Tank Rm	Behind Tank, 10-15'	TS-A	Spirax Sarco	RTA-125	3/4"	2	171	157	OK	Inlet Isolation.
277775	Drip Leg	Eastview / Basement / Tank Rm	Back Wall Center, 5-10'	TS-A	Spirax Sarco	RTA-125	3/4"	2	210	164	OK	Inlet Isolation.
277776	Drip Leg	Eastview / Basement / Tank Rm	Back Wall Right, 5-10'	FT	Barnes & Jones	FT2015-3	3/4"	2	214	197	OK	Inlet Isolation, Strainer, Outlet Isolation.
277777	Drip Leg	Eastview / Basement / Tank Rm	Far Right Corner, 5-10'	TS-A	Spirax Sarco	RTA-125	3/4"	2	212	178	OK	Inlet Isolation.
296635	Air Handling Unit	Eastview / Mezzanine / Auditorium	AHU Rm Above Lights Rm For Auditorium, 0-5'	FT	Spirax Sarco	FT15	2"	2	214	189	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296636	Air Handling Unit	Eastview / Mezzanine / Auditorium	AHU Rm Above Lights Rm For Auditorium, 5-10'	FT	Spirax Sarco	FT15	2"	2	215	199	L	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296637	Air Handling Unit	Eastview / Mezzanine / Auditorium	AHU Rm Above Lights Rm For Auditorium, 5-10'	FT	Spirax Sarco	FT15	2"	2	214	188	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
296638	Air Handling Unit	Eastview / Mezzanine / Auditorium	AHU Rm Above Lights Rm For Auditorium AHU Rm Above Lights Rm For Auditorium, 5-10'	FT	Spirax Sarco	FT15	2"	2	214	199	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
296631	Radiator Trap	Eastview / Upper Level / Auditorium	South Side Upper Seating, 0-5'	TS-A	Hoffman	8C	3/4"	2	215	180	OK	Thermostatic Radiator Valve. No Trap Station Components.
296632	Radiator Trap	Eastview / Upper Level / Auditorium	Girls Bathroom, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out. Thermostatic Valve Stuck Closed
296633	Radiator Trap	Eastview / Upper Level / Auditorium	North Wall Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	212	177	OK	Thermostatic Radiator Valve. No Trap Station Components.
296634	Radiator Trap	Eastview / Upper Level / Auditorium	Boys Bathroom, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	100	P	Thermostatic Radiator Valve. No Trap Station Components.
291965	Radiator Trap	Eastview / 2nd / Boys Bathroom Next To 2001	Above Window, Above Ceiling	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	178	OK	DDC Radiator Valve. Inlet Isolation, Strainer, Outlet Isolation.
291966	Radiator Trap	Eastview / 2nd / Girls Bathroom Next To 221	Above Window, Above Ceiling	TS-A	Spirax Sarco	RTA-125	3/4"	2	215	182	OK	DDC Radiator Valve. Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
291910	Radiator Trap	Eastview / 3rd / 319	Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	78	76	P	DDC Radiator Valve. No Trap Station Components.
291911	Univent	Eastview / 3rd / 319	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	214	186	OK	Inlet Isolation, Outlet Isolation.
291912	Univent	Eastview / 3rd / 320	Right Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	66	66	P	Inlet Isolation, Outlet Isolation.
291913	Radiator Trap	Eastview / 3rd / 320	Right Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	213	184	OK	DDC Radiator Valve. No Trap Station Components.
291914	Univent	Eastview / 3rd / 320	Left Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	212	184	OK	Inlet Isolation, Outlet Isolation.
291915	Radiator Trap	Eastview / 3rd / 320	Left Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	76	76	P	DDC Radiator Valve. No Trap Station Components.
291917	Radiator Trap	Eastview / 3rd / 321	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	195	OK	Thermostatic Radiator Valve. No Trap Station Components.
291918	Radiator Trap	Eastview / 3rd / 321	Right Radiator, 0-5'	TS-A	Barnes & Jones	1929	3/4"	2	215	191	OK	DDC Radiator Valve. No Trap Station Components.
291919	Univent	Eastview / 3rd / 321	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	178	OK	Inlet Isolation, Outlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
291920	Radiator Trap	Eastview / 3rd / 322	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	191	OK	Manual Radiator Valve. No Trap Station Components. Manual Valve Stuck Open
291921	Radiator Trap	Eastview / 3rd / 322	Right Radiator, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	213	194	OK	DDC Radiator Valve. No Trap Station Components.
291922	Univent	Eastview / 3rd / 322	Univent, 0-5'	TS-A	Spirax Sarco	RTA-125	3/4"	2	210	182	OK	Inlet Isolation, Outlet Isolation.
291923	Radiator Trap	Eastview / 3rd / 324	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	182	OK	Thermostatic Radiator Valve. No Trap Station Components.
291924	Radiator Trap	Eastview / 3rd / 324	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	81	80	P	Thermostatic Radiator Valve. No Trap Station Components.
291928	Radiator Trap	Eastview / 3rd / 325	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	186	OK	Thermostatic Radiator Valve. No Trap Station Components.
329327	Radiator Trap	Eastview / 3rd / 325	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	207	L	Thermostatic Radiator Valve. No Trap Station Components.
291931	Radiator Trap	Eastview / 3rd / 3256	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	209	B	DDC Radiator Valve. No Trap Station Components.
291926	Radiator Trap	Eastview / 3rd / 325B	Closet, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	78	78	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out. Manual Valve Stuck Closed
291929	Radiator Trap	Eastview / 3rd / 327	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	189	OK	DDC Radiator Valve. No Trap Station Components.
291930	Radiator Trap	Eastview / 3rd / 327	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	199	OK	DDC Radiator Valve. No Trap Station Components.
291932	Radiator Trap	Eastview / 3rd / 328	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	192	OK	DDC Radiator Valve. No Trap Station Components.
291933	Radiator Trap	Eastview / 3rd / 329	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	189	OK	DDC Radiator Valve. No Trap Station Components.
291934	Radiator Trap	Eastview / 3rd / 329	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	200	OK	DDC Radiator Valve. No Trap Station Components.
291935	Radiator Trap	Eastview / 3rd / 329	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	194	OK	DDC Radiator Valve. No Trap Station Components.
291936	Radiator Trap	Eastview / 3rd / 330	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	197	OK	DDC Radiator Valve. No Trap Station Components.
291937	Radiator Trap	Eastview / 3rd / 331	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	209	B	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
291938	Radiator Trap	Eastview / 3rd / 331	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	202	OK	DDC Radiator Valve. No Trap Station Components.
291939	Radiator Trap	Eastview / 3rd / 333	Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	211	B	DDC Radiator Valve. No Trap Station Components.
291940	Radiator Trap	Eastview / 3rd / 334	Left Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	192	OK	DDC Radiator Valve. No Trap Station Components.
291941	Radiator Trap	Eastview / 3rd / 334	Middle Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	913	OK	DDC Radiator Valve. No Trap Station Components.
291942	Radiator Trap	Eastview / 3rd / 334	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	208	L	DDC Radiator Valve. No Trap Station Components.
291944	Radiator Trap	Eastview / 3rd / 335	Right Radiator, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	207	L	DDC Radiator Valve. No Trap Station Components.
291916	Radiator Trap	Eastview / 3rd / Hallway	Outside 319, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	218	208	L	Thermostatic Radiator Valve. No Trap Station Components.
291925	Radiator Trap	Eastview / 3rd / Hallway	Stairwell At 325, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	215	181	OK	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Leaking From Valve Body
291943	Radiator Trap	Eastview / 3rd / Hallway	Stairwell At 334, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	207	L	Thermostatic Radiator Valve. No Trap Station Components. Thermostatic Valve Radiator Valve Leaking By
291948	Radiator Trap	Eastview / 4th / Cafeteria	1st On Right Wall, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	213	183	OK	DDC Radiator Valve. No Trap Station Components.
291961	Radiator Trap	Eastview / 4th / Cafeteria Office	Below Window, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	214	208	L	DDC Radiator Valve. No Trap Station Components.
291947	Radiator Trap	Eastview / 4th / Stairwell D	Landing, 0-5'	TS-A	Barnes & Jones	1721	1/2"	2	76	76	NIS	Thermostatic Radiator Valve. No Trap Station Components. Not Calling. Thermostatic Valve Stuck Closed
291973	Air Handling Unit	Eastview / Basement / G001 Fan Rm	Upper Gym AHU, 0-5'	FT	Spirax Sarco	FTI-15	1"	2	164	157	OK	Strainer, Blowdown.
291974	Air Handling Unit	Eastview / Basement / G001 Fan Rm	Lower Gym AHU, 0-5'	FT	Spirax Sarco	FTI-15	1"	2	214	199	OK	Strainer, Blowdown.
291945	Air Handling Unit	Eastview / PH / Penthouse	ERU 1, 0-5'	FT	Watts	WFT	2"	2	172	164	OK	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291946	Air Handling Unit	Eastview / PH / Penthouse	ERU 2, 0-5'	FT	Watson McDaniel	WFT	2"	2	167	158	OK	Inlet Isolation, Strainer, Outlet Isolation.
291972	Unit Heater	Locker Room / Ground / Hallway	Outside Boys Bathroom In Locker Rm, Above Ceiling	TS-A	Barnes & Jones	5007	1/2"	3	80	80	NIS	No Trap Station Components. Valved Out.
291998	Drip Leg	Youth Building / Ground / Leadership And Counseling Rm	Against Back Wall Above Ceiling Tile, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	215	200	OK	No Trap Station Components.
255749	Drip Leg	Youth Building / Ground / Computer Rm	Front Right Corner Of Rm, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	214	177	OK	No Trap Station Components.
255752	Radiator Trap	Youth Building / Ground / Computer Rm	Against Left Wall Behind Computers, 0-5'	TS-A	Barnes & Jones	3146	3/4"	3	80	80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
291992	Radiator Trap	Youth Building / Ground / Copy Rm	Radiator On Wall, 0-5'	TS-A	Barnes & Jones	1998	3/4"	3	213	178	OK	Thermostatic Radiator Valve. No Trap Station Components.
291994	Drip Leg	Youth Building / Ground / Copy Rm	In Corner Above Ceiling, 0-5'	TS-A	Barnes & Jones	1998	3/4"	3	215	212	L	No Trap Station Components.
291987	Drip Leg	Youth Building / Ground / Directors Office	Above Desk Middle Of Rm, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	215	189	OK	No Trap Station Components.
291988	Radiator Trap	Youth Building / Ground / Directors Office	Radiator Above Ceiling Against Left Wall, Above Ceiling	TS-A	Barnes & Jones	1908	1/2"	3	215	199	OK	Pneumatic Radiator Valve. No Trap Station Components.
291975	Radiator Trap	Youth Building / Ground / Gym	Radiator Above Southwest Wall, 10-15'	TS-A	Barnes & Jones	1998	1/2"	3	215	180	OK	DDC Radiator Valve. No Trap Station Components.
291976	Drip Leg	Youth Building / Ground / Gym	Southwest Wall Above Window, 10-15'	TS-A	Barnes & Jones	1998	3/4"	3	214	198	OK	No Trap Station Components.
291977	Drip Leg	Youth Building / Ground / Gym	Above Emergency Exit Door, 10-15'	TS-A	Barnes & Jones	1985	3/4"	3	215	214	L	No Trap Station Components.
291978	Radiator Trap	Youth Building / Ground / Gym	Radiator Above Mirrored Back Wall, 10-15'	TS-A	Barnes & Jones	1908	1/2"	3	215	190	OK	DDC Radiator Valve. No Trap Station Components.
291980	Radiator Trap	Youth Building / Ground / Gym	Radiator In Front Of Storage Closet, 10-15'	TS-A	Barnes & Jones	1908	1/2"	3	214	198	OK	DDC Radiator Valve. No Trap Station Components.
291981	Drip Leg	Youth Building / Ground / Gym	In Front Of Storage Closet, 10-15'	TS-A	Barnes & Jones	1998	3/4"	3	214	188	OK	No Trap Station Components.
291982	Radiator Trap	Youth Building / Ground / Gym	In Storage Closet, 10-15'	TS-A	Barnes & Jones	1908	1/2"	3	215	180	OK	DDC Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In	Temp °F Out	Result	Comments
255748	Drip Leg	Youth Building / Ground / Hallway	End Of Hallway Outside Computer Rm, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	214	214	L	No Trap Station Components.
255753	Drip Leg	Youth Building / Ground / Hallway	Storage Closet End Of Hallway By Computer Rm, 5-10'	TS-A	Warren Webster	544	1"	3	216	212	L	No Trap Station Components.
255742	Drip Leg	Youth Building / Ground / Leadership And Counseling Rm	Right Side Of Rm Above Divider Wall, Above Ceiling	TS-A	Warren Webster	N04	3/4"	3	215	180	OK	No Trap Station Components.
291997	Drip Leg	Youth Building / Ground / Leadership And Counseling Rm	Above Left Divider Wall, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	215	190	OK	No Trap Station Components.
291999	Drip Leg	Youth Building / Ground / Leadership And Counseling Rm	Against Back Wall Above Ceiling, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	215	199	OK	No Trap Station Components.
292000	Radiator Trap	Youth Building / Ground / Leadership And Counseling Rm	Radiator Against Back Wall, 0-5'	TS-A	Hoffman	17C	1/2"	3	214	189	OK	Thermostatic Radiator Valve. No Trap Station Components.
255746	Drip Leg	Youth Building / Ground / Staff Lounge	Against Back Wall, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	3	214	187	OK	No Trap Station Components.
255747	Radiator Trap	Youth Building / Ground / Staff Lounge	Radiator On Wall, 0-5'	TS-A	Hoffman	17C	1/2"	3	215	198	OK	Thermostatic Radiator Valve. No Trap Station Components.
291979	Drip Leg	Youth Building / Ground / Water Meter Rm	Back Corner, 10-15'	TS-A	Barnes & Jones	1998	3/4"	3	216	177	OK	No Trap Station Components.
255745	Radiator Trap	Youth Building / Ground / After School Center	Above Printer, Above Ceiling	TS-A	Barnes & Jones	1998	1/2"	2	106	104	P	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Open
291986	Radiator Trap	Youth Building / Ground / Business Assistant	Between Desks, Above Ceiling	TS-A	Warren Webster	513	3/4"	2	98	96	P	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Open
255750	Drip Leg	Youth Building / Ground / Computer Rm	2 Panels From Far Corner, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	2	215	207	L	No Trap Station Components.
255751	Drip Leg	Youth Building / Ground / Computer Rm	Far Right Corner, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	2	215	208	L	No Trap Station Components.
291989	Drip Leg	Youth Building / Ground / Deputy Director	3rd Tile From AC, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	2	213	207	L	No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out		Result	Comments
291990	Radiator Trap	Youth Building / Ground / Deputy Director	End Of Desk, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	2	214	198	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Open
291991	Drip Leg	Youth Building / Ground / Ladder Storage Closet	Left Wall, 5-10'	TS-A	Warren Webster	544	1"	2	216	211	B	No Trap Station Components.
255743	Drip Leg	Youth Building / Ground / Large Conference Rm	Left Of Window, Above Ceiling	TS-A	Warren Webster	533	3/4"	2	216	207	L	No Trap Station Components.
255744	Drip Leg	Youth Building / Ground / Large Conference Rm	Left Of Window, Above Ceiling	TS-A	Warren Webster	513	3/4"	2	215	209	B	No Trap Station Components.
291995	Drip Leg	Youth Building / Ground / Large Conference Rm	Right Of Window, Above Ceiling	TS-A	Warren Webster	513	3/4"	2	216	209	B	No Trap Station Components.
291984	Drip Leg	Youth Building / Ground / Neighborhood Services	Above Desk, Above Ceiling	TS-A	Barnes & Jones	1997	3/4"	2	214	196	OK	No Trap Station Components.
291985	Drip Leg	Youth Building / Ground / Neighborhood Services	Above Ac, Above Ceiling	TS-A	Spirax Sarco	RTA-125	3/4"	2	91	91	P	Outlet Isolation.
291983	Drip Leg	Youth Building / Ground / Reception	Above Fire Extinguisher, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	2	215	193	OK	No Trap Station Components.
291993	Radiator Trap	Youth Building / Ground / Women's Bathroom	Above Soap, Above Ceiling	TS-A	Barnes & Jones	1998	3/4"	2	214	207	L	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Open

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Table 2: Blowing, Leaking, and Plugged Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
277862	Radiator Trap	Eastview / 1st / 107	Radiator Next To Univent, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, System Shutdown Required
277868	Radiator Trap	Eastview / 1st / 110	Radiator On Wall, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, System Shutdown Required
296627	Radiator Trap	Eastview / 1st / 115D	Front Of Entrance, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, System Shutdown Required
296629	Radiator Trap	Eastview / 1st / 115E	Back Wall Under Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Full Trap, System Shutdown Required
277891	Radiator Trap	Eastview / 1st / 121	Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Full Trap, System Shutdown Required
296679	Radiator Trap	Eastview / 1st / 131	Radiator Trap Above Sink, 5-10'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
296883	Radiator Trap	Eastview / 1st / 135	Radiator Against Back Windows, 10-15'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Full Trap, System Shutdown Required
296614	Radiator Trap	Eastview / 1st / Auditorium	North Side 2nd Radiator From Stage, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	P	Full Trap, System Shutdown Required, Will Need Drill To Unscrew About 12 Screws
296618	Radiator Trap	Eastview / 1st / Auditorium	South Wall Third Radiator From Stage, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Full Trap, Difficult Access, System Shutdown Required
296642	Radiator Trap	Eastview / 1st / Entrance 3 Vestibule	Right Side Upon Entrance, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
277855	Radiator Trap	Eastview / 1st / Hallway	Stairwell By 101, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
296691	Radiator Trap	Eastview / 2nd / 203	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
296692	Univent	Eastview / 2nd / 203	Univent, 0-5'	Armstrong	20	Thermostatic Straight	2	3/4"	NPT	P	Full Trap, Difficult Access, Scheduling Issues
296693	Radiator Trap	Eastview / 2nd / 203	Middle Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	B	Repair Kit, Scheduling Issues
296694	Radiator Trap	Eastview / 2nd / 203	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Difficult Access, Scheduling Issues
296695	Radiator Trap	Eastview / 2nd / 204	Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Scheduling Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
291805	Radiator Trap	Eastview / 2nd / 207	Radiator, 0-5'	Barnes & Jones	1998	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291814	Radiator Trap	Eastview / 2nd / 212	Radiator, 0-5'	Barnes & Jones	134	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Scheduling Issues
291816	Radiator Trap	Eastview / 2nd / 214	Radiator, 0-5'	Watts	3GH	Thermostatic Straight	2	3/4"	NPT	P	Full Trap, Difficult Access, Scheduling Issues
291826	Univent	Eastview / 2nd / 218	Univent, 0-5'	Spirax Sarco	RTA-125	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Scheduling Issues
291831	Radiator Trap	Eastview / 2nd / 219	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291829	Radiator Trap	Eastview / 2nd / 220	Right Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Scheduling Issues
291834	Univent	Eastview / 2nd / 222	Univent, 0-5'	Spirax Sarco	RTA-125	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
291836	Radiator Trap	Eastview / 2nd / 222	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291843	Radiator Trap	Eastview / 2nd / 223	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291847	Radiator Trap	Eastview / 2nd / 224	Closet, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291851	Radiator Trap	Eastview / 2nd / 225	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291848	Radiator Trap	Eastview / 2nd / 226	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291853	Radiator Trap	Eastview / 2nd / 227B	Below Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291854	Radiator Trap	Eastview / 2nd / 229	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291859	Radiator Trap	Eastview / 2nd / 230	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
291861	Radiator Trap	Eastview / 2nd / 230	Right Radiator, 0-5'	Hoffman	17C	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291855	Radiator Trap	Eastview / 2nd / 231	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291856	Radiator Trap	Eastview / 2nd / 231	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
291864	Radiator Trap	Eastview / 2nd / 234	Below Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291270	Radiator Trap	Eastview / 2nd / 236	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291827	Radiator Trap	Eastview / 2nd / Hallway	Outside 218, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291844	Radiator Trap	Eastview / 2nd / Hallway	Stairwell By 224, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291858	Radiator Trap	Eastview / 2nd / Hallway	Across From 229 Left, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291869	Radiator Trap	Eastview / 2nd / Hallway	Stairwell F Right, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Difficult Access
291881	Radiator Trap	Eastview / 3rd / 302	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, No Issues
291884	Radiator Trap	Eastview / 3rd / 304	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291887	Radiator Trap	Eastview / 3rd / 306	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, No Issues
291963	Radiator Trap	Eastview / 3rd / 315	Above Ceiling Tile Between Two Entrances, Above Ceiling	Spirax Sarco	125	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, System Shutdown Required
291873	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Outside 302, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, No Issues
291906	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Across From 316, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, No Issues
291909	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Across From 319, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
292894	Radiator Trap	Eastview / 3rd / Hallway	Stairwell Outside 309, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, No Issues
291955	Radiator Trap	Eastview / 4th / Cafeteria	2nd Radiator From Southeast Corner, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, System Shutdown Required
291956	Radiator Trap	Eastview / 4th / Cafeteria	South Wall In Corner Southeast Corner, 0-5'	Barnes & Jones	1929	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, System Shutdown Required
291957	Radiator Trap	Eastview / 4th / Cafeteria	2nd Radiator Against Southeast Wall, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, System Shutdown Required
291958	Radiator Trap	Eastview / 4th / Cafeteria	1st Radiator Against Southeast Wall, 0-5'	Barnes & Jones	1721	Thermostatic Angle	3	1/2"	NPT	P	Repair Kit, System Shutdown Required

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
291960	Radiator Trap	Eastview / 4th / Southeast Stairwell	On Platform, 10-15'	Barnes & Jones	1721	Thermostatic Angle	3	3/4"	NPT	P	Repair Kit, No Issues
296608	Drip Leg	Eastview / Basement / Boiler Rm	By Large Condensate Tank In Front Of Spiral Staircase, Above 15'	N/A	NA	Thermostatic Angle	2	1"	NPT	P	Full Trap, Lift Required, Difficult Access, System Shutdown Required, May Require Scaffolding As Lift Will Be Difficult To Get Down To Boiler Room
296610	Drip Leg	Eastview / Basement / Girls Rm Below Auditorium Stairs	In Right Corner Above Stalls, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, System Shutdown Required
27778	Drip Leg	Eastview / Basement / Staff Break Rm	Back Corner Behind Cabinets, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, System Shutdown Required
296656	Drip Leg	Eastview / Basement / 007 Weight Rm	Left Of Lockers, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	B	Repair Kit, Difficult Access
296661	Drip Leg	Eastview / Basement / 007 Weight Rm	In Front Of Emergency Window, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	B	Repair Kit, Difficult Access
296665	Drip Leg	Eastview / Basement / 007 Weight Rm Storage	Right Corner, 5-10'	Barnes & Jones	134	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Difficult Access
277786	Radiator Trap	Eastview / Basement / Bathroom	Left Of Door, 5-10'	Barnes & Jones	5000	Thermostatic Straight	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
296654	Drip Leg	Eastview / Basement / Gym Boys Bathroom	In Front Of Stalls, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, No Issues
296648	Drip Leg	Eastview / Basement / Gym Office	Above Entry, 5-10'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Scheduling Issues
296649	Radiator Trap	Eastview / Basement / Gym Office	In Front Of Bathroom Door, 5-10'	Barnes & Jones	1821	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
296647	Radiator Trap	Eastview / Basement / Stair A	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
296670	Radiator Trap	Eastview / Basement / Stair B	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
277772	Drip Leg	Eastview / Basement / Tank Rm	FWD Left Of Tank, 10-15'	Barnes & Jones	FT2015-3	Float & Thermostatic	2	3/4"	NPT	L	Repair Kit, Difficult Access, Ladder In Boiler Room
296636	Air Handling Unit	Eastview / Mezzanine / Auditorium	AHU Rm Above Lights Rm For Auditorium, 5-10'	Spirax Sarco	FT15	Float & Thermostatic	2	2"	NPT	L	Repair Kit, No Issues
296634	Radiator Trap	Eastview / Upper Level / Auditorium	Boys Bathroom, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
291910	Radiator Trap	Eastview / 3rd / 319	Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
291912	Univent	Eastview / 3rd / 320	Right Univent, 0-5'	Spirax Sarco	RTA-125	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Scheduling Issues
291915	Radiator Trap	Eastview / 3rd / 320	Left Radiator, 0-5'	Barnes & Jones	1929	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Scheduling Issues
291924	Radiator Trap	Eastview / 3rd / 324	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
329327	Radiator Trap	Eastview / 3rd / 325	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291931	Radiator Trap	Eastview / 3rd / 3256	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291937	Radiator Trap	Eastview / 3rd / 331	Left Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291939	Radiator Trap	Eastview / 3rd / 333	Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	B	Repair Kit, Scheduling Issues
291942	Radiator Trap	Eastview / 3rd / 334	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
291944	Radiator Trap	Eastview / 3rd / 335	Right Radiator, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291916	Radiator Trap	Eastview / 3rd / Hallway	Outside 319, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
291943	Radiator Trap	Eastview / 3rd / Hallway	Stairwell At 334, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
291961	Radiator Trap	Eastview / 4th / Cafeteria Office	Below Window, 0-5'	Barnes & Jones	1721	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, Scheduling Issues
291994	Drip Leg	Youth Building / Ground / Copy Rm	In Corner Above Ceiling, 0-5'	Barnes & Jones	1998	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
291977	Drip Leg	Youth Building / Ground / Gym	Above Emergency Exit Door, 10-15'	Barnes & Jones	1985	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
255748	Drip Leg	Youth Building / Ground / Hallway	End Of Hallway Outside Computer Rm, Above Ceiling	Barnes & Jones	1998	Thermostatic Angle	3	3/4"	NPT	L	Repair Kit, System Shutdown Required
255753	Drip Leg	Youth Building / Ground / Hallway	Storage Closet End Of Hallway By Computer Rm, 5-10'	Warren Webster	544	Thermostatic Angle	3	1"	NPT	L	Repair Kit, Difficult Access, Little Room To Maneuver Between Closet Walls And Will Have To Clear Out Closet

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 2: Blowing, Leaking, and Plugged Traps

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
255745	Radiator Trap	Youth Building / Ground / After School Center	Above Printer, Above Ceiling	Barnes & Jones	1998	Thermostatic Angle	2	1/2"	NPT	P	Repair Kit, Scheduling Issues
291986	Radiator Trap	Youth Building / Ground / Business Assistant	Between Desks, Above Ceiling	Warren Webster	513	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Difficult Access, Scheduling Issues
255750	Drip Leg	Youth Building / Ground / Computer Rm	2 Panels From Far Corner, Above Ceiling	Barnes & Jones	1998	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues, System Shutdown Required
255751	Drip Leg	Youth Building / Ground / Computer Rm	Far Right Corner, Above Ceiling	Barnes & Jones	1998	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Scheduling Issues, System Shutdown Required
291989	Drip Leg	Youth Building / Ground / Deputy Director	3rd Tile From Ac, Above Ceiling	Barnes & Jones	1998	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Difficult Access, Scheduling Issues
291991	Drip Leg	Youth Building / Ground / Ladder Storage Closet	Left Wall, 5-10'	Warren Webster	544	Thermostatic Angle	2	1"	NPT	B	Full Trap, System Shutdown Required
255743	Drip Leg	Youth Building / Ground / Large Conference Rm	Left Of Window, Above Ceiling	Warren Webster	533	Thermostatic Angle	2	3/4"	NPT	L	Full Trap, Scheduling Issues, System Shutdown Required
255744	Drip Leg	Youth Building / Ground / Large Conference Rm	Left Of Window, Above Ceiling	Warren Webster	513	Thermostatic Angle	2	3/4"	NPT	B	Repair Kit, Scheduling Issues, System Shutdown Required
291995	Drip Leg	Youth Building / Ground / Large Conference Rm	Right Of Window, Above Ceiling	Warren Webster	513	Thermostatic Angle	2	3/4"	NPT	B	Full Trap, Scheduling Issues, System Shutdown Required
291985	Drip Leg	Youth Building / Ground / Neighborhood Services	Above AC, Above Ceiling	Spirax Sarco	RTA-125	Thermostatic Angle	2	3/4"	NPT	P	Repair Kit, Scheduling Issues
291993	Radiator Trap	Youth Building / Ground / Women's Bathroom	Above Soap, Above Ceiling	Barnes & Jones	1998	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Scheduling Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 1: All Steam Trap Survey Information

## 3. GATHERED DATA

Table 1: All Steam Trap Survey Information Sorted by Trap Tag Number

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
269254	Radiator Trap	Main / 2nd / 210 Main Office	Under Left Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	216 197	OK	Thermostatic Radiator Valve. No Trap Station Components.
269255	Radiator Trap	Main / 2nd / 210 Main Office	Under Right Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	212 180	OK	Thermostatic Radiator Valve. No Trap Station Components.
269256	Radiator Trap	Main / 2nd / 210 Main Office	Principal's Office, 0-5'	TS-A	Warren Webster	523	3/4"	2	214 197	OK	Thermostatic Radiator Valve. No Trap Station Components.
269257	Radiator Trap	Main / 2nd / 210 Main Office	Conference Rm, 0-5'	TS-A	Warren Webster	523	3/4"	2	213 187	OK	Pneumatic Radiator Valve. No Trap Station Components.
269258	Radiator Trap	Main / 2nd / 210 Main Office	Vice Principal's Office, 0-5'	TS-A	Barnes & Jones	134	3/4"	2	215 189	L	Pneumatic Radiator Valve. No Trap Station Components.
269250	Radiator Trap	Main / 2nd / 211 Nurse's Office	Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	215 198	OK	Thermostatic Radiator Valve. No Trap Station Components.
269260	Univent	Main / 2nd / 213	Univent, 0-5'	TS-A	Hoffman	8C	3/4"	2	214 178	OK	No Trap Station Components.
269261	Radiator Trap	Main / 2nd / 213	Radiator Behind Cabinet, 0-5'	TS-A	Warren Webster	523	3/4"	2	217 215	L	DDC Radiator Valve. No Trap Station Components.
269248	Univent	Main / 2nd / 214	Univent, 0-5'	TS-A	Barnes & Jones	134	3/4"	2	214 198	OK	No Trap Station Components.
269249	Radiator Trap	Main / 2nd / 214	Radiator Right Window, 0-5'	TS-A	Warren Webster	512	3/4"	2	215 178	OK	DDC Radiator Valve. No Trap Station Components.
269259	Radiator Trap	Main / 2nd / 215 Girl's Bathroom	Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	220 187	OK	Pneumatic Radiator Valve. No Trap Station Components.
269243	Univent	Main / 2nd / 216	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	217 180	OK	No Trap Station Components.
269244	Radiator Trap	Main / 2nd / 216	Radiator Right Side, 0-5'	TS-A	Warren Webster	523	3/4"	2	214 188	OK	DDC Radiator Valve. No Trap Station Components.
269247	Radiator Trap	Main / 2nd / 219 Boy's Bathroom	Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	216 199	OK	Pneumatic Radiator Valve. No Trap Station Components.
269245	Univent	Main / 2nd / 223	Univent, 0-5'	TS-A	Hoffman	8C	3/4"	2	214 198	NIS	No Trap Station Components. Valved Out.
269246	Radiator Trap	Main / 2nd / 223	Radiator Left Window, 0-5'	TS-A	Warren Webster	523	3/4"	2	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
269241	Radiator Trap	Main / 2nd / Exit 15	Right Side, 0-5'	TS-A	Warren Webster	512	1/2"	2	80 80	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out.
269242	Radiator Trap	Main / 2nd / Exit 15	Left Side, 0-5'	TS-A	Warren Webster	512	1/2"	2	80 80	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out.
269252	Radiator Trap	Main / 2nd / Hallway	Outside Nurse's Office, 5-10'	TS-A	Warren Webster	512	1/2"	2	213 198	OK	Manual Radiator Valve. No Trap Station Components.
269253	Radiator Trap	Main / 2nd / Hallway	Across From Nurse's Office, 5-10'	TS-A	Warren Webster	512	1/2"	2	224 165	OK	Manual Radiator Valve. No Trap Station Components.
269251	Radiator Trap	Main / 2nd / Main Entrance	Right Side, 0-5'	TS-A	Warren Webster	512	1/2"	2	214 176	OK	Manual Radiator Valve. No Trap Station Components.
269279	Univent	Main / 3rd / 308	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	215 178	OK	No Trap Station Components.
269280	Radiator Trap	Main / 3rd / 308	Radiator Under Window, 0-5'	TS-A	N/A	N/A	3/4"	2	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Access Panel Required .
269278	Radiator Trap	Main / 3rd / 310	Radiator Behind Cabinet, 0-5'	TS-A	Warren Webster	523	3/4"	2	213 212	L	DDC Radiator Valve. No Trap Station Components.
279277	Univent	Main / 3rd / 310	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	216 198	OK	No Trap Station Components.
269272	Radiator Trap	Main / 3rd / 312	Radiator Under Window, 0-5'	TS-A	Barnes & Jones	N/A	1/2"	2	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Access Panel Required.
269273	Radiator Trap	Main / 3rd / 312A	Radiator Under Left Window, 0-5'	TS-A	Hoffman	8C	3/4"	2	215 176	OK	DDC Radiator Valve. No Trap Station Components.
269274	Radiator Trap	Main / 3rd / 312A	Radiator Under Right Window, 0-5'	TS-A	Hoffman	8C	3/4"	2	215 180	OK	DDC Radiator Valve. No Trap Station Components.
269281	Univent	Main / 3rd / 313	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	80 80	NIS	No Trap Station Components. Valved Out.
269270	Univent	Main / 3rd / 314	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	216 189	NIS	Inlet Isolation, Outlet Isolation. Valved Out.
269271	Radiator Trap	Main / 3rd / 314	Radiator Behind Cabinet, 0-5'	TS-A	Barnes & Jones	134	3/4"	2	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.
269276	Radiator Trap	Main / 3rd / 315 Girl's Bathroom	Radiator Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	215 198	OK	Pneumatic Radiator Valve. No Trap Station Components. Pneumatic Valve Stuck Open
269263	Univent	Main / 3rd / 316	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	80 80	NIS	Inlet Isolation, Outlet Isolation. Valved Out, Univent No Connection To System Cant Turn On.
269264	Radiator Trap	Main / 3rd / 316	Radiator Behind Cabinets, 0-5'	TS-A	Warren Webster	523	3/4"	2	80 80	NIS	DDC Radiator Valve. No Trap Station Components. Valved Out.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
269275	Radiator Trap	Main / 3rd / 317	Under Window, 0-5'	TS-A	Warren Webster	513	1/2"	2	216 178	OK	Manual Radiator Valve. No Trap Station Components.
269268	Radiator Trap	Main / 3rd / 321 Boy's Bathroom	Radiator Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	215 187	OK	Manual Radiator Valve. No Trap Station Components.
269269	Radiator Trap	Main / 3rd / 321 Boy's Bathroom	Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	80 80	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out.
269265	Univent	Main / 3rd / 323	Univent, 0-5'	TS-S	Barnes & Jones	134	3/4"	2	216 198	OK	Inlet Isolation, Outlet Isolation.
269266	Radiator Trap	Main / 3rd / 323	Radiator Behind Cabinets, 0-5'	TS-A	N/A	N/A	1/2"	2	NA NA	NA	DDC Radiator Valve. No Trap Station Components. Access Panel Required In Cabinet .
269262	Radiator Trap	Main / 3rd / Faculty Rm End Of Hall	Radiator Under Window, 0-5'	TS-A	Warren Webster	512	1/2"	2	80 80	NIS	Thermostatic Radiator Valve. No Trap Station Components. Valved Out.
269282	Radiator Trap	Main / 3rd / Stairwell Next To 313	Platform, 0-5'	TS-A	Warren Webster	513	1/2"	2	226 197	L	Manual Radiator Valve. No Trap Station Components.
269267	Radiator Trap	Main / 3rd / Stairwell Next To 523	Platform, 0-5'	TS-A	Warren Webster	512	1/2"	2	80 89	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out.
269225	Reheat Coil	Main / Ground / 113	Right Wall Above Cutout For Steam Coil, 5-10'	FT	Spirax Sarco	FT15	3/4"	2	80 80	NIS	Inlet Isolation, Strainer, Blowdown, Outlet Isolation. Valved Out.
269227	Radiator Trap	Main / Ground / 113	Radiator Under Left Window, 0-5'	TS-A	Warren Webster	02H	1/2"	2	214 212	L	Pneumatic Radiator Valve. No Trap Station Components.
269228	Radiator Trap	Main / Ground / 108	Radiator Behind Cabinets, 0-5'	TS-A	N/A	N/A	1/2"	2	NA NA	NA	Pneumatic Radiator Valve. No Trap Station Components. Cabinets Built Around With No Access Panel .
269229	Reheat Coil	Main / Ground / 108	Storage Closet In Back, Above Ceiling	TS-S	Barnes & Jones	3500	1/2"	2	215 189	OK	No Trap Station Components.
269221	Radiator Trap	Main / Ground / 110	Back Wall, 0-5'	TS-A	Hoffman	8C	3/4"	2	215 177	OK	Pneumatic Radiator Valve. No Trap Station Components.
269224	Radiator Trap	Main / Ground / 110A	Under Window, 5-10'	TS-A	Hoffman	8C	3/4"	2	215 178	OK	Pneumatic Radiator Valve. No Trap Station Components.
269219	Radiator Trap	Main / Ground / 112	Back Wall, 0-5'	TS-A	Hoffman	8C	3/4"	2	214 176	OK	Pneumatic Radiator Valve. No Trap Station Components.
269217	Radiator Trap	Main / Ground / 112B	Back Corner, 0-5'	TS-A	Hoffman	8C	3/4"	2	213 194	OK	Pneumatic Radiator Valve. No Trap Station Components.
269218	Radiator Trap	Main / Ground / 112B	Trap In Right Corner, 0-5'	TS-A	Barnes & Jones	122	1/2"	2	216 212	L	Pneumatic Radiator Valve. No Trap Station Components.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice

Table 1: All Steam Trap Survey Information

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Trap Type	Mfr.	Model	Pipe Size	System PSI	Temp °F In Out	Result	Comments
269220	Radiator Trap	Main / Ground / 112D	On Wall, 0-5'	TS-A	Hoffman	8C	3/4"	2	213 197	OK	Pneumatic Radiator Valve. No Trap Station Components.
269226	Radiator Trap	Main / Ground / 113	Radiator Under Right Window, 0-5'	TS-A	Warren Webster	N/A	3/4"	2	215 176	OK	Pneumatic Radiator Valve. No Trap Station Components.
269222	Radiator Trap	Main / Ground / 117	Radiator Above Ductwork, 10-15'	TS-A	Warren Webster	512	1/2"	2	214 198	OK	Manual Radiator Valve. No Trap Station Components.
269223	Radiator Trap	Main / Ground / 117	In Bathroom, 5-10'	TS-A	Warren Webster	512	1/2"	2	80 80	NIS	Manual Radiator Valve. No Trap Station Components. Valved Out, Radiator Valve Stuck Closed. Manual Valve Stuck Closed
269240	Reheat Coil	Main / Ground / 118 Storage Rm	Above Entrance, Above Ceiling	FT	Spirax Sarco	FT15	3/4"	2	214 180	OK	Inlet Isolation, Strainer, Blowdown, Outlet Isolation.
269215	Radiator Trap	Main / Ground / 123	Radiator Towards Left Wall, Above Ceiling	TS-A	Warren Webster	PATD	1/2"	2	215 198	OK	Pneumatic Radiator Valve. No Trap Station Components.
269216	Unit Heater	Main / Ground / 123	Unit Heater In Corner, 5-10'	TS-A	N/A	N/A	1"	2	214 198	NIS	Inlet Isolation, Outlet Isolation. Valved Out.
269231	Heat Exchanger	Main / Ground / 127 Boiler Rm	Against Right Wall By Condensate Tank, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	2	199 165	OK	Inlet Isolation, Strainer, Outlet Isolation.
269232	Heat Exchanger	Main / Ground / 127 Boiler Rm	Against Right Wall By Condensate Tank, 5-10'	FT	Barnes & Jones	FT2015-8	2"	2	187 145	OK	Strainer, Outlet Isolation.
269233	Drip Leg	Main / Ground / 127 Boiler Rm	Against Right Wall By Condensate Tank, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	2	213 165	OK	Inlet Isolation, Strainer, Outlet Isolation.
269234	Drip Leg	Main / Ground / 127 Boiler Rm	By Pillar Between Boiler And HEX, 10-15'	FT	Barnes & Jones	FT2015-4	1"	2	215 212	L	Inlet Isolation, Strainer, Outlet Isolation.
269235	Drip Leg	Main / Ground / 127 Boiler Rm	Front Of Pillar Between Boiler And HEX, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	2	213 186	OK	Inlet Isolation, Strainer, Outlet Isolation.
269236	Drip Leg	Main / Ground / 127 Boiler Rm	Above HEX1 (Red HEX), 10-15'	FT	Barnes & Jones	FT2015-4	1"	2	212 175	OK	Inlet Isolation, Strainer, Outlet Isolation.
269237	Drip Leg	Main / Ground / 127 Boiler Rm	Front Of Boiler 2, 5-10'	FT	Barnes & Jones	FT2015-6	1 1/2"	2	213 167	OK	Inlet Isolation, Strainer, Outlet Isolation.
269238	Drip Leg	Main / Ground / 127 Boiler Rm	Between Boiler 1 And 2, 5-10'	FT	Hoffman	FT015H-3	3/4"	2	213 167	OK	Inlet Isolation.
269239	Drip Leg	Main / Ground / 127 Boiler Rm	Between Boiler 1 And 2, 5-10'	FT	Hoffman	FT53	3/4"	2	214 187	L	Inlet Isolation.

Result Key: OK = Okay B= Blowing L= Leaking P= Plugged NIS= Not In Service LBD= Leak By Design NA= Not Accessible RIP= Retired In Place  
 Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float & Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice



Table 2: Leaking Traps

Table 2: Leaking Traps from the Survey

Tag #	Application	Building / Floor / Room	Trap Location, Elevation	Mfr	Model	Trap Type	System PSI	Pipe Size	Conn Type	Result	Install/Access Issues
269258	Radiator Trap	Main / 2nd / 210 Main Office	Vice Principal's Office, 0-5'	Barnes & Jones	134	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, No Issues
269261	Radiator Trap	Main / 2nd / 213	Radiator Behind Cabinet, 0-5'	Warren Webster	523	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, No Issues
269278	Radiator Trap	Main / 3rd / 310	Radiator Behind Cabinet, 0-5'	Warren Webster	523	Thermostatic Angle	2	3/4"	NPT	L	Repair Kit, Difficult Access
269282	Radiator Trap	Main / 3rd / Stairwell Next To 313	Platform, 0-5'	Warren Webster	513	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
269227	Radiator Trap	Main / Ground / 113	Radiator Under Left Window, 0-5'	Warren Webster	02H	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
269218	Radiator Trap	Main / Ground / 112B	Trap In Right Corner, 0-5'	Barnes & Jones	122	Thermostatic Angle	2	1/2"	NPT	L	Repair Kit, No Issues
269234	Drip Leg	Main / Ground / 127 Boiler Rm	By Pillar Between Boiler And HEX, 10-15'	Barnes & Jones	FT2015-4	Float & Thermostatic	2	1"	NPT	L	Repair Kit, No Issues
269239	Drip Leg	Main / Ground / 127 Boiler Rm	Between Boiler 1 And 2, 5-10'	Hoffman	FT53	Float & Thermostatic	2	3/4"	NPT	L	Full Trap, No Issues

Result Key: B= Blowing L= Leaking P= Plugged

Trap Type Key: IB=Inverted Bucket VIB=Vertical Inverted Bucket FT=Float &amp; Thermostatic BM=Bimetallic TD=Thermodynamic TS= Thermostatic OR=Orifice