



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Pine Hill Middle School

1003 Turnersville Road

Pine Hill, NJ 08021

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
T113917	PHMS - FB	11/20/2021 07:40	11/30/2021 13:00	<2.00	15.5	SM3113B
T113918	PHMS - IM-01-KITCH	11/20/2021 07:46	11/30/2021 13:07	<2.00	15.5	SM3113B
T113919	PHMS - KC-01-KITCH	11/20/2021 07:47	11/30/2021 13:27	2.53	15.5	SM3113B
T113921	PHMS - WC-01-GYM1	11/20/2021 07:51	11/30/2021 13:47	<2.00	15.5	SM3113B
T113922	PHMS - WC-01-GYM2	11/20/2021 07:52	11/30/2021 13:53	<2.00	15.5	SM3113B
T113923	PHMS - TL-01-FALCG	11/20/2021 07:53	11/30/2021 14:00	<2.00	15.5	SM3113B
T113925	PHMS - WC-01-CAFE1	11/20/2021 07:55	11/30/2021 14:06	<2.00	15.5	SM3113B
T113926	PHMS - WC-01-CAFE2	11/20/2021 07:56	11/30/2021 14:12	<2.00	15.5	SM3113B
T113927	PHMS - BF-CAFE	11/20/2021 07:56	11/30/2021 14:19	<2.00	15.5	SM3113B
T113928	PHMS - SO-01-MNOFF	11/20/2021 07:58	11/30/2021 14:25	3.04	15.5	SM3113B
T113930	PHMS - NS-01-NURSER	11/20/2021 08:02	11/30/2021 14:45	3.15	15.5	SM3113B
T113932	PHMS - NS-01-NURSE	11/20/2021 08:03	11/30/2021 14:52	<2.00	15.5	SM3113B
T113934	PHMS - WC-01-HALL1	11/20/2021 08:06	11/30/2021 14:58	<2.00	15.5	SM3113B
T113935	PHMS - WC-01-HALL2	11/20/2021 08:06	11/30/2021 15:05	<2.00	15.5	SM3113B
T113936	PHMS - BF-01-HALL	11/20/2021 08:07	11/30/2021 15:11	<2.00	15.5	SM3113B
T113937	PHMS - WC-02-HALL1	11/20/2021 08:08	11/30/2021 15:18	<2.00	15.5	SM3113B
T113938	PHMS - WC-02-HALL2	11/20/2021 08:08	11/30/2021 15:25	<2.00	15.5	SM3113B
T113939	PHMS - WC-01-HALL3	11/20/2021 08:12	11/30/2021 15:31	<2.00	15.5	SM3113B
T113940	PHMS - WC-01-HALL4	11/20/2021 08:13	11/30/2021 15:38	<2.00	15.5	SM3113B
T113941	PHMS - WC-02-HALL3	11/20/2021 08:14	11/30/2021 15:44	<2.00	15.5	SM3113B
T113942	PHMS - WC-02-HALL4	11/20/2021 08:15	11/30/2021 16:04	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

12/22/2021 12:00:00 AM

Date

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006



Customer: Pine Hill Borough School District
 Contact: Greg Sawyer
 Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
 Phone: (856) 783-6900
 Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
1113917	PHMS-FB	11/20/21	0740	X		D	1 x 250	HNO3* First Draw Lead	FIELD BANK
1113918	1M-01-KITCH		0746	X		D	1 x 250	HNO3* First Draw Lead	
1113919	KC-01-KITCH		0747	X		D	1 x 250	HNO3* First Draw Lead	
1113920	↓ (FLUSH)		0748	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1113921	WC-01-GYM 1		0751	X		D	1 x 250	HNO3* First Draw Lead	
1113922	WC-01-GYM 2		0752	X		D	1 x 250	HNO3* First Draw Lead	
1113923	TL-01-FACLG		0753	X		D	1 x 250	HNO3* First Draw Lead	
1113924	↓ (FLUSH)		0754	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1113925	WC-01-CAFE 1		0755	X		D	1 x 250	HNO3* First Draw Lead	
1113926	✓ WC-01-CAFE 2	✓	0756	X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WWW: WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard X NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions Rush to be Flushed for 1st Draw over 15.5 pph * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Properly Preserved Yes No
--	---	--	---

Sampled by:

(Print) James Eberts

Sampled by/Relinquished by:

(Signature) [Signature]

Relinquished by:

(Signature) [Signature]

Relinquished by:

(Signature) [Signature]

Date

11/23/21

Time

1414

Received by:

(Signature) [Signature]

Date

11/23/21

Time

1414

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006



Customer:	Pine Hill Borough School District	MIDDLE SCHOOL
Contact:	Greg Sawyer	
Address:	1003 Turnerville Road	
	Pine Hill, NJ 08021	
Phone:	(856) 783-6900	
Office:	Fax:	

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
1113927	PHMS-BF-AFE	11/20/21	0756	X		D	1 x 250	HNO3* First Draw Lead	
1113928	SO-01-MNOFF		0758	X		D	1 x 250	HNO3* First Draw Lead	
1113929	↓ (FLUSH)		0758	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1113930	NS-01-NURSER		0802	X		D	1 x 250	HNO3* First Draw Lead	
1113931	↓ (FLUSH)		0803	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1113932	NS-01-NURSE		0803	X		D	1 x 250	HNO3* First Draw Lead	
1113933	↓ (FLUSH)		0804	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1113934	WC-01-HALL 1		0806	X		D	1 x 250	HNO3* First Draw Lead	
1113935	WC-01-HALL 2		0806	X		D	1 x 250	HNO3* First Draw Lead	
1113936	↓ BF-01-HALL		0807	X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	* HNO3 preserved upon receipt at laboratory Yes _____ No _____	°C Properly Preserved

Sampled by: (Print) James Ebert	Date	Time	Received by: (Signature)	Date	Time
Sampled by/Relinquished by: (Signature) [Signature]	11/22/21	1414	[Signature]	11/23/21	1414
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwaterest.com

NJ DEP Certification #08006



Customer: Pine Hill Borough School District
 Contact: Greg Sawyer
 Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
 Phone: (856) 783-6900
 Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
1113937	PHMS-82-HALL 1	11/20/21	0808	X		D	1 x 250	HNO3* First Draw Lead	
1113938	WC-02-HALL 2		0808	X		D	1 x 250	HNO3* First Draw Lead	
1113939	WC-01-HALL 3		0812	X		D	1 x 250	HNO3* First Draw Lead	
1113940	WC-01-HALL 4		0813	X		D	1 x 250	HNO3* First Draw Lead	
1113941	WC-02-HALL 3		0814	X		D	1 x 250	HNO3* First Draw Lead	
1113942	WC-02-HALL 4		0815	X		D	1 x 250	HNO3* First Draw Lead	
	(end)			X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions		Cooler Temp
				°C
		* HNO3 preserved upon receipt at laboratory		Properly Preserved
				Yes
				No

Sampled by:

(Print) James Eberts

Sampled by/Relinquished by:

(Signature) J. Eberts

Relinquished by:

(Signature)

Relinquished by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)