

May 3, 2023

Pine Hill School District
1003 Turnerville Rd
Pine Hill NJ 08021

Dear Pine Hill School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our Community and be in compliance with the Department of Education regulations, Pine Hill School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 ug/l(parts per billion(ppb)). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK-SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 109 samples taken district wide, all but 2 drinking outlets tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 ug/l ppb). Those 2 were retested and shown to be below the action level also.

The table below identifies the drinking water outlets that tested above the 15 ug/l for lead and what remedial action Pine Hill School District has taken to reduce the levels of lead at these locations.

Sample Location	Result	Remedial Action
John Glenn Elementary School Hallway ID: GLN-DW-Hall 2	25.1	Drinking fountain, Flushed and Re-tested
Hallway ID: GLN-DW-Hall 2	<2.00	Retest.

John Glenn Elementary School

Kitchen ID: GLN-KC-Kitch1	18.75	Re tested and found to be within allowable limits
Kitchen ID: GLN-KC-Kitch1	<2.00	Re test,Result <2.00
Kitchen ID: GLN-KC-Kitch1	<2.00	Re-test again <2.00
Kitchen ID: GLN-KC-Kitch-2	29.67	Re tested and found to be within allowable limits
Kitchen ID: GLN-KC-Kitch-2	2.28	Re test, result 2.28
Kitchen ID: GLN-KC-Kitch-2	<2.00	Re-test again <2.00

Overbrook High School

Kitchen ID: OVR-KE-01-Kitch1	502.4	This is for Handwashing only and was flushed and second sample drawn
Kitchen ID: OVR-KE-01-Kitch1(Flush)	16.4	This faucet is for handwashing only and sign is posted.
Kitchen ID: OVR-KE-01-Kitch2(Flush)	225.1	This is for Handwashing only and was flushed and second sample drawn.
Kitchen ID: OVR-KE-01-Kitch2	10.14	Second sample, below limit. Handwashing only posted
Cafeteria ID DW-01-CAFÉ(Flush)	18.63	Drinking fountain was not in service. Flushed and re-tested. Below limit but permantley removed from service
Cafeteria ID DW-01-CAFÉ	3.85	Re-test. Below limit. Permantly removed from service.
Classroom ID: CS-02-B213(4)	45.13	Classroom Handwashing sink. Flushed and re -test Below limit
Classroom ID: CS-02-B213(4)(Flush)	2.19	Classroom Handwashing sink. Flushed and re -test Below Limit.