



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

John Glenn Elementary School

1005 Turnersville Rd

Pine Hill, NJ 08021

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
T113943	GLN - FB	11/20/2021 08:23	11/30/2021 16:24	<2.00	15.5	SM3113B
T113944	GLN - WC-HALL3	11/20/2021 08:26	11/30/2021 16:30	<2.00	15.5	SM3113B
T113945	GLN - DW-HALL1	11/20/2021 08:27	11/30/2021 16:37	14.95	15.5	SM3113B
T113947	GLN - DW-HALL3	11/20/2021 08:29	11/30/2021 16:43	4.37	15.5	SM3113B
T113949	GLN - DW-HALL2	11/20/2021 08:30	11/30/2021 16:50	25.10	15.5	SM3113B
T113950	GLN - DW-HALL2 (FLUSH)	11/20/2021 08:31	12/2/2021 13:20	<2.00	15.5	SM3113B
T113951	GLN - WC-HALL2	11/20/2021 08:33	11/30/2021 16:56	<2.00	15.5	SM3113B
T113952	GLN - BF-HALL2	11/20/2021 08:33	11/30/2021 17:03	<2.00	15.5	SM3113B
T113953	GLN - NS-NURSE	11/20/2021 08:35	11/30/2021 17:22	4.21	15.5	SM3113B
T113955	GLN - DW-HALL4	11/20/2021 08:38	11/30/2021 17:29	11.24	15.5	SM3113B
T113957	GLN - WC-HALL1	11/20/2021 08:40	11/30/2021 17:36	<2.00	15.5	SM3113B
T113958	GLN - BF-HALL1	11/20/2021 08:41	11/30/2021 17:42	<2.00	15.5	SM3113B
T113959	GLN - KC-KITCH1	11/20/2021 08:43	11/30/2021 17:49	18.75	15.5	SM3113B
T113960	GLN - KC-KITCH1 (FLUSH)	11/20/2021 08:44	12/2/2021 13:26	<2.00	15.5	SM3113B
T113961	GLN - KC-KITCH2	11/20/2021 08:43	11/30/2021 17:55	29.67	15.5	SM3113B
T113962	GLN - KC-KITCH2 (FLUSH)	11/20/2021 08:44	12/2/2021 13:33	2.28	15.5	SM3113B
T113963	GLN - WC-HALL4	11/24/2021 07:50	11/30/2021 18:02	<2.00	15.5	SM3113B
T113964	GLN - BF-HALL4	11/24/2021 07:50	11/30/2021 18:09	<2.00	15.5	SM3113B
T113965	GLN - WC-ADMIN	11/24/2021 07:50	11/30/2021 18:15	<2.00	15.5	SM3113B
T113966	GLN - BF-ADMIN	11/24/2021 07:50	11/30/2021 18:22	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

12/22/2021 12:00:00 AM

Date

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer:	Pine Hill Borough School District
Contact:	Greg Sawyer
Address:	1003 Turnerville Road Pine Hill, NJ 08021
Phone:	(856) 783-6900
Office:	Fax:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
T113943	GLN - FB	11/20/21	0823	X		D	1 x 250	HNO3* First Draw Lead	FIELD BLANK
T113944	GLN-WC-HALL 3		0826	X		D	1 x 250	HNO3* First Draw Lead	
T113945	DW-HALL 1		0827	X		D	1 x 250	HNO3* First Draw Lead	
T113946	↓ (FLUSH)		0828	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
T113947	DW-HALL 3		0829	X		D	1 x 250	HNO3* First Draw Lead	
T113948	↓ (FLUSH)		0830	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
T113949	DW-HALL 2		0830	X		D	1 x 250	HNO3* First Draw Lead	
T113950	↓ (FLUSH)		0831	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
T113951	WC-HALL 2		0833	X		D	1 x 250	HNO3* First Draw Lead	
T113952	↓ BF-HALL 2		0833	X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time ☒ SJWT Standard is 10-20 work days ☐ Rush turnaround available upon request and lab approval	Report Format ☒ Standard ☐ NJ DEP Reduced Deliverables ☐ NJ DEP Full Deliverables ☐ Electronic Data Deliverables ☐ PWTA Format	Comments/Special Instructions Analyze Flush for 1st Draw over 15.5 ppb * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Properly Preserved Yes No
--	--	--	--

Sampled by: (Print) James Ebert	Received by: (Signature) [Signature]	Date 11/21/21	Date 11/23/21	Time 1414
Sampled by/Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date 11/21/21	Date 11/23/21	Time 1414
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date 11/21/21	Date 11/23/21	Time 1414

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Pine Hill Borough School District **GLENN E.S.**
Contact: Greg Sawyer
Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
Phone: (856) 783-6900
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Not. Pres.	Analysis Requested	Comments
T113953	GLN-NS-NURSE	11/20/21	0835	X		D	1 x 250	HNO3*	First Draw Lead	
T113954	↓ (FLUSH)		0836	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T113955	DW-HALL 4		0838	X		D	1 x 250	HNO3*	First Draw Lead	
T113956	↓ (FLUSH)		0839	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T113957	WC-HALL 1		0840	X		D	1 x 250	HNO3*	First Draw Lead	
T113958	BF-HALL 1		0841	X		D	1 x 250	HNO3*	First Draw Lead	
T113959	KC-KITCH 1		0843	X		D	1 x 250	HNO3*	First Draw Lead	
T113960	↓ (FLUSH)		0844	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T113961	KC-KITCH 2		0843	X		D	1 x 250	HNO3*	First Draw Lead	
T113962	↓ (FLUSH)		0844	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL S/LSLUDGE G/WGROUND WATER S/W/SURFACE WATER W/WWASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format	Comments/Special Instructions	Cooler Temp
	Standard		°C
	NJ DEP Reduced Deliverables		
	NJ DEP Full Deliverables		Properly Preserved
	Electronic Data Deliverables		Yes
	PWTA Format		No

Sampled by: <u>James Ebert</u>	Date	Time	Received by: <u>[Signature]</u>	Date	Time
Sampled by/Relinquished by: <u>[Signature]</u>	11/23/21	1414		11/23/21	1414
Relinquished by: <u>[Signature]</u>			Received by: <u>[Signature]</u>		
Relinquished by: <u>[Signature]</u>			Received by: <u>[Signature]</u>		

South Jersey Water Test, LLC

4077 South Black Horse Pike
Williamstown, NJ 08094
Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Pine Hill Borough School District
Contact: Greg Sawyer
Address: 1003 Turnerville Road
Pine Hill, NJ 08021
Phone: (856) 783-6900
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
1113963	GLN-WC-HALL 4	11/20/21	0846	X		D	1 x 250	HNO3* First Draw Lead	
1113964	BF-HALL 4		0847	X		D	1 x 250	HNO3* First Draw Lead	
1113965	WC-ADMIN		0853	X		D	1 x 250	HNO3* First Draw Lead	
1113966	BF-ADMIN		0853	X		D	1 x 250	HNO3* First Draw Lead	
	(end)			X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL S/LSLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
			Properly Preserved
			Yes No

Sampled by: (Print) James Liberty

Sampled by/Relinquished by: (Signature) [Signature] Date 11/23/21 Time 11:23 AM

Relinquished by: (Signature) [Signature] Date Time

Relinquished by: (Signature) [Signature] Date Time