

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006


Overbrook High School

1200 Turnersville Rd
Pine Hill, NJ 08021

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
T114040	OVR - FB	11/20/2021 06:05	12/2/2021 17:14	<2.00	15.5	SM3113B
T114041	OVR - WC-01-D112	11/20/2021 06:06	12/2/2021 17:20	11.24	15.5	SM3113B
T114042	OVR - WC-01-GLR	11/20/2021 06:10	12/2/2021 17:27	<2.00	15.5	SM3113B
T114043	OVR - BF-01-GLR	11/20/2021 06:11	12/2/2021 18:07	<2.00	15.5	SM3113B
T114044	OVR - WC-01-GLR	11/20/2021 06:12	12/2/2021 18:13	<2.00	15.5	SM3113B
T114045	OVR - BF-01-GLR	11/20/2021 06:13	12/2/2021 18:20	<2.00	15.5	SM3113B
T114046	OVR - WC-01-HALL1	11/20/2021 06:14	12/2/2021 18:26	<2.00	15.5	SM3113B
T114047	OVR - BF-01-GALL1	11/20/2021 06:15	12/2/2021 18:33	<2.00	15.5	SM3113B
T114048	OVR - IM-01-TRAIN	11/20/2021 06:16	12/2/2021 18:39	<2.00	15.5	SM3113B
T114049	OVR - SO-01-TRAIN	11/20/2021 06:17	12/2/2021 18:46	4.70	15.5	SM3113B
T114051	OVR - HB-01-TRAIN	11/20/2021 06:19	12/2/2021 19:06	9.12	15.5	SM3113B
T114053	OVR - WC-01-G104	11/20/2021 06:26	12/2/2021 19:12	<2.00	15.5	SM3113B
T114054	OVR - BF-01-G104	11/20/2021 06:27	12/2/2021 19:19	<2.00	15.5	SM3113B
T114055	OVR - KC-01-KITCH1	11/20/2021 06:31	12/2/2021 19:25	5.19	15.5	SM3113B
T114057	OVR - KE-01-KITCH1	11/20/2021 06:34	12/2/2021 19:52	502.40	15.5	SM3113B
T114058	OVR - KE-01-KITCH1 (FLUSH)	11/20/2021 06:35	12/6/2021 12:21	16.40	15.5	SM3113B
T114059	OVR - KE-01-KITCH2	11/20/2021 06:36	12/2/2021 20:19	225.10	15.5	SM3113B
T114060	OVR - KE-01-KITCH2 (FLUSH)	11/20/2021 06:37	12/6/2021 12:27	10.14	15.5	SM3113B
T114061	OVR - KC-01-KITCH2	11/20/2021 06:40	12/2/2021 20:39	4.47	15.5	SM3113B
T114063	OVR - KC-01-KITCH3	11/20/2021 06:40	12/2/2021 20:46	<2.00	15.5	SM3113B
T114065	OVR - IM-01-KITCH	11/20/2021 06:44	12/2/2021 20:47	<2.00	15.5	SM3113B
T114066	OVR - DW-01-CAFE	11/20/2021 06:47	12/6/2021 12:14	18.63	15.5	SM3113B
T114067	OVR - DW-01-CAFE (FLUSH)	11/20/2021 06:48	12/6/2021 15:11	3.85	15.5	SM3113B
T114068	OVR - WC-01-HALL1A	11/20/2021 06:52	12/2/2021 20:59	<2.00	15.5	SM3113B
T114069	OVR - BF-01-HALL1A	11/20/2021 06:52	12/6/2021 12:54	<2.00	15.5	SM3113B
T114070	OVR - WC-02-HALL2	11/20/2021 06:57	12/6/2021 12:34	<2.00	15.5	SM3113B
T114071	OVR - BF-02-HALL3	11/20/2021 06:58	12/6/2021 13:13	<2.00	15.5	SM3113B
T114072	OVR - WC-01-HALL3	11/20/2021 07:02	12/6/2021 13:20	<2.00	15.5	SM3113B
T114073	OVR - BF-01-HALL3	11/20/2021 07:03	12/6/2021 13:26	<2.00	15.5	SM3113B
T114074	OVR - SO-01-NUR	11/20/2021 07:05	12/6/2021 13:33	9.53	15.5	SM3113B
T114076	OVR - WC-01-HALL	11/20/2021 07:06	12/6/2021 13:39	<2.00	15.5	SM3113B
T114077	OVR - BF-01-HALL	11/20/2021 07:07	12/6/2021 13:46	<2.00	15.5	SM3113B
T114078	OVR - WC-02-HALL	11/20/2021 07:09	12/6/2021 13:52	<2.00	15.5	SM3113B
T114079	OVR - BF-02-HALL	11/20/2021 07:10	12/6/2021 14:12	<2.00	15.5	SM3113B
T114080	OVR - CS-02-B213(3)	11/20/2021 07:12	12/6/2021 14:18	<2.00	15.5	SM3113B
T114082	OVR - CS-02-B213(2)	11/20/2021 07:14	12/6/2021 14:25	3.35	15.5	SM3113B
T114084	OVR - CS-02-B213(1)	11/20/2021 07:13	12/6/2021 14:32	6.06	15.5	SM3113B

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Overbrook High School

1200 Turnersville Rd
Pine Hill, NJ 08021

Results of Lead Analysis

Sample ID:	Sample Location	Date/Time Collected	Date/Time Analyzed	Result	Action Level	Method
T114086	OVR - CS-02-B213(4)	11/20/2021 07:15	12/6/2021 14:38	45.13	15.5	SM3113B
T114087	OVR - CS-02-B213(4) (FLUSH)	11/20/2021 07:16	12/6/2021 16:17	2.19	15.5	SM3113B
T114088	OVR - WC-01-HALL5	11/20/2021 07:17	12/6/2021 14:45	<2.00	15.5	SM3113B
T114089	OVR - BF-01-HALL5	11/20/2021 07:20	12/6/2021 14:51	<2.00	15.5	SM3113B
T114090	OVR - WC-02-HALL2	11/20/2021 07:22	12/6/2021 14:58	<2.00	15.5	SM3113B
T114091	OVR - BF-02-HALL2	11/20/2021 07:23	12/6/2021 15:05	<2.00	15.5	SM3113B

Mark J. Riether, Lab Director

12/22/2021 12:00:00 AM

Date

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer:	Pine Hill Borough School District
Contact:	Greg Sawyer
Address:	1003 Turnerville Road Pine Hill, NJ 08021
Phone:	(856) 783-6900
Office:	Fax:

Lab ID#	Sample Location	Collection Date	Time	Grb	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
T114040	OVR - FB	11/20/21	0605	X		D	1 x 250	HNO3* First Draw Lead	FIELD BLANK
T114041	OVR - WC-01-D112		0606	X		D	1 x 250	HNO3* First Draw Lead	
T114042	OVR - WC-01-GLR		0610	X		D	1 x 250	HNO3* First Draw Lead	
T114043	OVR - BF-01-GLR		0611	X		D	1 x 250	HNO3* First Draw Lead	
T114044	OVR - WC-01-BLR		0612	X		D	1 x 250	HNO3* First Draw Lead	
T114045	OVR - BF-01-BLR		0613	X		D	1 x 250	HNO3* First Draw Lead	
T114046	OVR - WC-01-HALL		0614	X		D	1 x 250	HNO3* First Draw Lead	
T114047	OVR - BF-01-HALL		0615	X		D	1 x 250	HNO3* First Draw Lead	
T114048	OVR - IM-01-TRAIN		0616	X		D	1 x 250	HNO3* First Draw Lead	
T114049	OVR - SO-01-TRAIN		0617	X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format ☒ Standard ☐ NJ DEP Reduced Deliverables ☐ NJ DEP Full Deliverables ☐ Electronic Data Deliverables ☐ PWTA Format	Comments/Special Instructions Analyze for 1st draw over 15.5 ppb * HNO3 preserved upon receipt at laboratory	Cooler Temp °C Properly Preserved Yes No
--	--	--	--

Sampled by: (Print) James Eberts	Received by: (Signature) [Signature]	Date 11/23/21	Time 1414
Sampled by/Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Time
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Time
Relinquished by: (Signature) [Signature]	Received by: (Signature) [Signature]	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006



Customer: Pine Hill Borough School District
 Contact: Greg Sawyer
 Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
 Phone: (856) 783-6900
 Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Grb	Comp	Matrix	No. of Bottles	Not Pres.	Analysis Requested	Comments
T114050	OVR-SO-01-TRAIN (FLUSH)	11/26/21	0618	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T114051	HB-01-TRAIN		0619	X		D	1 x 250	HNO3*	First Draw Lead	
T114052	↓ (FLUSH)		0620	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T114053	WC-01-G104		0626	X		D	1 x 250	HNO3*	First Draw Lead	
T114054	BF-01-G104		0627	X		D	1 x 250	HNO3*	First Draw Lead	
T114055	KC-01-KITCH 1		0631	X		D	1 x 250	HNO3*	First Draw Lead	
T114056	↓ (FLUSH)		0632	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T114057	KE-01-KITCH 1		0634	X		D	1 x 250	HNO3*	First Draw Lead	
T114058	↓ (FLUSH)		0635	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
T114059	↓ KE-01-KITCH 2		0636	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL\SLUDGE GW\GROUND WATER SWSURFACE WATER WWWASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard ___ NJ DEP Reduced Deliverables ___ NJ DEP Full Deliverables ___ Electronic Data Deliverables ___ PWTA Format	Comments/Special Instructions		Cooler Temp
				°C
		* HNO3 preserved upon receipt at laboratory		Properly Preserved
				Yes No

Sampled by: James Ebert

Sampled by/Relinquished by: [Signature]

Relinquished by: [Signature]

Relinquished by: [Signature]

Date

Time

Date

Time

Date

Time

Date

Time

Date

Time

Date

Time

Date

Time

Date

Time

Date

Time

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Pine Hill Borough School District
Contact: Greg Sawyer
Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
Phone: (856) 783-6900
Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Gr	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
1114060	OVR-KE-01-KITCH 2 (FLUSH)	11/20/21	0637	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114061	KC-01-KITCH 2		0640	X		D	1 x 250	HNO3* First Draw Lead	
1114062	↓ (FLUSH)		0641	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114063	KC-01-KITCH 3		0640	X		D	1 x 250	HNO3* First Draw Lead	
1114064	↓ (FLUSH)		0641	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114065	IM-01-KITCH		0644	X		D	1 x 250	HNO3* First Draw Lead	
1114066	DW-01-CAFE		0647	X		D	1 x 250	HNO3* First Draw Lead	
1114067	↓ (FLUSH)		0648	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114068	WC-01-HALL 31A		0652	X		D	1 x 250	HNO3* First Draw Lead	
1114069	BF-01-HALL 1A		0652	X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions		Cooler Temp
		Standard		
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval	Standard			°C
	NJ DEP Reduced Deliverables			
	NJ DEP Full Deliverables			Properly Preserved
	Electronic Data Deliverables			
	PWTA Format			
				Yes
				No

Sampled by: (Print) James Ebert	Date	Time	Received by: (Signature) [Signature]	Date	Time
Sampled by/Relinquished by: (Signature) James Ebert	11/23/21	1414		11/23/21	1414
Relinquished by: (Signature)			Received by: (Signature)		
Relinquished by: (Signature)			Received by: (Signature)		

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike

Williamstown, NJ 08094

Phone: 856-875-3506 Fax: 856-875-3507

www.sjwatertest.com

NJ DEP Certification #08006



Customer: Pine Hill Borough School District
 Contact: Greg Sawyer
 Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
 Phone: (856) 783-6900
 Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	Gr	Comp	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
1114070	DVR-WC-02-HALL 3	11/20/21	0657	X		D	1 x 250	HNO3*	First Draw Lead	
1114071	BF-02-HALL 3		0658	X		D	1 x 250	HNO3*	First Draw Lead	
1114072	WC-01-HALL 3		0702	X		D	1 x 250	HNO3*	First Draw Lead	
1114073	BF-01-HALL 3		0703	X		D	1 x 250	HNO3*	First Draw Lead	
1114074	SO-01-NUR		0705	X		D	1 x 250	HNO3*	First Draw Lead	
1114075	↓ (FLUSH)		0706	X		D	1 x 250	HNO3*	First Draw Lead	FLUSH
1114076	WC-01-HALL		0706	X		D	1 x 250	HNO3*	First Draw Lead	
1114077	BF-01-HALL		0707	X		D	1 x 250	HNO3*	First Draw Lead	
1114078	WC-02-HALL		0709	X		D	1 x 250	HNO3*	First Draw Lead	
1114079	BF-02-HALL		0710	X		D	1 x 250	HNO3*	First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL S/LSLUDGE G/W/GROUND WATER S/W/SURFACE WATER W/W/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory Yes No	Properly Preserved °C

Sampled by:
 (Print) James Eberts

Sampled by/Relinquished by:
 (Signature) Dan J. Eberts

Relinquished by:
 (Signature)

Relinquished by:
 (Signature)

Date	Time	Received by: (Signature)	Date	Time
11/23/21	1414	[Signature]	11/23/21	1414
Date	Time	Received by: (Signature)	Date	Time
Date	Time	Received by: (Signature)	Date	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Pine Hill Borough School District
 Contact: Greg Sawyer
 Address: 1003 Turnerville Road
 Pine Hill, NJ 08021
 Phone: (856) 783-6900
 Office: Fax:

Lab ID#	Sample Location	Collection Date	Time	g	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
1114080	OVR-CS-02-B213(3)	11/20/21	0712	X		D	1 x 250	HNO3* First Draw Lead	
1114081	↓ (FLUSH)		0713	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114082	CS-02-B213(2)		0712	X		D	1 x 250	HNO3* First Draw Lead	
1114083	↓ (FLUSH)		0713	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114084	CS-02-B213(1)		0714	X		D	1 x 250	HNO3* First Draw Lead	
1114085	↓ (FLUSH)		0715	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114086	CS-02-B213(4)		0716	X		D	1 x 250	HNO3* First Draw Lead	
1114087	↓ (FLUSH)		0717	X		D	1 x 250	HNO3* First Draw Lead	FLUSH
1114088	WC-01-HALLS		0719	X		D	1 x 250	HNO3* First Draw Lead	
1114089	↓ BF-01-HALLS		0720	X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DRINKING WATER AQUEOUS SISOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	* HNO3 preserved upon receipt at laboratory Yes No	Properly Preserved Yes No

Sampled by:

(Print) James Eberts

Sampled by/Relinquished by:

(Signature) Jan Kelle

Relinquished by:

(Signature)

Relinquished by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)

Date

11/23/21

Time

1414

Received by:

(Signature)

Overbrook H.S.

Page 6 of 6

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Customer:	Pine Hill Borough School District
Contact:	Greg Sawyer
Address:	1003 Turnerville Road Pine Hill, NJ 08021
Phone:	(856) 783-6900
Office:	Fax:

Lab ID#	Sample Location	Collection Date	Time	Grab	Comp	Matrix	No. of Bottles	Analysis Requested	Comments
T114090	OVER-WC-02-HALL 2	11/20/21	0722	X		D	1 x 250	HNO3* First Draw Lead	
T114091	↓ BF-02-HALL 2	↓	0723	X		D	1 x 250	HNO3* First Draw Lead	
	end			X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	
				X		D	1 x 250	HNO3* First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL S/LSLUDGE G/WG/GROUND WATER S/W/SURFACE WATER W/W/WASTE WATER

Turnaround Time SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	Report Format Standard NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	Comments/Special Instructions * HNO3 preserved upon receipt at laboratory	Cooler Temp °C
			Properly Preserved
		Yes	No

Sampled by: (Print) James Eberts	Date 11/23/21	Time 1414
Sampled by/Relinquished by: (Signature) [Signature]	Date 11/23/21	Time 1414
Relinquished by: (Signature) [Signature]	Date	Time
Relinquished by: (Signature) [Signature]	Date	Time