JURGIEL
JOHN A. JURGIEL & ASSOCIATES, INC.

ST. LOUIS
123 N. Main Street
St. Charles, Missouri 63301
Phone: 636-757-3060

DALLAS/FORT WORTH
2235 St. Andrew Drive
Highland Village, Texas 75077
Phone: 214-735-8055

March 5, 2024

Mr. Michael Smith
Director of Operations
Ritenour School District
2420 Woodson Road
St. Louis, MO 63114

Via: smithm@ritenourschools.org

Re: Lead In Drinking Water Sampling
Wyland Elementary School
February 19, 2024

Dear Michael,

This letter will serve as our report concerning the water sampling conducted at Wyland Elementary School on February 19, 2024, for compliance with the State of Missouri Title XI, Chapter 160.077, "Get The Lead Out of School Drinking Water Act".

Potable water sources for drinking or food preparation such as sinks, faucets, water fountains, ice makers, etc., were identified and first draw water samples were collected after a stagnation period of at least eight hours. Two hundred and fifty milliliter non-preservative plastic containers were utilized for the sample collection. The water samples were analyzed by EPA 200.8 methods at a laboratory accredited for analysis of drinking water by the National Environmental Laboratory Accreditation Program (NELAP) and the Illinois EPA (ILEPA). Results are reported in micrograms per liter (µg/L), which is the same as parts per billion (ppb). Water sample results must be less than (<) 5.0 µg/L or ppb, per the regulation. Results above 5.0 µg/L require corrective actions.

Eighty-five samples were collected, and the results ranged from less than the laboratory limit of detection of 1.0 (<1.0) µg/L to 1,150 µg/L. Twelve of the results were above the mandated threshold of <5.0 µg/L. Corrective actions are warranted for the twelve locations. If these sources will be taken out of service, the source and the supply pipe should be removed or disconnected as close as possible to the remaining active pipes to minimize any dead-end lines that could allow for bacteria or Legionella growth. Sample locations and laboratory results are contained in the attached table.

Sincerely,

Gregory K. Young
Senior Project Manager

TABLE 1
Lead Sampling Results
Wyland Elementary (February 19, 2024)

Sample ID	Location	Results (µg/L)
WYL-1	Classroom 107, Sink Faucet	**80.6**
WYL-2	Classroom 107, Sink Water Fountain	**7.12**
WYL-3	Classroom 108, Sink Faucet	**15.0**
WYL-4	Classroom 108, Sink Water Fountain	4.47
WYL-5	Classroom 106, Sink Faucet	1.32
WYL-6	Classroom 106, Sink Water Fountain	2.56
WYL-7	Hall Water Fountain Near Room 108	< 1.00
WYL-8	Classroom 109, Sink Faucet	**7.34**
WYL-9	Classroom 109, Sink Water Fountain	**36.1**
WYL-10	Classroom 105, Sink Faucet	4.89
WYL-11	Classroom 105, Sink Water Fountain	2.14
WYL-12	Classroom 110, Sink Faucet	3.48
WYL-13	Classroom 110, Sink Water Fountain	1.80
WYL-14	Classroom 104, Sink Faucet	2.47
WYL-15	Classroom 104, Sink Water Fountain	2.62
WYL-16	Hall Water Fountain Near Custodian Room 20	< 1.00
WYL-17	Boy's Restroom 21, Left Sink	< 1.00
WYL-18	Boy's Restroom 21, Right Sink	< 1.00
WYL-19	Girl's Restroom 5, Left Sink	< 1.00
WYL-20	Girl's Restroom 5, Middle Sink	< 1.00
WYL-21	Girl's Restroom 5, Right Sink	< 1.00
WYL-22	Classroom 103, Sink Faucet	1.07
WYL-23	Classroom 103, Sink Water Fountain	3.72

Notes:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Wyland Elementary (February 19, 2024)

Sample ID	Location	Results (µg/L)
WYL-24	Restroom 19, Sink	2.20
WYL-25	Restroom 16, Sink	< 1.00
WYL-26	Classroom 102, Sink Faucet	3.35
WYL-27	Classroom 102, Sink Water Fountain	**10.6**
WYL-28	Classroom 111, Sink Faucet	2.82
WYL-29	Classroom 111, Sink Water Fountain	**7.14**
WYL-30	Classroom 101, Sink Faucet	2.39
WYL-31	Classroom 101, Sink Water Fountain	1.37
WYL-32	Classroom 101, Restroom Sink	< 1.0
WYL-33	Classroom 112, Sink Faucet	1.77
WYL-34	Classroom 112, Sink Water Fountain	3.30
WYL-35	Hall Water Fountain Near Room 100	< 1.00
WYL-36	Classroom 100, Sink Faucet	**1,150**
WYL-37	Classroom 100, Sink Water Fountain	**13.5**
WYL-38	Classroom 100, Restroom Sink	< 1.00
WYL-39	Classroom 115, Sink Faucet	< 1.00
WYL-40	Classroom 115, Sink Water Fountain	< 1.00
WYL-41	Classroom 116, Sink Faucet	3.40
WYL-42	Classroom 116, Sink Water Fountain	1.89
WYL-43	Psychologist Room 121A, Sink	< 1.00
WYL-44	Classroom 119, Sink Faucet	2.45
WYL-45	Classroom 119, Sink Water Fountain	< 1.00
WYL-46	Office Workroom	1.70

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Wyland Elementary (February 19, 2024)

Sample ID	Location	Results (µg/L)
WYL-47	Office Restroom, Sink	< 1.00
WYL-48	Kitchen, Wash Sink	4.96
WYL-49	Kitchen, Restroom Sink	**6.10**
WYL-50	Kitchen, Food Prep Counter, Sink	< 1.00
WYL-51	Kitchen, Dishwashing Area, Left Sink	< 1.00
WYL-52	Kitchen, Dishwashing Area, Right Sink	**6.27**
WYL-53	Kitchen, Dishwashing Area, Sprayer	< 1.00
WYL-54	Cafeteria, Water Fountain	< 1.00
WYL-55	Main Lobby, Water Fountain	< 1.00
WYL-56	Nurse's Office 211, Sink	< 1.00
WYL-57	Nurse's Office 211, Restroom, Sink	< 1.00
WYL-58	Classroom 200, Sink Faucet	1.47
WYL-59	Classroom 200, Sink Water Fountain	2.74
WYL-60	Classroom 201, Sink Faucet	< 1.00
WYL-61	Classroom 201, Sink Water Fountain	1.61
WYL-62	Hall Water Fountain Near Room 202	< 1.00
WYL-63	Classroom 202, Sink Faucet	1.48
WYL-64	Classroom 202, Sink Water Fountain	1.09
WYL-65	Girl's Restroom, Near Custodian's Room 4, Left Sink	< 1.00
WYL-66	Girl's Restroom, Near Custodian's Room 4, Middle Sink	< 1.00
WYL-67	Girl's Restroom, Near Custodian's Room 4, Right Sink	< 1.00
WYL-68	Hall Water Fountain Near Room 209	< 1.00
WYL-69	Boy's Restroom 22, Left Sink	< 1.00

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Wyland Elementary (February 19, 2024)

Sample ID	Location	Results (µg/L)
WYL-70	Boy's Restroom 22, Middle Sink	< 1.00
WYL-71	Boy's Restroom 22, Right Sink	< 1.00
WYL-72	Faculty Lounge, Kitchen Sink	< 1.00
WYL-73	Faculty Lounge, Restroom Sink	< 1.00
WYL-74	Classroom 204, Sink Faucet	3.46
WYL-75	Classroom 204, Sink Water Fountain	1.98
WYL-76	Classroom 205, Sink Faucet	3.48
WYL-77	Classroom 205, Sink Water Fountain	2.99
WYL-78	Classroom 206, Sink Faucet	3.14
WYL-79	Classroom 206, Sink Water Fountain	2.01
WYL-80	Classroom 207, Sink Faucet	1.59
WYL-81	Classroom 207, Sink Water Fountain	**14.8**
WYL-82	Classroom 208, Sink Faucet	1.59
WYL-83	Classroom 208, Sink Water Fountain	< 1.00
WYL-84	Classroom 203, Sink Faucet	< 1.00
WYL-85	Classroom 203, Sink Water Fountain	1.12

Note:
µg/L – micrograms per liter

Sources not sampled:
Wyland Elementary, Boy's Restroom 21, Middle Sink (inoperable)
Wyland Elementary, Classroom 100, Water Fountain (inoperable)
Wyland Elementary, Classroom 118, No Water Sources Tested (Classroom flooded with faucets running wide open)

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

March 04, 2024

Greg Young
Jurgiel & Associates, Inc.
123 North Main Street
St. Charles, MO 63301

RE: Ritenour Drinking Water -Wyland

Dear Greg Young:

Please find enclosed the analytical results for the **85** sample(s) the laboratory received on **2/20/24 1:48 pm** and logged in under work order **HB03341**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order HB03341

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

Case Narrative

The original sample set was collected 02/19/24 and was missing samples WYL-84 and WYL-85. These samples were collected 02/21/24 and were received 2/26/24 @1410. Sample results are included here and report as samples HB03341-84 and HB03341-85.

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-01 **Sampled:** 02/19/24 13:00
Name: WYL - 1 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	80.6	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:25	wjm	EPA 200.8 REV 5.4

Sample: HB03341-02 **Sampled:** 02/19/24 13:00
Name: WYL - 2 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	7.12	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:26	wjm	EPA 200.8 REV 5.4

Sample: HB03341-03 **Sampled:** 02/19/24 13:00
Name: WYL - 3 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	15.0	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:31	wjm	EPA 200.8 REV 5.4

Sample: HB03341-04 **Sampled:** 02/19/24 13:00
Name: WYL - 4 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.47	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:35	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-05
Name: WYL - 5
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.32	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:36	wjm	EPA 200.8 REV 5.4

Sample: HB03341-06
Name: WYL - 6
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.56	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:38	wjm	EPA 200.8 REV 5.4

Sample: HB03341-07
Name: WYL - 7
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:39	wjm	EPA 200.8 REV 5.4

Sample: HB03341-08
Name: WYL - 8
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	7.34	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:40	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-09
Name: WYL - 9
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	36.1	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:42	wjm	EPA 200.8 REV 5.4

Sample: HB03341-10
Name: WYL - 10
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.89	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:43	wjm	EPA 200.8 REV 5.4

Sample: HB03341-11
Name: WYL - 11
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.14	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:44	wjm	EPA 200.8 REV 5.4

Sample: HB03341-12
Name: WYL - 12
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.48	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:46	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-13 **Sampled:** 02/19/24 13:00
Name: WYL - 13 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.80	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:53	wjm	EPA 200.8 REV 5.4

Sample: HB03341-14 **Sampled:** 02/19/24 13:00
Name: WYL - 14 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.47	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:54	wjm	EPA 200.8 REV 5.4

Sample: HB03341-15 **Sampled:** 02/19/24 13:00
Name: WYL - 15 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.62	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:56	wjm	EPA 200.8 REV 5.4

Sample: HB03341-16 **Sampled:** 02/19/24 13:00
Name: WYL - 16 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:57	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-17 **Sampled:** 02/19/24 13:00
Name: WYL - 17 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 10:58	wjm	EPA 200.8 REV 5.4

Sample: HB03341-18 **Sampled:** 02/19/24 13:00
Name: WYL - 18 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:00	wjm	EPA 200.8 REV 5.4

Sample: HB03341-19 **Sampled:** 02/19/24 13:00
Name: WYL - 19 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:01	wjm	EPA 200.8 REV 5.4

Sample: HB03341-20 **Sampled:** 02/19/24 13:00
Name: WYL - 20 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:02	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-21 **Sampled:** 02/19/24 13:00
Name: WYL - 21 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:04	wjm	EPA 200.8 REV 5.4

Sample: HB03341-22 **Sampled:** 02/19/24 13:00
Name: WYL - 22 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.07	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:08	wjm	EPA 200.8 REV 5.4

Sample: HB03341-23 **Sampled:** 02/19/24 13:00
Name: WYL - 23 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.72	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:12	wjm	EPA 200.8 REV 5.4

Sample: HB03341-24 **Sampled:** 02/19/24 13:00
Name: WYL - 24 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.20	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:13	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-25
Name: WYL - 25
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:15	wjm	EPA 200.8 REV 5.4

Sample: HB03341-26
Name: WYL - 26
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.35	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:16	wjm	EPA 200.8 REV 5.4

Sample: HB03341-27
Name: WYL - 27
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	10.6	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:18	wjm	EPA 200.8 REV 5.4

Sample: HB03341-28
Name: WYL - 28
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.82	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:19	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-29 **Sampled:** 02/19/24 13:00
Name: WYL - 29 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	7.14	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:20	wjm	EPA 200.8 REV 5.4

Sample: HB03341-30 **Sampled:** 02/19/24 13:00
Name: WYL - 30 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.39	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:25	wjm	EPA 200.8 REV 5.4

Sample: HB03341-31 **Sampled:** 02/19/24 13:00
Name: WYL - 31 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.37	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:26	wjm	EPA 200.8 REV 5.4

Sample: HB03341-32 **Sampled:** 02/19/24 13:00
Name: WYL - 32 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:27	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-33
Name: WYL - 33
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.77	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:52	wjm	EPA 200.8 REV 5.4

Sample: HB03341-34
Name: WYL - 34
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.30	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:54	wjm	EPA 200.8 REV 5.4

Sample: HB03341-35
Name: WYL - 35
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:55	wjm	EPA 200.8 REV 5.4

Sample: HB03341-36
Name: WYL - 36
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1150	ug/L		02/29/24 10:04	10	10.0	02/29/24 17:59	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-37 **Sampled:** 02/19/24 13:00
Name: WYL - 37 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	13.5	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:58	wjm	EPA 200.8 REV 5.4

Sample: HB03341-38 **Sampled:** 02/19/24 13:00
Name: WYL - 38 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:59	wjm	EPA 200.8 REV 5.4

Sample: HB03341-39 **Sampled:** 02/19/24 13:00
Name: WYL - 39 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:01	wjm	EPA 200.8 REV 5.4

Sample: HB03341-40 **Sampled:** 02/19/24 13:00
Name: WYL - 40 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:05	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-41 **Sampled:** 02/19/24 13:00
Name: WYL - 41 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.40	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:06	wjm	EPA 200.8 REV 5.4

Sample: HB03341-42 **Sampled:** 02/19/24 13:00
Name: WYL - 42 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.89	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:08	wjm	EPA 200.8 REV 5.4

Sample: HB03341-43 **Sampled:** 02/19/24 13:00
Name: WYL - 43 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:12	wjm	EPA 200.8 REV 5.4

Sample: HB03341-44 **Sampled:** 02/19/24 13:00
Name: WYL - 44 **Received:** 02/20/24 13:48
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.45	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:13	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-45
Name: WYL - 45
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:15	wjm	EPA 200.8 REV 5.4

Sample: HB03341-46
Name: WYL - 46
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.70	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:16	wjm	EPA 200.8 REV 5.4

Sample: HB03341-47
Name: WYL - 47
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:18	wjm	EPA 200.8 REV 5.4

Sample: HB03341-48
Name: WYL - 48
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.96	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:22	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-49
Name: WYL - 49
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.10	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:23	wjm	EPA 200.8 REV 5.4

Sample: HB03341-50
Name: WYL - 50
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:24	wjm	EPA 200.8 REV 5.4

Sample: HB03341-51
Name: WYL - 51
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:26	wjm	EPA 200.8 REV 5.4

Sample: HB03341-52
Name: WYL - 52
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.27	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:27	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-53
Name: WYL - 53
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:31	wjm	EPA 200.8 REV 5.4

Sample: HB03341-54
Name: WYL - 54
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:33	wjm	EPA 200.8 REV 5.4

Sample: HB03341-55
Name: WYL - 55
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:34	wjm	EPA 200.8 REV 5.4

Sample: HB03341-56
Name: WYL - 56
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:38	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-57
Name: WYL - 57
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:40	wjm	EPA 200.8 REV 5.4

Sample: HB03341-58
Name: WYL - 58
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.47	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:41	wjm	EPA 200.8 REV 5.4

Sample: HB03341-59
Name: WYL - 59
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.74	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:43	wjm	EPA 200.8 REV 5.4

Sample: HB03341-60
Name: WYL - 60
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:44	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-61
Name: WYL - 61
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.61	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:45	wjm	EPA 200.8 REV 5.4

Sample: HB03341-62
Name: WYL - 62
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:47	wjm	EPA 200.8 REV 5.4

Sample: HB03341-63
Name: WYL - 63
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.48	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:51	wjm	EPA 200.8 REV 5.4

Sample: HB03341-64
Name: WYL - 64
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.09	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:55	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-65
Name: WYL - 65
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:57	wjm	EPA 200.8 REV 5.4

Sample: HB03341-66
Name: WYL - 66
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:58	wjm	EPA 200.8 REV 5.4

Sample: HB03341-67
Name: WYL - 67
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 13:59	wjm	EPA 200.8 REV 5.4

Sample: HB03341-68
Name: WYL - 68
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 14:01	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-69
Name: WYL - 69
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 14:02	wjm	EPA 200.8 REV 5.4

Sample: HB03341-70
Name: WYL - 70
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 14:04	wjm	EPA 200.8 REV 5.4

Sample: HB03341-71
Name: WYL - 71
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:31	wjm	EPA 200.8 REV 5.4

Sample: HB03341-72
Name: WYL - 72
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:33	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-73
Name: WYL - 73
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:34	wjm	EPA 200.8 REV 5.4

Sample: HB03341-74
Name: WYL - 74
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.46	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:36	wjm	EPA 200.8 REV 5.4

Sample: HB03341-75
Name: WYL - 75
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.96	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:37	wjm	EPA 200.8 REV 5.4

Sample: HB03341-76
Name: WYL - 76
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.48	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:41	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-77
Name: WYL - 77
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.99	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:43	wjm	EPA 200.8 REV 5.4

Sample: HB03341-78
Name: WYL - 78
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.14	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:44	wjm	EPA 200.8 REV 5.4

Sample: HB03341-79
Name: WYL - 79
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.01	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:45	wjm	EPA 200.8 REV 5.4

Sample: HB03341-80
Name: WYL - 80
Matrix: Drinking Water - Grab

Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.59	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:47	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-81
Name: WYL - 81
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	14.8	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:51	wjm	EPA 200.8 REV 5.4

Sample: HB03341-82
Name: WYL - 82
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.59	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:52	wjm	EPA 200.8 REV 5.4

Sample: HB03341-83
Name: WYL - 83
Matrix: Drinking Water - Grab
Sampled: 02/19/24 13:00
Received: 02/20/24 13:48

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 11:54	wjm	EPA 200.8 REV 5.4

Sample: HB03341-84
Name: WYL - 84 ROOM 203
Matrix: Drinking Water - Grab
Sampled: 02/21/24 08:00
Received: 02/26/24 14:10

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:24	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HB03341-85
Name: WYL - 85
Matrix: Drinking Water - Grab

Sampled: 02/21/24 08:00
Received: 02/26/24 14:10

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.12	ug/L		02/29/24 10:04	1	1.00	02/29/24 12:26	wjm	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050
TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615
TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553
Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807
USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042
TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389
TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050
Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: Wyland
PURCHASE ORDER #:
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
DATE SHIPPED: 2/19/24
SAMPLER (PLEASE PRINT): Kevin Obermiller
SAMPLER'S SIGNATURE: Kevin Obermiller

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

3 ANALYSIS REQUESTED: LEAD (EPA 200.8)

4 (FOR LAB USE ONLY)
LOGIN # HB03341
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
WYL-1 Water Samples	2/19/24	1:00pm	X		DW	1		X	
-2									
-3									
-4									
-5									
-6									
-7									
-8									
-9									
-10									
-11									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/19/24	4:00pm		2-20-24	950
RELINQUISHED BY: (SIGNATURE)	2-20-24	1348	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)			RECEIVED BY: (SIGNATURE)	2/20/24	1348

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

(1) CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: Wyland
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
SAMPLER (PLEASE PRINT): Kevin Obermiller
SAMPLER'S SIGNATURE: Kevin Obermiller

PURCHASE ORDER #:
DATE SHIPPED: 2/19/24

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

(3) ANALYSIS REQUESTED: LEAD (EPA 200.8)

(4) (FOR LAB USE ONLY)
LOGIN #:
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

(2) SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
WYL-12 Water Samples	2/19/24	1:00pm	X		DW	1		X	
-13									
-14									
-15									
-16									
-17									
-18									
-19									
-20									
-21									
-22									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

(5) TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED:

(6) *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

(7)

RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/19/24	4:00pm		2-20-24	950
RELINQUISHED BY: (SIGNATURE)	2-20-24	1348	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)			RECEIVED BY: (SIGNATURE)	2/20/24	1348

(8) COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 3

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: Wyland
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
PURCHASE ORDER #:
DATE SHIPPED: 2/19/24
SAMPLER (PLEASE PRINT): Kevin Obermiller
SAMPLER'S SIGNATURE: Kevin Obermiller

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

3 ANALYSIS REQUESTED

4 (FOR LAB USE ONLY)
LOGIN #:
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
WYL-23 Water Samples	2/19/24	1:00pm	X		DW	1		X	
-24									
-25									
-26									
-27									
-28									
-29									
-30									
-31									
-32									
-33									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/19/24	4:00pm			
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	2-20-24	1348		2-20-24	950
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
				2/20/24	1348

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

Pace

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 4

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	Wyland	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	2/19/24
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	Kevin Obermiller	WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Kevin Obermiller		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	4 (FOR LAB USE ONLY) REMARKS
WYL-34 Water Sample	2/19/24	1:00pm	X		DW	1		X	
-35									
-36									
-37									
-38									
-39									
-40									
-41									
-42									
-43									
-44									

4 (FOR LAB USE ONLY)
LOGIN #:
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL / RUSH
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE / TIME	RECEIVED BY: (SIGNATURE)	DATE / TIME
Kevin Obermiller	2/19/24 4:00pm		
RELINQUISHED BY: (SIGNATURE)	DATE / TIME	RECEIVED BY: (SIGNATURE)	DATE / TIME
	2-20-24 1348		2-20-24 950
RELINQUISHED BY: (SIGNATURE)	DATE / TIME	RECEIVED BY: (SIGNATURE)	DATE / TIME
			2/20/24 1348

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: Wyland
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
SAMPLER (PLEASE PRINT): Kevin Obermiller
SAMPLER'S SIGNATURE: Kevin Obermiller

PURCHASE ORDER #:
DATE SHIPPED: 2/19/24

MATRIX TYPES: WW-WASTEWATER, DW-DRINKING WATER, GW-GROUND WATER, WWSL-SLUDGE, NAS-NON AQUEOUS SOLID, LCHT-LEACHATE, OIL-OIL, SO-SOIL, SOL-SOLID

3 ANALYSIS REQUESTED: LEAD (EPA 200.8)

4 (FOR LAB USE ONLY)
LOGIN #:
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
WYL-45 Water Sampler	2/19/24	1:00pm	X		DW	1		X	
-46									
-47									
-48									
-49									
-50									
-51									
-52									
-53									
-54									
-55									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/19/24	4:00pm		2-20-24	950
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	2-20-24	1348			
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
				2/20/24	1348

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 6

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	Wyland	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	2/19/24
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	Kevin Obermiller	WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Kevin Obermiller		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
WYL-56 Water Samples	2/19/24	1:00pm	X		DW	1		X	
-57									
-58									
-59									
-60									
-61									
-62									
-63									
-64									
-65									
-66									

4 (FOR LAB USE ONLY)
LOGIN #
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/19/24	4:00pm		2-20-24	950
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	2-20-24	1348			
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
				2/20/24	1349

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT — °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT
REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

Pace

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	Wyland	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	2/19/24
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	Kevin Obermiller	WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WW/SL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREGG YOUNG	Kevin Obermiller		

3 ANALYSIS REQUESTED

4 (FOR LAB USE ONLY)

LOGIN #: _____
LOGGED BY: _____
CLIENT: _____
PROJECT: _____
PROJ. MGR.: _____
CUSTODY SEAL #: _____

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
WYL-67 Water Samples	2/19/24	1:00pm	X		DW	1		X	
-68									
-69									
-70									
-71									
-72									
-73									
-74									
-75									
-76									
-77									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL / RUSH

DATE RESULTS NEEDED:

RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE

EMAIL IF DIFFERENT FROM ABOVE:

PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*

PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/19/24	4:00pm	Cindy	2.20.24	950
Cindy	2-20-24	1348			

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: — °C
TEMPERATURE GUN ID: _____
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE: _____

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 8

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	Wyland	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	2/19/24
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	Kevin Obermiller	WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Kevin Obermiller		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE (CLIENT PROVIDED)	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
WYL-78 Water Samples	2/19/24	1:00pm	X		DW	1		X	
-79									
-80									
-81									
-82									
-83									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

4 (FOR LAB USE ONLY)
LOGIN #:
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	Kevin Obermiller	2/19/24	4:00pm		2-20-24	0950
	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
		2-20-24	1348			
	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
					2/20/24	1348

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT — °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: Wyland
PHONE NUMBER: 636-757-3060
E-MAIL: gyounge@jurgiel.com
SAMPLER (PLEASE PRINT): Kevin Obermiller
SAMPLER'S SIGNATURE: Kevin Obermiller
PURCHASE ORDER #:
DATE SHIPPED:

MATRIX TYPES:
WW-WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

3 ANALYSIS REQUESTED

4 (FOR LAB USE ONLY)
LOGIN #:
LOGGED BY:
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
WYL-84 Room 203 Water Sample	2/21/24	8:00am	X		DW	1		X	
↓ -85	↓	↓	↓		↓	↓		↓	

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7 RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Kevin Obermiller	2/23/24	4:00pm			
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME

8 COMMENTS: (FOR LAB USE ONLY)
SAMPLE TEMPERATURE UPON RECEIPT: °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE: