

Fairfield Public Schools

Lead in Water Sampling Report

Fairfield Ludlowe High School
785 Unquowa Road
Fairfield, CT



Big East Environmental, LLC
Project No. 24220.001



March 11, 2024

Mr. Angelus Papageorge
Executive Director of Operations
Fairfield Public Schools
501 Kings Highway East, Suite 210
Fairfield, CT 06824
apapageorge@fairfieldschools.org

Re: Lead in Water Sampling
Fairfield Ludlowe High School
785 Unquowa Road
Fairfield, CT

Mr. Papageorge,

At your request, Big East Environmental has performed a targeted lead-in-water sampling survey at Fairfield Ludlowe High School (Subject Site) on March 8, 2024. The sampling was conducted in accordance with current Connecticut Department of Public Health (CT DPH) and United States Environmental Protection Agency (US EPA) sampling protocols.

Results of the targeted water sampling have identified concentrations of lead in water below the US EPA lead in water action level of 0.015 parts per million (mg/L).

If you have any questions regarding this report, please feel free to contact us at 203.354.4955 or contact@bigeastlabs.com.

Sincerely,

A handwritten signature in black ink that reads "Eric Gelhaus". The signature is written in a cursive, flowing style.

Eric Gelhaus
CT Lead Inspector/ Risk Assessor #00291
US EPA Risk Assessor LBP-R-1188157-2

SUBJECT SITE:	Fairfield Ludlowe High School 785 Unquowa Road Fairfield, CT
CLIENT:	Fairfield Public Schools c/o Angelus Papageorge 501 Kings Highway east, Suite 210 Fairfield, CT 06824 203-209-9132 apapageorge@fairfieldschools.org
INSPECTION DATE:	March 8, 2024
BIG EAST PROJECT #:	24220.001

INTRODUCTION

Big East Environmental, LLC has performed targeted lead in water sampling at Fairfield Ludlowe High School, Fairfield, CT (Subject Site) in accordance with Connecticut Department of Public Health and United States Environmental Protection Agency lead in water sampling protocols. The subject site serves as a public education facility.

METHODS

Big East Environmental collected first draw and flush water samples from client selected water outlets which are used or have the potential to be used for drinking and/or cooking. The sampling plan was developed in accordance with the US EPA's Lead and Copper Rule 40 CFR Part 141 Subpart I. School maintenance personnel was directed to not open the taps for a minimum of eight hours prior to sample collection. Representative first-draw water samples were collected into 250ml bottles containing a NHO_3 preservative. The tap was then flushed for two-minutes upon which a second "flush" sample was collected into a 250ml bottle with NHO_3 preservative. All samples, once collected, were labeled with a unique individual sample ID, stored in a cooler, and transported to Phoenix Environmental Laboratories, Inc. under chain of custody protocol. The laboratory report is attached in Appendix A of this report.

APPLICABLE REGULATIONS

Water sample analysis results were applied to the United States Environmental Protection Agency's (US EPA) Lead and Copper Rule, 40 CFR Part 141.80, which establishes an action level of 15 parts per billion (15 $\mu\text{g/L}$) / 0.015 parts per million (15 mg/L) for lead in water.

For purposes of this report, all units have been reported and discussed in "parts per million" / "mg/L."

FINDINGS

Concentrations of lead in water samples have not exceeded the US EPA's action level of 0.015 mg/L (ppm). Please see Table I below for summary of water sample results.

TABLE I: WATER SAMPLE RESULTS

SAMPLE ID	LOCATION	SOURCE	1 st DRAW	FLUSH	RESULTS (mg/L)
W-01-A #5	1 st Floor Cafeteria	Fountain	X		<0.0005
W-01-B #5				X	<0.0005
W-02-A #6	1 st Floor Culinary Class	Sink	X		<0.0005
W-02-B #6				X	<0.0005
W-03-A #9	2 nd Floor Webster Hall	Fountain	X		<0.0005
W-03-B #9				X	<0.0005
W-04-A #8	2 nd Floor Library	Fountain	X		0.0039
W-04-B #8				X	0.0021
W-05-A #10	3 rd Floor Biology Wing	Fountain	X		<0.0005
W-05-B #10				X	<0.0005
W-06-A #11	3 rd Floor Warner Hall	Fountain	X		<0.0005
W-06-B #11				X	<0.0005
W-07-A #12	3 rd Floor Room 313	Eye Wash Station	X		0.0076
W-07-B #12				X	0.0111
W-08-A #7	2 nd Floor Nurse Office	Sink	X		0.0006
W-08-B #7				X	<0.0005
W-09-A #4	1 st Floor Orchestra Hall	Fountain	X		<0.0005
W-09-B #4				X	<0.0005
W-10-A #3	1 st Floor Main Gym Hall	Fountain	X		<0.0005
W-10-B #3				X	<0.0005
W-11-A #2	Lower-Level Locker Hall	Fountain	X		<0.0005
W-11-B #2				X	<0.0005
W-12-A #1	Lower-Level CAD Hall	Bottle Fill Station	X		<0.0005
W-12-B #1				X	<0.0005

BOLD # indicates Action Level Exceedance

mg/L – milligrams per liter of water / parts per million

SUMMARY

Laboratory analysis of water samples has not detected levels of lead in any of the tested sources above the US Environmental Protections Agencies action level for lead in water.

Sincerely,



Eric Gelhaus
Senior Project Manager
CT DPH Lead Inspector/ Risk Assessor
US EPA Risk Assessor



ATTACHMENT A

Laboratory Analysis Report



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23217

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W01 A #5

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23218

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W01 B #5

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23219

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W02 A #6

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23220

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W02 B #6

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23221

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W03 A #9

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23222

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W03 B #9

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23223

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W04 A #8

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0039	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23224

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W04 B #8

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0021	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23225

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W05 A #10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23226

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W05 B #10

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23227

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W06 A #11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23228

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W06 B #11

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23229

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W07 A #12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0076	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23230

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W07 B #12

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0111	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23231

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W08 A #7

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	0.0006	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23232

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W08 B #7

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23233

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W09 A #4

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23234

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W09 B #4

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23235

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W10 A #3

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23236

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W10 B #3

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23237

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W11 A #2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23238

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W11 B #2

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23239

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W12 A #1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow



Environmental Laboratories, Inc.

587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102 Fax (860) 645-0823

Analysis Report

March 11, 2024

FOR: Attn: Mr. Steve Dinapoli
Big East Environmental LLC
57 Chestnut Street Unit 10
Norwalk, CT 06854

Sample Information

Matrix: DRINKING WATER
Location Code: BIG-EAST
Rush Request: 24 Hour
P.O.#:

Custody Information

Collected by:
Received by: SR1
Analyzed by: see "By" below

Date

03/08/24
03/08/24

Time

7:00
14:10

Laboratory Data

SDG ID: GCQ23217
Phoenix ID: CQ23240

Project ID: FAIRFIELD LUDLOWE HIGH SCHOOL
Client ID: W12 B #1

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Lead	< 0.0005	0.0005	2	mg/L	0.015			03/11/24	CPP	E200.8
Total Metal Digestion (MS)	Completed							03/08/24	BF	E200.8

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): 40 CFR Part 141.80 Lead & Copper ALs.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200.
The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

March 11, 2024

Official Report Release To Follow

Sample Criteria Exceedances Report
GCQ23217 - BIG-EAST

Criteria: CT: DW

State: CT

SampNo	Acode	Phoenix Analyte	Criteria	Result	RL	Criteria	RL Criteria	Analysis Units
--------	-------	-----------------	----------	--------	----	----------	----------------	-------------------

*** No Data to Display ***

Phoenix Laboratories does not assume responsibility for the data contained in this exceedance report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



ATTACHMENT B

Licensing and Certifications

United States Environmental Protection Agency

This is to certify that

Big East Environmental

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires November 13, 2026

LBP-F179377-3

Certification #

November 15, 2023

Issued On



Michelle Price, Chief

Lead, Heavy Metals, and Inorganics Branch

United States Environmental Protection Agency

This is to certify that



Eric S Gelhaus

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories


This certification is valid from the date of issuance and expires June 20, 2025

LBP-R-I188157-2

Certification #

June 17, 2022

Issued On



Ben Conetta, Chief

Chemicals and Multimedia Programs Branch

STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT

THE INDIVIDUAL NAMED BELOW IS CERTIFIED
BY THIS DEPARTMENT AS A
LEAD INSPECTOR RISK ASSESSOR

ERIC S GELHAUS

CERTIFICATE NO.

002291

CURRENT THROUGH


08/31/24

VALIDATION NO.

03-062918



SIGNATURE



COMMISSIONER

STATE OF CONNECTICUT

DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT

THE INDIVIDUAL NAMED BELOW IS CERTIFIED
BY THIS DEPARTMENT AS A
LEAD PLANNER/PROJECT DESIGNER

ERIC S GELHAUS

CERTIFICATE NO.

002177

CURRENT THROUGH


08/31/24

VALIDATION NO.

03-062916



SIGNATURE



COMMISSIONER

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

PURSUANT TO THE PROVISIONS OF THE GENERAL STATUTES OF CONNECTICUT

THE INDIVIDUAL NAMED BELOW IS LICENSED
BY THIS DEPARTMENT AS A
LEAD CONSULTANT CONTRACTOR

BIG EAST ENVIRONMENTAL

LICENSE NO.

002099

CURRENT THROUGH

11/30/24

VALIDATION NO.

03-072388

SIGNATURE

COMMISSIONER