


Eastern Analytical Services, Inc.

Page 1 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2463672	Custodians Lunch Room - Water Fountain - Elkay EZ H2O	Water	BDL < 0.001 mg/L
2 2463673	Custodians Room/Closet - Slop Sink	Water	BDL < 0.001 mg/L
3 2463674	Cafeteria - Serving Line "B" - Hand Washing Sink	Water	0.047 mg/L
4 2463675	Cafeteria - Serving Line "A" - Sink	Water	0.002 mg/L
5 2463676	Room 104E - Storage - Slop Sink	Water	BDL < 0.001 mg/L
6 2463677	Restroom Near Room 104E - Sink	Water	BDL < 0.001 mg/L
8 2463680	Girls Locker Room - Bathroom Near Room 104 - Sink #1 (Left to Right)	Water	BDL < 0.001 mg/L
9 2463681	Girls Locker Room - Bathroom Near Room 104 - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
11 2463682	Room 103E - Girls Coaches Office - Sink	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 2 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
12 2463683	Room 1031 - Boys Coaches Office	Water	BDL < 0.001 mg/L
13 2463684	Boys Locker Room - Bathroom - Room 103J - Sink #2 (Left to Right)	Water	0.001 mg/L
14 2463685	Boys Locker Room - Bathroom - Room 103J - Sink #3 (Left to Right)	Water	BDL < 0.001 mg/L
15 2463686	Bathroom - Near Room 109C - Sink	Water	0.003 mg/L
16 2463687	Training Room/Coaches Office/Room 1070 - Sink	Water	0.001 mg/L
17 2463688	Training Room/Coaches Office/Room 1070 - Ice Machine	Water	0.001 mg/L
18 2463689	Room 106W Commons Womens Bathroom - Sink #1 (Left to Right)	Water	0.001 mg/L
19 2463690	Room 106W Commons Womens Bathroom - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
20 2463691	Room 106M - Mens Bathroom - Sink #1 (Left to Right)	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 3 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
21 2463692	Room 106M - Mens Bathroom - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
22 2463693	Room 110 - Computer Lab - Sink #1 (Left to Right)	Water	0.005 mg/L
23 2463694	Room 110 - Computer Lab - Sink #2 (Left to Right)	Water	0.002 mg/L
24 2463695	Room 112 - Sink #1 - Art Room (Left to Right)	Water	BDL < 0.001 mg/L
25 2463696	Room 112 - Sink #2 - Art Room (Left to Right)	Water	BDL < 0.001 mg/L
26 2463697	Room 11 - Sink #1 (Left to Right)	Water	BDL < 0.001 mg/L
27 2463698	Room 11 - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
28 2463699	Womens Bathroom Near 113A - Sink	Water	0.019 mg/L
29 2463700	Mens Bathroom Near 113A - Sink	Water	0.006 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 4 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
31 2463701	Room 118 - Music Room - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
33 2463704	Room 119F - Storage Room - Slop Sink	Water	0.003 mg/L
34 2463705	Mens Bathroom - Next to Room 119F - Sink	Water	BDL < 0.001 mg/L
35 2463706	Room 119 - Health Office - Sink	Water	0.002 mg/L
36 2463707	Room 119 - Health Office Bathroom - Sink	Water	0.002 mg/L
37 2463708	Mens Room - Next to Room 119 - Sink	Water	BDL < 0.001 mg/L
38 2463709	Room 121 - Teacher Lounge - Sink	Water	BDL < 0.001 mg/L
39 2463710	Room 121 - Teacher Lounge Bathroom - Sink	Water	BDL < 0.001 mg/L
40 2463711	Classroom 127 - Sink	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 5 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
41 2463712	Room 126 - Science Lab - Sink #1 - Enter Door Near Eye Wash Station (Left to Right)	Water	0.005 mg/L
42 2463713	Room 126 - Science Lab - Sink #2 - Enter Door Near Eye Wash Station (Left to Right)	Water	0.030 mg/L
43 2463714	Room 126 - Science Lab - Sink #3 - Enter Door Near Eye Wash Station (Left to Right)	Water	0.003 mg/L
44 2463715	Room 126 - Science Lab - Sink #4 - Enter Door Near Eye Wash Station (Left to Right)	Water	0.003 mg/L
45 2463716	Room 126 - Science Lab - Sink #5 - Enter Door Near Eye Wash Station (Left to Right)	Water	0.002 mg/L
46 2463717	Room 126 - Science Lab - Sink #6 - Hot Water Only	Water	0.002 mg/L
47 2463718	Room 126 - Science Lab - Sink #7	Water	0.001 mg/L
48 2463719	Room 126 - Science Lab - Sink #8	Water	0.011 mg/L
49 2463720	Womens Restroom - Next to Room 129 - Sink #1 (Left to Right)	Water	0.004 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

ATHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 6 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
50 2463721	Womens Restroom - Next to Room 129 - Sink #2 (Left to Right)	Water	0.004 mg/L
51 2463722	Classroom 130 - Science Lab - Sink #1 - Enter Door Near Library Side (Left to Right)	Water	0.033 mg/L
52 2463723	Classroom 130 - Science Lab - Sink #2 - Near Prep Room Side (Left to Right)	Water	0.005 mg/L
53 2463724	Classroom 130 - Science Lab - Sink #3 - Near Prep Room Side (Left to Right)	Water	0.013 mg/L
54 2463725	Classroom 130 - Science Lab - Sink #4 - Near Prep Room Side (Left to Right)	Water	0.006 mg/L
55 2463726	Classroom 130 - Science Lab - Sink #5	Water	0.004 mg/L
56 2463727	Classroom 130 - Science Lab - Sink #6	Water	0.009 mg/L
57 2463728	Classroom 130 - Science Lab - Sink #7	Water	0.005 mg/L
58 2463729	Classroom 130 - Science Lab - Sink #8	Water	0.003 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 7 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
59 2463730	Room 132 - Prep Room - Sink #1 (Left to Right)	Water	0.010 mg/L
60 2463731	Room 132 - Prep Room - Sink #2 (Left to Right)	Water	0.004 mg/L
61 2463732	Room 129B - Custodians Closet - Slop Sink	Water	0.004 mg/L
62 2463733	Mens Room - Next to Kitchen - Room 131 - Sink	Water	0.005 mg/L
63 2463734	Mens Room - Next to Room 143E - Sink	Water	0.001 mg/L
64 2463735	Womens Bathroom - Next to Room 140 - Sink	Water	BDL < 0.001 mg/L
65 2463736	Room 143J - Custodians Closet - Slop Sink	Water	0.001 mg/L
66 2463737	Boys Bathroom - Room 145B - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
67 2463738	Womens Bathroom - Room 145G - Sink #1 (Left to Right)	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 8 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
68 2463739	Womens Bathroom - Room 1456 - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
69 2463740	Womens Bathroom - Room 1456 - Sink #3 (Left to Right)	Water	BDL < 0.001 mg/L
70 2463741	Classroom 201 Bathroom - Sink	Water	BDL < 0.001 mg/L
71 2463742	Classroom 203 Bathroom - Sink	Water	0.001 mg/L
72 2463743	Classroom 204 & 206 - Shared Bathroom - Sink	Water	0.001 mg/L
73 2463744	Classroom 205 Bathroom - Sink	Water	0.001 mg/L
74 2463745	Girls Bathroom - Next to Room 213A - Sink	Water	0.005 mg/L
75 2463746	Room 213A - Custodians Closet - Slop Sink	Water	0.025 mg/L
76 2463747	Boys Bathroom - Next to Room 213A - Sink	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 9 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
77 2463748	Room 212 - Sink - Sink is Located Between 212 & 214	Water	0.002 mg/L
78 2463749	Room 215 - Science Room - Sink #2 (Left to Right)	Water	0.009 mg/L
79 2463750	Room 215 - Science Room - Sink #3 (Left to Right)	Water	0.075 mg/L
80 2463751	Room 215 - Science Room - Sink #4 - Bench Closet to Door (Left to Right)	Water	0.003 mg/L
81 2463752	Room 215 - Science Room - Sink #5 (Left to Right)	Water	0.035 mg/L
82 2463753	Room 215 - Science Room - Sink #6 (Left to Right)	Water	0.242 mg/L
83 2463754	Room 215 - Science Room - Sink #7 (Left to Right)	Water	0.184 mg/L
84 2463755	Room 215 - Science Room - Sink #8 (Left to Right)	Water	0.029 mg/L
85 2463756	Room 215 - Science Room - Sink #9 (Left to Right)	Water	0.410 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

ATHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 10 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
86 2463757	Room 215 - Science Room - Sink #10 (Left to Right)	Water	0.006 mg/L
87 2463758	Room 215 - Science Room - Sink #11 (Left to Right)	Water	0.115 mg/L
88 2463759	Room 215 - Science Room - Sink #12 (Left to Right)	Water	0.039 mg/L
89 2463760	Room 215 - Science Room - Sink #13 (Left to Right)	Water	0.052 mg/L
90 2463761	Room 215 - Science Room - Sink #14 (Left to Right)	Water	0.052 mg/L
91 2463762	Room 217 - Science Lab - Sink #1 (Left to Right)	Water	0.015 mg/L
92 2463763	Room 217 - Science Lab - Sink #2 (Left to Right)	Water	0.036 mg/L
93 2463764	Room 217 - Science Lab - Sink #3 (Left to Right)	Water	0.016 mg/L
94 2463765	Room 217 - Science Lab - Sink #4 (Left to Right)	Water	0.007 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 11 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
95 2463766	Room 217 - Science Lab - Sink #5 (Left to Right)	Water	0.008 mg/L
96 2463767	Room 217 - Science Lab - Sink #6 (Left to Right)	Water	0.006 mg/L
97 2463768	Room 217 - Science Lab - Sink #7 (Left to Right)	Water	0.048 mg/L
98 2463769	Room 217 - Science Lab - Sink #8 (Left to Right)	Water	0.004 mg/L
99 2463770	Room 217 - Science Lab - Fume Hood - Sink #9 (Left to Right)	Water	0.863 mg/L
100 2463771	Room 217 - Science Lab - Sink #10 (Left to Right)	Water	0.068 mg/L
101 2463772	Room 217 - Science Lab - Sink #11 (Left to Right)	Water	0.048 mg/L
102 2463773	Room 217 - Science Lab - Sink #12 (Left to Right)	Water	0.025 mg/L
103 2463774	Room 217 - Science Lab - Sink #13 (Left to Right)	Water	0.009 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 12 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
104 2463775	Room 217 - Science Lab - Sink #14 (Left to Right)	Water	0.014 mg/L
105 2463776	Room 217 - Science Lab - Sink #15 (Left to Right)	Water	0.006 mg/L
106 2463777	Room 219 - Science Lab - Sink #1 - Enter Near Prep Room (Left to Right)	Water	0.257 mg/L
107 2463778	Room 219 - Science Lab - Sink #2 (Left to Right)	Water	0.007 mg/L
108 2463779	Room 219 - Science Lab - Sink #3 (Left to Right)	Water	0.004 mg/L
109 2463780	Room 219 - Science Lab - Sink #4 (Left to Right)	Water	0.010 mg/L
110 2463781	Room 219 - Science Lab - Sink #5 (Left to Right)	Water	0.007 mg/L
111 2463782	Room 219 - Science Lab - Sink #6 (Left to Right)	Water	0.002 mg/L
112 2463783	Room 219 - Science Lab - Sink #7 (Left to Right)	Water	0.005 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 13 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
113 2463784	Room 219 - Science Lab - Sink #8 (Left to Right)	Water	0.006 mg/L
114 2463785	Room 219 - Science Lab - Sink #9 (Left to Right)	Water	0.005 mg/L
115 2463786	Room 219 - Science Lab - Sink #10 (Left to Right)	Water	0.015 mg/L
116 2463787	Room 219 - Science Lab - Sink #11 (Left to Right)	Water	0.002 mg/L
117 2463788	Prep Room Between Room 217 & 216	Water	0.093 mg/L
118 2463789	Room 218 - Science Lab - Sink #1 Enter Near Eye Wash Station (Left to Right)	Water	0.055 mg/L
119 2463790	Room 218 - Science Lab - Sink #2 (Left to Right)	Water	0.006 mg/L
120 2463791	Room 218 - Science Lab - Sink #3 (Left to Right)	Water	0.039 mg/L
121 2463792	Room 218 - Science Lab - Sink #4 (Left to Right)	Water	0.002 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 14 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
122 2463793	Room 218 - Science Lab - Sink #5 (Left to Right)	Water	0.001 mg/L
123 2463794	Room 218 - Science Lab - Sink #6 (Left to Right)	Water	0.004 mg/L
124 2463795	Room 218 - Science Lab - Sink #7 (Left to Right)	Water	0.001 mg/L
125 2463796	Room 220 - Science Lab - Sink #1 Enter Near Fume Hood (Left to Right)	Water	0.084 mg/L
126 2463797	Room 220 - Science Lab - Sink #2 (Left to Right)	Water	0.011 mg/L
127 2463798	Room 220 - Science Lab - Sink #3 (Left to Right)	Water	0.014 mg/L
128 2463799	Room 220 - Science Lab - Sink #4 (Left to Right)	Water	0.019 mg/L
129 2463800	Room 220 - Science Lab - Sink #5 (Left to Right)	Water	0.021 mg/L
130 2463801	Room 220 - Science Lab - Sink #6 (Left to Right)	Water	0.006 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
131 2463802	Womens Bathroom - Next to Room 221 - Sink #1 (Left to Right)	Water	0.004 mg/L
132 2463803	Womens Bathroom - Next to Room 22 - Sink #2 (Left to Right)	Water	0.002 mg/L
133 2463804	Room 221 - Prep Room - Sink #1	Water	0.046 mg/L
134 2463805	Room 221 - Prep Room - Sink #2	Water	0.091 mg/L
135 2463806	Room 221 - Prep Room - Sink #3	Water	0.178 mg/L
136 2463807	Room 224 - Science Lab - Sink #1 - Enter Door Near Fume Hood (Left to Right)	Water	0.050 mg/L
137 2463808	Room 224 - Science Lab - Sink #2 (Left to Right)	Water	0.007 mg/L
138 2463809	Room 224 - Science Lab - Sink #3 (Left to Right)	Water	0.032 mg/L
139 2463810	Room 224 - Science Lab - Sink #4 (Left to Right)	Water	0.394 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 16 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
140 2463811	Room 224 - Science Lab - Sink #5 (Left to Right)	Water	0.046 mg/L
141 2463812	Room 224 - Science Lab - Sink #6 (Left to Right)	Water	0.020 mg/L
142 2463813	Room 224 - Science Lab - Sink #7 - Hot Water Only (Left to Right)	Water	0.034 mg/L
143 2463814	Room 224 - Science Lab - Sink #8 (Left to Right)	Water	0.034 mg/L
144 2463815	Room 223B - Storage Room - Slop Sink	Water	0.005 mg/L
145 2463816	Room 226 - Science Lab - Sink #1 (Left to Right)	Water	0.010 mg/L
146 2463817	Room 226 - Science Lab - Sink #2 (Left to Right)	Water	0.105 mg/L
147 2463818	Room 226 - Science Lab - Sink #3 (Left to Right)	Water	0.007 mg/L
148 2463819	Room 226 - Science Lab - Sink #4 (Left to Right)	Water	0.013 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


APIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 17 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/08/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
149 2463820	Room 226 - Science Lab - Sink #5 (Left to Right)	Water	0.006 mg/L
150 2463821	Room 226 - Science Lab - Sink #6 (Left to Right)	Water	0.001 mg/L
151 2463822	Room 226 - Science Lab - Sink #7 (Left to Right)	Water	1.311 mg/L
152 2463823	Room 226 - Science Lab - Sink #8 (Left to Right)	Water	0.009 mg/L
153 2463824	Room 226 - Science Lab - Sink #9 (Left to Right)	Water	0.013 mg/L
154 2463825	Room 226 - Science Lab - Sink #10 (Left to Right)	Water	0.021 mg/L
155 2463826	Mens Room - Next to Room 225 - Sink	Water	0.001 mg/L
156 2463827	Room 225 - Science Lab - Sink #1 (Left to Right)	Water	0.004 mg/L
157 2463828	Room 225 - Science Lab - Sink #2 (Left to Right)	Water	0.072 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 18 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
158 2463829	Room 225 - Scince Lab - Sink #3 (Left to Right)	Water	3.311 mg/L
159 2463830	Room 225 - Scince Lab - Sink #4 (Left to Right)	Water	2.889 mg/L
160 2463831	Room 225 - Scince Lab - Sink #6 (Left to Right)	Water	0.009 mg/L
161 2463832	Room 225 - Scince Lab - Sink #7 (Left to Right)	Water	0.040 mg/L
162 2463833	Mens' Room - Next to Room 241 - Sink #1 (Left to Right)	Water	0.001 mg/L
163 2463834	Men's Room - Next to Room 241 - Sink #2 (Left to Right)	Water	0.001 mg/L
164 2463835	Men's Room - Next to Room 241 - Sink #3 (Left to Right)	Water	0.001 mg/L
165 2463836	Women's Room - Next to Room 241 - Sink #1 (Left to Right)	Water	0.001 mg/L
166 2463837	Women's Room - Next to Room 241 - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 19 of 19

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/08/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
167 2463838	Not Applicable	Water Blank	BDL < 0.001 mg/L
168 2463839	Ice Machine - Kitchen - 3 Bottles Collected & to be Combined	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 1 of 1

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - High School


Date Collected: 11/09/2016

Collected By: S. Coon

Date Received: 11/09/2016

Date Analyzed: 11/11/2016

Analyzed By: Peter P. Argyrakakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2464945	H.S. - Kitchen Bathroom - Staff Bathroom by Room 104 - Sink	Water	0.005 mg/L
2 2464946	H.S. - Women Locker Room by Room 104 - Sink #1	Water	BDL < 0.001 mg/L
3 2464947	H.S. - Music Room #118 - Sink #1	Water	BDL < 0.001 mg/L
4 2464948	H.S. - Women Restroom by Room 113M - Sink	Water	0.001 mg/L
5 2464949	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 1 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2463535	M.S. - Custodian Office Back Room - Sink - By Kitchen	Water	0.002 mg/L
2 2463536	M.S. - Janitor Closet - Water Outlet - Near Kitchen/Storage Room	Water	BDL < 0.001 mg/L
3 2463537	M.S. - Girls Restroom 250G - Sink #1 - Mixing Value	Water	0.005 mg/L
4 2463538	M.S. - Girls Restroom 250G - Sink #2 - Mixing Value	Water	0.012 mg/L
5 2463539	M.S. - Girls Restroom 250G - Sink #3 - Mixing Value	Water	0.002 mg/L
6 2463540	M.S. - Boys Restroom 250B - Sink #1 - Mixing Value	Water	BDL < 0.001 mg/L
7 2463541	M.S. - Boys Restroom 250B - Sink #2 - Mixing Value	Water	0.015 mg/L
8 2463542	M.S. - Boys Restroom 250B - Sink #3 - Mixing Value	Water	0.004 mg/L
9 2463543	M.S. - Girls Restroom 214G - Sink #1 - Mixing Value	Water	0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 2 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School


Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2463544	M.S. - Girls Restroom 214G - Sink #2 - Mixing Value	Water	0.002 mg/L
11 2463545	M.S. - Girls Restroom 214G - Sink #3 - Mixing Value	Water	0.002 mg/L
12 2463546	M.S. - Boys Restroom 214B - Sink #1 - Mixing Value	Water	0.006 mg/L
13 2463547	M.S. - Boys Restroom 214B - Sink #2 - Mixing Value	Water	0.007 mg/L
14 2463548	M.S. - Boys Restroom 214B - Sink #3 - Mixing Value	Water	0.034 mg/L
15 2463549	M.S. - Janitor Closet - Water Outlet - Room 214J	Water	0.020 mg/L
16 2463550	M.S. - Women Bathroom - Next to Assistant Principal - Sink	Water	0.001 mg/L
17 2463551	M.S. - Unisex Bathroom - Next to Womens & Assistant Principal - Sink	Water	0.002 mg/L
18 2463552	M.S. - Science Room 215 - Sink #1 - Tap 1 - Teacher Desk - Closest to White Board	Water	0.002 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 3 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2463553	M.S. - Room 215 - Sink #1 - Tap 2 - Teacher Desk	Water	0.024 mg/L
20 2463554	M.S. - Room 215 - Sink #2	Water	0.154 mg/L
21 2463555	M.S. - Room 215 - Sink #3	Water	0.015 mg/L
22 2463556	M.S. - Room 215A - Prep Room - Sink	Water	0.194 mg/L
23 2463557	M.S. - Room 216 - Sink 1 - Tap 1 - Teacher Desk/Closest to White Board	Water	0.344 mg/L
24 2463558	M.S. - Room 216 - Sink 1 - Tap 2	Water	0.374 mg/L
25 2463559	M.S. - Room 216 - Sink #2	Water	0.018 mg/L
26 2463560	M.S. - Room 216 - Sink #3	Water	0.259 mg/L
27 2463561	M.S. - Room 201 - Sink #1	Water	0.040 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 4 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School


Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2463562	M.S. - Room 201 - Sink #2	Water	0.021 mg/L
29 2463563	M.S. - Room 201 - Sink #3	Water	0.015 mg/L
30 2463564	M.S. - Faculty Room 217 Bathroom - Sink	Water	0.003 mg/L
31 2463565	M.S. - Womens Bathroom Near Library - Sink #1	Water	0.013 mg/L
32 2463566	M.S. - Womens Bathroom Near Library - Sink #2	Water	0.009 mg/L
33 2463567	M.S. - Mens Bathroom - Sink - Near Library/Auditorium	Water	0.022 mg/L
34 2463568	M.S. - Janitor Closet - Water Outlet - Near Library/Auditorium	Water	0.012 mg/L
35 2463569	M.S. - Boys Locker - Janitor Closet 107 - Water Outlet	Water	0.001 mg/L
36 2463570	M.S. - Boys Shower 106 - Sink #1	Water	0.001 mg/L

Eastern Analytical Services, Inc.

Page 5 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School


Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
37 2463571	M.S. - Boys Shower 106 - Sink #2	Water	0.002 mg/L
38 2463572	M.S. - Boys Bathroom 105 - Sink - Next to Boys PE Office)	Water	0.001 mg/L
39 2463573	M.S. - Girls Bathroom 103 - Sink - Next to Girls PE Office)	Water	0.001 mg/L
40 2463574	M.S. - Girls Locker - Janitor Closet 110 - Water Outlet	Water	0.014 mg/L
41 2463575	M.S. - Girls Locker Room Bathroom 111 - Sink #1	Water	0.001 mg/L
42 2463576	M.S. - Girls Locker Room Bathroom 111 - Sink #2	Water	0.001 mg/L
43 2463577	M.S. - Boys Toilet 108B - Sink #1 - Mixing Valve	Water	0.011 mg/L
44 2463578	M.S. - Boys Toilet 108B - Sink #2 - Mixing Valve	Water	0.007 mg/L
45 2463579	M.S. - Boys Toilet 108B - Sink #3 - Mixing Valve	Water	0.007 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 6 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School


Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
46 2463580	M.S. - Boys Toilet 108B - Sink #4 - Mixing Valve	Water	0.005 mg/L
47 2463581	M.S. - Girls Toilet 108G - Sink #1 - Mixing Valve	Water	0.010 mg/L
48 2463582	M.S. - Girls Toilet 108G - Sink #2 - Mixing Valve	Water	0.010 mg/L
49 2463583	M.S. - Girls Toilet 108G - Sink #3 - Mixing Valve	Water	0.011 mg/L
50 2463584	M.S. - Girls Toilet 108G - Sink #4 - Mixing Valve	Water	0.026 mg/L
51 2463585	M.S. - Girls Toilet 108G - Sink #5 - Mixing Valve	Water	0.032 mg/L
52 2463586	M.S. - Nurse Office - First Aid - Closest to Hallway - Sink	Water	0.006 mg/L
53 2463587	M.S. - Nurse Office - First Aid 2 - Sink - Bathroom	Water	0.008 mg/L
54 2463588	M.S. - Main Office Room 123 Bathroom - Sink	Water	0.003 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 7 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
55 2463589	M.S. - Room 408 - Perimeter - Sink #1	Water	0.016 mg/L
56 2463590	M.S. - Room 408 - Perimeter - Sink #2	Water	0.014 mg/L
57 2463591	M.S. - Room 408 - Perimeter - Sink #3 - Teacher Desk	Water	0.254 mg/L
58 2463592	M.S. - Room 408 - Interior - Sink #1	Water	0.006 mg/L
59 2463593	M.S. - Room 408 - Inner - Sink #2	Water	0.007 mg/L
60 2463594	M.S. - Room 408 - Inner - Sink #3	Water	0.008 mg/L
61 2463595	M.S. - Room 408 - Inner - Sink #4	Water	0.009 mg/L
62 2463596	M.S. - Room 408 - Inner - Sink #5	Water	0.012 mg/L
63 2463597	M.S. - Room 408 - Inner - Sink #6	Water	0.004 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 8 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School


Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
64 2463598	M.S. - Room 408 - Inner - Sink #7	Water	0.003 mg/L
65 2463599	M.S. - Room 408 - Inner - Sink #8	Water	0.001 mg/L
66 2463600	M.S. - Room 408 - Inner - Sink #9	Water	0.007 mg/L
67 2463601	M.S. - Room 408 - Inner - Sink #10	Water	0.006 mg/L
68 2463602	M.S. - Room 408 - Inner - Sink #11	Water	0.007 mg/L
69 2463603	M.S. - Room 408 - Inner - Sink #12	Water	0.009 mg/L
70 2463604	M.S. - Room 407 - Teacher Desk - Sink	Water	0.076 mg/L
71 2463605	M.S. - Room 407 - Interior - Sink #1	Water	0.007 mg/L
72 2463606	M.S. - Room 407 - Interior - Sink #2	Water	0.007 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 9 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
73 2463607	M.S. - Room 407 - Interior - Sink #3	Water	0.036 mg/L
74 2463608	M.S. - Room 407 - Interior - Sink #4	Water	0.018 mg/L
75 2463609	M.S. - Room 407 - Interior - Sink #5	Water	0.011 mg/L
76 2463610	M.S. - Room 407 - Interior - Sink #6	Water	0.012 mg/L
77 2463611	M.S. - Room 407 - Interior - Sink #7	Water	0.020 mg/L
78 2463612	M.S. - Room 407 - Interior - Sink #8	Water	0.016 mg/L
79 2463613	M.S. - Room 407 - Interior - Sink #9	Water	0.008 mg/L
80 2463614	M.S. - Room 407 - Interior - Sink #10	Water	0.005 mg/L
81 2463615	M.S. - Room 407 - Interior - Sink #11	Water	0.010 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 10 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
82 2463616	M.S. - Room 407 - Interior - Sink #12	Water	0.021 mg/L
83 2463617	M.S. - Room 406 - Perimeter - Sink #1	Water	0.057 mg/L
84 2463618	M.S. - Room 406 - Perimeter - Sink #2	Water	0.006 mg/L
85 2463619	M.S. - Room 406 - Interior - Sink #1 (Table Closest to Dishwasher)	Water	0.026 mg/L
86 2463620	M.S. - Room 406 - Inner - Sink #2	Water	0.020 mg/L
87 2463621	M.S. - Room 406 - Inner - Sink #3	Water	0.010 mg/L
88 2463622	M.S. - Room 406 - Inner - Sink #4	Water	0.031 mg/L
89 2463623	M.S. - Room 406 - Inner - Sink #5	Water	0.018 mg/L
90 2463624	M.S. - Room 406 - Inner - Sink #6	Water	0.022 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 11 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
91 2463625	M.S. - Room 406 - Inner - Sink #7	Water	0.052 mg/L
92 2463626	M.S. - Room 406 - Inner - Sink #8	Water	0.013 mg/L
93 2463627	M.S. - Room 406 - Inner - Sink #9	Water	0.030 mg/L
94 2463628	M.S. - Room 406 - Inner - Sink #10	Water	0.020 mg/L
95 2463629	M.S. - Room 406 - Inner - Sink #11 (Table Closest to Entrance)	Water	0.014 mg/L
96 2463630	M.S. - Room 406 - Inner - Sink #12 (Table Closest to Entrance)	Water	0.010 mg/L
97 2463631	M.S. - Room 406 - Teacher Desk - Sink	Water	0.019 mg/L
98 2463632	M.S. - Janitor Closet 405A - Water Outlet	Water	0.009 mg/L
99 2463633	M.S. - Tech Ed Room 405 - Sink #1 - Tap #1	Water	0.005 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 12 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016
Collected By: S. Coon
Date Received: 11/05/2016
Date Analyzed: 11/07/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
100 2463634	M.S. - Tech Ed Room 405 - Sink #1 - Tap #2	Water	0.003 mg/L
101 2463635	M.S. - Tech Ed Room 405 - Sink #1 - Tap #3	Water	0.001 mg/L
102 2463636	M.S. - Tech Ed Room 405 - Sink #1 - Tap #4	Water	0.003 mg/L
103 2463637	M.S. - Life Science Room 404 - Sink #1	Water	0.018 mg/L
104 2463638	M.S. - Life Science Room 404 - Sink #2	Water	0.006 mg/L
105 2463639	M.S. - Life Science Room 404 - Sink #3 (Teacher Desk)	Water	0.033 mg/L
106 2463640	M.S. - Life Science Room 404 - Sink #4	Water	0.008 mg/L
107 2463641	M.S. - Life Science Room 404 - Sink #5	Water	0.004 mg/L
108 2463642	M.S. - Room 404B - Prep Room - Sink	Water	0.264 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 13 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
109 2463643	M.S. - Staff Bathroom 405W - Sink (Women Room)	Water	0.009 mg/L
110 2463644	M.S. - Room 405M - Mens Staff Bathroom - Sink	Water	0.014 mg/L
111 2463645	M.S. - Room 403 - Sink #1	Water	0.022 mg/L
112 2463646	M.S. - Room 403 - Sink #2	Water	0.054 mg/L
113 2463647	M.S. - Room 403 - Sink #3	Water	0.003 mg/L
114 2463648	M.S. - Room 403 - Sink #4	Water	0.003 mg/L
115 2463649	M.S. - Room 402B - Prep Room - Sink	Water	0.019 mg/L
116 2463650	M.S. - Room 402 - Sink #1	Water	0.003 mg/L
117 2463651	M.S. - Room 402 - Sink #2	Water	0.006 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 14 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School


Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
118 2463652	M.S. - Room 402 - Sink #3	Water	0.001 mg/L
119 2463653	M.S. - Room 402 - Sink #4	Water	0.002 mg/L
120 2463654	M.S. - Boys Restroom Near LGI - Sink - Mixing Valve	Water	0.114 mg/L
121 2463655	M.S. - Girls Restroom Near LGI - Sink - Mixing Valve	Water	0.009 mg/L
122 2463656	Boys Locker Room 002 - Pool - Sink #1	Water	0.006 mg/L
123 2463657	Boys Locker Room 002 - Pool - Sink #2	Water	0.004 mg/L
124 2463658	M.S. - Pool Coaches Office - Sink - Boys	Water	0.114 mg/L
125 2463659	M.S. - Pool - Womens Coaches	Water	0.036 mg/L
126 2463660	Women Locker - Pool - Sink #1	Water	0.017 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 15 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
127 2463661	Women Locker - Pool - Sink #2	Water	0.022 mg/L
128 2463662	Women Locker - Pool - Sink #3	Water	0.003 mg/L
129 2463663	Womens Locker - Pool - Janitor Closet 010	Water	0.124 mg/L
130 2463664	Mens Locker - Pool - Janitor Closet 009	Water	0.013 mg/L
131 2463665	Pool M/K Bar - Sink	Water	0.042 mg/L
132 2463666	Pool Girls Room 001G - Sink #1 - Mixing Valve	Water	0.139 mg/L
133 2463667	Pool Girls Room 001G - Sink #2 - Mixing Valve	Water	0.071 mg/L
134 2463668	Pool Boys Room 001B - Sink #1 - Mixing Valve	Water	0.094 mg/L
135 2463669	Pool Boys Room 001B - Sink #2 - Mixing Valve	Water	0.229 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 16 of 16

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Middle School

Date Collected: 11/05/2016

Collected By: S. Coon

Date Received: 11/05/2016

Date Analyzed: 11/07/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
136 2463670	M.S. - Kitchen Bathroom - Sink	Water	BDL < 0.001 mg/L
Pool Fill 2463671	Mech Room by Pool - Water Outlet That Fills Pool	Water	0.002 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 1 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
169 2463840	Room 59 - Art Room - Sink #1 (Left to Right)	Water	0.001 mg/L
170 2463841	Room 59 - Art Room - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
171 2463842	Room 59 - Art Room - Sink #3 - Hot Water Only (Left to Right)	Water	0.002 mg/L
172 2463843	Room 59 - Art Room - Sink #4 - Hot Water Only (Left to Right)	Water	BDL < 0.001 mg/L
173 2463844	Room 58 - Art Room - Sink #1 (Left to Right)	Water	0.003 mg/L
174 2463845	Room 58 - Art Room - Sink #2 (Left to Right)	Water	0.003 mg/L
175 2463846	Boys Room - Next to Room 58 - Sink #1 (Left to Right)	Water	0.015 mg/L
176 2463847	Boys Room - Next to Room 58 - Sink #2 (Left to Right)	Water	0.043 mg/L
177 2463848	Girls Room - Next to Room 58 - Sink #1 (Left to Right)	Water	0.018 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 2 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
178 2463849	Girls Room - Next to Room 58 - Sink #2 (Left to Right)	Water	0.018 mg/L
179 2463850	Girls Room - Next to Room 58 - Sink #3 (Left to Right)	Water	0.015 mg/L
180 2463851	Girls Room - Next to Room 58 - Sink #4 (Left to Right)	Water	0.006 mg/L
181 2463852	Room 54 - Music Room - Sink	Water	0.001 mg/L
182 2463853	Room 56 - OP/PT Room - Sink	Water	0.002 mg/L
183 2463854	Custodian Closet - Slop Sink - Next to Room 58	Water	0.002 mg/L
184 2463855	Faculty Bathroom - Sink	Water	BDL < 0.001 mg/L
185 2463856	Womens Room - Next to Main Office - Sink #1 (Left to Right)	Water	BDL < 0.001 mg/L
186 2463857	Womens Room - Next to Main Office - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 3 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
187 2463858	Classroom 52 - Sink - Music Room	Water	0.003 mg/L
188 2463859	Womens Room - Room 11A - Sink	Water	0.002 mg/L
189 2463860	Mens Bathroom - Room 11 - Sink	Water	0.005 mg/L
190 2463861	Room 12C - Conference Room - Sink	Water	0.024 mg/L
191 2463862	Room 12C - Faculty Bathroom - Sink	Water	0.007 mg/L
192 2463863	Room 12A - Sink	Water	0.035 mg/L
193 2463864	Room 12 Bathroom - Sink	Water	0.013 mg/L
194 2463865	Room 12 - Sink	Water	0.010 mg/L
195 2463866	Boys Bathroom - Near Room 12 - Sink	Water	0.010 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 4 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
196 2463867	Girls Bathroom - Near Room 12 - Sink #2 (Left to Right)	Water	0.006 mg/L
197 2463868	Girls Bathroom - Near Room 12 - Sink #3 (Left to Right)	Water	0.040 mg/L
198 2463869	Room 10 - Sink	Water	0.038 mg/L
199 2463870	Room 10 Bathroom - Sink	Water	0.042 mg/L
200 2463871	Room 9 - Sink	Water	0.030 mg/L
201 2463872	Room 7 - Sink	Water	0.009 mg/L
202 2463873	Room 8	Water	0.068 mg/L
203 2463874	Room 8 Bathroom - Sink	Water	0.033 mg/L
205 2463875	Room 6 - Sink	Water	0.010 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 5 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
206 2463876	Room 6 Bathroom - Sink	Water	0.007 mg/L
207 2463877	Room 3 Bathroom - Sink	Water	0.008 mg/L
208 2463878	Room 4 - Sink	Water	0.428 mg/L
209 2463879	Room 4 Bathroom - Sink	Water	0.275 mg/L
210 2463880	Room 2 Bathroom - Sink - Near CR 2 Sink	Water	0.902 mg/L
211 2463881	Room 2 Bathroom - Sink	Water	0.602 mg/L
212 2463882	Room 2 - Sink	Water	0.002 mg/L
213 2463883	Room 1 - Sink	Water	0.014 mg/L
214 2463884	Room 1 Bathroom - Sink - Near CR Sink	Water	0.049 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 6 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
215 2463885	Room 1 Bathroom - Sink	Water	0.654 mg/L
216 2463886	Custodians Closet - Slop Sink - Near Room 014	Water	0.005 mg/L
217 2463887	Room 14 - Sink	Water	0.016 mg/L
218 2463888	Room 11 - Sink	Water	0.502 mg/L
219 2463889	Room 16 - Sink	Water	0.032 mg/L
220 2463890	Room 15 - Sink	Water	0.026 mg/L
221 2463891	Room 17 - Sink	Water	0.018 mg/L
222 2463892	Room 18 - Sink	Water	0.086 mg/L
223 2463893	Girls Bathroom - Sink #1 - Near CR 31 (Left to Right)	Water	0.013 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 7 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School


Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
224 2463894	Girls Bathroom - Sink #2 - Near CR 31 (Left to Right)	Water	0.025 mg/L
225 2463895	Boys Bathroom - Sink #1 - Near CR 31 (Left to Right)	Water	0.012 mg/L
226 2463896	Boys Bathroom - Sink #2 - Near CR 31 (Left to Right)	Water	0.010 mg/L
227 2463897	Custodians Closet - Slop Sink - Near CR 31	Water	0.033 mg/L
228 2463898	Room 31 - Sink	Water	0.014 mg/L
229 2463899	Room 32 - Sink	Water	0.012 mg/L
230 2463900	Room 33 - Sink	Water	0.005 mg/L
231 2463901	Room 34 - Sink	Water	0.011 mg/L
232 2463902	Room 36 - Sink	Water	0.019 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
233 2463903	Room 35 - Sink	Water	0.014 mg/L
234 2463904	Boys Bathroom - Sink #1 - Near Book Storage Upper Gym (Left to Right)	Water	0.003 mg/L
235 2463905	Boys Bathroom - Sink #2 - Near Book Storage Upper Gym (Left to Right)	Water	BDL < 0.001 mg/L
236 2463906	Girls Bathroom - Sink #1 - Near Book Storage Upper Gym (Left to Right)	Water	BDL < 0.001 mg/L
237 2463907	Girls Bathroom - Sink #2 - Near Book Storage Upper Gym (Left to Right)	Water	0.001 mg/L
238 2463908	Custodians Closet - Slop Sink	Water	0.004 mg/L
239 2463909	Room 41 - Sink	Water	0.007 mg/L
240 2463910	Room 41 Bathroom - Sink	Water	BDL < 0.001 mg/L
241 2463911	Room 42 - Sink	Water	0.002 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 9 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
242 2463912	Room 42 Bathroom - Sink	Water	0.003 mg/L
243 2463913	Room 43 - Sink	Water	0.001 mg/L
244 2463914	Room 46 - Sink	Water	0.001 mg/L
245 2463915	Room 45 - Sink	Water	BDL < 0.001 mg/L
246 2463916	Room 45 Bathroom - Sink	Water	BDL < 0.001 mg/L
247 2463917	Girls Bathroom - Near CR #2 - Sink #1 (Left to Right)	Water	0.008 mg/L
248 2463918	Girls Bathroom - Near CR #2 - Sink #2 (Left to Right)	Water	0.005 mg/L
249 2463919	Girls Bathroom - Near CR #2 - Sink #3 (Left to Right)	Water	0.015 mg/L
250 2463920	Boys Bathroom - Near CR #2 - Sink #1 (Left to Right)	Water	0.006 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 10 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
251 2463921	Boys Bathroom - Near CR #2 - Sink #2 (Left to Right)	Water	0.062 mg/L
252 2463922	Custodians Closet - Slop Sink - Near CR #2	Water	0.016 mg/L
253 2463923	Room 21 - Sink	Water	0.012 mg/L
254 2463924	Room 21 Bathroom - Sink	Water	BDL < 0.001 mg/L
255 2463925	Room 22 - Sink	Water	0.011 mg/L
256 2463926	Room 23 - Sink	Water	0.032 mg/L
257 2463927	Room 24 - Sink	Water	0.012 mg/L
258 2463928	Room 25 - Sink	Water	0.015 mg/L
259 2463929	Room 26 - Sink	Water	0.012 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 11 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
260 2463930	Girls Bathroom - Near Classroom L1 - Sink #1 (Left to Right)	Water	0.017 mg/L
261 2463931	Girls Bathroom - Near Classroom L1 - Sink #1 (Left to Right)	Water	0.002 mg/L
262 2463932	Boys Bathroom - Near Classroom L1 - Sink	Water	0.001 mg/L
263 2463933	Mens Bathroom - Near Classroom L1 - Adults Only - Sink	Water	BDL < 0.001 mg/L
264 2463934	Womens Bathroom - Near Classroom L1 - Adults Only - Sink	Water	BDL < 0.001 mg/L
265 2463935	Custodians Closet - Slop Sink	Water	0.005 mg/L
266 2463936	Room L2 - Sink	Water	0.002 mg/L
267 2463937	Room L2 Bathroom - Sink	Water	BDL < 0.001 mg/L
268 2463938	Library Office - Sink	Water	0.016 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 12 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
269 2463939	Room L3 - Sink	Water	0.037 mg/L
270 2463940	Room L3 Bathroom - Sink	Water	0.091 mg/L
271 2463941	Room L3 Water Fountain	Water	0.003 mg/L
272 2463942	Room L4 - Sink	Water	0.010 mg/L
273 2463943	Room L4 Bathroom - Sink	Water	BDL < 0.001 mg/L
274 2463944	Room P2 - Sink	Water	0.006 mg/L
275 2463945	Room P3 - Sink	Water	0.009 mg/L
276 2463946	Room P1 - Sink	Water	0.007 mg/L
277 2463947	Room P1A - Slop Sink	Water	0.191 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 13 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
278 2463948	Room P5 - Sink	Water	0.003 mg/L
279 2463949	Room P4 - Sink	Water	0.008 mg/L
280 2463950	Room P1A - Sink #2	Water	0.191 mg/L
281 2463951	Room P12 Bathroom - Sink	Water	0.003 mg/L
282 2463952	Room P12 Treatment Room	Water	0.001 mg/L
283 2463953	Mens Bathroom - Next to Room P12 - Sink	Water	0.008 mg/L
284 2463954	Room P11 - Sink	Water	0.005 mg/L
285 2463955	Room P11 Bathroom - Sink	Water	0.033 mg/L
286 2463956	Room P10 - Sink	Water	0.022 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 14 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
287 2463957	Room P10 Bathroom - Sink	Water	0.011 mg/L
288 2463958	Hallway Sink - Near Room P11A - Sink	Water	0.028 mg/L
289 2463959	Custodians Closet - Near Room P11A - Slop Sink	Water	0.006 mg/L
290 2463960	Room P9 - Sink	Water	0.006 mg/L
291 2463961	Room P9 Bathroom - Sink	Water	0.010 mg/L
292 2463962	Room P8 - Sink	Water	0.014 mg/L
293 2463963	Room P8 Bathroom - Sink	Water	0.013 mg/L
294 2463964	Room P7 - Sink	Water	0.018 mg/L
295 2463965	Room P7 Bathroom - Sink	Water	0.035 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 15 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
296 2463966	Room P6 - Sink	Water	0.003 mg/L
297 2463967	Room P6 Bathroom - Sink	Water	0.014 mg/L
298 2463968	Womens Bathroom - Near Room P6 - Sink	Water	0.002 mg/L
299 2463969	Room P14 - Sink	Water	0.011 mg/L
300 2463970	Room P14 Bathroom - Sink	Water	0.016 mg/L
301 2463971	Room P15 - Sink	Water	0.010 mg/L
302 2463972	Room P15 Bathroom - Sink	Water	0.012 mg/L
303 2463973	Hallway Sink - Near Room P16	Water	0.029 mg/L
304 2463974	Custodians Closet - Near Room P16 - Slop Sink	Water	0.043 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested


AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 16 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016
Collected By: Ernest Coon
Date Received: 11/05/2016
Date Analyzed: 11/09/2016
Analyzed By: Peter P. Argyrakakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
305 2463975	Room P16 - Sink	Water	0.011 mg/L
306 2463976	Room P16 Bathroom - Sink	Water	0.006 mg/L
307 2463977	Room P17 - Sink	Water	0.008 mg/L
308 2463978	Room P17 Bathroom - Sink	Water	0.019 mg/L
309 2463979	Room P18 - Sink	Water	0.021 mg/L
310 2463980	Room P18 Bathroom - Sink	Water	0.020 mg/L
311 2463981	Hallway Fountain Outside Room 25 - New Water Fountain	Water	0.003 mg/L
312 2463982	Kitchen Staff Bathroom - Sink	Water	0.002 mg/L
313 2463983	Girls Bathroom - Outside Upper Grade Cafeteria - Sink #1 (Left to Right)	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Page 17 of 17

Water Sample Report

RE: CPN ARD-1152-16-IH - Ardsley UFSD - Concord Road School

Date Collected: 11/05/2016

Collected By: Ernest Coon

Date Received: 11/05/2016

Date Analyzed: 11/09/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
314 2463984	Girls Bathroom - Outside Upper Grade Cafeteria - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
315 2463985	Boys Bathroom - Outside Upper Grade Cafeteria - Sink #1 (Left to Right)	Water	BDL < 0.001 mg/L
316 2463986	Boys Bathroom - Outside Upper Grade Cafeteria - Sink #2 (Left to Right)	Water	BDL < 0.001 mg/L
317 2463987	Custodians Closet - Outside Upper Grade Cafeteria - Slop Sink	Water	0.002 mg/L
318 2463988	Not Applicable	Water Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIHA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

