JURGIEL
JOHN A. JURGIEL & ASSOCIATES, INC.

ST. LOUIS
123 N. Main Street
St. Charles, Missouri 63301
Phone: 636-757-3060

DALLAS/FORT WORTH
2235 St. Andrew Drive
Highland Village, Texas 75077
Phone: 214-735-8055

March 4, 2024

Mr. Michael Smith
Director of Operations
Ritenour School District
2420 Woodson Road
St. Louis, MO 63114

Via: smithm@ritenourschools.org

Re: Lead In Drinking Water Sampling
Kratz Elementary School
January 15, 2024

Dear Michael,

This letter will serve as our report concerning the water sampling conducted at Kratz Elementary School on January 15, 2024, for compliance with the State of Missouri Title XI, Chapter 160.077, "Get The Lead Out of School Drinking Water Act".

Potable water sources for drinking or food preparation such as sinks, faucets, water fountains, ice makers, etc., were identified and first draw water samples were collected after a stagnation period of at least eight hours. Two hundred and fifty milliliter non-preservative plastic containers were utilized for the sample collection. The water samples were analyzed by EPA 200.8 methods at a laboratory accredited for analysis of drinking water by the National Environmental Laboratory Accreditation Program (NELAP) and the Illinois EPA (ILEPA). Results are reported in micrograms per liter (µg/L), which is the same as parts per billion (ppb). Water sample results must be less than (<) 5.0 µg/L or ppb, per the regulation. Results above 5.0 µg/L require corrective actions.

Seventy-three samples were collected, and the results ranged from less than the laboratory limit of detection of 1.0 (<1.0) µg/L to 22.0 µg/L. Five of the results were above the mandated threshold of <5.0 µg/L. Corrective actions are warranted for the five locations. If these sources will be taken out of service, the source and the supply pipe should be removed or disconnected as close as possible to the remaining active pipes to minimize any dead-end lines that could allow for bacteria or Legionella growth. Sample locations and laboratory results are contained in the attached table.

Sincerely,

Gregory K. Young
Senior Project Manager

TABLE 1
Lead Sampling Results
Kratz Elementary (January 15, 2024)

Sample ID	Location	Results (µg/L)
KRA-1	2nd Floor, Boy's Restroom Near Room 200, Left Sink	< 1.00
KRA-2	2nd Floor, Boy's Restroom Near Room 200, Right Sink	< 1.00
KRA-3	2nd Floor, Water Fountain Near Room 200	< 1.00
KRA-4	2nd Floor, Staff Restroom, Sink	< 1.00
KRA-5	2nd Floor, Girl's Restroom Near Room 206, Left Sink	< 1.00
KRA-6	2nd Floor, Girl's Restroom Near Room 206, Right Sink	< 1.00
KRA-7	2nd Floor, Classroom 210, Water Fountain	1.93
KRA-8	2nd Floor, Classroom 210, Faucet	< 1.00
KRA-9	2nd Floor, Classroom 212, Water Fountain	2.03
KRA-10	2nd Floor, Classroom 212, Faucet	< 1.00
KRA-11	2nd Floor, Classroom 214, Water Fountain	4.84
KRA-12	2nd Floor, Classroom 214, Faucet	3.45
KRA-13	2nd Floor, Girl's Restroom Near Room 214, Left Sink	< 1.00
KRA-14	2nd Floor, Girl's Restroom Near Room 214, Right Sink	< 1.00
KRA-15	2nd Floor, Water Fountain Near Room 216	< 1.00
KRA-16	2nd Floor, Boy's Restroom Near Room 216, Left Sink	< 1.00
KRA-17	2nd Floor, Boy's Restroom Near Room 216, Right Sink	< 1.00
KRA-18	2nd Floor, Classroom 216, Faucet	4.62
KRA-19	2nd Floor, Classroom 215, Water Fountain	3.57
KRA-20	2nd Floor, Classroom 215, Faucet	1.10
KRA-21	1st Floor, Classroom 100, Water Fountain	2.00
KRA-22	1st Floor, Classroom 100, Faucet	3.32
KRA-23	1st Floor, Classroom 100, Restroom, Sink	3.72

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Kratz Elementary (January 15, 2024)

Sample ID	Location	Results (µg/L)
KRA-24	1st Floor, Faculty Lounge, Sink	4.93
KRA-25	1st Floor, Faculty Lounge, Ice Maker	< 1.00
KRA-26	1st Floor, Boy's Restroom Neat Faculty Lounge, Left Sink	< 1.00
KRA-27	1st Floor, Boy's Restroom Neat Faculty Lounge, Right Sink	< 1.00
KRA-28	1st Floor, Water Fountain Near Faculty Lounge	< 1.00
KRA-29	1st Floor, Nurse's Office, Sink	1.61
KRA-30	1st Floor, Nurse's Office, Restroom, Sink	1.79
KRA-31	1st Floor, Office Copier Room, Sink	2.09
KRA-32	1st Floor, Office Restroom, Sink	< 1.00
KRA-33	1st Floor, Classroom 103, Faucet	4.33
KRA-34	1st Floor, Classroom 103, Restroom, Sink	< 1.00
KRA-35	1st Floor, Girl's Restroom Near Library, Left Sink	< 1.00
KRA-36	1st Floor, Girl's Restroom Near Library, Right Sink	< 1.00
KRA-37	1st Floor, Classroom 108, Faucet	< 1.00
KRA-38	1st Floor, Classroom 110, Water Fountain	3.78
KRA-39	1st Floor, Classroom 110, Faucet	1.75
KRA-40	1st Floor, Classroom 112, Water Fountain	< 1.00
KRA-41	1st Floor, Classroom 112, Faucet	< 1.00
KRA-42	1st Floor, Girl's Restroom Near Room 112, Left Sink	< 1.00
KRA-43	1st Floor, Girl's Restroom Near Room 112, Right Sink	< 1.00
KRA-44	1st Floor, Water Fountain Near Room 114	< 1.00
KRA-45	1st Floor, Boy's Restroom Near Room 114, Left Sink	< 1.00
KRA-46	1st Floor, Boy's Restroom Near Room 114, Right Sink	< 1.00

Note:

µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Kratz Elementary (January 15, 2024)

Sample ID	Location	Results (µg/L)
KRA-47	1st Floor, Classroom 114, Water Fountain	1.79
KRA-48	1st Floor, Classroom 114, Faucet	< 1.00
KRA-49	1st Floor, Classroom 113, Water Fountain	4.51
KRA-50	1st Floor, Classroom 113, Faucet	3.13
KRA-51	Ground Floor, Classroom 010, Water Fountain	**14.1**
KRA-52	Ground Floor, Classroom 010, Faucet	4.64
KRA-53	Ground Floor, Boy's Restroom Near Room 010, Left Sink	< 1.00
KRA-54	Ground Floor, Boy's Restroom Near Room 010, Right Sink	< 1.00
KRA-55	Ground Floor, Water Fountain Near Room 010	< 1.00
KRA-56	Ground Floor, Girl's Restroom Near Room 008, Left Sink	< 1.00
KRA-57	Ground Floor, Girl's Restroom Near Room 008, Right Sink	< 1.00
KRA-58	Ground Floor, Classroom 008, Water Fountain	**8.07**
KRA-59	Ground Floor, Classroom 008, Faucet	**21.7**
KRA-60	Ground Floor, Classroom 006, Left Sink	2.39
KRA-61	Ground Floor, Classroom 006, Right Sink	**7.06**
KRA-62	Ground Floor, Unisex Restroom Near Room 004, Sink	< 1.00
KRA-63	Ground Floor, Cafeteria, Left Water Fountain	< 1.00
KRA-64	Ground Floor, Cafeteria, Right Water Fountain	< 1.00
KRA-65	Ground Floor, Kitchen, Restroom, Sink	2.02
KRA-66	Ground Floor, Kitchen, South Prep Sink	< 1.00
KRA-67	Ground Floor, Kitchen, Pot Filler Near Stove	**22.0**
KRA-68	Ground Floor, Kitchen, North Prep Area, Left Sink	< 1.00
KRA-69	Ground Floor, Kitchen, North Prep Area, Right Sink	2.08

Note:
µg/L – micrograms per liter

TABLE 1 (Continued)
Lead Sampling Results
Kratz Elementary (January 15, 2024)

Sample ID	Location	Results (µg/L)
KRA-70	Ground Floor, Kitchen, Handwashing Sink	< 1.00
KRA-71	Ground Floor, Kitchen, Dishwashing Sink, North	< 1.00
KRA-72	Ground Floor, Kitchen, Dishwashing Sink, South, Left Sink	3.24
KRA-73	Ground Floor, Kitchen, Dishwashing Sink, South, Right Sink	3.70

Note:
µg/L – micrograms per liter

Sources not sampled:
Kratz Elementary, 2nd Floor, Classroom 216, Water Fountain (inoperable)
Kratz Elementary, 1st Floor, Faculty Lounge, Restroom Sink (inoperable)
Kratz Elementary, 1st Floor, Classroom 103, Water Fountain (inoperable)
Kratz Elementary, 1st Floor, Classroom 108, Water Fountain (inoperable)

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

February 05, 2024

Greg Young
Jurgiel & Associates, Inc.
123 North Main Street
St. Charles, MO 63301

RE: Ritenour Drinking Water-Kratz Elem

Dear Greg Young:

Please find enclosed the analytical results for the **72** sample(s) the laboratory received on **1/16/24 2:40 pm** and logged in under work order **HA02367**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order HA02367

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
NO	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

Case Narrative

Sample KRA-70 was not received.

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-01
Name: KRA-1
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:17	BRS	EPA 200.8 REV 5.4

Sample: HA02367-02
Name: KRA-2
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:18	BRS	EPA 200.8 REV 5.4

Sample: HA02367-03
Name: KRA-3
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:19	BRS	EPA 200.8 REV 5.4

Sample: HA02367-04
Name: KRA-4
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:21	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-05 **Sampled:** 01/15/24 14:30
Name: KRA-5 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:22	BRS	EPA 200.8 REV 5.4

Sample: HA02367-06 **Sampled:** 01/15/24 14:30
Name: KRA-6 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:26	BRS	EPA 200.8 REV 5.4

Sample: HA02367-07 **Sampled:** 01/15/24 14:30
Name: KRA-7 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.93	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:28	BRS	EPA 200.8 REV 5.4

Sample: HA02367-08 **Sampled:** 01/15/24 14:30
Name: KRA-8 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:29	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-09 **Sampled:** 01/15/24 14:30
Name: KRA-9 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.03	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:31	BRS	EPA 200.8 REV 5.4

Sample: HA02367-10 **Sampled:** 01/15/24 14:30
Name: KRA-10 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:32	BRS	EPA 200.8 REV 5.4

Sample: HA02367-11 **Sampled:** 01/15/24 14:30
Name: KRA-11 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.84	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:36	BRS	EPA 200.8 REV 5.4

Sample: HA02367-12 **Sampled:** 01/15/24 14:30
Name: KRA-12 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.45	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:38	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-13 **Sampled:** 01/15/24 14:30
Name: KRA-13 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:39	BRS	EPA 200.8 REV 5.4

Sample: HA02367-14 **Sampled:** 01/15/24 14:30
Name: KRA-14 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:43	BRS	EPA 200.8 REV 5.4

Sample: HA02367-15 **Sampled:** 01/15/24 14:30
Name: KRA-15 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:45	BRS	EPA 200.8 REV 5.4

Sample: HA02367-16 **Sampled:** 01/15/24 14:30
Name: KRA-16 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:46	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-17 **Sampled:** 01/15/24 14:30
Name: KRA-17 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:47	BRS	EPA 200.8 REV 5.4

Sample: HA02367-18 **Sampled:** 01/15/24 14:30
Name: KRA-18 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.62	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:49	BRS	EPA 200.8 REV 5.4

Sample: HA02367-19 **Sampled:** 01/15/24 14:30
Name: KRA-19 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.57	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:50	BRS	EPA 200.8 REV 5.4

Sample: HA02367-20 **Sampled:** 01/15/24 14:30
Name: KRA-20 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.10	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:52	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-21
Name: KRA-21
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 13:56	BRS	EPA 200.8 REV 5.4

Sample: HA02367-22
Name: KRA-22
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.32	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:00	BRS	EPA 200.8 REV 5.4

Sample: HA02367-23
Name: KRA-23
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.72	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:01	BRS	EPA 200.8 REV 5.4

Sample: HA02367-24
Name: KRA-24
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.93	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:03	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-25
Name: KRA-25
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:04	BRS	EPA 200.8 REV 5.4

Sample: HA02367-26
Name: KRA-26
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:06	BRS	EPA 200.8 REV 5.4

Sample: HA02367-27
Name: KRA-27
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:07	BRS	EPA 200.8 REV 5.4

Sample: HA02367-28
Name: KRA-28
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:08	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-29
Name: KRA-29
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.61	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:10	BRS	EPA 200.8 REV 5.4

Sample: HA02367-30
Name: KRA-30
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.79	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:11	BRS	EPA 200.8 REV 5.4

Sample: HA02367-31
Name: KRA-31
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.09	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:18	BRS	EPA 200.8 REV 5.4

Sample: HA02367-32
Name: KRA-32
Matrix: Drinking Water - Grab
Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:20	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-33 **Sampled:** 01/15/24 14:30
Name: KRA-33 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.33	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:21	BRS	EPA 200.8 REV 5.4

Sample: HA02367-34 **Sampled:** 01/15/24 14:30
Name: KRA-34 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:23	BRS	EPA 200.8 REV 5.4

Sample: HA02367-35 **Sampled:** 01/15/24 14:30
Name: KRA-35 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:24	BRS	EPA 200.8 REV 5.4

Sample: HA02367-36 **Sampled:** 01/15/24 14:30
Name: KRA-36 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:25	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-37 **Sampled:** 01/15/24 14:30
Name: KRA-37 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:27	BRS	EPA 200.8 REV 5.4

Sample: HA02367-38 **Sampled:** 01/15/24 14:30
Name: KRA-38 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.78	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:28	BRS	EPA 200.8 REV 5.4

Sample: HA02367-39 **Sampled:** 01/15/24 14:30
Name: KRA-39 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.75	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:30	BRS	EPA 200.8 REV 5.4

Sample: HA02367-40 **Sampled:** 01/15/24 14:30
Name: KRA-40 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:34	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-41 **Sampled:** 01/15/24 14:30
Name: KRA-41 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:38	BRS	EPA 200.8 REV 5.4

Sample: HA02367-42 **Sampled:** 01/15/24 14:30
Name: KRA-42 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:39	BRS	EPA 200.8 REV 5.4

Sample: HA02367-43 **Sampled:** 01/15/24 14:30
Name: KRA-43 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:41	BRS	EPA 200.8 REV 5.4

Sample: HA02367-44 **Sampled:** 01/15/24 14:30
Name: KRA-44 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:42	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-45
Name: KRA-45
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:43	BRS	EPA 200.8 REV 5.4

Sample: HA02367-46
Name: KRA-46
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:45	BRS	EPA 200.8 REV 5.4

Sample: HA02367-47
Name: KRA-47
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.79	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:46	BRS	EPA 200.8 REV 5.4

Sample: HA02367-48
Name: KRA-48
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:50	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-49
Name: KRA-49
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.51	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:52	BRS	EPA 200.8 REV 5.4

Sample: HA02367-50
Name: KRA-50
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.13	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:53	BRS	EPA 200.8 REV 5.4

Sample: HA02367-51
Name: KRA-51
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	14.1	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:57	BRS	EPA 200.8 REV 5.4

Sample: HA02367-52
Name: KRA-52
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	4.64	ug/L		01/26/24 11:07	1	1.00	01/26/24 14:59	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-53 **Sampled:** 01/15/24 14:30
Name: KRA-53 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:00	BRS	EPA 200.8 REV 5.4

Sample: HA02367-54 **Sampled:** 01/15/24 14:30
Name: KRA-54 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:01	BRS	EPA 200.8 REV 5.4

Sample: HA02367-55 **Sampled:** 01/15/24 14:30
Name: KRA-55 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:03	BRS	EPA 200.8 REV 5.4

Sample: HA02367-56 **Sampled:** 01/15/24 14:30
Name: KRA-56 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:07	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-57 **Sampled:** 01/15/24 14:30
Name: KRA-57 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:08	BRS	EPA 200.8 REV 5.4

Sample: HA02367-58 **Sampled:** 01/15/24 14:30
Name: KRA-58 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	8.07	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:10	BRS	EPA 200.8 REV 5.4

Sample: HA02367-59 **Sampled:** 01/15/24 14:30
Name: KRA-59 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	21.7	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:11	BRS	EPA 200.8 REV 5.4

Sample: HA02367-60 **Sampled:** 01/15/24 14:30
Name: KRA-60 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.39	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:13	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-61 **Sampled:** 01/15/24 14:30
Name: KRA-61 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	7.06	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:17	BRS	EPA 200.8 REV 5.4

Sample: HA02367-62 **Sampled:** 01/15/24 14:30
Name: KRA-62 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:18	BRS	EPA 200.8 REV 5.4

Sample: HA02367-63 **Sampled:** 01/15/24 14:30
Name: KRA-63 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:19	BRS	EPA 200.8 REV 5.4

Sample: HA02367-64 **Sampled:** 01/15/24 14:30
Name: KRA-64 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:24	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-65 **Sampled:** 01/15/24 14:30
Name: KRA-65 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.02	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:25	BRS	EPA 200.8 REV 5.4

Sample: HA02367-66 **Sampled:** 01/15/24 14:30
Name: KRA-66 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:26	BRS	EPA 200.8 REV 5.4

Sample: HA02367-67 **Sampled:** 01/15/24 14:30
Name: KRA-67 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	22.0	ug/L		01/31/24 13:57	1	1.11	02/01/24 13:19	BRS	EPA 200.8 REV 5.4

Sample: HA02367-68 **Sampled:** 01/15/24 14:30
Name: KRA-68 **Received:** 01/16/24 14:40
Matrix: Drinking Water - Grab

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:28	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

ANALYTICAL RESULTS

Sample: HA02367-69
Name: KRA-69
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	2.08	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:29	BRS	EPA 200.8 REV 5.4

Sample: HA02367-70
Name: KRA-71
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:31	BRS	EPA 200.8 REV 5.4

Sample: HA02367-71
Name: KRA-72
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.24	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:32	BRS	EPA 200.8 REV 5.4

Sample: HA02367-72
Name: KRA-73
Matrix: Drinking Water - Grab

Sampled: 01/15/24 14:30
Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	3.70	ug/L		01/26/24 11:07	1	1.00	01/26/24 15:36	BRS	EPA 200.8 REV 5.4

Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050
TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615
TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553
Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807
USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042
TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389
TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050
Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	KRATZ ELEM	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	GREG YOUNG	WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
KRA-1	1/15/24	1:00pm-2:30pm	X		DW	1		X	
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									

4 (FOR LAB USE ONLY)
LOGIN # HA023667
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)
DATE RESULTS NEEDED
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7		DATE	TIME		DATE	TIME
RELINQUISHED BY: (SIGNATURE)	Greg Young	1/15/24		RECEIVED BY: (SIGNATURE) Darrell Campbell	1-15-24	15:30
RELINQUISHED BY: (SIGNATURE)				RECEIVED BY: (SIGNATURE)	1-16-24	1009
RELINQUISHED BY: (SIGNATURE)		1-16-24	1440	RECEIVED BY: (SIGNATURE) Sarah McDaniel	1-16-24	1440

8 COMMENTS: (FOR LAB USE ONLY)
IR-5

SAMPLE TEMPERATURE UPON RECEIPT 16.3 12.3 °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 2

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	KRATZ ELEM.	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**		**MATRIX TYPES:**
ST. CHARLES, MO 63301	GREG YOUNG		WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
KRA-12	1/15/24	1:00pm-2:30pm	X		DW	1		X	
13									
14									
15									
16									
17									
18									
19									
20									
21									
22									

4 (FOR LAB USE ONLY)
LOGIN # HA023667
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH
DATE RESULTS NEEDED
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
RELINQUISHED BY: (SIGNATURE) Greg Young	1/15/24		Clary YM	1-16-24	1009
RELINQUISHED BY: (SIGNATURE) Clary YM	1-16-24	1440	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)			RECEIVED BY: (SIGNATURE) Sarah McDaniel	1-16-24	1440

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT 12.3 °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 3

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

(1) CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PHONE NUMBER: 636-757-3060
SAMPLER (PLEASE PRINT): GREG YOUNG
SAMPLER'S SIGNATURE: Greg Young

PROJECT LOCATION: KRATZ ELEM
E-MAIL: gyoung@jurgiel.com

PURCHASE ORDER #:
DATE SHIPPED:

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

(3) ANALYSIS REQUESTED: LEAD (EPA 200.8)

(4) (FOR LAB USE ONLY)
LOGIN # 23607 HA023607
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

(2) SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
KRA-23	1/15/24	1:00pm-2:30pm	X		DW	1		X	
24									
25									
26									
27									
28									
29									
30									
31									
32									
33									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

(5) TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

(6) *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

(7)	RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
	Greg Young	1/15/24		[illegible]	1-16-24	1009
	[illegible]	1-16-24	1440			
				Sarah McDaniel	1-16-24	1440

(8) COMMENTS: (FOR LAB USE ONLY)
C

SAMPLE TEMPERATURE UPON RECEIPT: 12.3 °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 4

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

(1) CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PROJECT LOCATION: KRATZ ELEM
PURCHASE ORDER #:
PHONE NUMBER: 636-757-3060
E-MAIL: gyoung@jurgiel.com
DATE SHIPPED:
SAMPLER (PLEASE PRINT): GREG YOUNG
SAMPLER'S SIGNATURE: Greg Young

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

(3) ANALYSIS REQUESTED: LEAD (EPA 200.8)

(4) (FOR LAB USE ONLY)
LOGIN # HA02367
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

(2) SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
KRA-34	1/15/24	1:00pm-2:30pm	X		DW	1		X	
35									
36									
37									
38									
39									
40									
41									
42									
43									
44									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

(5) TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
DATE RESULTS NEEDED:
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:

(6) *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

(7) RELINQUISHED BY: (SIGNATURE)	DATE	TIME	RECEIVED BY: (SIGNATURE)	DATE	TIME
Greg Young	1/15/24			1-16-24	1004
RELINQUISHED BY: (SIGNATURE)	1-16-24	1440	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)			RECEIVED BY: (SIGNATURE) Sarah McDaniel	1-16-24	1440

(8) COMMENTS: (FOR LAB USE ONLY)
C

SAMPLE TEMPERATURE UPON RECEIPT: 12.3 °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 5

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

(1) CLIENT: JOHN A. JURGIEL & ASSOCIATES, INC.
ADDRESS: 123 N. MAIN ST.
CITY STATE ZIP: ST. CHARLES, MO 63301
CONTACT PERSON: GREG YOUNG

PROJECT NUMBER: RITENOUR DRINKING WATER
PHONE NUMBER: 636-757-3060
SAMPLER (PLEASE PRINT): GREG YOUNG
SAMPLER'S SIGNATURE: Greg Young

PROJECT LOCATION: KRATZ ELEM.
E-MAIL: gyoung@jurgiel.com

PURCHASE ORDER #:
DATE SHIPPED:

MATRIX TYPES:
WW- WASTEWATER
DW- DRINKING WATER
GW- GROUND WATER
WWSL- SLUDGE
NAS- NON AQUEOUS SOLID
LCHT-LEACHATE
OIL-OIL
SO-SOIL
SOL-SOLID

(3) ANALYSIS REQUESTED

(4) (FOR LAB USE ONLY)
LOGIN # HA023667
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

(2) SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
KRA-45	1/15/24	1:00pm-2:30pm	X		DW	1		X	
46									
47									
48									
49									
50									
51									
52									
53									
54									
55									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

(5) TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE): NORMAL RUSH
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
EMAIL IF DIFFERENT FROM ABOVE:
PHONE # IF DIFFERENT FROM ABOVE:
DATE RESULTS NEEDED:

(6) *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*
PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

(7)		DATE	TIME		DATE	TIME
RELINQUISHED BY: (SIGNATURE)	Greg Young	1/15/24		RECEIVED BY: (SIGNATURE)		1/16/24 1009
RELINQUISHED BY: (SIGNATURE)		1/16/24	1440	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)				RECEIVED BY: (SIGNATURE)	Sarah McDaniel	1/16/24 1440

(8) COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT: 12.3 °C
TEMPERATURE GUN ID:
CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N
SAMPLE(S) RECEIVED ON ICE: Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE:

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	KRATZ ELEM.	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	GREG YOUNG	WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

3 ANALYSIS REQUESTED

4 (FOR LAB USE ONLY)

LOGIN # HA023607
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	LEAD (EPA 200.8)	REMARKS
KRA-56	1/15/24	1:00pm - 2:30pm	X		DW	1		X	
57									
58									
59									
60									
61									
62									
63									
64									
65									
66									

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) NORMAL RUSH

DATE RESULTS NEEDED

RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE

EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*

PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7		DATE	TIME		DATE	TIME
RELINQUISHED BY: (SIGNATURE)	Greg Young	1/15/24		RECEIVED BY: (SIGNATURE)		1009
RELINQUISHED BY: (SIGNATURE)		1-16-24	1440	RECEIVED BY: (SIGNATURE)		
RELINQUISHED BY: (SIGNATURE)				RECEIVED BY: (SIGNATURE)	1-16-24	1440

8 COMMENTS: (FOR LAB USE ONLY)

SAMPLE TEMPERATURE UPON RECEIPT 12.3 °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT Y OR N
REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE

PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #
JOHN A. JURGIEL & ASSOCIATES, INC.	RITENOUR DRINKING WATER	KRATZ ELEM	
ADDRESS	**PHONE NUMBER**	**E-MAIL**	**DATE SHIPPED**
123 N. MAIN ST.	636-757-3060	gyoung@jurgiel.com	
CITY STATE ZIP	**SAMPLER (PLEASE PRINT)**	**MATRIX TYPES:**	
ST. CHARLES, MO 63301	GREG YOUNG	WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID	
CONTACT PERSON	**SAMPLER'S SIGNATURE**		
GREG YOUNG	Greg Young		

2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)	DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	SAMPLE TYPE COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	3 ANALYSIS REQUESTED: LEAD (EPA 200.8)	REMARKS
KRA-67	1/15/24	1:00pm - 2:30pm	X		DW	1		X	
68									
69									
★ 70									★ Sample KRA-70 Not Received
71									
72									
73									
[illegible]									
[illegible]									

4 (FOR LAB USE ONLY)

LOGIN # HA023607
LOGGED BY: SM
CLIENT:
PROJECT:
PROJ. MGR.:
CUSTODY SEAL #:

CHEMICAL PRESERVATION CODES: 1 – HCL | 2 – H2SO4 | 3 – HNO3 | 4 – NAOH | 5 – NA2S2O3 | 6 – UNPRESERVED | 7 – OTHER

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH
(RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)

RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE

EMAIL IF DIFFERENT FROM ABOVE:

PHONE # IF DIFFERENT FROM ABOVE:

DATE RESULTS NEEDED

6 *I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.*

PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY

7		DATE	TIME
RELINQUISHED BY: (SIGNATURE)	Greg Young	1/15/24	
RECEIVED BY: (SIGNATURE)	[illegible]	1-16-24	1009
RELINQUISHED BY: (SIGNATURE)	[illegible]	1-16-24	1440
RECEIVED BY: (SIGNATURE)			
RELINQUISHED BY: (SIGNATURE)			
RECEIVED BY: (SIGNATURE)	Sara L McDaniel	1.16.24	10 1440

8 COMMENTS: (FOR LAB USE ONLY)
70 was not received

SAMPLE TEMPERATURE UPON RECEIPT 12.3 °C
TEMPERATURE GUN ID
CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N
SAMPLE(S) RECEIVED ON ICE Y OR N
SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N
DATE AND TIME TAKEN FROM SAMPLE BOTTLE