



ST. LOUIS
123 N. Main Street
St. Charles, Missouri 63301
Phone: 636-757-3060

DALLAS/FORT WORTH
2235 St. Andrew Drive
Highland Village, Texas 75077
Phone: 214-735-8055

March 4, 2024

Mr. Michael Smith
Director of Operations
Ritenour School District
2420 Woodson Road
St. Louis, MO 63114

Via: smithm@ritenourschools.org

Re: Lead In Drinking Water Sampling
Buder Elementary School
January 15, 2024

Dear Michael,

This letter will serve as our report concerning the water sampling conducted at Buder Elementary School on January 15, 2024, for compliance with the State of Missouri Title XI, Chapter 160.077, "Get The Lead Out of School Drinking Water Act".

Potable water sources for drinking or food preparation such as sinks, faucets, water fountains, ice makers, etc., were identified and first draw water samples were collected after a stagnation period of at least eight hours. Two hundred and fifty milliliter non-preserved plastic containers were utilized for the sample collection. The water samples were analyzed by EPA 200.8 methods at a laboratory accredited for analysis of drinking water by the National Environmental Laboratory Accreditation Program (NELAP) and the Illinois EPA (ILEPA). Results are reported in micrograms per liter ($\mu\text{g/L}$), which is the same as parts per billion (ppb). Water sample results must be less than ($<$) 5.0 $\mu\text{g/L}$ or ppb, per the regulation. Results above 5.0 $\mu\text{g/L}$ require corrective actions.

Sixty-nine samples were collected with results ranging from less than the laboratory limit of detection of 1.0 (<1.0) $\mu\text{g/L}$ to 8.84 $\mu\text{g/L}$. Only two results were above the mandated threshold of <5.0 $\mu\text{g/L}$. Corrective actions are warranted for the two locations. If these sources will be taken out of service, the source and the supply pipe should be removed or disconnected as close as possible to the remaining active pipes to minimize any dead-end lines that could allow for bacteria or Legionella growth. Sample locations and laboratory results are contained in the attached table.

Sincerely,

Gregory K. Young
Senior Project Manager

TABLE 1
Lead Sampling Results
Buder Elementary (January 15, 2024)

Sample ID	Location	Results (µg/L)
BUD-1	1 st Floor, Lobby Water Fountain	< 1.00
BUD-2	1 st Floor, Water Fountain Near Room 108	< 1.00
BUD-3	1 st Floor Girl's Restroom Near Room 108, Left Sink	< 1.00
BUD-4	1 st Floor Girl's Restroom Near Room 108, Middle Sink	< 1.00
BUD-5	1 st Floor Girl's Restroom Near Room 108, Right Sink	< 1.00
BUD-6	1 st Floor, Boy's Restroom Near Room 107, Left Sink	< 1.00
BUD-7	1 st Floor, Boy's Restroom Near Room 107, Middle Sink	< 1.00
BUD-8	1 st Floor, Boy's Restroom Near Room 107, Right Sink	< 1.00
BUD-9	1 st Floor, Classroom 107, Faucet	1.30
BUD-10	1 st Floor, Classroom 105, Faucet	< 1.00
BUD-11	1 st Floor, Classroom 106, Faucet	< 1.00
BUD-12	1 st Floor, Classroom 103, Water Fountain	1.28
BUD-13	1 st Floor, Classroom 106, Water Fountain	1.16
BUD-14	1 st Floor, Classroom 103, Faucet	1.67
BUD-15	1 st Floor, Classroom 104, Water Fountain	2.34
BUD-16	1 st Floor, Classroom 104, Faucet	2.41
BUD-17	1 st Floor, Classroom 101, Water Fountain	2.27
BUD-18	1 st Floor, Classroom 101, Faucet	1.51
BUD-19	1 st Floor, Classroom 102, Water Fountain	< 1.00
BUD-20	1 st Floor, Classroom 102, Faucet	< 1.00
BUD-21	1 st Floor, Water Fountain Near Main Office	< 1.00
BUD-22	1 st Floor, Boy's Restroom Near Main Office, Left Sink	< 1.00

Note:
µg/L – micrograms per liter

**TABLE 1 (Continued)
Lead Sampling Results
Buder Elementary (January 15, 2024)**

Sample ID	Location	Results (µg/L)
BUD-23	1 st Floor, Boy's Restroom Near Main Office, Middle Sink	< 1.00
BUD-24	1 st Floor, Boy's Restroom Near Main Office, Right Sink	< 1.00
BUD-25	1 st Floor, Nurse's Office Sink	< 1.00
BUD-26	1 st Floor, Nurse's Office Restroom Sink	< 1.00
BUD-27	1 st Floor, Girl's Restroom Near Work Room, Left Sink	< 1.00
BUD-28	1 st Floor, Girl's Restroom Near Work Room, Middle Sink	< 1.00
BUD-29	1 st Floor, Girl's Restroom Near Work Room, Right Sink	< 1.00
BUD-30	1 st Floor, Work Room Sink	< 1.00
BUD-31	1 st Floor, Work Room, Restroom Sink	< 1.00
BUD-32	1 st Floor, Water Fountain Near Room 116	< 1.00
BUD-33	1 st Floor, Water Fountain in East Lobby	< 1.00
BUD-34	1 st Floor, Girl's Restroom in East Lobby, Left Sink	< 1.00
BUD-35	1 st Floor, Girl's Restroom in East Lobby, Right Sink	< 1.00
BUD-36	1 st Floor, Boy's Restroom Near Room 118, Left Sink	< 1.00
BUD-37	1 st Floor, Boy's Restroom Near Room 118, Middle Sink	< 1.00
BUD-38	1 st Floor, Boy's Restroom Near Room 118, Right Sink	< 1.00
BUD-39	Ground Floor, Library Sink	1.66
BUD-40	Ground Floor, Kitchen Ice Maker	1.39
BUD-41	Ground Floor, Kitchen Sink Near Stove	1.34
BUD-42	Ground Floor, Kitchen, Prep Sink, Left	1.21
BUD-43	Ground Floor, Kitchen, Prep Sink, Right	1.61
BUD-44	Ground Floor, Kitchen, Handwashing Sink	5.02

Note:
µg/L – micrograms per liter

**TABLE 1 (Continued)
Lead Sampling Results
Buder Elementary (January 15, 2024)**

Sample ID	Location	Results (µg/L)
BUD-45	Ground Floor, Kitchen, Dishwashing Sink	< 1.00
BUD-46	Ground Floor, Cafeteria Water Fountain, Left	< 1.00
BUD-47	Ground Floor, Cafeteria Water Fountain, Right	< 1.00
BUD-48	Ground Floor, Teacher's Lounge, Sink	3.20
BUD-49	Ground Floor, Teacher's Lounge, Restroom Sink	< 1.00
BUD-50	Ground Floor, Water Fountain Near Teacher's Lounge	< 1.00
BUD-51	Ground Floor, Boy's Restroom Near Teacher's Lounge, Left Sink	< 1.00
BUD-52	Ground Floor, Boy's Restroom Near Teacher's Lounge, Middle Sink	< 1.00
BUD-53	Ground Floor, Boy's Restroom Near Teacher's Lounge, Right Sink	< 1.00
BUD-54	Ground Floor, Girl's Restroom Near West Elevator, Left Sink	< 1.00
BUD-55	Ground Floor, Girl's Restroom Near West Elevator, Middle Sink	< 1.00
BUD-56	Ground Floor, Girl's Restroom Near West Elevator, Right Sink	< 1.00
BUD-57	Ground Floor, Art Room 019, Left Sink	3.75
BUD-58	Ground Floor, Art Room 019, Right Sink	< 1.00
BUD-59	Ground Floor, Classroom 5, Faucet	8.84
BUD-60	Ground Floor, Classroom 6, Faucet	< 1.00
BUD-61	Ground Floor, Classroom 3, Water Fountain	< 1.00
BUD-62	Ground Floor, Classroom 3, Faucet	< 1.00
BUD-63	Ground Floor, Classroom 3, Restroom Sink	< 1.00
BUD-64	Ground Floor, Classroom 4, Water Fountain	< 1.00
BUD-65	Ground Floor, Classroom 4, Faucet	< 1.00
BUD-66	Ground Floor, Classroom 1, Faucet	< 1.00

Note:
µg/L – micrograms per liter

**TABLE 1 (Continued)
Lead Sampling Results
Buder Elementary (January 15, 2024)**

Sample ID	Location	Results (µg/L)
BUD-67	Ground Floor, Classroom 1, Water Fountain	2.55
BUD-68	Ground Floor, Classroom 1, Restroom, Sink	< 1.00
BUD-69	Ground Floor, Classroom 2, Faucet & Water Fountain Combo	1.10

Note:

µg/L – micrograms per liter

Sources not sampled:

Buder Elementary, 1st Floor, Classroom 105, Water Fountain (inoperable)
 Buder Elementary, 1st Floor, Classroom 107, Water Fountain (inoperable)
 Buder Elementary, Ground Floor, Teacher's Lounge, Refrigerator Ice Makers (2) (inoperable)
 Buder Elementary, Ground Floor, Water Fountain Near Gym (inoperable)
 Buder Elementary, Ground Floor, Classroom 5, Water Fountain (inoperable)
 Buder Elementary, Ground Floor, Classroom 6, Water Fountain (inoperable)
 Buder Elementary, Ground Floor, Classroom 1, Water Fountain (inoperable)



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

February 05, 2024

Greg Young
Jurgiel & Associates, Inc.
123 North Main Street
St. Charles, MO 63301

RE: Ritenour Drinking Water-Buder

Dear Greg Young:

Please find enclosed the analytical results for the **69** sample(s) the laboratory received on **1/16/24 2:40 pm** and logged in under work order **HA02368**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order HA02368

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HA02368-01

Name: BUD-1

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-02

Name: BUD-2

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-03

Name: BUD-3

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:07	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-04

Name: BUD-4

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:08	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-05

Name: BUD-5

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-06

Name: BUD-6

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:11	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-07

Name: BUD-7

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-08

Name: BUD-8

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-09

Name: BUD-9

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.30	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:20	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-10

Name: BUD-10

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:21	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-11

Name: BUD-11

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:23	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-12

Name: BUD-12

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.28	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:24	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-13

Name: BUD-13

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.16	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:26	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-14

Name: BUD-14

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.67	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:27	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-15

Name: BUD-15

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.34	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:28	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-16

Name: BUD-16

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.41	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:30	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-17

Name: BUD-17

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.27	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:31	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-18

Name: BUD-18

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.51	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:32	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-19

Name: BUD-19

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:39	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-20

Name: BUD-20

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:40	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-21

Name: BUD-21

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-22

Name: BUD-22

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-23

Name: BUD-23

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-24

Name: BUD-24

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:46	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-25

Name: BUD-25

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-26

Name: BUD-26

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:49	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-27

Name: BUD-27

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:53	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-28

Name: BUD-28

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:54	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-29

Name: BUD-29

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-30

Name: BUD-30

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 14:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-31

Name: BUD-31

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-32

Name: BUD-32

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-33

Name: BUD-33

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:03	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-34

Name: BUD-34

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-35

Name: BUD-35

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-36

Name: BUD-36

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:10	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-37

Name: BUD-37

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:12	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-38

Name: BUD-38

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:13	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-39

Name: BUD-39

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.66	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:17	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-40

Name: BUD-40

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.39	ug/L		01/31/24 13:57	1	1.11	02/01/24 13:20	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-41

Name: BUD-41

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.34	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:18	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-42

Name: BUD-42

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.21	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:20	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-43

Name: BUD-43

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	1.61	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:21	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-44

Name: BUD-44

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.02	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:25	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-45

Name: BUD-45

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:26	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-46

Name: BUD-46

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:28	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-47

Name: BUD-47

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:30	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-48

Name: BUD-48

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.20	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:31	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-49

Name: BUD-49

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:32	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-50

Name: BUD-50

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:36	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-51

Name: BUD-51

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:38	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-52

Name: BUD-52

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:42	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-53

Name: BUD-53

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:43	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-54

Name: BUD-54

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:44	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-55

Name: BUD-55

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:46	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-56

Name: BUD-56

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:47	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-57

Name: BUD-57

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.75	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:49	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-58

Name: BUD-58

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:50	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-59

Name: BUD-59

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	8.84	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:51	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-60

Name: BUD-60

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:58	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-61

Name: BUD-61

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 15:59	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-62

Name: BUD-62

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:01	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-63

Name: BUD-63

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:02	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-64

Name: BUD-64

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:04	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



ANALYTICAL RESULTS

Sample: HA02368-65

Name: BUD-65

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:05	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-66

Name: BUD-66

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:06	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-67

Name: BUD-67

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	2.55	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:08	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HA02368-68

Name: BUD-68

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	< 1.00	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:09	BRS	EPA 200.8 REV 5.4
------	--------	------	--	----------------	---	------	----------------	-----	-------------------



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: HA02368-69

Name: BUD-69

Matrix: Drinking Water - Regular Sample

Sampled: 01/15/24 08:00

Received: 01/16/24 14:40

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	1.10	ug/L		01/25/24 11:22	1	1.00	01/25/24 16:10	BRS	EPA 200.8 REV 5.4



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager



PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 1

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT <u>JOHNA JURGIEL & ASSOCIATES, INC.</u>		PROJECT NUMBER <u>RITENDOUR</u>		PROJECT LOCATION <u>Buder</u>		PURCHASE ORDER #		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>HA02368</u> LOGGED BY: <u>MSL</u> CLIENT: PROJECT: PROJ. MGR.: CUSTODY SEAL #:	
ADDRESS <u>123 N. MAIN ST.</u>		PHONE NUMBER <u>636-757-3060</u>		E-MAIL <u>gyoung@jurgiel.com</u>		DATE SHIPPED		LEAD (EPA 200.8)		REMARKS	
CITY STATE ZIP <u>ST. CHARLES, MO 63301</u>		SAMPLER (PLEASE PRINT) <u>Kevin Obermiller</u>		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCIL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID							
CONTACT PERSON <u>GREG YOUNG</u>		SAMPLER'S SIGNATURE <u>Kevin Obermiller</u>									
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED			
<u>BUD-1</u>		<u>1/15/24</u>	<u>8:00 AM</u>	<u>X</u>		<u>DW</u>	<u>1</u>		<u>X</u>		
<u>-2</u>											
<u>-3</u>											
<u>-4</u>											
<u>-5</u>											
<u>-6</u>											
<u>-7</u>											
<u>-8</u>											
<u>-9</u>											
<u>-10</u>											
<u>-11</u>											
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NaOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		<u>NORMAL</u>		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>GY</u> <u>IR-5</u>					
7 RELINQUISHED BY: (SIGNATURE) <u>Kevin Obermiller</u>		DATE <u>1/15/24</u>		RECEIVED BY: (SIGNATURE) <u>Darius Campbell</u>		DATE <u>1-15-24</u>		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		TIME		RECEIVED BY: (SIGNATURE)		TIME <u>15:30</u>					
RELINQUISHED BY: (SIGNATURE) <u>Clay M</u>		DATE <u>1-16-24</u>		RECEIVED BY: (SIGNATURE)		DATE <u>1-16-24</u>		SAMPLE TEMPERATURE UPON RECEIPT TEMPERATURE GUN ID <u>15</u> <u>16.3</u> °C			
		TIME <u>1440</u>				TIME <u>1440</u>		CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 2

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT JOHNA JURGIEL & ASSOCIATES, INC. ADDRESS 123 N. MAIN ST. CITY STATE ZIP ST. CHARLES, MD 63301 CONTACT PERSON GREG YOUNG		PROJECT NUMBER RITENDOUR DRINKING WATER PHONE NUMBER 636-757-3060		PROJECT LOCATION BUDER E-MAIL gyoung@jurgiel.com		PURCHASE ORDER #		3 ANALYSIS REQUESTED LEAD (EPA 200.8)		4 (FOR LAB USE ONLY) LOGIN # LOGGED BY: CLIENT: PROJECT: PROJ. MGR.: CUSTODY SEAL #:	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP		MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS		
BUD-12		1/15/24	8:00am	X		DW	1		X		
-13											
-14											
-15											
-16											
-17											
-18											
-19											
-20											
-21											
-22											
CHEMICAL PRESERVATION CODES:		1-HCL	2-H2SO4	3-HNO3	4-NAOH	5-NA2S2O3	6-UNPRESERVED	7-OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY			
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		EMAIL IF DIFFERENT FROM ABOVE:		PHONE # IF DIFFERENT FROM ABOVE:							
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE TIME	RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)		DATE TIME	8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT TEMPERATURE GUN ID CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE BOTTLE					
1/15/24 1/16/24 1/16/24		1/15/24 1/16/24 1/16/24		1/16/24 1/16/24 1/16/24		10.3 °C 15 FOR N FOR N Y OR N					



PACE ANALYTICAL SERVICES
WWW.PACELABS.COM

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MD

PAGE 3

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT <u>JOHNA JURGIEL & ASSOCIATES, INC.</u>		PROJECT NUMBER <u>RITENDUR</u>		PROJECT LOCATION <u>BUDER</u>		PURCHASE ORDER #		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) LOGIN # <u>H802368</u> LOGGED BY: <u>7/15/16</u> CLIENT: PROJECT: PROJ. MGR.: CUSTODY SEAL #:					
ADDRESS <u>123 N. MAIN ST.</u>		PHONE NUMBER <u>636-757-3060</u>		E-MAIL <u>gyoung@jurgiel.com</u>		DATE SHIPPED		LEAD (EPA 200.8)		REMARKS					
CITY STATE ZIP <u>ST. CHARLES, MD 63301</u>		SAMPLER (PLEASE PRINT) <u>Kevin Obermiller</u>		SAMPLER'S SIGNATURE <u>Kevin Obermiller</u>		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID									
CONTACT PERSON <u>GREG YOUNG</u>		DATE COLLECTED <u>1/15/24</u>		TIME COLLECTED <u>8:00am</u>		SAMPLE TYPE GRAB <u>X</u> COMP		MATRIX TYPE <u>DW</u>		BOTTLE COUNT <u>1</u>		PRES CODE CLIENT PROVIDED			
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)															
<u>BUD-23</u>															
<u>-24</u>															
<u>-25</u>															
<u>-26</u>															
<u>-27</u>															
<u>-28</u>															
<u>-29</u>															
<u>-30</u>															
<u>-31</u>															
<u>-32</u>															
<u>-33</u>															
CHEMICAL PRESERVATION CODES:		1-HCL		2-H2SO4		3-HNO3		4-NAOH		5-NA2S2O3		6-UNPRESERVED		7-OTHER	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		<u>NORMAL</u>		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>GY</u>							
7 RELINQUISHED BY: (SIGNATURE) <u>Kevin Obermiller</u>		DATE <u>1/15/24</u>		TIME		RECEIVED BY: (SIGNATURE) <u>cleny VM</u>		DATE <u>1-16-24</u>		TIME <u>1009</u>		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT TEMPERATURE GUN ID <u>15</u> <u>16.3</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANCE REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE			
RELINQUISHED BY: (SIGNATURE) <u>cleny VM</u>		DATE <u>1-16-24</u>		TIME <u>1440</u>		RECEIVED BY: (SIGNATURE)		DATE <u>1/16/24</u>		TIME <u>1440</u>					
RELINQUISHED BY: (SIGNATURE)		DATE		TIME		RECEIVED BY: (SIGNATURE)		DATE		TIME					



CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 4

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

Page 25 of 28

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF MO

PAGE 5

1 CLIENT JOHNA JURGIEL & ASSOCIATES, INC. ADDRESS 123 N. MAIN ST. CITY STATE ZIP ST. CHARLES, MD 63301 CONTACT PERSON GREG YOUNG		PROJECT NUMBER RITENDOUR DRINKING WATER PHONE NUMBER 636-757-3060		PROJECT LOCATION BUDER E-MAIL gyoung@jurgiel.com		PURCHASE ORDER #		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY) LOGIN # LOGGED BY: CLIENT: PROJECT: PROJ. MGR.: CUSTODY SEAL #:			
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED		TIME COLLECTED		SAMPLE TYPE GRAB COMP		MATRIX TYPE		BOTTLE COUNT		PRES CODE CLIENT PROVIDED		REMARKS	
BUD-45		11/15/24		8:00Am		X		DW		1					
-46															
-47															
-48															
-49															
-50															
-51															
-52															
-53															
-54															
-55															
CHEMICAL PRESERVATION CODES:		1 - HCL		2 - H2SO4		3 - HNO3		4 - NAOH		5 - NA2S2O3		6 - UNPRESERVED		7 - OTHER	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		NORMAL		RUSH		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) GY							
7 RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE) RELINQUISHED BY: (SIGNATURE)		DATE TIME		DATE TIME		RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE) RECEIVED BY: (SIGNATURE)		DATE TIME		DATE TIME		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT TEMPERATURE GUN ID CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED DATE AND TIME TAKEN FROM SAMPLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

SAMPLE COLLECTED IN THE STATE OF **MO**

PAGE 2

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

[illegible]