



# ROUND LAKE AREA SCHOOLS

## Community Unit School District #116

### 2024 Beach Elementary School Site Improvements Q & A

- Q1: Do the sidewalks-to-asphalt inface have a reveal? If so, what is the designated height?
- A1: The sidewalks adjacent to the front façade of the building will have a 4” exposed edge. Please see attached details for construction. The School District shall inspect and approve the concrete forms prior to installation of the sidewalk subbase.
- Q2: Is the paint striping specified as “paint” or “thermoplastic”?
- A2: The new pavement striping shall be two coats of paint, meeting the specifications in Article 780 of the IDOT Standard Specifications.
- Q3: Does the opening in the fence need to be aligned with the handicap stall?
- A3: Yes, the location of the fence opening shall be adjusted to align with the striped portion of the ADA compliant parking stall. In addition, the gate opening will be adjusted to 5-feet wide.
- Q4: Should the fence be in-line with the light posts? If so, please specify fence location.
- A4: The fence opening, between the play area and parking area will be shifted approximately 2-feet east to align with the center of the light pole bases. The School District shall approve the layout location prior to installation.
- Q5: Have pavement cores been conducted and can they be shared?
- A5: Yes, please see attached.
- Q6: Are bollards to be incorporated into the sidewalk or pavement?
- A6: No, the sidewalk adjacent to the building will include a 4” exposed edge to provide a demarcation between the drive aisle and sidewalk.
- Q7: Is a contingency be incorporated into the bid?
- A7: Yes, this bid will include a \$10,000 contingency, to be used at the approval of the School District. Please see updated bid form, attached.